

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 10/6/2026 4:30:21 PM

JOB DESCRIPTION

RED-HILL
PFAS: Halawa Wells P1

JOB NUMBER

380-238994-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Generated
10/6/2026 4:30:21 PM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	15
QC Association Summary	26
Lab Chronicle	27
Certification Summary	28
Method Summary	29
Sample Summary	30
Chain of Custody	31
Receipt Checklists	32



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-238994-1

Job ID: 380-238994-1

Eurofins Pomona

Job Narrative 380-238994-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 9/30/2026 9:21 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 2.3°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanesulfonic acid (PFHxS)	2.8		2.0	ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	3.0		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	2.6		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	2.0		2.0	ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	3.8		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	2.8		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanoic acid (PFHxA)	3.2		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	2.2		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	2.9		2.0	ng/L	1		EPA 537.1 V2	Total/NA

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-1

Date Collected: 09/28/26 10:19

Matrix: Drinking Water

Date Received: 09/30/26 09:21

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9CI-PF3ONS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluorohexanesulfonic acid (PFHxS)	2.8		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluorohexanoic acid (PFHxA)	3.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluorooctanesulfonic acid (PFOS)	2.6		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluorooctanoic acid (PFOA)	2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluoropentanoic acid (PFPeA)	3.8		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:31	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	106		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C6 PFDA	110		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C5 PFHxA	106		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C4 PFHpA	110		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C8 PFOA	109		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C9 PFNA	109		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C7 PFUnA	113		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C2 PFDoA	109		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C4 PFBA	109		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C5 PFPeA	106		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C3 PFBS	102		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C3 PFHxS	103		50 - 200	09/30/26 18:40	10/02/26 18:31	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-1

Date Collected: 09/28/26 10:19

Matrix: Drinking Water

Date Received: 09/30/26 09:21

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	105		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C2-4:2-FTS	103		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C2-6:2-FTS	98		50 - 200	09/30/26 18:40	10/02/26 18:31	1
13C2-8:2-FTS	109		50 - 200	09/30/26 18:40	10/02/26 18:31	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorooctanesulfonic acid (PFOS)	2.8		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorohexanoic acid (PFHxA)	3.2		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorooctanoic acid (PFOA)	2.2		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorohexanesulfonic acid (PFHxS)	2.9		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 03:21	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	106		70 - 130			10/01/26 03:18	10/02/26 03:21	1
13C2 PFHxA	107		70 - 130			10/01/26 03:18	10/02/26 03:21	1
13C2 PFDA	105		70 - 130			10/01/26 03:18	10/02/26 03:21	1
13C3-GenX	102		70 - 130			10/01/26 03:18	10/02/26 03:21	1

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-2

Date Collected: 09/28/26 10:19

Matrix: Water

Date Received: 09/30/26 09:21

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-2

Date Collected: 09/28/26 10:19

Matrix: Water

Date Received: 09/30/26 09:21

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		09/30/26 18:40	10/02/26 18:45	1
Isotope Dilution	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	103		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C6 PFDA	107		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C5 PFHxA	108		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C4 PFHpA	109		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C8 PFOA	109		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C9 PFNA	113		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C7 PFUnA	111		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C2 PFDoA	109		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C4 PFBA	109		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C5 PFPeA	107		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C3 PFBS	101		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C3 PFHxS	105		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C8 PFOS	107		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C2-4:2-FTS	104		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C2-6:2-FTS	100		50 - 200			09/30/26 18:40	10/02/26 18:45	1
13C2-8:2-FTS	102		50 - 200			09/30/26 18:40	10/02/26 18:45	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-2

Date Collected: 09/28/26 10:19

Matrix: Water

Date Received: 09/30/26 09:21

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		10/01/26 03:18	10/02/26 04:17	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	90		70 - 130			10/01/26 03:18	10/02/26 04:17	1
13C2 PFHxA	92		70 - 130			10/01/26 03:18	10/02/26 04:17	1
13C2 PFDA	104		70 - 130			10/01/26 03:18	10/02/26 04:17	1
13C3-GenX	86		70 - 130			10/01/26 03:18	10/02/26 04:17	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	2.8		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	2.6		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	2.8		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	2.2		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	2.9		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-238994-1	HALAWA WELLS P1 (331-023-WL0	106	107	105	102
380-238994-1 MS	HALAWA WELLS P1 (331-023-WL065)	106	104	106	105
380-238994-1 MSD	HALAWA WELLS P1 (331-023-WL065)	107	114	118	108
Surrogate Legend					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-238994-2	FB: HALAWA WELLS P1 (331-023-WL0	90	92	104	86
LCS 380-255751/22-A	Lab Control Sample	94	97	99	88
MBL 380-255751/20-A	Method Blank	90	99	107	85
MRL 380-255751/21-A	Lab Control Sample	90	93	103	80
Surrogate Legend					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-238994-1	HALAWA WELLS P1 (331-023-WL0	106	110	106	110	109	109	113	109

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-238994-1	HALAWA WELLS P1 (331-023-WL0	109	106	102	103	105	103	98	109

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA
13C5PHA = 13C5 PFHxA
C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDaA = 13C2 PFDaA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-238954-B-1-A MSD	Matrix Spike Duplicate	112	112	114	115	114	111	119	116
380-238954-C-1-A MS	Matrix Spike	109	110	109	108	108	108	114	112
380-238994-2	FB: HALAWA WELLS P1 (331-023-WL065)	103	107	108	109	109	113	111	109
LCS 380-255688/22-A	Lab Control Sample	112	115	111	111	111	112	115	115
MBL 380-255688/20-A	Method Blank	103	101	103	106	110	107	106	105
MRL 380-255688/21-A	Lab Control Sample	105	111	110	110	116	112	110	109

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-238954-B-1-A MSD	Matrix Spike Duplicate	110	102	104	106	104	106	110	109
380-238954-C-1-A MS	Matrix Spike	110	103	106	105	108	104	107	106
380-238994-2	FB: HALAWA WELLS P1 (331-023-WL065)	109	107	101	105	107	104	100	102
LCS 380-255688/22-A	Lab Control Sample	108	110	109	109	109	108	117	113
MBL 380-255688/20-A	Method Blank	107	109	102	103	105	107	114	103
MRL 380-255688/21-A	Lab Control Sample	108	111	104	104	104	103	110	108

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA

Eurofins Pomona

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFD_oA = 13C2 PFD_oA
- PFBA = 13C4 PFBA
- PFP_eA = 13C5 PFP_eA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-255688/20-A

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 255688

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<0.29		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9CI-PF3ONS)	<0.29		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluorobutanoic acid (PFBA)	<0.68		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.37		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.36		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.47		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.46		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.24		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.45		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluoropentanoic acid (PFPeA)	<0.37		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.35		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1
Perfluoropentanesulfonic acid (PFPeS)	<0.38		2.0	ng/L		09/30/26 18:40	10/02/26 14:17	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	103		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C6 PFDA	101		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C5 PFHxA	103		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C4 PFHpA	106		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C8 PFOA	110		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C9 PFNA	107		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C7 PFUnA	106		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C2 PFDoA	105		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C4 PFBA	107		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C5 PFPeA	109		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C3 PFBS	102		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C3 PFHxS	103		50 - 200	09/30/26 18:40	10/02/26 14:17	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-255688/20-A

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 255688

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	105		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C2-4:2-FTS	107		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C2-6:2-FTS	114		50 - 200	09/30/26 18:40	10/02/26 14:17	1
13C2-8:2-FTS	103		50 - 200	09/30/26 18:40	10/02/26 14:17	1

Lab Sample ID: LCS 380-255688/22-A

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 255688

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	118	112		ng/L		95	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	118	110		ng/L		93	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	118	114		ng/L		97	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	118	108		ng/L		92	70 - 130
Perfluorobutanesulfonic acid (PFBS)	118	111		ng/L		94	70 - 130
Perfluorodecanoic acid (PFDA)	118	109		ng/L		92	70 - 130
Perfluorododecanoic acid (PFDoA)	118	108		ng/L		91	70 - 130
Perfluorooheptanoic acid (PFHpA)	118	108		ng/L		92	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	118	113		ng/L		96	70 - 130
Perfluorohexanoic acid (PFHxA)	118	113		ng/L		96	70 - 130
Perfluorononanoic acid (PFNA)	118	109		ng/L		92	70 - 130
Perfluorooctanesulfonic acid (PFOS)	118	108		ng/L		92	70 - 130
Perfluorooctanoic acid (PFOA)	118	109		ng/L		92	70 - 130
Perfluoroundecanoic acid (PFUnA)	118	106		ng/L		90	70 - 130
Perfluorobutanoic acid (PFBA)	118	109		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	118	108		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	118	112		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	118	103		ng/L		87	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	118	109		ng/L		92	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	118	109		ng/L		92	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	118	104		ng/L		88	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	118	105		ng/L		88	70 - 130
Perfluoropentanoic acid (PFPeA)	118	109		ng/L		93	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	118	110		ng/L		93	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-255688/22-A

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 255688

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	118	115		ng/L		97	70 - 130
	LCS	LCS					
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	112		50 - 200				
13C6 PFDA	115		50 - 200				
13C5 PFHxA	111		50 - 200				
13C4 PFHpA	111		50 - 200				
13C8 PFOA	111		50 - 200				
13C9 PFNA	112		50 - 200				
13C7 PFUnA	115		50 - 200				
13C2 PFDoA	115		50 - 200				
13C4 PFBA	108		50 - 200				
13C5 PFPeA	110		50 - 200				
13C3 PFBS	109		50 - 200				
13C3 PFHxS	109		50 - 200				
13C8 PFOS	109		50 - 200				
13C2-4:2-FTS	108		50 - 200				
13C2-6:2-FTS	117		50 - 200				
13C2-8:2-FTS	113		50 - 200				

Lab Sample ID: MRL 380-255688/21-A

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 255688

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.97	2.30	J	ng/L		117	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.97	1.99	J	ng/L		101	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.97	2.02	J	ng/L		103	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	1.97	2.01	J	ng/L		102	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.97	2.01	J	ng/L		102	50 - 150
Perfluorodecanoic acid (PFDA)	1.97	2.09	J	ng/L		106	50 - 150
Perfluorododecanoic acid (PFDoA)	1.97	1.98	J	ng/L		100	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.97	2.10	J	ng/L		106	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.97	2.00	J	ng/L		102	50 - 150
Perfluorohexanoic acid (PFHxA)	1.97	2.06	J	ng/L		105	50 - 150
Perfluorononanoic acid (PFNA)	1.97	2.00	J	ng/L		102	50 - 150
Perfluorooctanesulfonic acid (PFOS)	1.97	1.98	J	ng/L		100	50 - 150
Perfluorooctanoic acid (PFOA)	1.97	2.03	J	ng/L		103	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.97	1.98	J	ng/L		101	50 - 150
Perfluorobutanoic acid (PFBA)	1.97	2.03	J	ng/L		103	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-255688/21-A

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 255688

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	1.97	1.92	J	ng/L		98	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	1.97	2.09	J	ng/L		106	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	1.97	1.96	J	ng/L		100	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	1.97	2.17	J	ng/L		110	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	1.97	2.13	J	ng/L		108	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	1.97	1.98	J	ng/L		101	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	1.97	1.96	J	ng/L		100	50 - 150
Perfluoropentanoic acid (PFPeA)	1.97	2.15	J	ng/L		109	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	1.97	1.98	J	ng/L		101	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	1.97	2.03	J	ng/L		103	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	105		50 - 200
13C6 PFDA	111		50 - 200
13C5 PFHxA	110		50 - 200
13C4 PFHpA	110		50 - 200
13C8 PFOA	116		50 - 200
13C9 PFNA	112		50 - 200
13C7 PFUnA	110		50 - 200
13C2 PFDoA	109		50 - 200
13C4 PFBA	108		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	104		50 - 200
13C3 PFHxS	104		50 - 200
13C8 PFOS	104		50 - 200
13C2-4:2-FTS	103		50 - 200
13C2-6:2-FTS	110		50 - 200
13C2-8:2-FTS	108		50 - 200

Lab Sample ID: 380-238954-B-1-A MSD

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 255688

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		118	113		ng/L		95	70 - 130	3	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		118	112		ng/L		94	70 - 130	5	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		118	108		ng/L		91	70 - 130	2	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-238954-B-1-A MSD

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 255688

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide	<2.0		118	110		ng/L		93	70 - 130	0	30
Dimer Acid (HFPO-DA/GenX)											
Perfluorobutanesulfonic acid (PFBS)	<2.0		118	115		ng/L		97	70 - 130	0	30
Perfluorodecanoic acid (PFDA)	<2.0		118	108		ng/L		92	70 - 130	3	30
Perfluorododecanoic acid (PFDoA)	<2.0		118	109		ng/L		92	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		118	106		ng/L		89	70 - 130	4	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		118	111		ng/L		94	70 - 130	2	30
Perfluorohexanoic acid (PFHxA)	3.3		118	110		ng/L		90	70 - 130	4	30
Perfluorononanoic acid (PFNA)	<2.0		118	111		ng/L		94	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		118	111		ng/L		94	70 - 130	3	30
Perfluorooctanoic acid (PFOA)	<2.0		118	104		ng/L		87	70 - 130	3	30
Perfluoroundecanoic acid (PFUnA)	<2.0		118	104		ng/L		88	70 - 130	1	30
Perfluorobutanoic acid (PFBA)	2.5		118	111		ng/L		92	70 - 130	0	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		118	106		ng/L		89	70 - 130	3	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		118	106		ng/L		89	70 - 130	5	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		118	105		ng/L		89	70 - 130	5	30
Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	<2.0		118	107		ng/L		90	70 - 130	2	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		118	114		ng/L		96	70 - 130	0	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		118	107		ng/L		90	70 - 130	2	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		118	112		ng/L		94	70 - 130	0	30
Perfluoropentanoic acid (PFPeA)	2.2		118	117		ng/L		97	70 - 130	2	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		118	112		ng/L		94	70 - 130	4	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		118	112		ng/L		95	70 - 130	2	30

Isotope Dilution	MSD %Recovery	MSD Qualifier	Limits
13C3 HFPO-DA	112		50 - 200
13C6 PFDA	112		50 - 200
13C5 PFHxA	114		50 - 200
13C4 PFHpA	115		50 - 200
13C8 PFOA	114		50 - 200
13C9 PFNA	111		50 - 200
13C7 PFUnA	119		50 - 200
13C2 PFDoA	116		50 - 200
13C4 PFBA	110		50 - 200
13C5 PFPeA	102		50 - 200
13C3 PFBS	104		50 - 200
13C3 PFHxS	106		50 - 200
13C8 PFOS	104		50 - 200

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-238954-B-1-A MSD

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 255688

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C2-4:2-FTS	106		50 - 200
13C2-6:2-FTS	110		50 - 200
13C2-8:2-FTS	109		50 - 200

Lab Sample ID: 380-238954-C-1-A MS

Matrix: Water

Analysis Batch: 256041

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 255688

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		118	109		ng/L		92	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		118	106		ng/L		90	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		118	110		ng/L		93	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		118	110		ng/L		93	70 - 130
Perfluorobutanesulfonic acid (PFBS)	<2.0		118	115		ng/L		96	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		118	112		ng/L		94	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		118	110		ng/L		93	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		118	110		ng/L		92	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		118	113		ng/L		95	70 - 130
Perfluorohexanoic acid (PFHxA)	3.3		118	114		ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		118	110		ng/L		93	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		118	108		ng/L		91	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		118	107		ng/L		90	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		118	103		ng/L		87	70 - 130
Perfluorobutanoic acid (PFBA)	2.5		118	111		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		118	109		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		118	111		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		118	110		ng/L		93	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		118	109		ng/L		92	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		118	114		ng/L		96	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		118	109		ng/L		92	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		118	112		ng/L		94	70 - 130
Perfluoropentanoic acid (PFPeA)	2.2		118	115		ng/L		95	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		118	107		ng/L		91	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		118	115		ng/L		97	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	109		50 - 200
13C6 PFDA	110		50 - 200
13C5 PFHxA	109		50 - 200
13C4 PFHpA	108		50 - 200
13C8 PFOA	108		50 - 200
13C9 PFNA	108		50 - 200
13C7 PFUnA	114		50 - 200
13C2 PFDoA	112		50 - 200
13C4 PFBA	110		50 - 200
13C5 PFPeA	103		50 - 200
13C3 PFBS	106		50 - 200
13C3 PFHxS	105		50 - 200
13C8 PFOS	108		50 - 200
13C2-4:2-FTS	104		50 - 200
13C2-6:2-FTS	107		50 - 200
13C2-8:2-FTS	106		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-255751/20-A
Matrix: Water
Analysis Batch: 255857

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 255751

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.57		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.41		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorotetradecanoic acid (PFTA)	<0.53		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Perfluorotridecanoic acid (PFTTrDA)	<0.35		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<0.29		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		10/01/26 03:18	10/02/26 02:51	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	90		70 - 130			10/01/26 03:18	10/02/26 02:51	1
13C2 PFHxA	99		70 - 130			10/01/26 03:18	10/02/26 02:51	1
13C2 PFDA	107		70 - 130			10/01/26 03:18	10/02/26 02:51	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-255751/20-A

Matrix: Water

Analysis Batch: 255857

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 255751

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	85		70 - 130	10/01/26 03:18	10/02/26 02:51	1

Lab Sample ID: LCS 380-255751/22-A

Matrix: Water

Analysis Batch: 255857

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 255751

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	24.6	21.5		ng/L		87	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	24.6	25.7		ng/L		105	70 - 130
Perfluoroundecanoic acid (PFUnA)	24.6	25.6		ng/L		104	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	24.6	24.5		ng/L		100	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	24.6	24.4		ng/L		99	70 - 130
Perfluorohexanoic acid (PFHxA)	24.6	24.9		ng/L		101	70 - 130
Perfluorododecanoic acid (PFDoA)	24.6	24.4		ng/L		99	70 - 130
Perfluorooctanoic acid (PFOA)	24.6	25.6		ng/L		104	70 - 130
Perfluorodecanoic acid (PFDA)	24.6	25.7		ng/L		105	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	24.6	25.0		ng/L		102	70 - 130
Perfluorobutanesulfonic acid (PFBS)	24.6	25.6		ng/L		104	70 - 130
Perfluoroheptanoic acid (PFHpA)	24.6	24.3		ng/L		99	70 - 130
Perfluorononanoic acid (PFNA)	24.6	25.9		ng/L		105	70 - 130
Perfluorotetradecanoic acid (PFTA)	24.6	18.3		ng/L		75	70 - 130
Perfluorotridecanoic acid (PFTrDA)	24.6	25.8		ng/L		105	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	24.6	24.3		ng/L		99	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	24.6	24.5		ng/L		100	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	24.6	22.2		ng/L		91	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	94		70 - 130
13C2 PFHxA	97		70 - 130
13C2 PFDA	99		70 - 130
13C3-GenX	88		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-255751/21-A

Matrix: Water

Analysis Batch: 255857

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 255751

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	1.96	1.65	J	ng/L		84	50 - 150
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	1.96	2.13	J	ng/L		109	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.96	2.07	J	ng/L		106	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	1.96	1.88	J	ng/L		96	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	1.96	1.63	J	ng/L		83	50 - 150
Perfluorohexanoic acid (PFHxA)	1.96	1.93	J	ng/L		98	50 - 150
Perfluorododecanoic acid (PFDoA)	1.96	2.01	J	ng/L		102	50 - 150
Perfluorooctanoic acid (PFOA)	1.96	2.13	J	ng/L		108	50 - 150
Perfluorodecanoic acid (PFDA)	1.96	2.05	J	ng/L		104	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.96	2.00	J	ng/L		102	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.96	2.05	J	ng/L		104	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.96	1.89	J	ng/L		96	50 - 150
Perfluorononanoic acid (PFNA)	1.96	2.09	J	ng/L		107	50 - 150
Perfluorotetradecanoic acid (PFTA)	1.96	1.72	J	ng/L		87	50 - 150
Perfluorotridecanoic acid (PFTrDA)	1.96	2.15	J	ng/L		109	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.96	1.96	J	ng/L		100	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.96	1.90	J	ng/L		97	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.96	1.68	J	ng/L		86	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	90		70 - 130
13C2 PFHxA	93		70 - 130
13C2 PFDA	103		70 - 130
13C3-GenX	80		70 - 130

Lab Sample ID: 380-238994-1 MS

Matrix: Drinking Water

Analysis Batch: 255857

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Prep Type: Total/NA

Prep Batch: 255751

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		24.6	24.1		ng/L		98	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorooctanesulfonic acid (PFOS)	2.8		24.6	27.4		ng/L		100	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	25.8		ng/L		105	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	26.8		ng/L		109	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-238994-1 MS

Matrix: Drinking Water

Analysis Batch: 255857

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Prep Type: Total/NA

Prep Batch: 255751

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	Limits		
	Result	Qualifier	Added	Result	Qualifier			%Rec			
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.6	26.3		ng/L		107	70 - 130		
Perfluorohexanoic acid (PFHxA)	3.2		24.6	29.2		ng/L		106	70 - 130		
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	25.3		ng/L		103	70 - 130		
Perfluorooctanoic acid (PFOA)	2.2		24.6	28.4		ng/L		107	70 - 130		
Perfluorodecanoic acid (PFDA)	<2.0		24.6	26.3		ng/L		107	70 - 130		
Perfluorohexanesulfonic acid (PFHxS)	2.9		24.6	29.1		ng/L		107	70 - 130		
Perfluorobutanesulfonic acid (PFBS)	<2.0		24.6	27.1		ng/L		105	70 - 130		
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	26.7		ng/L		104	70 - 130		
Perfluorononanoic acid (PFNA)	<2.0		24.6	24.9		ng/L		101	70 - 130		
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	19.3		ng/L		79	70 - 130		
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	26.7		ng/L		109	70 - 130		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	24.9		ng/L		101	70 - 130		
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	24.2		ng/L		98	70 - 130		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	24.5		ng/L		100	70 - 130		

Lab Sample ID: 380-238994-1 MSD

Matrix: Drinking Water

Analysis Batch: 255857

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Prep Type: Total/NA

Prep Batch: 255751

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		24.6	24.1		ng/L		98	70 - 130	0	30
Perfluorooctanesulfonic acid (PFOS)	2.8		24.6	27.7		ng/L		101	70 - 130	1	30
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	25.8		ng/L		105	70 - 130	0	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	25.7		ng/L		104	70 - 130	4	30
N-ethylperfluorooctanesulfonamidoacetic acid (NETFOSAA)	<2.0		24.6	23.0		ng/L		93	70 - 130	13	30
Perfluorohexanoic acid (PFHxA)	3.2		24.6	29.6		ng/L		107	70 - 130	1	30
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	24.9		ng/L		101	70 - 130	2	30
Perfluorooctanoic acid (PFOA)	2.2		24.6	27.5		ng/L		103	70 - 130	3	30
Perfluorodecanoic acid (PFDA)	<2.0		24.6	26.6		ng/L		108	70 - 130	1	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-238994-1 MSD

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Matrix: Drinking Water

Prep Type: Total/NA

Analysis Batch: 255857

Prep Batch: 255751

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorohexanesulfonic acid (PFHxS)	2.9		24.6	28.3		ng/L		103	70 - 130	3	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		24.6	26.7		ng/L		103	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	27.3		ng/L		106	70 - 130	2	30
Perfluorononanoic acid (PFNA)	<2.0		24.6	25.5		ng/L		103	70 - 130	2	30
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	19.9		ng/L		81	70 - 130	3	30
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	26.9		ng/L		109	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	24.9		ng/L		101	70 - 130	0	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	24.8		ng/L		101	70 - 130	3	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	24.6		ng/L		100	70 - 130	0	30
Surrogate	MSD %Recovery	MSD Qualifier	Limits								
d5-NEtFOSAA	107		70 - 130								
13C2 PFHxA	114		70 - 130								
13C2 PFDA	118		70 - 130								
13C3-GenX	108		70 - 130								

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

LCMS

Prep Batch: 255688

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-238994-1	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Drinking Water	533	
380-238994-2	FB: HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	533	
MBL 380-255688/20-A	Method Blank	Total/NA	Water	533	
LCS 380-255688/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-255688/21-A	Lab Control Sample	Total/NA	Water	533	
380-238954-B-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	
380-238954-C-1-A MS	Matrix Spike	Total/NA	Water	533	

Prep Batch: 255751

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-238994-1	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Drinking Water	537.1 DW	
380-238994-2	FB: HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	537.1 DW	
MBL 380-255751/20-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-255751/22-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-255751/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-238994-1 MS	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Drinking Water	537.1 DW	
380-238994-1 MSD	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Drinking Water	537.1 DW	

Analysis Batch: 255857

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-238994-1	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Drinking Water	EPA 537.1 V2	255751
380-238994-2	FB: HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	EPA 537.1 V2	255751
MBL 380-255751/20-A	Method Blank	Total/NA	Water	EPA 537.1 V2	255751
LCS 380-255751/22-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	255751
MRL 380-255751/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	255751
380-238994-1 MS	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Drinking Water	EPA 537.1 V2	255751
380-238994-1 MSD	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Drinking Water	EPA 537.1 V2	255751

Analysis Batch: 256041

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-238994-1	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Drinking Water	533	255688
380-238994-2	FB: HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	533	255688
MBL 380-255688/20-A	Method Blank	Total/NA	Water	533	255688
LCS 380-255688/22-A	Lab Control Sample	Total/NA	Water	533	255688
MRL 380-255688/21-A	Lab Control Sample	Total/NA	Water	533	255688
380-238954-B-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	255688
380-238954-C-1-A MS	Matrix Spike	Total/NA	Water	533	255688

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-1

Date Collected: 09/28/26 10:19

Matrix: Drinking Water

Date Received: 09/30/26 09:21

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			255688	E2HD	EA POM	09/30/26 18:40
Total/NA	Analysis	533		1	256041	UKDT	EA POM	10/02/26 18:31
Total/NA	Prep	537.1 DW			255751	G9MN	EA POM	10/01/26 03:18
Total/NA	Analysis	EPA 537.1 V2		1	255857	UKDT	EA POM	10/02/26 03:21

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-238994-2

Date Collected: 09/28/26 10:19

Matrix: Water

Date Received: 09/30/26 09:21

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			255688	E2HD	EA POM	09/30/26 18:40
Total/NA	Analysis	533		1	256041	UKDT	EA POM	10/02/26 18:45
Total/NA	Prep	537.1 DW			255751	G9MN	EA POM	10/01/26 03:18
Total/NA	Analysis	EPA 537.1 V2		1	255857	UKDT	EA POM	10/02/26 04:17

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-27

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-238994-1
SDG: PFAS: Halawa Wells P1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-238994-1	HALAWA WELLS P1 (331-023-WL065)	Drinking Water	09/28/26 10:19	09/30/26 09:21	Hawaii
380-238994-2	FB: HALAWA WELLS P1 (331-023-WL065)	Water	09/28/26 10:19	09/30/26 09:21	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Client Information		Lab PM: Lopez, Maria		Carrier Tracking No(s):		COC No:	
Client Contact: kirk iwamoto		E-Mail: Maria.Lopez@et.eurofinsus.com		State of Origin:		Page: Page 1 of 1	
City & County of Honolulu		PWSID:		Analysis Requested		Job #:	
Address: 630 South Beretania Street, Chemistry Lab		Due Date Requested:		TAT Requested (days):		Preservation Codes:	
City: Honolulu		Compliance Project: A No		PO #: C20525101 exp 05312023		A - HCL	
State, Zip: HI, 96843		WO #: 38001111		Project #: 38001111		B - NaOH	
Phone: 808-748-5840 (tel)		Matrix (H-water, Small, On-site, ST-Tissue, Anal)		Sample Type (C-Comp, G-grab)		C - Zn Acetate	
Email: kiwamoto@hbws.org		Sample Date		Sample Time		D - Nitric Acid	
Project Name: RED-HILL/HBWS sites Event Desc: RUSH Weekly Red Hill		28-Sep-2026		1019		E - NaHSO4	
Site:		28-Sep-2026		1019		F - MeOH	
Sample Identification		Halawa Wells P1 (331-023-WL065)		Matrix		G - Amchlor	
Halawa Wells P1 (331-023-WL065)		28-Sep-2026		1019		H - Ascorbic Acid	
FB: Halawa Wells P1 (331-023-WL065)		28-Sep-2026		1019		I - Ice	
Possible Hazard Identification		28-Sep-2026		1019		J - DI Water	
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological		28-Sep-2026		1019		K - EDTA	
Deliverable Requested: I, II, III, IV, Other (specify)		28-Sep-2026		1019		L - EDA	
Empty Kit Relinquished by:		28-Sep-2026		1019		Other:	
Relinquished by:		28-Sep-2026		1019		Special Instructions/Note:	
Relinquished by:		28-Sep-2026		1019		M - Hexane	
Custody Seals Intact: Δ Yes Δ No		28-Sep-2026		1019		N - None	
Custody Seal No.:		28-Sep-2026		1019		O - AsNaO2	
380-238994 COC		28-Sep-2026		1019		P - Na2O4S	
		28-Sep-2026		1019		Q - Na2SO3	
		28-Sep-2026		1019		R - Na2S2O3	
		28-Sep-2026		1019		S - H2SO4	
		28-Sep-2026		1019		T - TSP Dodecaldehyde	
		28-Sep-2026		1019		U - Acetone	
		28-Sep-2026		1019		V - MCAA	
		28-Sep-2026		1019		W - pH 4-5	
		28-Sep-2026		1019		Y - Trizma	
		28-Sep-2026		1019		Z - other (specify)	

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-238994-1
SDG Number: PFAS: Halawa Wells P1

Login Number: 238994

List Number: 1

Creator: Abaya, Ashton

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	