

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 7/21/2026 4:04:08 PM

JOB DESCRIPTION

RED-HILL
PFAS: Ka'amilo Wells P2

JOB NUMBER

380-225115-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Generated
7/21/2026 4:04:08 PM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	14
QC Association Summary	25
Lab Chronicle	26
Certification Summary	27
Method Summary	28
Sample Summary	29
Chain of Custody	30
Receipt Checklists	31



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-225115-1

Job ID: 380-225115-1

Eurofins Pomona

Job Narrative 380-225115-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 7/15/2026 10:10 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 3.1°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanesulfonic acid (PFBS)	3.3		2.0	ng/L	1		533	Total/NA
Perfluoroheptanoic acid (PFHpA)	2.0		2.0	ng/L	1		533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.5		2.0	ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	4.1		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.5		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.9		2.0	ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	4.4		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.3		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanoic acid (PFHxA)	3.9		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.6		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorobutanesulfonic acid (PFBS)	3.0		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluoroheptanoic acid (PFHpA)	2.0		2.0	ng/L	1		EPA 537.1 V2	Total/NA

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-1

Date Collected: 07/13/26 12:59

Matrix: Water

Date Received: 07/15/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluorobutanesulfonic acid (PFBS)	3.3		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluoroheptanoic acid (PFHpA)	2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluorohexanesulfonic acid (PFHxS)	3.5		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluorohexanoic acid (PFHxA)	4.1		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluorooctanesulfonic acid (PFOS)	4.5		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluorooctanoic acid (PFOA)	3.9		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluoropentanoic acid (PFPeA)	4.4		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:22	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	64		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C6 PFDA	79		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C5 PFHxA	68		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C4 PFHpA	74		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C8 PFOA	77		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C9 PFNA	80		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C7 PFUnA	77		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C2 PFDoA	79		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C4 PFBA	77		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C5 PFPeA	75		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C3 PFBS	81		50 - 200	07/17/26 07:44	07/18/26 04:22	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-1

Date Collected: 07/13/26 12:59

Matrix: Water

Date Received: 07/15/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 PFHxS	88		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C8 PFOS	90		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C2-4:2-FTS	76		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C2-6:2-FTS	83		50 - 200	07/17/26 07:44	07/18/26 04:22	1
13C2-8:2-FTS	84		50 - 200	07/17/26 07:44	07/18/26 04:22	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorooctanesulfonic acid (PFOS)	4.3		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorohexanoic acid (PFHxA)	3.9		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorooctanoic acid (PFOA)	4.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorohexanesulfonic acid (PFHxS)	3.6		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorobutanesulfonic acid (PFBS)	3.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluoroheptanoic acid (PFHpA)	2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Perfluorotridecanoic acid (PFTDA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:29	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	97		70 - 130			07/16/26 12:45	07/17/26 23:29	1
13C2 PFHxA	102		70 - 130			07/16/26 12:45	07/17/26 23:29	1
13C2 PFDA	101		70 - 130			07/16/26 12:45	07/17/26 23:29	1
13C3-GenX	100		70 - 130			07/16/26 12:45	07/17/26 23:29	1

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-2

Date Collected: 07/13/26 12:59

Matrix: Water

Date Received: 07/15/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-2

Date Collected: 07/13/26 12:59

Matrix: Water

Date Received: 07/15/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		07/17/26 07:44	07/18/26 04:32	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	77		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C6 PFDA	82		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C5 PFHxA	86		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C4 PFHpA	81		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C8 PFOA	85		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C9 PFNA	86		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C7 PFUnA	82		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C2 PFDoA	82		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C4 PFBA	90		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C5 PFPeA	88		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C3 PFBS	99		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C3 PFHxS	102		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C8 PFOS	104		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C2-4:2-FTS	91		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C2-6:2-FTS	93		50 - 200	07/17/26 07:44	07/18/26 04:32	1
13C2-8:2-FTS	93		50 - 200	07/17/26 07:44	07/18/26 04:32	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-2

Date Collected: 07/13/26 12:59

Matrix: Water

Date Received: 07/15/26 10:10

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/16/26 12:45	07/17/26 23:39	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	101		70 - 130	07/16/26 12:45	07/17/26 23:39	1
13C2 PFHxA	100		70 - 130	07/16/26 12:45	07/17/26 23:39	1
13C2 PFDA	104		70 - 130	07/16/26 12:45	07/17/26 23:39	1
13C3-GenX	95		70 - 130	07/16/26 12:45	07/17/26 23:39	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.5		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.5		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	3.9		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.3		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.6		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-224988-B-1-A MS	Matrix Spike	100	100	102	97
380-224988-C-1-A MSD	Matrix Spike Duplicate	100	97	100	100
380-225115-1	Ka'amilo Wells P2 (331-600-WL085)	97	102	101	100
380-225115-2	FB: Ka'amilo Wells P2 (331-600-WL085)	101	100	104	95
LCS 380-240246/21-A	Lab Control Sample	96	98	103	88
MBL 380-240246/19-A	Method Blank	104	100	108	99
MRL 380-240246/20-A	Lab Control Sample	96	101	95	95
Surrogate Legend					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
177-4024-B-1-A MS	Matrix Spike	108	111	106	109	111	110	110	111
177-4024-C-1-A MSD	Matrix Spike Duplicate	109	107	107	110	112	111	112	108
380-225115-1	Ka'amilo Wells P2 (331-600-WL085)	64	79	68	74	77	80	77	79
380-225115-2	FB: Ka'amilo Wells P2 (331-600-WL085)	77	82	86	81	85	86	82	82
LCS 380-240537/22-A	Lab Control Sample	109	112	106	112	111	109	111	113
MBL 380-240537/20-A	Method Blank	100	107	103	104	112	109	106	106
MRL 380-240537/21-A	Lab Control Sample	101	109	103	105	108	108	108	107
		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
177-4024-B-1-A MS	Matrix Spike	110	115	110	106	110	104	105	100
177-4024-C-1-A MSD	Matrix Spike Duplicate	109	113	106	111	110	104	102	104
380-225115-1	Ka'amilo Wells P2 (331-600-WL085)	77	75	81	88	90	76	83	84
380-225115-2	FB: Ka'amilo Wells P2 (331-600-WL085)	90	88	99	102	104	91	93	93
LCS 380-240537/22-A	Lab Control Sample	111	111	105	111	110	102	101	102
MBL 380-240537/20-A	Method Blank	112	111	113	112	114	111	112	102
MRL 380-240537/21-A	Lab Control Sample	109	111	110	116	113	107	107	104
Surrogate Legend									
HFPODA = 13C3 HFPO-DA									
C6PFDA = 13C6 PFDA									
13C5PHA = 13C5 PFHxA									
C4PFHA = 13C4 PFHpA									
C8PFOA = 13C8 PFOA									
C9PFNA = 13C9 PFNA									
13C7PUA = 13C7 PFUnA									
PFDaA = 13C2 PFDaA									
PFBA = 13C4 PFBA									
PFPeA = 13C5 PFPeA									
C3PFBS = 13C3 PFBS									
C3PFHS = 13C3 PFHxS									
C8PFOS = 13C8 PFOS									
42FTS = 13C2-4:2-FTS									
62FTS = 13C2-6:2-FTS									
82FTS = 13C2-8:2-FTS									

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-240537/20-A

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 240537

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.29		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluorobutanoic acid (PFBA)	<0.68		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.37		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.36		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.47		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.46		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.24		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.45		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluoropentanoic acid (PFPeA)	<0.37		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.35		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1
Perfluoropentanesulfonic acid (PFPeS)	<0.38		2.0	ng/L		07/17/26 07:44	07/18/26 01:19	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	100		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C6 PFDA	107		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C5 PFHxA	103		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C4 PFHpA	104		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C8 PFOA	112		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C9 PFNA	109		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C7 PFUnA	106		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C2 PFDoA	106		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C4 PFBA	112		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C5 PFPeA	111		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C3 PFBS	113		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C3 PFHxS	112		50 - 200	07/17/26 07:44	07/18/26 01:19	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-240537/20-A

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 240537

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	114		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C2-4:2-FTS	111		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C2-6:2-FTS	112		50 - 200	07/17/26 07:44	07/18/26 01:19	1
13C2-8:2-FTS	102		50 - 200	07/17/26 07:44	07/18/26 01:19	1

Lab Sample ID: LCS 380-240537/22-A

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240537

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	59.1	57.7		ng/L		98	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	59.1	61.0		ng/L		103	70 - 130
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	59.1	56.9		ng/L		96	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	59.1	57.0		ng/L		97	70 - 130
Perfluorobutanesulfonic acid (PFBS)	59.1	60.0		ng/L		102	70 - 130
Perfluorodecanoic acid (PFDA)	59.1	60.2		ng/L		102	70 - 130
Perfluorododecanoic acid (PFDoA)	59.1	55.6		ng/L		94	70 - 130
Perfluorooheptanoic acid (PFHpA)	59.1	59.6		ng/L		101	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	59.1	60.7		ng/L		103	70 - 130
Perfluorohexanoic acid (PFHxA)	59.1	59.8		ng/L		101	70 - 130
Perfluorononanoic acid (PFNA)	59.1	61.5		ng/L		104	70 - 130
Perfluorooctanesulfonic acid (PFOS)	59.1	58.7		ng/L		99	70 - 130
Perfluorooctanoic acid (PFOA)	59.1	56.7		ng/L		96	70 - 130
Perfluoroundecanoic acid (PFUnA)	59.1	58.5		ng/L		99	70 - 130
Perfluorobutanoic acid (PFBA)	59.1	59.7		ng/L		101	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	59.1	57.5		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	59.1	59.6		ng/L		101	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	59.1	60.1		ng/L		102	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	59.1	59.7		ng/L		101	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	59.1	62.8		ng/L		106	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	59.1	54.9		ng/L		93	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	59.1	53.1		ng/L		90	70 - 130
Perfluoropentanoic acid (PFPeA)	59.1	57.6		ng/L		98	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	59.1	60.4		ng/L		102	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-240537/22-A

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240537

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	59.1	57.9		ng/L		98	70 - 130
	LCS	LCS					
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	109		50 - 200				
13C6 PFDA	112		50 - 200				
13C5 PFHxA	106		50 - 200				
13C4 PFHpA	112		50 - 200				
13C8 PFOA	111		50 - 200				
13C9 PFNA	109		50 - 200				
13C7 PFUnA	111		50 - 200				
13C2 PFDoA	113		50 - 200				
13C4 PFBA	111		50 - 200				
13C5 PFPeA	111		50 - 200				
13C3 PFBS	105		50 - 200				
13C3 PFHxS	111		50 - 200				
13C8 PFOS	110		50 - 200				
13C2-4:2-FTS	102		50 - 200				
13C2-6:2-FTS	101		50 - 200				
13C2-8:2-FTS	102		50 - 200				

Lab Sample ID: MRL 380-240537/21-A

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240537

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.96	1.87	J	ng/L		95	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.96	1.98	J	ng/L		101	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.96	1.92	J	ng/L		98	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	1.96	1.87	J	ng/L		95	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.96	2.08	J	ng/L		106	50 - 150
Perfluorodecanoic acid (PFDA)	1.96	2.03	J	ng/L		104	50 - 150
Perfluorododecanoic acid (PFDoA)	1.96	1.92	J	ng/L		98	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.96	2.08	J	ng/L		106	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.96	1.96	J	ng/L		100	50 - 150
Perfluorohexanoic acid (PFHxA)	1.96	2.18	J	ng/L		111	50 - 150
Perfluorononanoic acid (PFNA)	1.96	2.12	J	ng/L		108	50 - 150
Perfluorooctanesulfonic acid (PFOS)	1.96	1.94	J	ng/L		99	50 - 150
Perfluorooctanoic acid (PFOA)	1.96	1.83	J	ng/L		93	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.96	2.00	J	ng/L		102	50 - 150
Perfluorobutanoic acid (PFBA)	1.96	2.23	J	ng/L		114	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-240537/21-A

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240537

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	1.96	1.90	J	ng/L		97	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	1.96	2.04	J	ng/L		104	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	1.96	2.08	J	ng/L		106	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	1.96	2.13	J	ng/L		108	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	1.96	1.98	J	ng/L		101	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	1.96	1.82	J	ng/L		93	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	1.96	1.81	J	ng/L		92	50 - 150
Perfluoropentanoic acid (PFPeA)	1.96	2.04	J	ng/L		104	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	1.96	1.90	J	ng/L		97	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	1.96	1.75	J	ng/L		89	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	101		50 - 200
13C6 PFDA	109		50 - 200
13C5 PFHxA	103		50 - 200
13C4 PFHpA	105		50 - 200
13C8 PFOA	108		50 - 200
13C9 PFNA	108		50 - 200
13C7 PFUnA	108		50 - 200
13C2 PFDoA	107		50 - 200
13C4 PFBA	109		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	110		50 - 200
13C3 PFHxS	116		50 - 200
13C8 PFOS	113		50 - 200
13C2-4:2-FTS	107		50 - 200
13C2-6:2-FTS	107		50 - 200
13C2-8:2-FTS	104		50 - 200

Lab Sample ID: 177-4024-B-1-A MS

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240537

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		59.3	56.3		ng/L		95	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		59.3	59.0		ng/L		99	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		59.3	60.6		ng/L		102	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 177-4024-B-1-A MS

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240537

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		59.3	57.0		ng/L		96	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		59.3	58.8		ng/L		98	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		59.3	59.2		ng/L		100	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		59.3	56.9		ng/L		96	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		59.3	62.2		ng/L		105	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		59.3	61.8		ng/L		103	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		59.3	61.4		ng/L		103	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		59.3	62.2		ng/L		104	70 - 130
Perfluorooctanesulfonic acid (PFOS)	2.1		59.3	61.4		ng/L		100	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		59.3	56.4		ng/L		94	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		59.3	60.2		ng/L		101	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		59.3	61.9		ng/L		104	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		59.3	56.1		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		59.3	57.3		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		59.3	56.7		ng/L		96	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		59.3	60.4		ng/L		102	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		59.3	57.3		ng/L		97	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		59.3	55.2		ng/L		93	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		59.3	58.2		ng/L		98	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		59.3	56.3		ng/L		95	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		59.3	59.0		ng/L		100	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		59.3	58.9		ng/L		99	70 - 130

Isotope Dilution	MS %Recovery	MS Qualifier	Limits
13C3 HFPO-DA	108		50 - 200
13C6 PFDA	111		50 - 200
13C5 PFHxA	106		50 - 200
13C4 PFHpA	109		50 - 200
13C8 PFOA	111		50 - 200
13C9 PFNA	110		50 - 200
13C7 PFUnA	110		50 - 200
13C2 PFDoA	111		50 - 200
13C4 PFBA	110		50 - 200
13C5 PFPeA	115		50 - 200
13C3 PFBS	110		50 - 200
13C3 PFHxS	106		50 - 200
13C8 PFOS	110		50 - 200

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 177-4024-B-1-A MS

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240537

Isotope Dilution	MS %Recovery	MS Qualifier	Limits
13C2-4:2-FTS	104		50 - 200
13C2-6:2-FTS	105		50 - 200
13C2-8:2-FTS	100		50 - 200

Lab Sample ID: 177-4024-C-1-A MSD

Matrix: Water

Analysis Batch: 240682

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 240537

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		59.2	55.1		ng/L		93	70 - 130	2	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		59.2	59.0		ng/L		100	70 - 130	0	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		59.2	58.8		ng/L		99	70 - 130	3	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		59.2	55.6		ng/L		94	70 - 130	2	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		59.2	61.8		ng/L		103	70 - 130	5	30
Perfluorodecanoic acid (PFDA)	<2.0		59.2	60.9		ng/L		103	70 - 130	3	30
Perfluorododecanoic acid (PFDoA)	<2.0		59.2	58.5		ng/L		99	70 - 130	3	30
Perfluoroheptanoic acid (PFHpA)	<2.0		59.2	60.8		ng/L		103	70 - 130	2	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		59.2	59.6		ng/L		99	70 - 130	4	30
Perfluorohexanoic acid (PFHxA)	<2.0		59.2	59.3		ng/L		100	70 - 130	3	30
Perfluorononanoic acid (PFNA)	<2.0		59.2	60.0		ng/L		101	70 - 130	4	30
Perfluorooctanesulfonic acid (PFOS)	2.1		59.2	60.8		ng/L		99	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	<2.0		59.2	56.1		ng/L		94	70 - 130	1	30
Perfluoroundecanoic acid (PFUnA)	<2.0		59.2	57.6		ng/L		97	70 - 130	4	30
Perfluorobutanoic acid (PFBA)	<2.0		59.2	62.2		ng/L		105	70 - 130	0	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		59.2	55.0		ng/L		93	70 - 130	2	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		59.2	61.5		ng/L		104	70 - 130	7	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		59.2	60.1		ng/L		102	70 - 130	6	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		59.2	59.5		ng/L		101	70 - 130	1	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		59.2	61.3		ng/L		104	70 - 130	7	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		59.2	54.7		ng/L		92	70 - 130	1	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		59.2	55.1		ng/L		93	70 - 130	6	30
Perfluoropentanoic acid (PFPeA)	<2.0		59.2	55.5		ng/L		94	70 - 130	1	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		59.2	60.8		ng/L		103	70 - 130	3	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		59.2	56.9		ng/L		96	70 - 130	3	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	109		50 - 200
13C6 PFDA	107		50 - 200
13C5 PFHxA	107		50 - 200
13C4 PFHpA	110		50 - 200
13C8 PFOA	112		50 - 200
13C9 PFNA	111		50 - 200
13C7 PFUnA	112		50 - 200
13C2 PFDoA	108		50 - 200
13C4 PFBA	109		50 - 200
13C5 PFPeA	113		50 - 200
13C3 PFBS	106		50 - 200
13C3 PFHxS	111		50 - 200
13C8 PFOS	110		50 - 200
13C2-4:2-FTS	104		50 - 200
13C2-6:2-FTS	102		50 - 200
13C2-8:2-FTS	104		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-240246/19-A
Matrix: Water
Analysis Batch: 240671

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 240246

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer	<0.98		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Acid (HFPO-DA/GenX)								
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.57		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.41		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluorotetradecanoic acid (PFTA)	<0.53		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Perfluorotridecanoic acid (PFTTrDA)	<0.35		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		07/16/26 12:45	07/17/26 20:07	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	104		70 - 130			07/16/26 12:45	07/17/26 20:07	1
13C2 PFHxA	100		70 - 130			07/16/26 12:45	07/17/26 20:07	1
13C2 PFDA	108		70 - 130			07/16/26 12:45	07/17/26 20:07	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-240246/19-A

Matrix: Water

Analysis Batch: 240671

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 240246

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	99		70 - 130	07/16/26 12:45	07/17/26 20:07	1

Lab Sample ID: LCS 380-240246/21-A

Matrix: Water

Analysis Batch: 240671

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240246

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	49.2	41.1		ng/L		83	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	49.2	46.4		ng/L		94	70 - 130
Perfluoroundecanoic acid (PFUnA)	49.2	47.6		ng/L		97	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	49.2	43.2		ng/L		88	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	49.2	44.1		ng/L		90	70 - 130
Perfluorohexanoic acid (PFHxA)	49.2	43.8		ng/L		89	70 - 130
Perfluorododecanoic acid (PFDoA)	49.2	46.9		ng/L		95	70 - 130
Perfluorooctanoic acid (PFOA)	49.2	44.0		ng/L		89	70 - 130
Perfluorodecanoic acid (PFDA)	49.2	44.1		ng/L		90	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	49.2	46.7		ng/L		95	70 - 130
Perfluorobutanesulfonic acid (PFBS)	49.2	44.6		ng/L		91	70 - 130
Perfluoroheptanoic acid (PFHpA)	49.2	44.7		ng/L		91	70 - 130
Perfluorononanoic acid (PFNA)	49.2	46.5		ng/L		94	70 - 130
Perfluorotetradecanoic acid (PFTA)	49.2	45.9		ng/L		93	70 - 130
Perfluorotridecanoic acid (PFTrDA)	49.2	48.9		ng/L		99	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	49.2	46.6		ng/L		95	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	49.2	44.8		ng/L		91	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	49.2	42.5		ng/L		86	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	96		70 - 130
13C2 PFHxA	98		70 - 130
13C2 PFDA	103		70 - 130
13C3-GenX	88		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-240246/20-A

Matrix: Water

Analysis Batch: 240671

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240246

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	1.96	1.83	J	ng/L		93	50 - 150
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	1.96	1.82	J	ng/L		93	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.96	1.87	J	ng/L		95	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	1.96	1.87	J	ng/L		95	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	1.96	1.93	J	ng/L		98	50 - 150
Perfluorohexanoic acid (PFHxA)	1.96	1.93	J	ng/L		98	50 - 150
Perfluorododecanoic acid (PFDoA)	1.96	1.88	J	ng/L		96	50 - 150
Perfluorooctanoic acid (PFOA)	1.96	1.85	J	ng/L		94	50 - 150
Perfluorodecanoic acid (PFDA)	1.96	1.92	J	ng/L		98	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.96	1.93	J	ng/L		98	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.96	1.93	J	ng/L		98	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.96	1.91	J	ng/L		97	50 - 150
Perfluorononanoic acid (PFNA)	1.96	1.90	J	ng/L		97	50 - 150
Perfluorotetradecanoic acid (PFTA)	1.96	1.82	J	ng/L		93	50 - 150
Perfluorotridecanoic acid (PFTrDA)	1.96	2.00	J	ng/L		102	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.96	1.87	J	ng/L		95	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.96	1.74	J	ng/L		89	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.96	1.80	J	ng/L		92	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	96		70 - 130
13C2 PFHxA	101		70 - 130
13C2 PFDA	95		70 - 130
13C3-GenX	95		70 - 130

Lab Sample ID: 380-224988-B-1-A MS

Matrix: Water

Analysis Batch: 240671

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240246

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		24.6	22.3		ng/L		90	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorooctanesulfonic acid (PFOS)	<2.0		24.6	24.3		ng/L		99	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	23.4		ng/L		95	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	22.0		ng/L		89	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-224988-B-1-A MS

Matrix: Water

Analysis Batch: 240671

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240246

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.6	23.0		ng/L		94	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		24.6	24.5		ng/L		94	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	24.1		ng/L		98	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		24.6	25.5		ng/L		97	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		24.6	23.2		ng/L		94	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	3.3		24.6	26.9		ng/L		96	70 - 130
Perfluorobutanesulfonic acid (PFBS)	<2.0		24.6	23.8		ng/L		93	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	24.0		ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		24.6	24.5		ng/L		100	70 - 130
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	24.1		ng/L		98	70 - 130
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	25.3		ng/L		103	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	22.7		ng/L		92	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	22.3		ng/L		91	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	22.7		ng/L		92	70 - 130
Surrogate	MS %Recovery	MS Qualifier	Limits						
d5-NEtFOSAA	100		70 - 130						
13C2 PFHxA	100		70 - 130						
13C2 PFDA	102		70 - 130						
13C3-GenX	97		70 - 130						

Lab Sample ID: 380-224988-C-1-A MSD

Matrix: Water

Analysis Batch: 240671

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 240246

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		24.6	23.2		ng/L		94	70 - 130	4	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		24.6	25.4		ng/L		103	70 - 130	4	30
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	25.3		ng/L		103	70 - 130	8	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	23.1		ng/L		94	70 - 130	5	30
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.6	24.3		ng/L		99	70 - 130	5	30
Perfluorohexanoic acid (PFHxA)	<2.0		24.6	25.7		ng/L		98	70 - 130	5	30
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	24.9		ng/L		101	70 - 130	4	30
Perfluorooctanoic acid (PFOA)	<2.0		24.6	25.7		ng/L		98	70 - 130	1	30
Perfluorodecanoic acid (PFDA)	<2.0		24.6	23.2		ng/L		94	70 - 130	0	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-224988-C-1-A MSD

Matrix: Water

Analysis Batch: 240671

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 240246

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorohexanesulfonic acid (PFHxS)	3.3		24.6	28.4		ng/L		102	70 - 130	5	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		24.6	25.7		ng/L		101	70 - 130	8	30
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	24.1		ng/L		95	70 - 130	1	30
Perfluorononanoic acid (PFNA)	<2.0		24.6	24.7		ng/L		100	70 - 130	1	30
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	24.0		ng/L		98	70 - 130	0	30
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	25.5		ng/L		104	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	24.0		ng/L		97	70 - 130	5	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	23.7		ng/L		96	70 - 130	6	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	23.7		ng/L		96	70 - 130	4	30
Surrogate	MSD %Recovery	MSD Qualifier	Limits								
d5-NEtFOSAA	100		70 - 130								
13C2 PFHxA	97		70 - 130								
13C2 PFDA	100		70 - 130								
13C3-GenX	100		70 - 130								

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

LCMS

Prep Batch: 240246

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225115-1	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	537.1 DW	
380-225115-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	537.1 DW	
MBL 380-240246/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-240246/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-240246/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-224988-B-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-224988-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

Prep Batch: 240537

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225115-1	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	533	
380-225115-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	533	
MBL 380-240537/20-A	Method Blank	Total/NA	Water	533	
LCS 380-240537/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-240537/21-A	Lab Control Sample	Total/NA	Water	533	
177-4024-B-1-A MS	Matrix Spike	Total/NA	Water	533	
177-4024-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 240671

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225115-1	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	EPA 537.1 V2	240246
380-225115-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	EPA 537.1 V2	240246
MBL 380-240246/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	240246
LCS 380-240246/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	240246
MRL 380-240246/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	240246
380-224988-B-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	240246
380-224988-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	240246

Analysis Batch: 240682

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225115-1	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	533	240537
380-225115-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	533	240537
MBL 380-240537/20-A	Method Blank	Total/NA	Water	533	240537
LCS 380-240537/22-A	Lab Control Sample	Total/NA	Water	533	240537
MRL 380-240537/21-A	Lab Control Sample	Total/NA	Water	533	240537
177-4024-B-1-A MS	Matrix Spike	Total/NA	Water	533	240537
177-4024-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	240537

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-1

Date Collected: 07/13/26 12:59

Matrix: Water

Date Received: 07/15/26 10:10

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			240537	XTD8	EA POM	07/17/26 07:44
Total/NA	Analysis	533		1	240682	Y5FM	EA POM	07/18/26 04:22
Total/NA	Prep	537.1 DW			240246	LM3A	EA POM	07/16/26 12:45
Total/NA	Analysis	EPA 537.1 V2		1	240671	Y5FM	EA POM	07/17/26 23:29

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-225115-2

Date Collected: 07/13/26 12:59

Matrix: Water

Date Received: 07/15/26 10:10

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			240537	XTD8	EA POM	07/17/26 07:44
Total/NA	Analysis	533		1	240682	Y5FM	EA POM	07/18/26 04:32
Total/NA	Prep	537.1 DW			240246	LM3A	EA POM	07/16/26 12:45
Total/NA	Analysis	EPA 537.1 V2		1	240671	Y5FM	EA POM	07/17/26 23:39

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225115-1
SDG: PFAS: Ka'amilo Wells P2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-225115-1	Ka'amilo Wells P2 (331-600-WL085)	Water	07/13/26 12:59	07/15/26 10:10	Hawaii
380-225115-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Water	07/13/26 12:59	07/15/26 10:10	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Monrovia, CA (Suite 100)
750 Royal Oaks Drive Suite 100
Monrovia, CA 91016
Phone (626) 386-1100

Chain of Custody Record



Environment Testing
America

Client Information		Sampler	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact Kirk Iwamoto		bailey	Lopez, Maria		
Company City & County of Honolulu		Phone: +1 808 748 5840	E-Mail: Maria.Lopez@ct.euronisus.com	State of Origin:	Page:
Address: 630 South Beretania Street; Chemistry Lab		PWSID:		Job #:	
City: Honolulu		Due Date Requested:		Analysis Requested	
State Zip: HI, 96843		TAT Requested (days): RUSH		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other	
Phone: 808-748-5840 (tel)		Compliance Project: ☐ No		Total Number of Containers	
Email: kiwamoto@hbws.org		PG #: C20525101 exp 05312023		Preservation Codes: M - Hexane N - None O - AsNaO2 P - Na2O4S Q - Na2SO3 R - Na2S2O3 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 Y - Tizma Z - other (specify)	
Project Name: RED-HILL/HBWS sites Event Desc: RUSH Weekly Red Hill		WO #:		Special Instructions/Note:	
Site:		Project #: 38001111			
		SSOW#:			
Sample Identification		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=organic, A=air)
Ka'amilo Wells P2 (331-600-WL085)	13-Jul-2026	1259	G	Water	
FB: Ka'amilo Wells P2 (331-600-WL085)	13-Jul-2026	1259		Water	
Possible Hazard Identification ☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) ☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months		Special Instructions/Note: 380-225115 COC	
Deliverable Requested I, II, III, IV, Other (specify)		Special Instructions/Note: Requirements			
Empty Kit Relinquished by		Date:		Method of Shipment: FEDEX	
Relinquished by		Date/Time:		Date/Time:	
Relinquished by		Date/Time:		Date/Time:	
Custody Seals Intact: ☐ Yes ☐ No		Custody Seal No.		Cooler Temperature(s) °C and Other Remarks: 751A 3.1°-0.0°=3.1°	

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-225115-1
SDG Number: PFAS: Ka'amilo Wells P2

Login Number: 225115

List Number: 1

Creator: Ngo, Theodore

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	