eurofins | Environment Testing

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 11/2/2026 4:49:22 PM

JOB DESCRIPTION

RED-HILL
Weekly: Ka'amilo Wells P1

JOB NUMBER

380-241906-1

Eurofins Pomona
941 Corporate Center Drive
Pomona CA 91768-2642

See page two for job notes and contact information.

my EOL

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW,Water matrices)

Authorization



Generated
11/2/2026 4:49:22 PM

Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Table of Contents

Cover Page 1
Table of Contents 3
Definitions/Glossary 4
Case Narrative 5
Detection Summary 6
Client Sample Results 7
Action Limit Summary 11
Surrogate Summary 12
QC Sample Results 14
QC Association Summary 28
Lab Chronicle 30
Certification Summary 31
Method Summary 33
Sample Summary 34
Chain of Custody 35
Receipt Checklists 37

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Qualifiers

GC/MS Semi VOA

Qualifier	Qualifier Description
*-	LCS and/or LCSD is outside acceptance limits, low biased.
*+	LCS and/or LCSD is outside acceptance limits, high biased.
^3+	Reporting Limit Check Standard is outside acceptance limits, high biased
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Job Narrative
380-241906-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt
The samples were received on 10/14/2026 9:55 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 2.9°C.

GC/MS Semi VOA
Method 625.1 SIM: The laboratory control sample duplicate (LCSD) for preparation batch 570-816560 and analytical batch 570-818406 recovered outside control limits for the following analytes: 1-Methylnaphthalene and Fluorene. This is not indicative of a systematic control problem because these were random marginal exceedances. Qualified results have been reported.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Gasoline Range Organics
No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Diesel Range Organics
Method 8015B: The method reporting limit check (MRL) for preparation batch 570-816038 and analytical batch 570-821156 recovered outside control limits for the following analytes: C10-C28. These analytes were biased high in the MRL and were not detected in the associated samples; therefore, the data have been reported.
Method: 8015B_DRO_LL_CS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)
Lab Sample ID: 380-241906-1
PWSID Number: HI0000331

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Dieldrin	0.076		0.0096		ug/L	1		525.2	Total/NA
Heptachlor epoxide (isomer B)	0.011		0.0096		ug/L	1		525.2	Total/NA

Client Sample ID: TB: Ka'amilo Wells P1 (331-031-WL008)
Lab Sample ID: 380-241906-2

No Detections.

This Detection Summary does not include radiochemical test results.

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)
Date Collected: 10/12/26 12:19
Date Received: 10/14/26 09:55

Lab Sample ID: 380-241906-1
Matrix: Water
PWSID Number: HI0000331

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
2,4'-DDD	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
2,4'-DDE	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
2,4'-DDT	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
2,4-Dinitrotoluene	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
2,6-Dinitrotoluene	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
2-Methylnaphthalene	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
4,4'-DDD	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
4,4'-DDE	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
4,4'-DDT	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Acenaphthene	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Acenaphthylene	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Acetochlor	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Alachlor	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
alpha-BHC	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
alpha-Chlordane	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Anthracene	<0.019		0.019		ug/L		10/15/26 10:08	10/16/26 17:04	1
Atrazine	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Benz(a)anthracene	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Benzo[a]pyrene	<0.019		0.019		ug/L		10/15/26 10:08	10/16/26 17:04	1
Benzo[b]fluoranthene	<0.019		0.019		ug/L		10/15/26 10:08	10/16/26 17:04	1
Benzo[g,h,i]perylene	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Benzo[k]fluoranthene	<0.019		0.019		ug/L		10/15/26 10:08	10/16/26 17:04	1
beta-BHC	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Bis(2-ethylhexyl) phthalate	<0.58		0.58		ug/L		10/15/26 10:08	10/16/26 17:04	1
Bromacil	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Butachlor	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Butylbenzylphthalate	<0.48		0.48		ug/L		10/15/26 10:08	10/16/26 17:04	1
Chlorobenzilate	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Chloroneb	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Chlorothalonil (Draconil, Bravo)	<0.096	^3+ *+	0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Chlorpyrifos	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Chrysene	<0.019		0.019		ug/L		10/15/26 10:08	10/16/26 17:04	1
delta-BHC	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Di(2-ethylhexyl)adipate	<0.58		0.58		ug/L		10/15/26 10:08	10/16/26 17:04	1
Dibenz(a,h)anthracene	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Diclorvos (DDVP)	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Dieldrin	**0.076**		0.0096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Diethylphthalate	<0.48		0.48		ug/L		10/15/26 10:08	10/16/26 17:04	1
Dimethylphthalate	<0.48		0.48		ug/L		10/15/26 10:08	10/16/26 17:04	1
Di-n-butyl phthalate	<0.96		0.96		ug/L		10/15/26 10:08	10/16/26 17:04	1
Di-n-octyl phthalate	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Endosulfan I (Alpha)	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Endosulfan II (Beta)	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Endosulfan sulfate	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Endrin	<0.0096		0.0096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Endrin aldehyde	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
EPTC	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Fluoranthene	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)
Date Collected: 10/12/26 12:19
Date Received: 10/14/26 09:55

Lab Sample ID: 380-241906-1
Matrix: Water
PWSID Number: HI0000331

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
gamma-Chlordane	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Heptachlor	<0.0096		0.0096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Heptachlor epoxide (isomer B)	**0.011**		0.0096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Hexachlorobenzene	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Hexachlorocyclopentadiene	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Indeno[1,2,3-cd]pyrene	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Isophorone	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Lindane	<0.0096		0.0096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Malathion	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Methoxychlor	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Metolachlor	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Molinate	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Naphthalene	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Parathion	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Pendimethalin (Penoxaline)	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Phenanthrene	<0.039		0.039		ug/L		10/15/26 10:08	10/16/26 17:04	1
Propachlor	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Pyrene	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Simazine	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Terbacil	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Terbuthylazine	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Thiobencarb	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1
Total Permethrin (mixed isomers)	<0.19		0.19		ug/L		10/15/26 10:08	10/16/26 17:04	1
trans-Nonachlor	<0.048		0.048		ug/L		10/15/26 10:08	10/16/26 17:04	1
Trifluralin	<0.096		0.096		ug/L		10/15/26 10:08	10/16/26 17:04	1

Tentatively Identified Compound	*Est. Result*	*Qualifier*	*Unit*	*D*	*RT*	*CAS No.*	*Prepared*	*Analyzed*	*Dil Fac*
Tentatively Identified Compound	*None*		*ug/L*			*N/A*	*10/15/26 10:08*	*10/16/26 17:04*	*1*

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2-Nitro-m-xylene	*96*		*70 - 130*	*10/15/26 10:08*	*10/16/26 17:04*	*1*
Perylene-d12	*91*		*70 - 130*	*10/15/26 10:08*	*10/16/26 17:04*	*1*
Triphenylphosphate	*100*		*70 - 130*	*10/15/26 10:08*	*10/16/26 17:04*	*1*

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.19	*-	0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
2-Methylnaphthalene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Acenaphthene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Acenaphthylene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Anthracene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Benzo[a]anthracene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Benzo[a]pyrene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Benzo[b]fluoranthene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Benzo[g,h,i]perylene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Benzo[k]fluoranthene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Chrysene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Dibenz(a,h)anthracene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Fluoranthene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-241906-1
Date Collected: 10/12/26 12:19
Matrix: Water
Date Received: 10/14/26 09:55
PWSID Number: HI0000331

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.19	*-	0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Indeno[1,2,3-cd]pyrene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Naphthalene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Phenanthrene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1
Pyrene	<0.19		0.19		ug/L		10/16/26 07:58	10/22/26 00:46	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2,4,6-Tribromophenol (Surr)	*93*		*28 - 127*	*10/16/26 07:58*	*10/22/26 00:46*	*1*
2-Fluorobiphenyl (Surr)	*81*		*31 - 120*	*10/16/26 07:58*	*10/22/26 00:46*	*1*
2-Fluorophenol (Surr)	*50*		*17 - 120*	*10/16/26 07:58*	*10/22/26 00:46*	*1*
Nitrobenzene-d5 (Surr)	*88*		*27 - 120*	*10/16/26 07:58*	*10/22/26 00:46*	*1*
Phenol-d6 (Surr)	*35*		*10 - 120*	*10/16/26 07:58*	*10/22/26 00:46*	*1*
p-Terphenyl-d14 (Surr)	*84*		*45 - 120*	*10/16/26 07:58*	*10/22/26 00:46*	*1*

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)

Tentatively Identified Compound	*Est. Result*	*Qualifier*	*Unit*	*D*	*RT*	*CAS No.*	*Prepared*	*Analyzed*	*Dil Fac*
Tentatively Identified Compound	*None*		*ug/L*			*N/A*	*10/16/26 07:58*	*10/30/26 00:24*	*1*

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2,4,6-Tribromophenol (Surr)	*80*		*33 - 139*	*10/16/26 07:58*	*10/30/26 00:24*	*1*
2-Fluorobiphenyl (Surr)	*88*		*33 - 126*	*10/16/26 07:58*	*10/30/26 00:24*	*1*
2-Fluorophenol (Surr)	*49*		*12 - 120*	*10/16/26 07:58*	*10/30/26 00:24*	*1*
Nitrobenzene-d5 (Surr)	*78*		*36 - 120*	*10/16/26 07:58*	*10/30/26 00:24*	*1*
Phenol-d6 (Surr)	*28*		*10 - 120*	*10/16/26 07:58*	*10/30/26 00:24*	*1*
p-Terphenyl-d14 (Surr)	*96*		*47 - 131*	*10/16/26 07:58*	*10/30/26 00:24*	*1*

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10		ug/L			10/24/26 12:51	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
4-Bromofluorobenzene (Surr)	*96*		*38 - 134*		*10/24/26 12:51*	*1*

Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26		ug/L		10/15/26 11:48	10/26/26 16:49	1
Motor Oil Range Organics [C24-C36]	<26		26		ug/L		10/15/26 11:48	10/26/26 16:49	1
C8-C18	<26		26		ug/L		10/15/26 11:48	10/26/26 16:49	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
n-Octacosane (Surr)	*97*		*60 - 130*	*10/15/26 11:48*	*10/26/26 16:49*	*1*

Client Sample ID: TB: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-241906-2
Date Collected: 10/12/26 12:19
Matrix: Water
Date Received: 10/14/26 09:55

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10		ug/L			10/24/26 17:51	1

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: TB: Ka'amilo Wells P1 (331-031-WL008)
Date Collected: 10/12/26 12:19
Date Received: 10/14/26 09:55

Lab Sample ID: 380-241906-2
Matrix: Water

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	*97*		*38 - 134*		*10/24/26 17:51*	*1*

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-241906-1

PWSID Number: HI0000331

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Alachlor	<0.048		ug/L	2	0.048	525.2	Total/NA
Atrazine	<0.048		ug/L	3	0.048	525.2	Total/NA
Benzo[a]pyrene	<0.019		ug/L	0.2	0.019	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.58		ug/L	6	0.58	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.58		ug/L	400	0.58	525.2	Total/NA
Endrin	<0.0096		ug/L	2	0.0096	525.2	Total/NA
Heptachlor	<0.0096		ug/L	0.4	0.0096	525.2	Total/NA
Heptachlor epoxide (isomer B)	0.011		ug/L	0.2	0.0096	525.2	Total/NA
Hexachlorobenzene	<0.048		ug/L	1	0.048	525.2	Total/NA
Hexachlorocyclopentadiene	<0.048		ug/L	50	0.048	525.2	Total/NA
Lindane	<0.0096		ug/L	0.2	0.0096	525.2	Total/NA
Methoxychlor	<0.048		ug/L	40	0.048	525.2	Total/NA
Simazine	<0.048		ug/L	4	0.048	525.2	Total/NA
Benzo[a]pyrene	<0.19		ug/L	0.2	0.19	625.1 SIM	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)								
Lab Sample ID	Client Sample ID	2NMX (70-130)	PRY (70-130)	TPP (70-130)						
380-241904-I-1-A DU	Duplicate	97	90	104						
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	96	91	100						
380-242052-AG-1-A MS	Matrix Spike	98	96	105						
LCS 380-258866/23-A	Lab Control Sample	96	97	106						
MB 380-258866/21-A	Method Blank	97	86	104						
MRL 380-258866/22-A	Lab Control Sample	98	91	105						

Surrogate Legend

2NMX = 2-Nitro-m-xylene
PRY = Perylene-d12
TPP = Triphenylphosphate

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)		
380-241906-1	Ka'amilo Wells P1 (331-031-WL(	80	88	49	78	28	96		
MB 570-816560/1-A	Method Blank	78	82	49	79	29	88		

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)		
380-241906-1	Ka'amilo Wells P1 (331-031-WL(	93	81	50	88	35	84		
LCS 570-816560/2-A	Lab Control Sample	83	76	48	59	33	83		
LCSD 570-816560/3-A	Lab Control Sample Dup	73	61	40	52	30	73		
MB 570-816560/1-A	Method Blank	75	73	45	76	32	76		

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)
Lab Sample ID	Client Sample ID	BFB1 (38-134)
380-241906-1	Ka'amilo Wells P1 (331-031-WL(	96
380-241906-2	TB: Ka'amilo Wells P1 (331-031-WL008)	97
380-241911-B-1 MS	Matrix Spike	99
380-241911-B-1 MSD	Matrix Spike Duplicate	100
LCS 570-820765/3	Lab Control Sample	95
LCSD 570 820765/4	Lab Control Sample Dup	97
MB 570-820765/5	Method Blank	96
MRL 570-820765/6	Lab Control Sample	95

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)
Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-241906-1	Ka'amilo Wells P1 (331-031-WL(	97
380-241911-C-1-A MS	Matrix Spike	104
380-241911-C-1-B MSD	Matrix Spike Duplicate	103
LCS 570-816038/2-A	Lab Control Sample	104
LCSD 570-816038/3-A	Lab Control Sample Dup	103
MB 570-816038/1-A	Method Blank	109

Surrogate Legend

OTCSN = n-Octacosane (Surr)

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-258866/21-A
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 258866

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
2,4'-DDD	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
2,4'-DDE	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
2,4'-DDT	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
2,4-Dinitrotoluene	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
2,6-Dinitrotoluene	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
2-Methylnaphthalene	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
4,4'-DDD	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
4,4'-DDE	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
4,4'-DDT	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Acenaphthene	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Acenaphthylene	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Acetochlor	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Alachlor	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
alpha-BHC	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
alpha-Chlordane	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Anthracene	<0.020		0.020		ug/L		10/15/26 10:08	10/16/26 13:42	1
Atrazine	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Benz(a)anthracene	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Benzo[a]pyrene	<0.020		0.020		ug/L		10/15/26 10:08	10/16/26 13:42	1
Benzo[b]fluoranthene	<0.020		0.020		ug/L		10/15/26 10:08	10/16/26 13:42	1
Benzo[g,h,i]perylene	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Benzo[k]fluoranthene	<0.020		0.020		ug/L		10/15/26 10:08	10/16/26 13:42	1
beta-BHC	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59		ug/L		10/15/26 10:08	10/16/26 13:42	1
Bromacil	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Butachlor	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Butylbenzylphthalate	<0.49		0.49		ug/L		10/15/26 10:08	10/16/26 13:42	1
Chlorobenzilate	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Chloroneb	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Chlorothalonil (Draconil, Bravo)	<0.098	^3+	0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Chlorpyrifos	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Chrysene	<0.020		0.020		ug/L		10/15/26 10:08	10/16/26 13:42	1
delta-BHC	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Di(2-ethylhexyl)adipate	<0.59		0.59		ug/L		10/15/26 10:08	10/16/26 13:42	1
Dibenz(a,h)anthracene	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Diclorvos (DDVP)	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Dieldrin	<0.0098		0.0098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Diethylphthalate	<0.49		0.49		ug/L		10/15/26 10:08	10/16/26 13:42	1
Dimethylphthalate	<0.49		0.49		ug/L		10/15/26 10:08	10/16/26 13:42	1
Di-n-butyl phthalate	<0.98		0.98		ug/L		10/15/26 10:08	10/16/26 13:42	1
Di-n-octyl phthalate	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Endosulfan I (Alpha)	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Endosulfan II (Beta)	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Endosulfan sulfate	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Endrin	<0.0098		0.0098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Endrin aldehyde	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
EPTC	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-258866/21-A
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 258866

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Fluorene	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
gamma-Chlordane	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Heptachlor	<0.0098		0.0098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Heptachlor epoxide (isomer B)	<0.0098		0.0098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Hexachlorobenzene	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Hexachlorocyclopentadiene	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Isophorone	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Lindane	<0.0098		0.0098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Malathion	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Methoxychlor	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Metolachlor	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Molinate	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Naphthalene	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Parathion	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Pendimethalin (Penoxaline)	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Phenanthrene	<0.039		0.039		ug/L		10/15/26 10:08	10/16/26 13:42	1
Propachlor	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Pyrene	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Simazine	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Terbacil	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Terbuthylazine	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Thiobencarb	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1
Total Permethrin (mixed isomers)	<0.20		0.20		ug/L		10/15/26 10:08	10/16/26 13:42	1
trans-Nonachlor	<0.049		0.049		ug/L		10/15/26 10:08	10/16/26 13:42	1
Trifluralin	<0.098		0.098		ug/L		10/15/26 10:08	10/16/26 13:42	1

Tentatively Identified Compound	*MB Est. Result*	*MB Qualifier*	*Unit*	*D*	*RT*	*CAS No.*	*Prepared*	*Analyzed*	*Dil Fac*
Unknown	*0.740*	*T J*	*ug/L*		*2.60*	*N/A*	*10/15/26 10:08*	*10/16/26 13:42*	*1*
Unknown	*0.850*	*T J*	*ug/L*		*3.06*	*N/A*	*10/15/26 10:08*	*10/16/26 13:42*	*1*
Undecane	*5.09*	*T J N*	*ug/L*		*3.20*	*1120-21-4*	*10/15/26 10:08*	*10/16/26 13:42*	*1*
9-Octadecenamide, (Z)-	*1.22*	*T J N*	*ug/L*		*8.06*	*301-02-0*	*10/15/26 10:08*	*10/16/26 13:42*	*1*

Surrogate	*MB %Recovery*	*MB Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2-Nitro-m-xylene	*97*		*70 - 130*	*10/15/26 10:08*	*10/16/26 13:42*	*1*
Perylene-d12	*86*		*70 - 130*	*10/15/26 10:08*	*10/16/26 13:42*	*1*
Triphenylphosphate	*104*		*70 - 130*	*10/15/26 10:08*	*10/16/26 13:42*	*1*

Lab Sample ID: LCS 380-258866/23-A
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 258866

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	1.97	2.04		ug/L		104	70 - 130
2,4'-DDD	1.97	2.13		ug/L		108	70 - 130
2,4'-DDE	1.97	2.17		ug/L		110	70 - 130
2,4'-DDT	1.97	2.23		ug/L		113	70 - 130

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-258866/23-A
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 258866

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
2,4-Dinitrotoluene	1.97	2.01		ug/L		102	70 - 130
2,6-Dinitrotoluene	1.97	2.02		ug/L		103	70 - 130
2-Methylnaphthalene	1.97	2.01		ug/L		102	70 - 130
4,4'-DDD	1.97	2.30		ug/L		117	70 - 130
4,4'-DDE	1.97	2.09		ug/L		107	70 - 130
4,4'-DDT	1.97	2.18		ug/L		111	70 - 130
Acenaphthene	1.97	1.95		ug/L		99	70 - 130
Acenaphthylene	1.97	1.91		ug/L		97	70 - 130
Acetochlor	1.97	2.05		ug/L		104	70 - 130
Alachlor	1.97	2.12		ug/L		108	70 - 130
alpha-BHC	1.97	2.06		ug/L		105	70 - 130
alpha-Chlordane	1.97	2.06		ug/L		105	70 - 130
Anthracene	1.97	1.95		ug/L		99	70 - 130
Atrazine	1.97	2.35		ug/L		120	70 - 130
Benz(a)anthracene	1.97	2.08		ug/L		106	70 - 130
Benzo[a]pyrene	1.97	1.94		ug/L		99	70 - 130
Benzo[b]fluoranthene	1.97	2.01		ug/L		102	70 - 130
Benzo[g,h,i]perylene	1.97	2.12		ug/L		108	70 - 130
Benzo[k]fluoranthene	1.97	1.97		ug/L		100	70 - 130
beta-BHC	1.97	2.12		ug/L		108	70 - 130
Bis(2-ethylhexyl) phthalate	1.97	1.70		ug/L		86	70 - 130
Bromacil	1.97	1.81		ug/L		92	70 - 130
Butachlor	1.97	2.08		ug/L		106	70 - 130
Butylbenzylphthalate	1.97	2.23		ug/L		113	70 - 130
Chlorobenzilate	1.97	1.98		ug/L		101	70 - 130
Chloroneb	1.97	2.19		ug/L		111	70 - 130
Chlorothalonil (Draconil, Bravo)	1.97	2.61	*+	ug/L		133	70 - 130
Chlorpyrifos	1.97	2.09		ug/L		107	70 - 130
Chrysene	1.97	1.94		ug/L		99	70 - 130
delta-BHC	1.97	2.14		ug/L		109	70 - 130
Di(2-ethylhexyl)adipate	1.97	2.12		ug/L		108	70 - 130
Dibenz(a,h)anthracene	1.97	2.06		ug/L		105	70 - 130
Diclorvos (DDVP)	1.97	1.95		ug/L		99	70 - 130
Dieldrin	1.97	2.23		ug/L		114	70 - 130
Diethylphthalate	1.97	2.19		ug/L		112	70 - 130
Dimethylphthalate	1.97	2.07		ug/L		105	70 - 130
Di-n-butyl phthalate	3.93	4.00		ug/L		102	70 - 130
Di-n-octyl phthalate	1.97	1.64		ug/L		83	70 - 130
Endosulfan I (Alpha)	1.97	2.00		ug/L		102	70 - 130
Endosulfan II (Beta)	1.97	1.86		ug/L		95	70 - 130
Endosulfan sulfate	1.97	2.41		ug/L		123	70 - 130
Endrin	1.97	2.34		ug/L		119	70 - 130
Endrin aldehyde	1.97	2.03		ug/L		103	60 - 130
EPTC	1.97	2.07		ug/L		106	70 - 130
Fluoranthene	1.97	1.95		ug/L		99	70 - 130
Fluorene	1.97	2.05		ug/L		104	70 - 130
gamma-Chlordane	1.97	2.13		ug/L		108	70 - 130
Heptachlor	1.97	2.16		ug/L		110	70 - 130
Heptachlor epoxide (isomer B)	1.97	2.02		ug/L		103	70 - 130

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-258866/23-A
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 258866

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexachlorobenzene	1.97	2.15		ug/L		109	70 - 130
Hexachlorocyclopentadiene	1.97	2.33		ug/L		118	70 - 130
Indeno[1,2,3-cd]pyrene	1.97	2.08		ug/L		106	70 - 130
Isophorone	1.97	1.88		ug/L		96	70 - 130
Lindane	1.97	2.24		ug/L		114	70 - 130
Malathion	1.97	2.04		ug/L		104	70 - 130
Methoxychlor	1.97	1.78		ug/L		91	70 - 130
Metolachlor	1.97	1.97		ug/L		100	70 - 130
Molinate	1.97	2.10		ug/L		107	70 - 130
Naphthalene	1.97	1.92		ug/L		98	70 - 130
Parathion	1.97	2.05		ug/L		104	70 - 130
Pendimethalin (Penoxaline)	1.97	2.24		ug/L		114	70 - 130
Phenanthrene	1.97	1.90		ug/L		97	70 - 130
Propachlor	1.97	2.21		ug/L		112	70 - 130
Pyrene	1.97	2.06		ug/L		105	70 - 130
Simazine	1.97	2.13		ug/L		108	70 - 130
Terbacil	1.97	2.07		ug/L		105	70 - 130
Terbuthylazine	1.97	2.27		ug/L		116	70 - 130
Thiobencarb	1.97	2.06		ug/L		105	70 - 130
trans-Nonachlor	1.97	2.04		ug/L		104	70 - 130
Trifluralin	1.97	2.24		ug/L		114	70 - 130

Surrogate	*LCS %Recovery*	*LCS Qualifier*	*Limits*
2-Nitro-m-xylene	*96*		*70 - 130*
Perylene-d12	*97*		*70 - 130*
Triphenylphosphate	*106*		*70 - 130*

Lab Sample ID: MRL 380-258866/22-A
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 258866

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	0.0984	0.0932	J	ug/L		95	50 - 150
2,4'-DDD	0.0984	0.0887	J	ug/L		90	50 - 150
2,4'-DDE	0.0984	0.110		ug/L		111	50 - 150
2,4'-DDT	0.0984	0.112		ug/L		114	50 - 150
2,4-Dinitrotoluene	0.0984	0.116		ug/L		118	50 - 150
2,6-Dinitrotoluene	0.0984	0.115		ug/L		117	50 - 150
2-Methylnaphthalene	0.0984	0.0906	J	ug/L		92	50 - 150
4,4'-DDD	0.0984	0.111		ug/L		113	50 - 150
4,4'-DDE	0.0984	0.126		ug/L		128	50 - 150
4,4'-DDT	0.0984	0.116		ug/L		118	50 - 150
Acenaphthene	0.0984	0.101		ug/L		103	50 - 150
Acenaphthylene	0.0984	0.0899	J	ug/L		91	50 - 150
Acetochlor	0.0984	0.111		ug/L		113	50 - 150
Alachlor	0.0492	0.0545		ug/L		111	50 - 150
alpha-BHC	0.0984	0.124		ug/L		126	50 - 150
alpha-Chlordane	0.0246	<0.029		ug/L		106	50 - 150

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-258866/22-A
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 258866

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Anthracene	0.0197	0.0210		ug/L		107	50 - 150
Atrazine	0.0492	0.0593		ug/L		120	50 - 150
Benz(a)anthracene	0.0492	0.0494		ug/L		100	50 - 150
Benzo[a]pyrene	0.0197	0.0167	J	ug/L		85	50 - 150
Benzo[b]fluoranthene	0.0197	0.0162	J	ug/L		82	50 - 150
Benzo[g,h,i]perylene	0.0492	0.0570		ug/L		116	50 - 150
Benzo[k]fluoranthene	0.0197	0.0184	J	ug/L		94	50 - 150
beta-BHC	0.0984	0.127		ug/L		129	50 - 150
Bis(2-ethylhexyl) phthalate	0.590	0.587	J	ug/L		99	50 - 150
Bromacil	0.0984	0.111		ug/L		113	50 - 150
Butachlor	0.0492	0.0587		ug/L		119	50 - 150
Butylbenzylphthalate	0.492	0.659		ug/L		134	50 - 150
Chlorobenzilate	0.0984	0.106		ug/L		107	50 - 150
Chloroneb	0.0984	0.108		ug/L		110	50 - 150
Chlorothalonil (Draconil, Bravo)	0.0984	0.149	^3+	ug/L		152	50 - 150
Chlorpyrifos	0.0492	0.0605		ug/L		123	50 - 150
Chrysene	0.0197	0.0179	J	ug/L		91	50 - 150
delta-BHC	0.0984	0.130		ug/L		132	50 - 150
Di(2-ethylhexyl)adipate	0.590	0.756		ug/L		128	50 - 150
Dibenz(a,h)anthracene	0.0492	0.0574		ug/L		117	50 - 150
Diclorvos (DDVP)	0.0492	0.0587		ug/L		119	50 - 150
Dieldrin	0.00984	0.0139		ug/L		141	50 - 150
Diethylphthalate	0.492	0.717		ug/L		146	50 - 150
Dimethylphthalate	0.492	0.619		ug/L		126	50 - 150
Di-n-butyl phthalate	0.492	0.586	J	ug/L		119	49 - 243
Di-n-octyl phthalate	0.0984	0.0806	J	ug/L		82	50 - 150
Endosulfan I (Alpha)	0.0984	0.0937	J	ug/L		95	50 - 150
Endosulfan II (Beta)	0.0984	0.123		ug/L		125	50 - 150
Endosulfan sulfate	0.0984	0.145		ug/L		147	50 - 150
Endrin	0.00984	0.0126		ug/L		128	50 - 150
Endrin aldehyde	0.0984	0.116		ug/L		118	50 - 150
EPTC	0.0984	0.106		ug/L		108	50 - 150
Fluoranthene	0.0984	0.105		ug/L		106	50 - 150
Fluorene	0.0492	0.0546		ug/L		111	50 - 150
gamma-Chlordane	0.0246	0.0283	J	ug/L		115	50 - 150
Heptachlor	0.00984	0.0136		ug/L		138	50 - 150
Heptachlor epoxide (isomer B)	0.00984	0.0117		ug/L		119	50 - 150
Hexachlorobenzene	0.0492	0.0545		ug/L		111	50 - 150
Hexachlorocyclopentadiene	0.0492	<0.037		ug/L		60	50 - 150
Indeno[1,2,3-cd]pyrene	0.0492	0.0574		ug/L		117	50 - 150
Isophorone	0.0984	0.103		ug/L		104	50 - 150
Lindane	0.00984	0.00995		ug/L		101	50 - 150
Malathion	0.0984	0.120		ug/L		122	50 - 150
Methoxychlor	0.0492	0.0484	J	ug/L		98	50 - 150
Metolachlor	0.0492	0.0598		ug/L		122	50 - 150
Molinate	0.0984	0.121		ug/L		123	50 - 150
Naphthalene	0.0984	0.0919	J	ug/L		93	50 - 150
Parathion	0.0984	0.108		ug/L		110	50 - 150
Pendimethalin (Penoxaline)	0.0984	0.108		ug/L		110	50 - 150

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-258866/22-A
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 258866

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
Phenanthrene			0.0394	0.0437		ug/L		111	50 - 150		
Propachlor			0.0492	0.0606		ug/L		123	50 - 150		
Pyrene			0.0492	0.0513		ug/L		104	50 - 150		
Simazine			0.0492	0.0574		ug/L		117	50 - 150		
Terbacil			0.0984	0.104		ug/L		105	50 - 150		
Terbuthylazine			0.0984	0.111		ug/L		113	50 - 150		
Thiobencarb			0.0984	0.113		ug/L		115	50 - 150		
trans-Nonachlor			0.0246	0.0291	J	ug/L		118	50 - 150		
Trifluralin			0.0984	0.125		ug/L		127	50 - 150		

Surrogate	*MRL %Recovery*	*MRL Qualifier*	*Limits*
2-Nitro-m-xylene	*98*		*70 - 130*
Perylene-d12	*91*		*70 - 130*
Triphenylphosphate	*105*		*70 - 130*

Lab Sample ID: 380-242052-AG-1-A MS
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 258866

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
1-Methylnaphthalene	<0.096		1.93	2.03		ug/L		105	70 - 130		
2,4'-DDD	<0.096		1.93	2.10		ug/L		109	70 - 130		
2,4'-DDE	<0.096		1.93	2.15		ug/L		111	70 - 130		
2,4'-DDT	<0.096		1.93	2.17		ug/L		113	70 - 130		
2,4-Dinitrotoluene	<0.096		1.93	1.98		ug/L		103	70 - 130		
2,6-Dinitrotoluene	<0.096		1.93	2.03		ug/L		105	70 - 130		
2-Methylnaphthalene	<0.096		1.93	2.00		ug/L		104	70 - 130		
4,4'-DDD	<0.096		1.93	2.27		ug/L		118	70 - 130		
4,4'-DDE	<0.096		1.93	2.03		ug/L		105	70 - 130		
4,4'-DDT	<0.096		1.93	2.16		ug/L		112	70 - 130		
Acenaphthene	<0.096		1.93	1.85		ug/L		96	70 - 130		
Acenaphthylene	<0.096		1.93	1.73		ug/L		90	70 - 130		
Acetochlor	<0.096		1.93	2.05		ug/L		106	70 - 130		
Alachlor	<0.048		1.93	2.06		ug/L		107	70 - 130		
alpha-BHC	<0.096		1.93	1.97		ug/L		102	70 - 130		
alpha-Chlordane	<0.048		1.93	2.04		ug/L		106	70 - 130		
Anthracene	<0.019	F1	1.93	0.0641	F1	ug/L		3	70 - 130		
Atrazine	<0.048		1.93	2.29		ug/L		119	70 - 130		
Benz(a)anthracene	<0.048		1.93	1.64		ug/L		85	70 - 130		
Benzo[a]pyrene	<0.019		1.93	1.40		ug/L		73	70 - 130		
Benzo[b]fluoranthene	<0.019		1.93	1.98		ug/L		103	70 - 130		
Benzo[g,h,i]perylene	<0.048		1.93	2.05		ug/L		106	70 - 130		
Benzo[k]fluoranthene	<0.019		1.93	1.97		ug/L		102	70 - 130		
beta-BHC	<0.096		1.93	2.01		ug/L		105	70 - 130		
Bis(2-ethylhexyl) phthalate	<0.58		1.93	1.78		ug/L		93	70 - 130		
Bromacil	<0.096		1.93	1.91		ug/L		99	70 - 130		
Butachlor	<0.048		1.93	2.07		ug/L		108	70 - 130		
Butylbenzylphthalate	<0.48		1.93	2.16		ug/L		112	70 - 130		

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-242052-AG-1-A MS
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 258866

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Chlorobenzilate	<0.096		1.93	2.00		ug/L		104	70 - 130
Chloroneb	<0.096		1.93	2.13		ug/L		111	70 - 130
Chlorothalonil (Draconil, Bravo)	<0.096	^3+ F1 *+	1.93	2.53	F1	ug/L		132	70 - 130
Chlorpyrifos	<0.048		1.93	2.20		ug/L		114	70 - 130
Chrysene	<0.019		1.93	1.92		ug/L		100	70 - 130
delta-BHC	<0.096		1.93	2.12		ug/L		110	70 - 130
Di(2-ethylhexyl)adipate	<0.58		1.93	2.11		ug/L		110	70 - 130
Dibenz(a,h)anthracene	<0.048		1.93	2.09		ug/L		109	70 - 130
Diclorvos (DDVP)	<0.048		1.93	1.88		ug/L		98	70 - 130
Dieldrin	<0.0096		1.93	2.23		ug/L		116	70 - 130
Diethylphthalate	<0.48		1.93	2.13		ug/L		108	70 - 130
Dimethylphthalate	<0.48		1.93	2.04		ug/L		106	70 - 130
Di-n-butyl phthalate	<0.96		3.85	4.00		ug/L		104	70 - 130
Di-n-octyl phthalate	<0.096		1.93	1.74		ug/L		90	70 - 130
Endosulfan I (Alpha)	<0.096		1.93	1.95		ug/L		102	70 - 130
Endosulfan II (Beta)	<0.096		1.93	1.77		ug/L		92	70 - 130
Endosulfan sulfate	<0.096		1.93	2.34		ug/L		122	70 - 130
Endrin	<0.0096		1.93	2.33		ug/L		121	70 - 130
Endrin aldehyde	<0.096		1.93	1.58		ug/L		82	60 - 130
EPTC	<0.096		1.93	2.03		ug/L		106	70 - 130
Fluoranthene	<0.096		1.93	1.91		ug/L		99	70 - 130
Fluorene	<0.048		1.93	2.00		ug/L		104	70 - 130
gamma-Chlordane	<0.048		1.93	2.08		ug/L		108	70 - 130
Heptachlor	<0.0096		1.93	2.17		ug/L		112	70 - 130
Heptachlor epoxide (isomer B)	<0.0096		1.93	1.98		ug/L		103	70 - 130
Hexachlorobenzene	<0.048		1.93	2.08		ug/L		108	70 - 130
Hexachlorocyclopentadiene	<0.048		1.93	2.21		ug/L		115	70 - 130
Indeno[1,2,3-cd]pyrene	<0.048		1.93	2.08		ug/L		108	70 - 130
Isophorone	<0.096		1.93	1.83		ug/L		95	70 - 130
Lindane	<0.0096		1.93	2.18		ug/L		113	70 - 130
Malathion	<0.096		1.93	2.00		ug/L		104	70 - 130
Methoxychlor	<0.048		1.93	1.76		ug/L		91	70 - 130
Metolachlor	<0.048		1.93	1.98		ug/L		103	70 - 130
Molinate	<0.096		1.93	2.03		ug/L		106	70 - 130
Naphthalene	<0.096		1.93	1.91		ug/L		99	70 - 130
Parathion	<0.096		1.93	2.05		ug/L		106	70 - 130
Pendimethalin (Penoxaline)	<0.096		1.93	2.24		ug/L		116	70 - 130
Phenanthrene	<0.038		1.93	1.91		ug/L		99	70 - 130
Propachlor	<0.048		1.93	2.10		ug/L		109	70 - 130
Pyrene	<0.048		1.93	1.95		ug/L		101	70 - 130
Simazine	<0.048		1.93	2.09		ug/L		108	70 - 130
Terbacil	<0.096		1.93	2.05		ug/L		106	70 - 130
Terbuthylazine	<0.096		1.93	2.18		ug/L		113	70 - 130
Thiobencarb	<0.096		1.93	2.02		ug/L		105	70 - 130
trans-Nonachlor	<0.048		1.93	1.99		ug/L		103	70 - 130
Trifluralin	<0.096		1.93	2.20		ug/L		114	70 - 130

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-242052-AG-1-A MS
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 258866

Surrogate	*MS %Recovery*	*MS Qualifier*	*Limits*
2-Nitro-m-xylene	*98*		*70 - 130*
Perylene-d12	*96*		*70 - 130*
Triphenylphosphate	*105*		*70 - 130*

Lab Sample ID: 380-241904-I-1-A DU
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Duplicate
Prep Type: Total/NA
Prep Batch: 258866

Analyte	Sample Result	Sample Qualifier		DU Result	DU Qualifier	Unit	D			RPD	RPD Limit
1-Methylnaphthalene	<0.096			<0.096		ug/L				NC	20
2,4'-DDD	<0.096			<0.096		ug/L				NC	20
2,4'-DDE	<0.096			<0.096		ug/L				NC	20
2,4'-DDT	<0.096			<0.096		ug/L				NC	20
2,4-Dinitrotoluene	<0.096			<0.096		ug/L				NC	20
2,6-Dinitrotoluene	<0.096			<0.096		ug/L				NC	20
2-Methylnaphthalene	<0.096			<0.096		ug/L				NC	20
4,4'-DDD	<0.096			<0.096		ug/L				NC	20
4,4'-DDE	<0.096			<0.096		ug/L				NC	20
4,4'-DDT	<0.096			<0.096		ug/L				NC	20
Acenaphthene	<0.096			<0.096		ug/L				NC	20
Acenaphthylene	<0.096			<0.096		ug/L				NC	20
Acetochlor	<0.096			<0.096		ug/L				NC	20
Alachlor	<0.048			<0.048		ug/L				NC	20
alpha-BHC	<0.096			<0.096		ug/L				NC	20
alpha-Chlordane	<0.048			<0.048		ug/L				NC	20
Anthracene	<0.019			<0.019		ug/L				NC	20
Atrazine	<0.048			<0.048		ug/L				NC	20
Benz(a)anthracene	<0.048			<0.048		ug/L				NC	20
Benzo[a]pyrene	<0.019			<0.019		ug/L				NC	20
Benzo[b]fluoranthene	<0.019			<0.019		ug/L				NC	20
Benzo[g,h,i]perylene	<0.048			<0.048		ug/L				NC	20
Benzo[k]fluoranthene	<0.019			<0.019		ug/L				NC	20
beta-BHC	<0.096			<0.096		ug/L				NC	20
Bis(2-ethylhexyl) phthalate	<0.58			<0.58		ug/L				NC	20
Bromacil	<0.096			<0.096		ug/L				NC	20
Butachlor	<0.048			<0.048		ug/L				NC	20
Butylbenzylphthalate	<0.48			<0.48		ug/L				NC	20
Chlorobenzilate	<0.096			<0.096		ug/L				NC	20
Chloroneb	<0.096			<0.096		ug/L				NC	20
Chlorothalonil (Draconil, Bravo)	<0.096	^3+ *+		<0.096	*+	ug/L				NC	20
Chlorpyrifos	<0.048			<0.048		ug/L				NC	20
Chrysene	<0.019			<0.019		ug/L				NC	20
delta-BHC	<0.096			<0.096		ug/L				NC	20
Di(2-ethylhexyl)adipate	<0.58			<0.58		ug/L				NC	20
Dibenz(a,h)anthracene	<0.048			<0.048		ug/L				NC	20
Diclorvos (DDVP)	<0.048			<0.048		ug/L				NC	20
Dieldrin	0.061			0.0595		ug/L				3	20
Diethylphthalate	<0.48			<0.48		ug/L				NC	20

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-241904-I-1-A DU
Matrix: Water
Analysis Batch: 259205

Client Sample ID: Duplicate
Prep Type: Total/NA
Prep Batch: 258866

Analyte	Sample Result	Sample Qualifier		DU Result	DU Qualifier	Unit	D			RPD	RPD Limit
Dimethylphthalate	<0.48			<0.48		ug/L				NC	20
Di-n-butyl phthalate	<0.96			<0.96		ug/L				NC	20
Di-n-octyl phthalate	<0.096			<0.096		ug/L				NC	20
Endosulfan I (Alpha)	<0.096			<0.096		ug/L				NC	20
Endosulfan II (Beta)	<0.096			<0.096		ug/L				NC	20
Endosulfan sulfate	<0.096			<0.096		ug/L				NC	20
Endrin	<0.0096			<0.0096		ug/L				NC	20
Endrin aldehyde	<0.096			<0.096		ug/L				NC	20
EPTC	<0.096			<0.096		ug/L				NC	20
Fluoranthene	<0.096			<0.096		ug/L				NC	20
Fluorene	<0.048			<0.048		ug/L				NC	20
gamma-Chlordane	<0.048			<0.048		ug/L				NC	20
Heptachlor	<0.0096			<0.0096		ug/L				NC	20
Heptachlor epoxide (isomer B)	0.011			0.0104		ug/L				3	20
Hexachlorobenzene	<0.048			<0.048		ug/L				NC	20
Hexachlorocyclopentadiene	<0.048			<0.048		ug/L				NC	20
Indeno[1,2,3-cd]pyrene	<0.048			<0.048		ug/L				NC	20
Isophorone	<0.096			<0.096		ug/L				NC	20
Lindane	<0.0096			<0.0096		ug/L				NC	20
Malathion	<0.096			<0.096		ug/L				NC	20
Methoxychlor	<0.048			<0.048		ug/L				NC	20
Metolachlor	<0.048			<0.048		ug/L				NC	20
Molinate	<0.096			<0.096		ug/L				NC	20
Naphthalene	<0.096			<0.096		ug/L				NC	20
Parathion	<0.096			<0.096		ug/L				NC	20
Pendimethalin (Penoxaline)	<0.096			<0.096		ug/L				NC	20
Phenanthrene	<0.038			<0.039		ug/L				NC	20
Propachlor	<0.048			<0.048		ug/L				NC	20
Pyrene	<0.048			<0.048		ug/L				NC	20
Simazine	<0.048			<0.048		ug/L				NC	20
Terbacil	<0.096			<0.096		ug/L				NC	20
Terbuthylazine	<0.096			<0.096		ug/L				NC	20
Thiobencarb	<0.096			<0.096		ug/L				NC	20
Total Permethrin (mixed isomers)	<0.19			<0.19		ug/L				NC	20
trans-Nonachlor	<0.048			<0.048		ug/L				NC	20
Trifluralin	<0.096			<0.096		ug/L				NC	20

Surrogate	*DU %Recovery*	*DU Qualifier*	*Limits*
2-Nitro-m-xylene	*97*		*70 - 130*
Perylene-d12	*90*		*70 - 130*
Triphenylphosphate	*104*		*70 - 130*

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 570-816560/1-A
Matrix: Water
Analysis Batch: 823736

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 816560

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	10/16/26 07:57	10/29/26 19:56	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	78		33 - 139	10/16/26 07:57	10/29/26 19:56	1
2-Fluorobiphenyl (Surr)	82		33 - 126	10/16/26 07:57	10/29/26 19:56	1
2-Fluorophenol (Surr)	49		12 - 120	10/16/26 07:57	10/29/26 19:56	1
Nitrobenzene-d5 (Surr)	79		36 - 120	10/16/26 07:57	10/29/26 19:56	1
Phenol-d6 (Surr)	29		10 - 120	10/16/26 07:57	10/29/26 19:56	1
p-Terphenyl-d14 (Surr)	88		47 - 131	10/16/26 07:57	10/29/26 19:56	1

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: MB 570-816560/1-A
Matrix: Water
Analysis Batch: 818406

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 816560

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
2-Methylnaphthalene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Acenaphthene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Acenaphthylene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Anthracene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Benzo[a]anthracene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Benzo[a]pyrene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Benzo[b]fluoranthene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Benzo[g,h,i]perylene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Benzo[k]fluoranthene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Chrysene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Dibenz(a,h)anthracene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Fluoranthene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Fluorene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Naphthalene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Phenanthrene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1
Pyrene	<0.20		0.20		ug/L		10/16/26 07:57	10/20/26 17:15	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	75		28 - 127	10/16/26 07:57	10/20/26 17:15	1
2-Fluorobiphenyl (Surr)	73		31 - 120	10/16/26 07:57	10/20/26 17:15	1
2-Fluorophenol (Surr)	45		17 - 120	10/16/26 07:57	10/20/26 17:15	1
Nitrobenzene-d5 (Surr)	76		27 - 120	10/16/26 07:57	10/20/26 17:15	1
Phenol-d6 (Surr)	32		10 - 120	10/16/26 07:57	10/20/26 17:15	1
p-Terphenyl-d14 (Surr)	76		45 - 120	10/16/26 07:57	10/20/26 17:15	1

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCS 570-816560/2-A
Matrix: Water
Analysis Batch: 818406

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 816560

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
1-Methylnaphthalene			20.0	10.3		ug/L		52	47 - 120		
2-Methylnaphthalene			20.0	10.4		ug/L		52	43 - 120		
Acenaphthene			20.0	14.7		ug/L		74	60 - 132		
Acenaphthylene			20.0	14.6		ug/L		73	54 - 126		
Anthracene			20.0	14.9		ug/L		74	43 - 120		
Benzo[a]anthracene			20.0	15.5		ug/L		78	42 - 133		
Benzo[a]pyrene			20.0	15.5		ug/L		77	32 - 148		
Benzo[b]fluoranthene			20.0	14.8		ug/L		74	42 - 140		
Benzo[g,h,i]perylene			20.0	15.6		ug/L		78	1 - 195		
Benzo[k]fluoranthene			20.0	16.2		ug/L		81	25 - 146		
Chrysene			20.0	15.7		ug/L		78	44 - 140		
Dibenz(a,h)anthracene			20.0	15.7		ug/L		79	1 - 200		
Fluoranthene			20.0	15.6		ug/L		78	43 - 121		
Fluorene			20.0	14.8		ug/L		74	70 - 120		
Indeno[1,2,3-cd]pyrene			20.0	14.8		ug/L		74	1 - 151		
Naphthalene			20.0	10.1		ug/L		50	36 - 120		
Phenanthrene			20.0	15.5		ug/L		77	65 - 120		
Pyrene			20.0	16.2		ug/L		81	70 - 120		

Surrogate	*LCS %Recovery*	*LCS Qualifier*	*Limits*
2,4,6-Tribromophenol (Surr)	*83*		*28 - 127*
2-Fluorobiphenyl (Surr)	*76*		*31 - 120*
2-Fluorophenol (Surr)	*48*		*17 - 120*
Nitrobenzene-d5 (Surr)	*59*		*27 - 120*
Phenol-d6 (Surr)	*33*		*10 - 120*
p-Terphenyl-d14 (Surr)	*83*		*45 - 120*

Lab Sample ID: LCSD 570-816560/3-A
Matrix: Water
Analysis Batch: 818406

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 816560

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene			20.0	8.60	*-	ug/L		43	47 - 120	18	20
2-Methylnaphthalene			20.0	8.62		ug/L		43	43 - 120	19	20
Acenaphthene			20.0	12.7		ug/L		63	60 - 132	15	29
Acenaphthylene			20.0	12.6		ug/L		63	54 - 126	14	45
Anthracene			20.0	13.5		ug/L		67	43 - 120	10	40
Benzo[a]anthracene			20.0	14.1		ug/L		71	42 - 133	9	32
Benzo[a]pyrene			20.0	14.0		ug/L		70	32 - 148	10	43
Benzo[b]fluoranthene			20.0	13.7		ug/L		69	42 - 140	7	43
Benzo[g,h,i]perylene			20.0	13.9		ug/L		70	1 - 195	12	61
Benzo[k]fluoranthene			20.0	14.3		ug/L		71	25 - 146	13	38
Chrysene			20.0	14.2		ug/L		71	44 - 140	10	53
Dibenz(a,h)anthracene			20.0	13.8		ug/L		69	1 - 200	13	75
Fluoranthene			20.0	14.7		ug/L		73	43 - 121	6	40
Fluorene			20.0	13.4	*-	ug/L		67	70 - 120	10	23
Indeno[1,2,3-cd]pyrene			20.0	13.2		ug/L		66	1 - 151	11	60
Naphthalene			20.0	7.93		ug/L		40	36 - 120	24	39

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCSD 570-816560/3-A
Matrix: Water
Analysis Batch: 818406

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 816560

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Phenanthrene			20.0	13.8		ug/L		69	65 - 120	12	24
Pyrene			20.0	14.3		ug/L		72	70 - 120	12	30

Surrogate	*LCSD %Recovery*	*LCSD Qualifier*	*Limits*
2,4,6-Tribromophenol (Surr)	*73*		*28 - 127*
2-Fluorobiphenyl (Surr)	*61*		*31 - 120*
2-Fluorophenol (Surr)	*40*		*17 120*
Nitrobenzene-d5 (Surr)	*52*		*27 - 120*
Phenol-d6 (Surr)	*30*		*10 - 120*
p-Terphenyl-d14 (Surr)	*73*		*45 - 120*

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: MB 570-820765/5
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10		ug/L			10/24/26 11:27	1

Surrogate	*MB %Recovery*	*MB Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
4-Bromofluorobenzene (Surr)	*96*		*38 - 134*		*10/24/26 11:27*	*1*

Lab Sample ID: LCS 570-820765/3
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)			400	331		ug/L		83	78 - 120		

Surrogate	*LCS %Recovery*	*LCS Qualifier*	*Limits*
4-Bromofluorobenzene (Surr)	*95*		*38 - 134*

Lab Sample ID: LCSD 570-820765/4
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)			400	325		ug/L		81	78 - 120	2	10

Surrogate	*LCSD %Recovery*	*LCSD Qualifier*	*Limits*
4-Bromofluorobenzene (Surr)	*97*		*38 - 134*

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Lab Sample ID: MRL 570-820765/6
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)			10.0	10.9		ug/L		109	50 - 150		

Surrogate	*MRL %Recovery*	*MRL Qualifier*	*Limits*
4-Bromofluorobenzene (Surr)	*95*		*38 - 134*

Lab Sample ID: 380-241911-B-1 MS
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)	<10		400	340		ug/L		85	68 - 122		

Surrogate	*MS %Recovery*	*MS Qualifier*	*Limits*
4-Bromofluorobenzene (Surr)	*99*		*38 - 134*

Lab Sample ID: 380-241911-B-1 MSD
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	328		ug/L		82	68 - 122	4	18

Surrogate	*MSD %Recovery*	*MSD Qualifier*	*Limits*
4-Bromofluorobenzene (Surr)	*100*		*38 - 134*

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Lab Sample ID: MB 570-816038/1-A
Matrix: Water
Analysis Batch: 821788

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 816038

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25		ug/L		10/15/26 11:48	10/27/26 11:01	1
Motor Oil Range Organics [C24-C36]	<25		25		ug/L		10/15/26 11:48	10/27/26 11:01	1
C8-C18	<25		25		ug/L		10/15/26 11:48	10/27/26 11:01	1

Surrogate	*MB %Recovery*	*MB Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
n-Octacosane (Surr)	*109*		*60 - 130*	*10/15/26 11:48*	*10/27/26 11:01*	*1*

Lab Sample ID: LCS 570-816038/2-A
Matrix: Water
Analysis Batch: 821788

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 816038

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
C10-C28			1600	1490		ug/L		93	56 - 127		

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

Lab Sample ID: LCS 570-816038/2-A
Matrix: Water
Analysis Batch: 821788

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 816038

Surrogate	LCS %Recovery	LCS Qualifier	Limits
n-Octacosane (Surr)	104		60 - 130

Lab Sample ID: LCSD 570-816038/3-A
Matrix: Water
Analysis Batch: 821788

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 816038

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
C10-C28			1600	1500		ug/L		94	56 - 127	1	23

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
n-Octacosane (Surr)	103		60 - 130

Lab Sample ID: 380-241911-C-1-A MS
Matrix: Water
Analysis Batch: 821156

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 816038

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
C10-C28	<26		1670	1610		ug/L		97	70 - 130

Surrogate	MS %Recovery	MS Qualifier	Limits
n-Octacosane (Surr)	104		60 - 130

Lab Sample ID: 380-241911-C-1-B MSD
Matrix: Water
Analysis Batch: 821156

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 816038

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
C10-C28	<26		1690	1660		ug/L		98	70 - 130	3	20

Surrogate	MSD %Recovery	MSD Qualifier	Limits
n-Octacosane (Surr)	103		60 - 130

GC/MS Semi VOA

Prep Batch: 258866

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	525.2	
MB 380-258866/21-A	Method Blank	Total/NA	Water	525.2	
LCS 380-258866/23-A	Lab Control Sample	Total/NA	Water	525.2	
MRL 380-258866/22-A	Lab Control Sample	Total/NA	Water	525.2	
380-242052-AG-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-241904-I-1-A DU	Duplicate	Total/NA	Water	525.2	

Analysis Batch: 259205

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	525.2	258866
MB 380-258866/21-A	Method Blank	Total/NA	Water	525.2	258866
LCS 380-258866/23-A	Lab Control Sample	Total/NA	Water	525.2	258866
MRL 380-258866/22-A	Lab Control Sample	Total/NA	Water	525.2	258866
380-242052-AG-1-A MS	Matrix Spike	Total/NA	Water	525.2	258866
380-241904-I-1-A DU	Duplicate	Total/NA	Water	525.2	258866

Prep Batch: 816560

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	625.1	
MB 570-816560/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-816560/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-816560/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	

Analysis Batch: 818406

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-816560/1-A	Method Blank	Total/NA	Water	625.1 SIM	816560
LCS 570-816560/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	816560
LCSD 570-816560/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	816560

Analysis Batch: 819137

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	625.1 SIM	816560

Analysis Batch: 823736

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	625.1	816560
MB 570-816560/1-A	Method Blank	Total/NA	Water	625.1	816560

GC VOA

Analysis Batch: 820765

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	8015B GRO LL	
380-241906-2	TB: Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	8015B GRO LL	
MB 570-820765/5	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-820765/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-820765/4	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-820765/6	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-241911-B-1 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-241911-B-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

GC Semi VOA

Prep Batch: 816038

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	3510C	
MB 570-816038/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-816038/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-816038/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
380-241911-C-1-A MS	Matrix Spike	Total/NA	Water	3510C	
380-241911-C-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	3510C	

Analysis Batch: 821156

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	8015B	816038
380-241911-C-1-A MS	Matrix Spike	Total/NA	Water	8015B	816038
380-241911-C-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	8015B	816038

Analysis Batch: 821788

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-816038/1-A	Method Blank	Total/NA	Water	8015B	816038
LCS 570-816038/2-A	Lab Control Sample	Total/NA	Water	8015B	816038
LCSD 570-816038/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	816038

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-241906-1
Matrix: Water
Date Collected: 10/12/26 12:19
Date Received: 10/14/26 09:55

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			258866	H3MJ	EA POM	10/15/26 10:08
Total/NA	Analysis	525.2		1	259205	Q8LA	EA POM	10/16/26 17:04
Total/NA	Prep	625.1			816560	OAJ3	EET CAL 4	10/16/26 07:58
Total/NA	Analysis	625.1		1	823736	5BV3	EET CAL 4	10/30/26 00:24
Total/NA	Prep	625.1			816560	OAJ3	EET CAL 4	10/16/26 07:58
Total/NA	Analysis	625.1 SIM		1	819137	S4EA	EET CAL 4	10/22/26 00:46
Total/NA	Analysis	8015B GRO LL		1	820765	W4LC	EET CAL 4	10/24/26 12:51
Total/NA	Prep	3510C			816038	TVD6	EET CAL 4	10/15/26 11:48
Total/NA	Analysis	8015B		1	821156	TR8L	EET CAL 4	10/26/26 16:49

Client Sample ID: TB: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-241906-2
Matrix: Water
Date Collected: 10/12/26 12:19
Date Received: 10/14/26 09:55

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	820765	W4LC	EET CAL 4	10/24/26 17:51

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100
EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Laboratory: Eurofins Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-27

The following analytes are included in this report, but the laboratory is not certified by Hawaii State CA00006. This list may include analytes for which the agency does not offer certification:

Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Water	1-Methylnaphthalene
525.2	525.2	Water	2,4'-DDD
525.2	525.2	Water	2,4'-DDE
525.2	525.2	Water	2,4'-DDT
525.2	525.2	Water	2,4-Dinitrotoluene
525.2	525.2	Water	2,6-Dinitrotoluene
525.2	525.2	Water	2-Methylnaphthalene
525.2	525.2	Water	4,4'-DDD
525.2	525.2	Water	4,4'-DDE
525.2	525.2	Water	4,4'-DDT
525.2	525.2	Water	Acetochlor
525.2	525.2	Water	alpha-BHC
525.2	525.2	Water	alpha-Chlordane
525.2	525.2	Water	beta-BHC
525.2	525.2	Water	Chlorobenzilate
525.2	525.2	Water	Chloroneb
525.2	525.2	Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Water	Chlorpyrifos
525.2	525.2	Water	delta-BHC
525.2	525.2	Water	Diclorvos (DDVP)
525.2	525.2	Water	Endosulfan I (Alpha)
525.2	525.2	Water	Endosulfan II (Beta)
525.2	525.2	Water	Endosulfan sulfate
525.2	525.2	Water	Endrin aldehyde
525.2	525.2	Water	EPTC
525.2	525.2	Water	gamma-Chlordane
525.2	525.2	Water	Isophorone
525.2	525.2	Water	Malathion
525.2	525.2	Water	Parathion
525.2	525.2	Water	Pendimethalin (Penoxaline)
525.2	525.2	Water	Terbacil
525.2	525.2	Water	Terbuthylazine
525.2	525.2	Water	Total Permethrin (mixed isomers)
525.2	525.2	Water	trans-Nonachlor

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	7296.01	11-30-26
A2LA	ISO/IEC 17025	7296.01	11-30-26
Alaska (UST)	State	25-005	03-02-27
Arizona	State	AZ0830	11-16-26
California	Los Angeles County Sanitation Districts	9257304	07-31-28
California	SCAQMD LAP	17LA0919	11-30-26

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Laboratory: Eurofins Calscience (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
California	State	3082	07-31-28
Kansas	NELAP	E-10420	07-31-27
Nevada	State	CA00111	07-31-27
Oregon	NELAP	4175	02-02-27
Texas	NELAP	T104704499	07-31-27
USDA	US Federal Programs	525-23-159-97150	01-01-27
Utah	NELAP	CA00111	02-28-27
Washington	State	C916	10-11-27

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Method	Method Description	Protocol	Laboratory
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA POM
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
525.2	Extraction of Semivolatile Compounds	EPA	EA POM
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.
EPA = US Environmental Protection Agency
SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100
EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-241906-1
SDG: Weekly: Ka'amilo Wells P1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-241906-1	Ka'amilo Wells P1 (331-031-WL008)	Water	10/12/26 12:19	10/14/26 09:55	HI0000331
380-241906-2	TB: Ka'amilo Wells P1 (331-031-WL008)	Water	10/12/26 12:19	10/14/26 09:55	

Eurofins Eaton Analytical Pomona
941 Corporate Center Drive
Pomona, CA 91768-2642
Phone (626) 386-1100

Chain of Custody Record

eurofins | Envi

380-241906 COC

Client Information	Sampler: bailey	Lab PM: Lopez, Maria	Carrier Tracking No(s):	COC No:
Client Contact: Mr. Kirk Iwamoto	Phone: +1 808 748 5840	E-Mail: Maria.Lopez@et.eurofinsus.com	State of Origin:	Page:
Company: City & County of Honolulu	PWSID:			Job #:
Address: 630 South Beretania Street Chemistry Lab	Due Date Requested:			
City: Honolulu	TAT Requested (days):			
State, Zip: HI, 96843	Compliance Project: Δ Yes Δ No			
Phone: 808-748-5840 (Tel)	PO #: C20525101 exp 05312023			
Email: kiwamoto@hbws.org	WO #:			
Project Name: RED-HILL/HBWS Sites Event Desc: RUSH Weekly Red Hill	Project #: 38001111			
Site: Hawaii	SSOW#:			

Analysis Requested

Preservation Codes:
R - NaThioSO4
RA - NaThio/HCl
Q - Na2SO3
QA - Na2SO3/HCl
Y - Trizma
I - NH4 Acetate
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	625.1; 625.1_SIM	8015B_GRO_LL - (MOD) GRO	8015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C36/C8-C18	525.2_PREC - (MOD) 525plus Plus TICs	537.1_DW_PREC - 537.1 Full List	533 - All Analytes	Total Number of containers	Special Instructions/Note:
			Preservation Code:				R	RA	Q	QA	Y	I		
Ka'amilo Wells P1 (331-031-WL008)	12-Oct-2026	1219	G	Water			2	3	2	2				
Ka'amilo Wells Pump 1 (Matrix Spike)				Water										
Ka'amilo Wells Pump 1 (Matrix Spike Duplicate)				Water										
TB: Ka'amilo Wells P1 (331-031-WL008)	12-Oct-2026	1219		Water				2						

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☐ Disposal By Lab ☐ Archive For ____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment: FX

	Date/Time:	Company	Received by:	Date/Time:	Company
[redacted]	13 Oct. 2026 1400	HBWS	[illegible]	10/14/26 955	EEAP
	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.:

Cooler Temperature(s) °C and Other Remarks: 0.5 (IR) 2.1 (2) Gel Frozen

Ver: 04/02/2024

11/2/2026

Eurofins Pomona
941 Corporate Center Drive
Pomona, CA 91768-2642
Phone: 626-386-1100

Chain of Custody Record

eurofins | Envir

Loc: 380
241906

Client Information (Sub Contract Lab)	Sampler: N/A	Lab PM: Lopez, Maria	Carrier Tracking No(s): N/A	COC No: 380-393067.1
Client Contact: Shipping/Receiving	Phone: N/A	E-Mail: Maria.Lopez@et.eurofinsus.com	State of Origin: Hawaii	Page: Page 1 of 1
Company: Eurofins Environment Testing Southwest L		Accreditations Required (See note): State - Hawaii		Job #: 380-241906-1
Address: 2841 Dow Avenue, Suite 100	Due Date Requested: 10/26/2026			
City: Tustin	TAT Requested (days): N/A			
State, Zip: CA, 92780				
Phone: 714-895-5494(Tel)	PO #: N/A			
Email: N/A	WO #: N/A			
Project Name: RED-HILL	Project #: 38001111			
Site: Honolulu BWS Sites	SSOW#: N/A			

Analysis Requested

Preservation Codes:

Other: N/A

Sample Identification - Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=wasteoil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	8015B_DRO_LL_CS/3510C_LLHNL Ranges: C10-C24/C24-C36/C8-C18	8015B_GRO_LL/5030C(MOD) GRO	625.1_SIM/625_Prep(MOD) Extended PAH List	Total Number of containers	Special Instructions/Note:
			Preservation Code:								
Ka'amilo Wells P1 (331-031-WL008) (380-241906-1)	10/12/26	12:19 Hawaiian	G	Water			X	X	X	7	MRLs are needed. Confirm any hits >RL.
TB: Ka'amilo Wells P1 (331-031-WL008) (380-241906-2)	10/12/26	12:19 Hawaiian	G	Water				X		2	MRLs are needed. Confirm any hits >RL.

380-241906 Chain of Custody

Note: Since laboratory accreditations are subject to change, Eurofins Drinking Water and Wastewater West, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Drinking Water and Wastewater West, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Drinking Water and Wastewater West, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Drinking Water and Wastewater West, LLC.

Possible Hazard Identification	Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
Unconfirmed	☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months
Deliverable Requested: I, II, III, IV, Other (specify) Primary Deliverable Rank: 2	Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Manuel Garcia	10/14/26 1624		Manuel Garcia	10/14/26 1624	
Relinquished by: Manuel Garcia	Date/Time: 10/14/26 1818	Company	Received by:	Date/Time: 10/14/26 1818	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: ☐ Yes ☐ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks: 1.3/ 1.5 IR-8

Ver: 08/18/2026

11/2/2026

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-241906-1
SDG Number: Weekly: Ka'amilo Wells P1

Login Number: 241906
List Number: 1
Creator: Tran, Kristine

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
ClO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-241906-1
SDG Number: Weekly: Ka'amilo Wells P1

Login Number: 241906
List Number: 2
Creator: Mills, Mary

List Source: Eurofins Calscience
List Creation: 10/14/26 09:24 PM

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	1.5
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	