

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

# ANALYTICAL REPORT

## PREPARED FOR

Attn: Mr. Erwin Kawata  
City & County of Honolulu  
630 South Beretania Street  
Public Service Bldg. Room 310  
Honolulu, Hawaii 96843

Generated 6/26/2026 4:55:06 PM

## JOB DESCRIPTION

RED-HILL  
PFAS: Aiea Gulch Wells Pump 1

## JOB NUMBER

380-221336-1

# Eurofins Pomona

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

## Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

## Authorization



Authorized for release by  
Maria Lopez, Project Manager  
[Maria.Lopez@et.eurofinsus.com](mailto:Maria.Lopez@et.eurofinsus.com)  
(626)386-1100

Generated  
6/26/2026 4:55:06 PM



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	7
Action Limit Summary . . . . .	11
Surrogate Summary . . . . .	12
Isotope Dilution Summary . . . . .	13
QC Sample Results . . . . .	15
QC Association Summary . . . . .	26
Lab Chronicle . . . . .	27
Certification Summary . . . . .	28
Method Summary . . . . .	29
Sample Summary . . . . .	30
Chain of Custody . . . . .	31
Receipt Checklists . . . . .	32

# Definitions/Glossary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Qualifiers

### LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: City & County of Honolulu  
Project: RED-HILL

Job ID: 380-221336-1

**Job ID: 380-221336-1**

**Eurofins Pomona**

## Job Narrative 380-221336-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

### Receipt

The samples were received on 6/24/2026 9:30 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 5.6°C.

### PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

# Detection Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-221336-1**

No Detections.

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-221336-2**

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

This Detection Summary does not include radiochemical test results.

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-221336-1**

**Date Collected: 06/22/26 10:39**

**Matrix: Drinking Water**

**Date Received: 06/24/26 09:30**

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosfluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 22:10	1
<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>			<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3 HFPO-DA	104		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C6 PFDA	112		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C5 PFHxA	109		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C4 PFHpA	110		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C8 PFOA	113		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C9 PFNA	114		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C7 PFUnA	116		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C2 PFDoA	113		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C4 PFBA	116		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C5 PFPeA	114		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C3 PFBS	113		50 - 200			06/25/26 06:28	06/25/26 22:10	1
13C3 PFHxS	114		50 - 200			06/25/26 06:28	06/25/26 22:10	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-221336-1**

Date Collected: 06/22/26 10:39

Matrix: Drinking Water

Date Received: 06/24/26 09:30

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	116		50 - 200	06/25/26 06:28	06/25/26 22:10	1
13C2-4:2-FTS	125		50 - 200	06/25/26 06:28	06/25/26 22:10	1
13C2-6:2-FTS	123		50 - 200	06/25/26 06:28	06/25/26 22:10	1
13C2-8:2-FTS	116		50 - 200	06/25/26 06:28	06/25/26 22:10	1

**Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:18	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	104		70 - 130	06/25/26 10:00	06/25/26 21:18	1
13C2 PFHxA	98		70 - 130	06/25/26 10:00	06/25/26 21:18	1
13C2 PFDA	101		70 - 130	06/25/26 10:00	06/25/26 21:18	1
13C3-GenX	94		70 - 130	06/25/26 10:00	06/25/26 21:18	1

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-221336-2**

Date Collected: 06/22/26 10:39

Matrix: Water

Date Received: 06/24/26 09:30

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-221336-2**

**Date Collected: 06/22/26 10:39**

**Matrix: Water**

**Date Received: 06/24/26 09:30**

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/25/26 06:28	06/25/26 23:55	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	104		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C6 PFDA	117		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C5 PFHxA	113		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C4 PFHpA	110		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C8 PFOA	115		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C9 PFNA	114		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C7 PFUnA	113		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C2 PFDoA	118		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C4 PFBA	112		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C5 PFPeA	115		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C3 PFBS	112		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C3 PFHxS	112		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C8 PFOS	114		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C2-4:2-FTS	116		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C2-6:2-FTS	114		50 - 200	06/25/26 06:28	06/25/26 23:55	1
13C2-8:2-FTS	113		50 - 200	06/25/26 06:28	06/25/26 23:55	1

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-221336-2**

**Date Collected: 06/22/26 10:39**

**Matrix: Water**

**Date Received: 06/24/26 09:30**

**Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
N-methylperfluorooctanesulfonamideacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
N-ethylperfluorooctanesulfonamideacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/25/26 10:00	06/25/26 21:29	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>			<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
d5-NEtFOSAA	96		70 - 130			06/25/26 10:00	06/25/26 21:29	1
13C2 PFHxA	92		70 - 130			06/25/26 10:00	06/25/26 21:29	1
13C2 PFDA	102		70 - 130			06/25/26 10:00	06/25/26 21:29	1
13C3-GenX	88		70 - 130			06/25/26 10:00	06/25/26 21:29	1

# Action Limit Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-221336-1**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-221336-2**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

# Surrogate Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-221336-1  
 SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-221336-1	AIEA GULCH WELLS PUMP 1 (	104	98	101	94
<b>Surrogate Legend</b>					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-221319-F-1-A MS	Matrix Spike	101	102	105	99
380-221319-G-1-A MSD	Matrix Spike Duplicate	102	106	107	108
380-221336-2	FB: AIEA GULCH WELLS PUMF 1 (331-201-TP071)	96	92	102	88
LCS 380-236104/21-A	Lab Control Sample	102	110	107	103
MBL 380-236104/19-A	Method Blank	99	99	99	83
MRL 380-236104/20-A	Lab Control Sample	104	96	105	94
<b>Surrogate Legend</b>					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

# Isotope Dilution Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-221336-1	AIEA GULCH WELLS PUMP 1 (	104	112	109	110	113	114	116	113
380-221336-1 MS	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	113	116	116	113	119	119	117	116
380-221336-1 MSD	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	113	116	112	115	115	119	117	116

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-221336-1	AIEA GULCH WELLS PUMP 1 (	116	114	113	114	116	125	123	116
380-221336-1 MS	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	119	119	115	113	113	119	113	114
380-221336-1 MSD	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	120	119	116	114	116	116	117	117

#### Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDoA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-221336-2	FB: AIEA GULCH WELLS PUMf	104	117	113	110	115	114	113	118
LCS 380-236110/22-A	Lab Control Sample	110	117	111	113	114	115	117	115
MBL 380-236110/20-A	Method Blank	100	108	107	108	110	110	113	113
MRL 380-236110/21-A	Lab Control Sample	101	110	108	105	113	114	111	111

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-221336-2	FB: AIEA GULCH WELLS PUMf	112	115	112	112	114	116	114	113
LCS 380-236110/22-A	Lab Control Sample	112	111	112	114	114	116	115	117
MBL 380-236110/20-A	Method Blank	113	110	116	117	116	127	128	124
MRL 380-236110/21-A	Lab Control Sample	116	116	114	110	114	121	121	114

#### Surrogate Legend

Eurofins Pomona

# Isotope Dilution Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

HFPODA = 13C3 HFPO-DA  
C6PFDA = 13C6 PFDA  
13C5PHA = 13C5 PFHxA  
C4PFHA = 13C4 PFHpA  
C8PFOA = 13C8 PFOA  
C9PFNA = 13C9 PFNA  
13C7PUA = 13C7 PFUnA  
PFDoA = 13C2 PFDoA  
PFBA = 13C4 PFBA  
PFPeA = 13C5 PFPeA  
C3PFBS = 13C3 PFBS  
C3PFHS = 13C3 PFHxS  
C8PFOS = 13C8 PFOS  
42FTS = 13C2-4:2-FTS  
62FTS = 13C2-6:2-FTS  
82FTS = 13C2-8:2-FTS

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

**Lab Sample ID: MBL 380-236110/20-A**  
**Matrix: Water**  
**Analysis Batch: 236283**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 236110**

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosfluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.48		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<0.25		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		06/25/26 06:28	06/25/26 21:40	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	100		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C6 PFDA	108		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C5 PFHxA	107		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C4 PFHpA	108		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C8 PFOA	110		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C9 PFNA	110		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C7 PFUnA	113		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C2 PFDoA	113		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C4 PFBA	113		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C5 PFPeA	110		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C3 PFBS	116		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C3 PFHxS	117		50 - 200	06/25/26 06:28	06/25/26 21:40	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MBL 380-236110/20-A**  
**Matrix: Water**  
**Analysis Batch: 236283**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 236110**

<i>Isotope Dilution</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	%Recovery	Qualifier				
13C8 PFOS	116		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C2-4:2-FTS	127		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C2-6:2-FTS	128		50 - 200	06/25/26 06:28	06/25/26 21:40	1
13C2-8:2-FTS	124		50 - 200	06/25/26 06:28	06/25/26 21:40	1

**Lab Sample ID: LCS 380-236110/22-A**  
**Matrix: Water**  
**Analysis Batch: 236283**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 236110**

<i>Analyte</i>	<i>Spike Added</i>	<i>LCS Result</i>	<i>LCS Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec Limits</i>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	60.2	52.8		ng/L		88	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	60.2	52.5		ng/L		87	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	60.2	56.1		ng/L		93	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	60.2	54.4		ng/L		90	70 - 130
Perfluorobutanesulfonic acid (PFBS)	60.2	55.8		ng/L		93	70 - 130
Perfluorodecanoic acid (PFDA)	60.2	54.1		ng/L		90	70 - 130
Perfluorododecanoic acid (PFDoA)	60.2	55.2		ng/L		92	70 - 130
Perfluoroheptanoic acid (PFHpA)	60.2	55.9		ng/L		93	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	60.2	54.7		ng/L		91	70 - 130
Perfluorohexanoic acid (PFHxA)	60.2	55.7		ng/L		92	70 - 130
Perfluorononanoic acid (PFNA)	60.2	54.6		ng/L		91	70 - 130
Perfluorooctanesulfonic acid (PFOS)	60.2	54.2		ng/L		90	70 - 130
Perfluorooctanoic acid (PFOA)	60.2	53.5		ng/L		89	70 - 130
Perfluoroundecanoic acid (PFUnA)	60.2	54.9		ng/L		91	70 - 130
Perfluorobutanoic acid (PFBA)	60.2	57.1		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	60.2	54.9		ng/L		91	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	60.2	54.8		ng/L		91	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	60.2	56.4		ng/L		94	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	60.2	55.4		ng/L		92	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	60.2	54.3		ng/L		90	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	60.2	54.8		ng/L		91	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	60.2	58.1		ng/L		96	70 - 130
Perfluoropentanoic acid (PFPeA)	60.2	56.1		ng/L		93	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	60.2	55.4		ng/L		92	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: LCS 380-236110/22-A**  
**Matrix: Water**  
**Analysis Batch: 236283**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 236110**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	60.2	55.2		ng/L		92	70 - 130
<b>LCS LCS</b>							
<b>Isotope Dilution</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				
13C3 HFPO-DA	110		50 - 200				
13C6 PFDA	117		50 - 200				
13C5 PFHxA	111		50 - 200				
13C4 PFHpA	113		50 - 200				
13C8 PFOA	114		50 - 200				
13C9 PFNA	115		50 - 200				
13C7 PFUnA	117		50 - 200				
13C2 PFDoA	115		50 - 200				
13C4 PFBA	112		50 - 200				
13C5 PFPeA	111		50 - 200				
13C3 PFBS	112		50 - 200				
13C3 PFHxS	114		50 - 200				
13C8 PFOS	114		50 - 200				
13C2-4:2-FTS	116		50 - 200				
13C2-6:2-FTS	115		50 - 200				
13C2-8:2-FTS	117		50 - 200				

**Lab Sample ID: MRL 380-236110/21-A**  
**Matrix: Water**  
**Analysis Batch: 236283**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 236110**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	1.84	J	ng/L		92	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	1.81	J	ng/L		90	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	1.90	J	ng/L		95	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	1.83	J	ng/L		91	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	1.88	J	ng/L		94	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.06	J	ng/L		103	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	1.96	J	ng/L		98	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	2.05	J	ng/L		102	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	1.97	J	ng/L		99	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	1.93	J	ng/L		96	50 - 150
Perfluorononanoic acid (PFNA)	2.00	1.93	J	ng/L		96	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	1.84	J	ng/L		92	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	1.87	J	ng/L		93	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.07	J	ng/L		103	50 - 150
Perfluorobutanoic acid (PFBA)	2.00	1.98	J	ng/L		99	50 - 150

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MRL 380-236110/21-A**  
**Matrix: Water**  
**Analysis Batch: 236283**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 236110**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.00	2.05	J	ng/L		102	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.00	1.82	J	ng/L		91	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.00	2.18	J	ng/L		109	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.00	1.92	J	ng/L		96	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.00	1.87	J	ng/L		93	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.00	1.79	J	ng/L		89	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.00	1.81	J	ng/L		90	50 - 150
Perfluoropentanoic acid (PFPeA)	2.00	2.00	J	ng/L		100	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.00	1.85	J	ng/L		92	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.00	1.88	J	ng/L		94	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	101		50 - 200
13C6 PFDA	110		50 - 200
13C5 PFHxA	108		50 - 200
13C4 PFHpA	105		50 - 200
13C8 PFOA	113		50 - 200
13C9 PFNA	114		50 - 200
13C7 PFUnA	111		50 - 200
13C2 PFDoA	111		50 - 200
13C4 PFBA	116		50 - 200
13C5 PFPeA	116		50 - 200
13C3 PFBS	114		50 - 200
13C3 PFHxS	110		50 - 200
13C8 PFOS	114		50 - 200
13C2-4:2-FTS	121		50 - 200
13C2-6:2-FTS	121		50 - 200
13C2-8:2-FTS	114		50 - 200

**Lab Sample ID: 380-221336-1 MS**  
**Matrix: Drinking Water**  
**Analysis Batch: 236283**

**Client Sample ID: AIEA GULCH WELLS PUMP 1 (331-201-TP071)**  
**Prep Type: Total/NA**  
**Prep Batch: 236110**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.4	52.0		ng/L		86	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.4	53.3		ng/L		88	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.4	54.7		ng/L		91	70 - 130

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-221336-1 MS

Client Sample ID: AIEA GULCH WELLS PUMP 1 (331-201-TP071)

Matrix: Drinking Water

Prep Type: Total/NA

Analysis Batch: 236283

Prep Batch: 236110

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		60.4	54.6		ng/L		90	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		60.4	53.5		ng/L		89	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		60.4	56.5		ng/L		94	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		60.4	55.4		ng/L		92	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		60.4	57.3		ng/L		95	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		60.4	55.4		ng/L		91	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		60.4	56.8		ng/L		93	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		60.4	53.0		ng/L		88	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		60.4	53.8		ng/L		89	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		60.4	54.9		ng/L		91	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		60.4	55.2		ng/L		91	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		60.4	53.7		ng/L		89	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.4	55.8		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.4	57.0		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.4	54.4		ng/L		90	70 - 130
Nonafluoro-3,6-dioxahheptanoic acid (NFDHA)	<2.0		60.4	52.2		ng/L		86	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.4	56.0		ng/L		93	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.4	54.2		ng/L		90	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.4	54.2		ng/L		90	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		60.4	54.2		ng/L		89	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.4	54.8		ng/L		91	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.4	53.7		ng/L		89	70 - 130

Isotope Dilution	MS %Recovery	MS Qualifier	MS Limits
13C3 HFPO-DA	113		50 - 200
13C6 PFDA	116		50 - 200
13C5 PFHxA	116		50 - 200
13C4 PFHpA	113		50 - 200
13C8 PFOA	119		50 - 200
13C9 PFNA	119		50 - 200
13C7 PFUnA	117		50 - 200
13C2 PFDoA	116		50 - 200
13C4 PFBA	119		50 - 200
13C5 PFPeA	119		50 - 200
13C3 PFBS	115		50 - 200
13C3 PFHxS	113		50 - 200
13C8 PFOS	113		50 - 200

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: 380-221336-1 MS**  
**Matrix: Drinking Water**  
**Analysis Batch: 236283**

**Client Sample ID: AIEA GULCH WELLS PUMP 1 (331-201-TP071)**  
**Prep Type: Total/NA**  
**Prep Batch: 236110**

<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>MS MS Qualifier</i>	<i>Limits</i>
13C2-4:2-FTS	119		50 - 200
13C2-6:2-FTS	113		50 - 200
13C2-8:2-FTS	114		50 - 200

**Lab Sample ID: 380-221336-1 MSD**  
**Matrix: Drinking Water**  
**Analysis Batch: 236283**

**Client Sample ID: AIEA GULCH WELLS PUMP 1 (331-201-TP071)**  
**Prep Type: Total/NA**  
**Prep Batch: 236110**

<b>Analyte</b>	<b>Sample Result</b>	<b>Sample Qualifier</b>	<b>Spike Added</b>	<b>MSD Result</b>	<b>MSD Qualifier</b>	<b>Unit</b>	<b>D</b>	<b>%Rec</b>	<b>%Rec Limits</b>	<b>RPD</b>	<b>RPD Limit</b>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.5	51.7		ng/L		86	70 - 130	0	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.5	51.6		ng/L		85	70 - 130	3	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.5	54.9		ng/L		91	70 - 130	0	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		60.5	53.7		ng/L		89	70 - 130	2	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		60.5	54.2		ng/L		90	70 - 130	1	30
Perfluorodecanoic acid (PFDA)	<2.0		60.5	57.1		ng/L		94	70 - 130	1	30
Perfluorododecanoic acid (PFDoA)	<2.0		60.5	55.9		ng/L		92	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		60.5	56.3		ng/L		93	70 - 130	2	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		60.5	55.5		ng/L		91	70 - 130	0	30
Perfluorohexanoic acid (PFHxA)	<2.0		60.5	56.8		ng/L		93	70 - 130	0	30
Perfluorononanoic acid (PFNA)	<2.0		60.5	52.8		ng/L		87	70 - 130	0	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		60.5	53.5		ng/L		89	70 - 130	0	30
Perfluorooctanoic acid (PFOA)	<2.0		60.5	54.4		ng/L		90	70 - 130	1	30
Perfluoroundecanoic acid (PFUnA)	<2.0		60.5	55.7		ng/L		92	70 - 130	1	30
Perfluorobutanoic acid (PFBA)	<2.0		60.5	54.1		ng/L		89	70 - 130	1	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.5	55.0		ng/L		91	70 - 130	1	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.5	54.4		ng/L		90	70 - 130	5	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.5	53.0		ng/L		88	70 - 130	3	30
Nonfluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		60.5	51.7		ng/L		85	70 - 130	1	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.5	53.8		ng/L		89	70 - 130	4	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.5	51.8		ng/L		86	70 - 130	5	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.5	54.9		ng/L		91	70 - 130	1	30
Perfluoropentanoic acid (PFPeA)	<2.0		60.5	54.9		ng/L		90	70 - 130	1	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.5	53.5		ng/L		88	70 - 130	2	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.5	55.3		ng/L		91	70 - 130	3	30

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	113		50 - 200
13C6 PFDA	116		50 - 200
13C5 PFHxA	112		50 - 200
13C4 PFHpA	115		50 - 200
13C8 PFOA	115		50 - 200
13C9 PFNA	119		50 - 200
13C7 PFUnA	117		50 - 200
13C2 PFDoA	116		50 - 200
13C4 PFBA	120		50 - 200
13C5 PFPeA	119		50 - 200
13C3 PFBS	116		50 - 200
13C3 PFHxS	114		50 - 200
13C8 PFOS	116		50 - 200
13C2-4:2-FTS	116		50 - 200
13C2-6:2-FTS	117		50 - 200
13C2-8:2-FTS	117		50 - 200

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

**Lab Sample ID: MBL 380-236104/19-A**  
**Matrix: Water**  
**Analysis Batch: 236281**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 236104**

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Perfluorotridecanoic acid (PFTrDA)	<0.36		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/25/26 10:00	06/25/26 18:40	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	99		70 - 130			06/25/26 10:00	06/25/26 18:40	1
13C2 PFHxA	99		70 - 130			06/25/26 10:00	06/25/26 18:40	1
13C2 PFDA	99		70 - 130			06/25/26 10:00	06/25/26 18:40	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

**Lab Sample ID: MBL 380-236104/19-A**  
**Matrix: Water**  
**Analysis Batch: 236281**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 236104**

<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3-GenX	83	Qualifier	70 - 130	06/25/26 10:00	06/25/26 18:40	1

**Lab Sample ID: LCS 380-236104/21-A**  
**Matrix: Water**  
**Analysis Batch: 236281**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 236104**

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>	<i>Limits</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>					
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	50.3	47.7		ng/L		95		70 - 130
Perfluorooctanesulfonic acid (PFOS)	50.3	49.9		ng/L		99		70 - 130
Perfluoroundecanoic acid (PFUnA)	50.3	52.3		ng/L		104		70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	50.3	48.9		ng/L		97		70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	50.3	49.6		ng/L		99		70 - 130
Perfluorohexanoic acid (PFHxA)	50.3	48.3		ng/L		96		70 - 130
Perfluorododecanoic acid (PFDoA)	50.3	49.3		ng/L		98		70 - 130
Perfluorooctanoic acid (PFOA)	50.3	51.9		ng/L		103		70 - 130
Perfluorodecanoic acid (PFDA)	50.3	52.0		ng/L		103		70 - 130
Perfluorohexanesulfonic acid (PFHxS)	50.3	53.3		ng/L		106		70 - 130
Perfluorobutanesulfonic acid (PFBS)	50.3	49.4		ng/L		98		70 - 130
Perfluoroheptanoic acid (PFHpA)	50.3	52.9		ng/L		105		70 - 130
Perfluorononanoic acid (PFNA)	50.3	53.0		ng/L		105		70 - 130
Perfluorotetradecanoic acid (PFTA)	50.3	45.5		ng/L		90		70 - 130
Perfluorotridecanoic acid (PFTrDA)	50.3	49.8		ng/L		99		70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	50.3	48.8		ng/L		97		70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	50.3	47.7		ng/L		95		70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	50.3	49.3		ng/L		98		70 - 130

<i>Surrogate</i>	<i>LCS</i>	<i>LCS</i>	<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
d5-NEtFOSAA	102		70 - 130
13C2 PFHxA	110		70 - 130
13C2 PFDA	107		70 - 130
13C3-GenX	103		70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

**Lab Sample ID: MRL 380-236104/20-A**  
**Matrix: Water**  
**Analysis Batch: 236281**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 236104**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	1.66	J	ng/L		82	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	1.91	J	ng/L		95	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.00	J	ng/L		99	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.01	1.87	J	ng/L		93	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.01	2.01	J	ng/L		100	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	1.87	J	ng/L		93	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	1.89	J	ng/L		94	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	1.98	J	ng/L		99	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.11	J	ng/L		105	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	1.98	J	ng/L		98	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	2.00	J	ng/L		100	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	1.95	J	ng/L		97	50 - 150
Perfluorononanoic acid (PFNA)	2.01	2.06	J	ng/L		103	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.01	1.93	J	ng/L		96	50 - 150
Perfluorotridecanoic acid (PFTTrDA)	2.01	2.13	J	ng/L		106	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	1.91	J	ng/L		95	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.84	J	ng/L		92	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.79	J	ng/L		89	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	104		70 - 130
13C2 PFHxA	96		70 - 130
13C2 PFDA	105		70 - 130
13C3-GenX	94		70 - 130

**Lab Sample ID: 380-221319-F-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 236281**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 236104**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		25.2	23.9		ng/L		95	70 - 130
Perfluorooctanesulfonic acid (PFOS)	2.8		25.2	28.2		ng/L		101	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		25.2	26.9		ng/L		107	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.2	26.1		ng/L		104	70 - 130

Eurofins Pomona



# QC Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-221336-1  
 SDG: PFAS: Aiea Gulch Wells Pump 1

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

**Lab Sample ID: 380-221319-G-1-A MSD**

**Matrix: Water**

**Analysis Batch: 236281**

**Client Sample ID: Matrix Spike Duplicate**

**Prep Type: Total/NA**

**Prep Batch: 236104**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorohexanesulfonic acid (PFHxS)	<2.0		25.2	27.8		ng/L		110	70 - 130	6	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		25.2	26.6		ng/L		104	70 - 130	5	30
Perfluoroheptanoic acid (PFHpA)	<2.0		25.2	27.3		ng/L		108	70 - 130	1	30
Perfluorononanoic acid (PFNA)	<2.0		25.2	27.4		ng/L		109	70 - 130	1	30
Perfluorotetradecanoic acid (PFTA)	<2.0		25.2	23.6		ng/L		94	70 - 130	8	30
Perfluorotridecanoic acid (PFTTrDA)	<2.0		25.2	27.9		ng/L		111	70 - 130	7	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		25.2	26.6		ng/L		106	70 - 130	7	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		25.2	27.0		ng/L		107	70 - 130	10	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		25.2	27.2		ng/L		108	70 - 130	4	30

Surrogate	MSD %Recovery	MSD Qualifier	Limits
d5-NEtFOSAA	102		70 - 130
13C2 PFHxA	106		70 - 130
13C2 PFDA	107		70 - 130
13C3-GenX	108		70 - 130

# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## LCMS

### Prep Batch: 236104

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-221336-1	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	537.1 DW	
380-221336-2	FB: AIEA GULCH WELLS PUMP 1 (331-201-TPC	Total/NA	Water	537.1 DW	
MBL 380-236104/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-236104/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-236104/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-221319-F-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-221319-G-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

### Prep Batch: 236110

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-221336-1	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	533	
380-221336-2	FB: AIEA GULCH WELLS PUMP 1 (331-201-TPC	Total/NA	Water	533	
MBL 380-236110/20-A	Method Blank	Total/NA	Water	533	
LCS 380-236110/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-236110/21-A	Lab Control Sample	Total/NA	Water	533	
380-221336-1 MS	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	533	
380-221336-1 MSD	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	533	

### Analysis Batch: 236281

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-221336-1	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	EPA 537.1 V2	236104
380-221336-2	FB: AIEA GULCH WELLS PUMP 1 (331-201-TPC	Total/NA	Water	EPA 537.1 V2	236104
MBL 380-236104/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	236104
LCS 380-236104/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	236104
MRL 380-236104/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	236104
380-221319-F-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	236104
380-221319-G-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	236104

### Analysis Batch: 236283

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-221336-1	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	533	236110
380-221336-2	FB: AIEA GULCH WELLS PUMP 1 (331-201-TPC	Total/NA	Water	533	236110
MBL 380-236110/20-A	Method Blank	Total/NA	Water	533	236110
LCS 380-236110/22-A	Lab Control Sample	Total/NA	Water	533	236110
MRL 380-236110/21-A	Lab Control Sample	Total/NA	Water	533	236110
380-221336-1 MS	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	533	236110
380-221336-1 MSD	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	533	236110

# Lab Chronicle

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-221336-1  
 SDG: PFAS: Aiea Gulch Wells Pump 1

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
 (331-201-TP071)**

**Lab Sample ID: 380-221336-1**

**Date Collected: 06/22/26 10:39**

**Matrix: Drinking Water**

**Date Received: 06/24/26 09:30**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			236110	XTD8	EA POM	06/25/26 06:28
Total/NA	Analysis	533		1	236283	Y5FM	EA POM	06/25/26 22:10
Total/NA	Prep	537.1 DW			236104	LM3A	EA POM	06/25/26 10:00
Total/NA	Analysis	EPA 537.1 V2		1	236281	SZ9R	EA POM	06/25/26 21:18

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1  
 (331-201-TP071)**

**Lab Sample ID: 380-221336-2**

**Date Collected: 06/22/26 10:39**

**Matrix: Water**

**Date Received: 06/24/26 09:30**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			236110	XTD8	EA POM	06/25/26 06:28
Total/NA	Analysis	533		1	236283	Y5FM	EA POM	06/25/26 23:55
Total/NA	Prep	537.1 DW			236104	LM3A	EA POM	06/25/26 10:00
Total/NA	Analysis	EPA 537.1 V2		1	236281	SZ9R	EA POM	06/25/26 21:29

**Laboratory References:**

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

# Accreditation/Certification Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

## Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

# Method Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



# Sample Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-221336-1  
SDG: PFAS: Aiea Gulch Wells Pump 1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-221336-1	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Drinking Water	06/22/26 10:39	06/24/26 09:30	Hawaii
380-221336-2	FB: AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Water	06/22/26 10:39	06/24/26 09:30	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17



# Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-221336-1  
SDG Number: PFAS: Aiea Gulch Wells Pump 1

**Login Number: 221336**

**List Number: 1**

**Creator: Del Rosario, Michael**

**List Source: Eurofins Pomona**

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

