

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

# ANALYTICAL REPORT

## PREPARED FOR

Attn: Mr. Erwin Kawata  
City & County of Honolulu  
630 South Beretania Street  
Public Service Bldg. Room 310  
Honolulu, Hawaii 96843

Generated 6/24/2026 4:22:03 PM

## JOB DESCRIPTION

RED-HILL  
PFAS: Aiea Gulch Wells Pump 2  
RUSH Weekly Red Hill

## JOB NUMBER

380-220718-1

# Eurofins Pomona

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

## Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

## Authorization



Authorized for release by  
Maria Lopez, Project Manager  
[Maria.Lopez@et.eurofinsus.com](mailto:Maria.Lopez@et.eurofinsus.com)  
(626)386-1100

Generated  
6/24/2026 4:22:03 PM



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	7
Action Limit Summary . . . . .	10
Surrogate Summary . . . . .	11
Isotope Dilution Summary . . . . .	12
QC Sample Results . . . . .	14
QC Association Summary . . . . .	25
Lab Chronicle . . . . .	26
Certification Summary . . . . .	27
Method Summary . . . . .	28
Sample Summary . . . . .	29
Chain of Custody . . . . .	30
Receipt Checklists . . . . .	31

# Definitions/Glossary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Qualifiers

### LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: City & County of Honolulu  
Project: RED-HILL

Job ID: 380-220718-1

**Job ID: 380-220718-1**

**Eurofins Pomona**

## Job Narrative 380-220718-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

### Receipt

The samples were received on 6/19/2026 9:55 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 3.0°C.

### PFAS

Method EPA 537.1 V2: The following QC issues in preparation batch 380-235374 and analytical batch 380-235510 were observed: Field blank FB AIEA GULCH WELLS PUMP 2 (331-202-TP072) (380-220718-2) had Perfluorohexanoic acid (PFHxA) detection greater than 1/3 MRL. Any Perfluorohexanoic acid (PFHxA) detection in native sample is not acceptable per method. Due to these QC issues data for the field blank was excluded. Analysis of the Field Blank is required only if a field sample contains a method analyte or analytes at, or above, the MRL. Sample results showed non detect thus valid for reporting. (XWB4)

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

# Detection Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**  
PWSID Number: HI0000331

**Lab Sample ID: 380-220718-1**

No Detections.

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-220718-2**

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-220718-1**

**Date Collected: 06/17/26 09:30**

**Matrix: Drinking Water**

**Date Received: 06/19/26 09:55**

**PWSID Number: HI0000331**

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosfluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:46	1
<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>			<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3 HFPO-DA	99		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C6 PFDA	99		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C5 PFHxA	103		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C4 PFHpA	104		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C8 PFOA	107		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C9 PFNA	107		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C7 PFUnA	103		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C2 PFDoA	105		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C4 PFBA	104		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C5 PFPeA	101		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C3 PFBS	106		50 - 200			06/22/26 07:39	06/22/26 21:46	1
13C3 PFHxS	108		50 - 200			06/22/26 07:39	06/22/26 21:46	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-220718-1**

Date Collected: 06/17/26 09:30

Matrix: Drinking Water

Date Received: 06/19/26 09:55

PWSID Number: HI0000331

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	110		50 - 200	06/22/26 07:39	06/22/26 21:46	1
13C2-4:2-FTS	107		50 - 200	06/22/26 07:39	06/22/26 21:46	1
13C2-6:2-FTS	103		50 - 200	06/22/26 07:39	06/22/26 21:46	1
13C2-8:2-FTS	91		50 - 200	06/22/26 07:39	06/22/26 21:46	1

**Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/22/26 09:45	06/23/26 01:33	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	97		70 - 130	06/22/26 09:45	06/23/26 01:33	1
13C2 PFHxA	103		70 - 130	06/22/26 09:45	06/23/26 01:33	1
13C2 PFDA	100		70 - 130	06/22/26 09:45	06/23/26 01:33	1
13C3-GenX	94		70 - 130	06/22/26 09:45	06/23/26 01:33	1

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-220718-2**

Date Collected: 06/17/26 09:30

Matrix: Water

Date Received: 06/19/26 09:55

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-220718-2**

**Date Collected: 06/17/26 09:30**

**Matrix: Water**

**Date Received: 06/19/26 09:55**

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/22/26 07:39	06/22/26 21:55	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	100		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C6 PFDA	92		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C5 PFHxA	105		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C4 PFHpA	102		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C8 PFOA	103		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C9 PFNA	105		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C7 PFUnA	99		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C2 PFDoA	101		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C4 PFBA	109		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C5 PFPeA	109		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C3 PFBS	109		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C3 PFHxS	116		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C8 PFOS	118		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C2-4:2-FTS	109		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C2-6:2-FTS	105		50 - 200	06/22/26 07:39	06/22/26 21:55	1
13C2-8:2-FTS	94		50 - 200	06/22/26 07:39	06/22/26 21:55	1

# Action Limit Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**  
PWSID Number: HI0000331

**Lab Sample ID: 380-220718-1**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-220718-2**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA

# Surrogate Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-220718-1  
 SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-220718-1	AIEA GULCH WELLS PUMP 2 (	97	103	100	94

**Surrogate Legend**

d5NEFOS = d5-NEtFOSAA  
 PFHxA = 13C2 PFHxA  
 PFDA = 13C2 PFDA  
 GenX = 13C3-GenX

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-220637-B-1-A MS	Matrix Spike	101	111	108	99
380-220637-C-1-A MSD	Matrix Spike Duplicate	90	98	96	91
LCS 380-235374/21-A	Lab Control Sample	96	96	100	89
MBL 380-235374/19-A	Method Blank	99	103	101	94
MRL 380-235374/20-A	Lab Control Sample	95	100	100	91

**Surrogate Legend**

d5NEFOS = d5-NEtFOSAA  
 PFHxA = 13C2 PFHxA  
 PFDA = 13C2 PFDA  
 GenX = 13C3-GenX

# Isotope Dilution Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-220718-1	AIEA GULCH WELLS PUMP 2 (	99	99	103	104	107	107	103	105

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-220718-1	AIEA GULCH WELLS PUMP 2 (	104	101	106	108	110	107	103	91

#### Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDaA = 13C2 PFDaA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-220637-E-1-A MS	Matrix Spike	106	98	104	107	109	109	108	106
380-220637-F-1-A MSD	Matrix Spike Duplicate	113	101	110	110	110	114	109	109
380-220718-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	100	92	105	102	103	105	99	101
LCS 380-235377/21-A	Lab Control Sample	109	105	109	115	107	116	111	107
MBL 380-235377/19-A	Method Blank	96	99	93	104	105	105	97	103
MRL 380-235377/20-A	Lab Control Sample	101	100	103	107	109	115	103	103

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-220637-E-1-A MS	Matrix Spike	107	109	110	114	113	112	106	95
380-220637-F-1-A MSD	Matrix Spike Duplicate	106	111	102	109	116	103	103	98
380-220718-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	109	109	109	116	118	109	105	94
LCS 380-235377/21-A	Lab Control Sample	109	117	111	111	116	108	101	98
MBL 380-235377/19-A	Method Blank	101	99	105	112	112	107	103	96
MRL 380-235377/20-A	Lab Control Sample	106	109	106	107	109	104	97	93

#### Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA

# Isotope Dilution Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

13C5PHA = 13C5 PFHxA  
C4PFHA = 13C4 PFHpA  
C8PFOA = 13C8 PFOA  
C9PFNA = 13C9 PFNA  
13C7PUA = 13C7 PFUnA  
PFDoA = 13C2 PFDoA  
PFBA = 13C4 PFBA  
PFPeA = 13C5 PFPeA  
C3PFBS = 13C3 PFBS  
C3PFHS = 13C3 PFHxS  
C8PFOS = 13C8 PFOS  
42FTS = 13C2-4:2-FTS  
62FTS = 13C2-6:2-FTS  
82FTS = 13C2-8:2-FTS

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

**Lab Sample ID: MBL 380-235377/19-A**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosfluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	0.618	J	2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<0.25		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		06/22/26 07:39	06/22/26 18:28	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	96		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C6 PFDA	99		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C5 PFHxA	93		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C4 PFHpA	104		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C8 PFOA	105		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C9 PFNA	105		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C7 PFUnA	97		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C2 PFDoA	103		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C4 PFBA	101		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C5 PFPeA	99		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C3 PFBS	105		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C3 PFHxS	112		50 - 200	06/22/26 07:39	06/22/26 18:28	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MBL 380-235377/19-A**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

<i>Isotope Dilution</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	%Recovery	Qualifier				
13C8 PFOS	112		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C2-4:2-FTS	107		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C2-6:2-FTS	103		50 - 200	06/22/26 07:39	06/22/26 18:28	1
13C2-8:2-FTS	96		50 - 200	06/22/26 07:39	06/22/26 18:28	1

**Lab Sample ID: LCS 380-235377/21-A**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

<i>Analyte</i>	<i>Spike Added</i>	<i>LCS Result</i>	<i>LCS Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec Limits</i>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	120	108		ng/L		89	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	120	106		ng/L		88	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	120	112		ng/L		93	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	120	120		ng/L		99	70 - 130
Perfluorobutanesulfonic acid (PFBS)	120	118		ng/L		98	70 - 130
Perfluorodecanoic acid (PFDA)	120	121		ng/L		100	70 - 130
Perfluorododecanoic acid (PFDoA)	120	112		ng/L		93	70 - 130
Perfluoroheptanoic acid (PFHpA)	120	108		ng/L		90	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	120	118		ng/L		98	70 - 130
Perfluorohexanoic acid (PFHxA)	120	122		ng/L		101	70 - 130
Perfluorononanoic acid (PFNA)	120	106		ng/L		88	70 - 130
Perfluorooctanesulfonic acid (PFOS)	120	110		ng/L		91	70 - 130
Perfluorooctanoic acid (PFOA)	120	115		ng/L		96	70 - 130
Perfluoroundecanoic acid (PFUnA)	120	112		ng/L		93	70 - 130
Perfluorobutanoic acid (PFBA)	120	111		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	120	115		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	120	117		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	120	113		ng/L		94	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	120	115		ng/L		96	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	120	119		ng/L		98	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	120	109		ng/L		91	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	120	112		ng/L		93	70 - 130
Perfluoropentanoic acid (PFPeA)	120	106		ng/L		88	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	120	113		ng/L		94	70 - 130

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: LCS 380-235377/21-A**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	120	121		ng/L		100	70 - 130
<b>LCS LCS</b>							
<b>Isotope Dilution</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				
13C3 HFPO-DA	109		50 - 200				
13C6 PFDA	105		50 - 200				
13C5 PFHxA	109		50 - 200				
13C4 PFHpA	115		50 - 200				
13C8 PFOA	107		50 - 200				
13C9 PFNA	116		50 - 200				
13C7 PFUnA	111		50 - 200				
13C2 PFDoA	107		50 - 200				
13C4 PFBA	109		50 - 200				
13C5 PFPeA	117		50 - 200				
13C3 PFBS	111		50 - 200				
13C3 PFHxS	111		50 - 200				
13C8 PFOS	116		50 - 200				
13C2-4:2-FTS	108		50 - 200				
13C2-6:2-FTS	101		50 - 200				
13C2-8:2-FTS	98		50 - 200				

**Lab Sample ID: MRL 380-235377/20-A**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	2.03	J	ng/L		101	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	1.91	J	ng/L		95	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	2.09	J	ng/L		105	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	2.15	J	ng/L		107	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	2.08	J	ng/L		104	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.27	J	ng/L		113	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.28	J	ng/L		114	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	2.11	J	ng/L		105	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	2.13	J	ng/L		106	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.30	J	ng/L		115	50 - 150
Perfluorononanoic acid (PFNA)	2.00	1.98	J	ng/L		99	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	1.99	J	ng/L		99	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.07	J	ng/L		103	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.07	J	ng/L		103	50 - 150
Perfluorobutanoic acid (PFBA)	2.00	2.27	J	ng/L		113	50 - 150

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MRL 380-235377/20-A**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.00	2.15	J	ng/L		107	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.00	2.16	J	ng/L		108	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.00	2.66	J	ng/L		133	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.00	2.31	J	ng/L		115	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.00	2.17	J	ng/L		108	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.00	2.11	J	ng/L		105	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.00	2.17	J	ng/L		108	50 - 150
Perfluoropentanoic acid (PFPeA)	2.00	2.12	J	ng/L		106	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.00	2.09	J	ng/L		104	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.00	2.04	J	ng/L		102	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	101		50 - 200
13C6 PFDA	100		50 - 200
13C5 PFHxA	103		50 - 200
13C4 PFHpA	107		50 - 200
13C8 PFOA	109		50 - 200
13C9 PFNA	115		50 - 200
13C7 PFUnA	103		50 - 200
13C2 PFDoA	103		50 - 200
13C4 PFBA	106		50 - 200
13C5 PFPeA	109		50 - 200
13C3 PFBS	106		50 - 200
13C3 PFHxS	107		50 - 200
13C8 PFOS	109		50 - 200
13C2-4:2-FTS	104		50 - 200
13C2-6:2-FTS	97		50 - 200
13C2-8:2-FTS	93		50 - 200

**Lab Sample ID: 380-220637-E-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	114		ng/L		95	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	111		ng/L		92	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	117		ng/L		97	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: 380-220637-E-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		120	114		ng/L		95	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		120	118		ng/L		98	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		120	122		ng/L		102	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		120	109		ng/L		90	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		120	110		ng/L		92	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		120	115		ng/L		95	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		120	112		ng/L		93	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		120	109		ng/L		91	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		120	111		ng/L		92	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		120	114		ng/L		95	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		120	111		ng/L		92	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		120	113		ng/L		93	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	114		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	105		ng/L		87	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	111		ng/L		92	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	109		ng/L		90	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		120	119		ng/L		99	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	114		ng/L		95	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	111		ng/L		92	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		120	108		ng/L		90	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	116		ng/L		96	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	115		ng/L		95	70 - 130

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	106		50 - 200
13C6 PFDA	98		50 - 200
13C5 PFHxA	104		50 - 200
13C4 PFHpA	107		50 - 200
13C8 PFOA	109		50 - 200
13C9 PFNA	109		50 - 200
13C7 PFUnA	108		50 - 200
13C2 PFDoA	106		50 - 200
13C4 PFBA	107		50 - 200
13C5 PFPeA	109		50 - 200
13C3 PFBS	110		50 - 200
13C3 PFHxS	114		50 - 200
13C8 PFOS	113		50 - 200

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: 380-220637-E-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>MS MS Qualifier</i>	<i>Limits</i>
13C2-4:2-FTS	112		50 - 200
13C2-6:2-FTS	106		50 - 200
13C2-8:2-FTS	95		50 - 200

**Lab Sample ID: 380-220637-F-1-A MSD**  
**Matrix: Water**  
**Analysis Batch: 235516**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 235377**

<b>Analyte</b>	<b>Sample Result</b>	<b>Sample Qualifier</b>	<b>Spike Added</b>	<b>MSD Result</b>	<b>MSD Qualifier</b>	<b>Unit</b>	<b>D</b>	<b>%Rec</b>	<b>%Rec Limits</b>	<b>RPD</b>	<b>RPD Limit</b>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	104		ng/L		86	70 - 130	9	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	103		ng/L		86	70 - 130	7	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	115		ng/L		96	70 - 130	2	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		120	113		ng/L		94	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		120	121		ng/L		101	70 - 130	3	30
Perfluorodecanoic acid (PFDA)	<2.0		120	130		ng/L		108	70 - 130	6	30
Perfluorododecanoic acid (PFDoA)	<2.0		120	110		ng/L		91	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		120	111		ng/L		92	70 - 130	1	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		120	116		ng/L		96	70 - 130	1	30
Perfluorohexanoic acid (PFHxA)	<2.0		120	114		ng/L		95	70 - 130	2	30
Perfluorononanoic acid (PFNA)	<2.0		120	110		ng/L		91	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		120	106		ng/L		88	70 - 130	5	30
Perfluorooctanoic acid (PFOA)	<2.0		120	112		ng/L		93	70 - 130	2	30
Perfluoroundecanoic acid (PFUnA)	<2.0		120	109		ng/L		91	70 - 130	2	30
Perfluorobutanoic acid (PFBA)	<2.0		120	113		ng/L		94	70 - 130	0	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	110		ng/L		91	70 - 130	4	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	117		ng/L		97	70 - 130	11	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	108		ng/L		89	70 - 130	3	30
Nonfluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	110		ng/L		91	70 - 130	1	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		120	125		ng/L		103	70 - 130	4	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	110		ng/L		91	70 - 130	3	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	110		ng/L		91	70 - 130	1	30
Perfluoropentanoic acid (PFPeA)	<2.0		120	108		ng/L		89	70 - 130	1	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	108		ng/L		90	70 - 130	7	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	118		ng/L		98	70 - 130	3	30

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	113		50 - 200
13C6 PFDA	101		50 - 200
13C5 PFHxA	110		50 - 200
13C4 PFHpA	110		50 - 200
13C8 PFOA	110		50 - 200
13C9 PFNA	114		50 - 200
13C7 PFUnA	109		50 - 200
13C2 PFDoA	109		50 - 200
13C4 PFBA	106		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	102		50 - 200
13C3 PFHxS	109		50 - 200
13C8 PFOS	116		50 - 200
13C2-4:2-FTS	103		50 - 200
13C2-6:2-FTS	103		50 - 200
13C2-8:2-FTS	98		50 - 200

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

**Lab Sample ID: MBL 380-235374/19-A**  
**Matrix: Water**  
**Analysis Batch: 235510**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 235374**

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Perfluorotridecanoic acid (PFTrDA)	<0.36		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/22/26 09:45	06/22/26 22:22	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	99		70 - 130			06/22/26 09:45	06/22/26 22:22	1
13C2 PFHxA	103		70 - 130			06/22/26 09:45	06/22/26 22:22	1
13C2 PFDA	101		70 - 130			06/22/26 09:45	06/22/26 22:22	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

**Lab Sample ID: MBL 380-235374/19-A**  
**Matrix: Water**  
**Analysis Batch: 235510**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 235374**

<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3-GenX	94	Qualifier	70 - 130	06/22/26 09:45	06/22/26 22:22	1

**Lab Sample ID: LCS 380-235374/21-A**  
**Matrix: Water**  
**Analysis Batch: 235510**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 235374**

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>	<i>Limits</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>					
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	50.2	44.1		ng/L		88		70 - 130
Perfluorooctanesulfonic acid (PFOS)	50.2	49.5		ng/L		99		70 - 130
Perfluoroundecanoic acid (PFUnA)	50.2	49.3		ng/L		98		70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	50.2	49.7		ng/L		99		70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	50.2	48.5		ng/L		97		70 - 130
Perfluorohexanoic acid (PFHxA)	50.2	48.1		ng/L		96		70 - 130
Perfluorododecanoic acid (PFDoA)	50.2	47.3		ng/L		94		70 - 130
Perfluorooctanoic acid (PFOA)	50.2	49.4		ng/L		98		70 - 130
Perfluorodecanoic acid (PFDA)	50.2	48.3		ng/L		96		70 - 130
Perfluorohexanesulfonic acid (PFHxS)	50.2	49.8		ng/L		99		70 - 130
Perfluorobutanesulfonic acid (PFBS)	50.2	50.3		ng/L		100		70 - 130
Perfluoroheptanoic acid (PFHpA)	50.2	45.5		ng/L		91		70 - 130
Perfluorononanoic acid (PFNA)	50.2	49.7		ng/L		99		70 - 130
Perfluorotetradecanoic acid (PFTA)	50.2	41.4		ng/L		83		70 - 130
Perfluorotridecanoic acid (PFTrDA)	50.2	45.9		ng/L		91		70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	50.2	49.3		ng/L		98		70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	50.2	49.5		ng/L		99		70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	50.2	47.5		ng/L		95		70 - 130

<i>Surrogate</i>	<i>LCS</i>	<i>LCS</i>	<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
d5-NEtFOSAA	96		70 - 130
13C2 PFHxA	96		70 - 130
13C2 PFDA	100		70 - 130
13C3-GenX	89		70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

**Lab Sample ID: MRL 380-235374/20-A**  
**Matrix: Water**  
**Analysis Batch: 235510**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 235374**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	1.74	J	ng/L		86	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	1.91	J	ng/L		95	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.02	J	ng/L		101	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.01	1.85	J	ng/L		92	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.01	2.02	J	ng/L		101	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	2.00	J	ng/L		100	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	1.88	J	ng/L		93	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	1.93	J	ng/L		96	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.01	J	ng/L		100	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	1.89	J	ng/L		94	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	1.97	J	ng/L		98	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	1.95	J	ng/L		97	50 - 150
Perfluorononanoic acid (PFNA)	2.01	2.03	J	ng/L		101	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.01	1.70	J	ng/L		84	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.01	1.95	J	ng/L		97	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	1.97	J	ng/L		98	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.98	J	ng/L		99	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.85	J	ng/L		92	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	95		70 - 130
13C2 PFHxA	100		70 - 130
13C2 PFDA	100		70 - 130
13C3-GenX	91		70 - 130

**Lab Sample ID: 380-220637-B-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 235510**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 235374**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		50.1	46.3		ng/L		92	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		50.1	51.5		ng/L		103	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		50.1	51.2		ng/L		102	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		50.1	49.2		ng/L		98	70 - 130

Eurofins Pomona





# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## LCMS

### Prep Batch: 235374

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220718-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	537.1 DW	
MBL 380-235374/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-235374/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-235374/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-220637-B-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-220637-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

### Prep Batch: 235377

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220718-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	533	
380-220718-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	533	
MBL 380-235377/19-A	Method Blank	Total/NA	Water	533	
LCS 380-235377/21-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-235377/20-A	Lab Control Sample	Total/NA	Water	533	
380-220637-E-1-A MS	Matrix Spike	Total/NA	Water	533	
380-220637-F-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

### Analysis Batch: 235510

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220718-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	EPA 537.1 V2	235374
MBL 380-235374/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	235374
LCS 380-235374/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	235374
MRL 380-235374/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	235374
380-220637-B-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	235374
380-220637-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	235374

### Analysis Batch: 235516

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220718-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	533	235377
380-220718-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	533	235377
MBL 380-235377/19-A	Method Blank	Total/NA	Water	533	235377
LCS 380-235377/21-A	Lab Control Sample	Total/NA	Water	533	235377
MRL 380-235377/20-A	Lab Control Sample	Total/NA	Water	533	235377
380-220637-E-1-A MS	Matrix Spike	Total/NA	Water	533	235377
380-220637-F-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	235377

# Lab Chronicle

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-220718-1**

**Date Collected: 06/17/26 09:30**

**Matrix: Drinking Water**

**Date Received: 06/19/26 09:55**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			235377	XTD8	EA POM	06/22/26 07:39
Total/NA	Analysis	533		1	235516	M7ML	EA POM	06/22/26 21:46
Total/NA	Prep	537.1 DW			235374	LM3A	EA POM	06/22/26 09:45
Total/NA	Analysis	EPA 537.1 V2		1	235510	M7ML	EA POM	06/23/26 01:33

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-220718-2**

**Date Collected: 06/17/26 09:30**

**Matrix: Water**

**Date Received: 06/19/26 09:55**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			235377	XTD8	EA POM	06/22/26 07:39
Total/NA	Analysis	533		1	235516	M7ML	EA POM	06/22/26 21:55

**Laboratory References:**

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

# Accreditation/Certification Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

## Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

# Method Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



# Sample Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-220718-1  
SDG: PFAS: Aiea Gulch Wells Pump 2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-220718-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Drinking Water	06/17/26 09:30	06/19/26 09:55	HI0000331
380-220718-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Water	06/17/26 09:30	06/19/26 09:55	

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Monrovia, CA (Suite 100)  
 750 Royal Oaks Drive Suite 100  
 Monrovia, CA 91016  
 Phone (626) 386-1100

# Chain of Custody Record



Environment  
America



380-220718 COC

<b>Client Information</b> Client Contact: Kirk Iwamoto Phone: +1 808 748 5840 City & County of Honolulu		Lab PM: Lopez Maria E-Mail: Maria.Lopez@eurofins.com PWSID:		Carrier Tracking No(s): State of Origin:		COC No: Page: Page 1 of 1 Job #:				
Address: 630 South Beretania Street, Chemistry Lab City: Honolulu State Zip: HI 96843 Phone: 808-748-5840 (tel) Email: kiwamoto@hbws.org Project Name: RED-HILL/HBWS sites Event Desc: RUSH Weekly Red Hill Site:		Due Date Requested: TAT Requested (days): RUSH Compliance Project: Δ No PO #: C20525101 exp 05312023 WO #:		<b>Analysis Requested</b>		<b>Preservation Codes:</b> A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other: M - Hexane N - None O - AsNaO2 P - Na2O4S Q - Na2SO3 R - Na2S2O3 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 Y - Trizma Z - other (specify) NH4 Acetate				
<b>Sample Identification</b> AIEA GULCH WELLS PUMP 2 (331-202-TP072)		Sample Date: 17-Jun-2026	Sample Time: 9:30	Sample Type (C=comp, G=grab): G	Matrix (W=water, S=solid, O=soil, T=tissue, A=air): Water	Field Filtered Sample (Yes or No): X	Perform MS/MSD (Yes or No): X	537 1 DW_PREC - 537 1 Full List 533 - All Analytes	Total Number of Containers: X	Special Instructions/Note:
FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)		Sample Date: 17-Jun-2026	Sample Time: 9:30	Sample Type (C=comp, G=grab): G	Matrix (W=water, S=solid, O=soil, T=tissue, A=air): Water	Field Filtered Sample (Yes or No): X	Perform MS/MSD (Yes or No): X	537 1 DW_PREC - 537 1 Full List 533 - All Analytes	Total Number of Containers: X	Special Instructions/Note:
<b>Possible Hazard Identification</b> <input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant Deliverable Requested I II III, IV Other (specify)		<input type="checkbox"/> Unknown <input type="checkbox"/> Radiological		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) <input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months		Special Instructions/QC Requirements:		Method of Shipment: FEK 87326792337 Date/Time: 6/19/26 955 Company: BCAA		
Empty Kit Relinquished by:		Date/Time: 6/18/26 12:00 Company: HBWS		Date/Time: 6/19/26 955 Company: BCAA		Date/Time:		Date/Time:		
Relinquished by:		Date/Time:		Date/Time:		Date/Time:		Date/Time:		
Relinquished by:		Date/Time:		Date/Time:		Date/Time:		Date/Time:		
Relinquished by:		Date/Time:		Date/Time:		Date/Time:		Date/Time:		
Custody Seals Intact: Δ Yes Δ No		Custody Seal No		Cooler Temperature(s) °C and Other Remarks: (631A) 3.0x10.0.30 96(-) 10000		Cooler Temperature(s) °C and Other Remarks:		Cooler Temperature(s) °C and Other Remarks:		



## Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-220718-1  
SDG Number: PFAS: Aiea Gulch Wells Pump 2

**Login Number: 220718**

**List Number: 1**

**Creator: Avila, Ivan**

**List Source: Eurofins Pomona**

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

