eurofins | Environment Testing

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 11/3/2026 5:44:44 PM

JOB DESCRIPTION

RED-HILL
PFAS: Ka'amilo Wells P2

JOB NUMBER

380-245002-1

Eurofins Pomona
941 Corporate Center Drive
Pomona CA 91768-2642

See page two for job notes and contact information.

my EOL

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW,Water matrices)

Authorization



Generated
11/3/2026 5:44:44 PM

Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Table of Contents

Cover Page 1
Table of Contents 3
Definitions/Glossary 4
Case Narrative 5
Detection Summary 6
Client Sample Results 7
Action Limit Summary 11
Surrogate Summary 12
Isotope Dilution Summary 13
QC Sample Results 14
QC Association Summary 31
Lab Chronicle 33
Certification Summary 34
Method Summary 35
Sample Summary 36
Chain of Custody 37
Receipt Checklists 39

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Job Narrative
380-245002-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt
The samples were received on 10/28/2026 10:00 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 2 coolers at receipt time were 0.6°C and 1.3°C.

PFAS
No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085) — Lab Sample ID: 380-245002-1

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanesulfonic acid (PFBS)	2.5		2.0		ng/L	1		533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.3		2.0		ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	3.6		2.0		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.5		2.0		ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.5		2.0		ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	3.8		2.0		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.2		2.0		ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanoic acid (PFHxA)	3.5		2.0		ng/L	1		EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	3.5		2.0		ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.5		2.0		ng/L	1		EPA 537.1 V2	Total/NA
Perfluorobutanesulfonic acid (PFBS)	2.5		2.0		ng/L	1		EPA 537.1 V2	Total/NA

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085) — Lab Sample ID: 380-245002-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)
Date Collected: 10/26/26 12:53
Date Received: 10/28/26 10:00

Lab Sample ID: 380-245002-1
Matrix: Water

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluorobutanesulfonic acid (PFBS)	**2.5**		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluorohexanesulfonic acid (PFHxS)	**3.3**		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluorohexanoic acid (PFHxA)	**3.6**		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluorononanoic acid (PFNA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluorooctanesulfonic acid (PFOS)	**4.5**		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluorooctanoic acid (PFOA)	**3.5**		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluoropentanoic acid (PFPeA)	**3.8**		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0		ng/L		11/02/26 07:35	11/03/26 12:49	1

Isotope Dilution	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
13C3 HFPO-DA	*74*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C6 PFDA	*56*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C5 PFHxA	*79*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C4 PFHpA	*78*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C8 PFOA	*73*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C9 PFNA	*68*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C7 PFUnA	*52*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C2 PFDoA	*53*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C4 PFBA	*83*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C5 PFPeA	*82*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*
13C3 PFBS	*100*		*50 - 200*	*11/02/26 07:35*	*11/03/26 12:49*	*1*

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-245002-1

Date Collected: 10/26/26 12:53
Matrix: Water
Date Received: 10/28/26 10:00

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 PFHxS	101		50 - 200	11/02/26 07:35	11/03/26 12:49	1
13C8 PFOS	99		50 - 200	11/02/26 07:35	11/03/26 12:49	1
13C2-4:2-FTS	89		50 - 200	11/02/26 07:35	11/03/26 12:49	1
13C2-6:2-FTS	85		50 - 200	11/02/26 07:35	11/03/26 12:49	1
13C2-8:2-FTS	90		50 - 200	11/02/26 07:35	11/03/26 12:49	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorooctanesulfonic acid (PFOS)	**4.2**		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorohexanoic acid (PFHxA)	**3.5**		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorooctanoic acid (PFOA)	**3.5**		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorohexanesulfonic acid (PFHxS)	**3.5**		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorobutanesulfonic acid (PFBS)	**2.5**		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorononanoic acid (PFNA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 15:18	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	116		70 - 130	10/29/26 10:54	10/30/26 15:18	1
13C2 PFHxA	106		70 - 130	10/29/26 10:54	10/30/26 15:18	1
13C2 PFDA	108		70 - 130	10/29/26 10:54	10/30/26 15:18	1
13C3-GenX	114		70 - 130	10/29/26 10:54	10/30/26 15:18	1

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-245002-2

Date Collected: 10/26/26 12:53
Matrix: Water
Date Received: 10/28/26 10:00

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)
Date Collected: 10/26/26 12:53
Date Received: 10/28/26 10:00

Lab Sample ID: 380-245002-2
Matrix: Water

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluorononanoic acid (PFNA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0		ng/L		10/29/26 08:10	10/30/26 17:17	1

Isotope Dilution	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
13C3 HFPO-DA	*90*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C6 PFDA	*84*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C5 PFHxA	*91*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C4 PFHpA	*92*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C8 PFOA	*98*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C9 PFNA	*94*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C7 PFUnA	*93*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C2 PFDoA	*94*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C4 PFBA	*98*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C5 PFPeA	*99*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C3 PFBS	*111*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C3 PFHxS	*116*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C8 PFOS	*117*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C2-4:2-FTS	*112*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C2-6:2-FTS	*107*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*
13C2-8:2-FTS	*108*		*50 - 200*	*10/29/26 08:10*	*10/30/26 17:17*	*1*

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)
Date Collected: 10/26/26 12:53
Date Received: 10/28/26 10:00

Lab Sample ID: 380-245002-2
Matrix: Water

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorononanoic acid (PFNA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0		ng/L		10/29/26 10:54	10/30/26 18:10	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
d5-NEtFOSAA	*110*		*70 - 130*	*10/29/26 10:54*	*10/30/26 18:10*	*1*
13C2 PFHxA	*108*		*70 - 130*	*10/29/26 10:54*	*10/30/26 18:10*	*1*
13C2 PFDA	*99*		*70 - 130*	*10/29/26 10:54*	*10/30/26 18:10*	*1*
13C3-GenX	*114*		*70 - 130*	*10/29/26 10:54*	*10/30/26 18:10*	*1*

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085) — Lab Sample ID: 380-245002-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.3		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	**4.5**		ng/L	**4**	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	3.5		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	**4.2**		ng/L	**4**	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	3.5		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.5		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085) — Lab Sample ID: 380-245002-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS	PFHxA	PFDA	GenX
Lab Sample ID	Client Sample ID	(70-130)	(70-130)	(70-130)	(70-130)
380-245002-1	Ka'amilo Wells P2 (331-600-WL085)	116	106	108	114
380-245002-1 MS	Ka'amilo Wells P2 (331-600-WL085)	108	104	106	115
380-245002-1 MSD	Ka'amilo Wells P2 (331-600-WL085)	120	104	104	118
380-245002-2	FB: Ka'amilo Wells P2 (331-600-WL085)	110	108	99	114
LCS 380-262130/22-A	Lab Control Sample	111	109	101	112
MBL 380-262130/20-A	Method Blank	95	112	112	109
MRL 380-262130/21-A	Lab Control Sample	105	98	104	100

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
PFHxA = 13C2 PFHxA
PFDA = 13C2 PFDA
GenX = 13C3-GenX

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water **Prep Type: Total/NA**

		Percent Isotope Dilution Recovery (Acceptance Limits)							
		HFPODA	C6PFDA	13C5PHA	C4PFHA	C8PFOA	C9PFNA	13C7PUA	PFDoA
Lab Sample ID	Client Sample ID	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)
380-244988-B-2-A MS	Matrix Spike	103	103	103	104	105	101	110	108
380-244988-C-2-A MSD	Matrix Spike Duplicate	116	108	112	112	115	110	116	117
380-245002-1	Ka'amilo Wells P2 (331-600-WL085)	74	56	79	78	73	68	52	53
380-245002-2	FB: Ka'amilo Wells P2 (331-600-WL085)	90	84	91	92	98	94	93	94
380-245384-B-1-A MS	Matrix Spike	111	105	100	100	100	104	109	109
380-245384-C-1-A MSD	Matrix Spike Duplicate	105	110	93	104	103	105	110	112
LCS 380-262133/22-A	Lab Control Sample	98	102	97	94	97	92	101	102
LCS 380-262768/46-A	Lab Control Sample	103	107	99	101	102	107	108	112
MBL 380-262133/20-A	Method Blank	91	105	98	102	103	104	106	100
MBL 380-262768/44-A	Method Blank	94	103	90	98	97	102	103	104
MRL 380-262133/21-A	Lab Control Sample	92	106	99	98	103	101	111	107
MRL 380-262768/45-A	Lab Control Sample	98	111	95	100	102	106	114	117

		Percent Isotope Dilution Recovery (Acceptance Limits)							
		PFBA	PFPeA	C3PFBS	C3PFHS	C8PFOS	42FTS	62FTS	82FTS
Lab Sample ID	Client Sample ID	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)
380-244988-B-2-A MS	Matrix Spike	105	109	104	113	112	107	100	102
380-244988-C-2-A MSD	Matrix Spike Duplicate	108	111	106	111	111	107	105	105
380-245002-1	Ka'amilo Wells P2 (331-600-WL085)	83	82	100	101	99	89	85	90
380-245002-2	FB: Ka'amilo Wells P2 (331-600-WL085)	98	99	111	116	117	112	107	108
380-245384-B-1-A MS	Matrix Spike	104	116	97	96	100	93	86	90
380-245384-C-1-A MSD	Matrix Spike Duplicate	106	111	93	97	103	99	90	90
LCS 380-262133/22-A	Lab Control Sample	102	105	105	112	112	109	104	102
LCS 380-262768/46-A	Lab Control Sample	104	115	96	99	102	92	85	89
MBL 380-262133/20-A	Method Blank	95	95	106	113	109	105	104	105
MBL 380-262768/44-A	Method Blank	103	104	88	95	97	83	83	86
MRL 380-262133/21-A	Lab Control Sample	95	96	106	114	112	113	105	103
MRL 380-262768/45-A	Lab Control Sample	102	97	97	103	107	92	92	97

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA
13C5PHA = 13C5 PFHxA
C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDoA = 13C2 PFDoA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-262133/20-A
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 262133

Analyte	MBL Result	MBL Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.29		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluorononanoic acid (PFNA)	<0.39		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluorobutanoic acid (PFBA)	<0.68		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.37		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.36		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.47		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.46		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.24		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.45		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluoropentanoic acid (PFPeA)	<0.37		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.35		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1
Perfluoropentanesulfonic acid (PFPeS)	<0.38		2.0		ng/L		10/29/26 08:10	10/30/26 14:15	1

Isotope Dilution	*MBL %Recovery*	*MBL Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
13C3 HFPO-DA	*91*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C6 PFDA	*105*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C5 PFHxA	*98*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C4 PFHpA	*102*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C8 PFOA	*103*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C9 PFNA	*104*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C7 PFUnA	*106*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C2 PFDoA	*100*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C4 PFBA	*95*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C5 PFPeA	*95*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C3 PFBS	*106*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*
13C3 PFHxS	*113*		*50 - 200*	*10/29/26 08:10*	*10/30/26 14:15*	*1*

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-262133/20-A
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 262133

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	109		50 - 200	10/29/26 08:10	10/30/26 14:15	1
13C2-4:2-FTS	105		50 - 200	10/29/26 08:10	10/30/26 14:15	1
13C2-6:2-FTS	104		50 - 200	10/29/26 08:10	10/30/26 14:15	1
13C2-8:2-FTS	105		50 - 200	10/29/26 08:10	10/30/26 14:15	1

Lab Sample ID: LCS 380-262133/22-A
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262133

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	59.1	57.2		ng/L		97	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	59.1	57.8		ng/L		98	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	59.1	57.8		ng/L		98	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	59.1	53.7		ng/L		91	70 - 130
Perfluorobutanesulfonic acid (PFBS)	59.1	60.6		ng/L		103	70 - 130
Perfluorodecanoic acid (PFDA)	59.1	54.7		ng/L		93	70 - 130
Perfluorododecanoic acid (PFDoA)	59.1	56.1		ng/L		95	70 - 130
Perfluoroheptanoic acid (PFHpA)	59.1	59.0		ng/L		100	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	59.1	57.6		ng/L		98	70 - 130
Perfluorohexanoic acid (PFHxA)	59.1	57.6		ng/L		98	70 - 130
Perfluorononanoic acid (PFNA)	59.1	62.0		ng/L		105	70 - 130
Perfluorooctanesulfonic acid (PFOS)	59.1	57.5		ng/L		97	70 - 130
Perfluorooctanoic acid (PFOA)	59.1	56.1		ng/L		95	70 - 130
Perfluoroundecanoic acid (PFUnA)	59.1	58.7		ng/L		99	70 - 130
Perfluorobutanoic acid (PFBA)	59.1	59.9		ng/L		101	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	59.1	58.3		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	59.1	55.1		ng/L		93	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	59.1	55.8		ng/L		95	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	59.1	57.0		ng/L		97	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	59.1	58.0		ng/L		98	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	59.1	57.6		ng/L		98	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	59.1	55.9		ng/L		95	70 - 130
Perfluoropentanoic acid (PFPeA)	59.1	59.2		ng/L		100	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	59.1	58.9		ng/L		100	70 - 130

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-262133/22-A
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262133

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Perfluoropentanesulfonic acid (PFPeS)			59.1	56.9		ng/L		96	70 - 130		

Isotope Dilution	*LCS %Recovery*	*LCS Qualifier*	*Limits*
13C3 HFPO-DA	*98*		*50 - 200*
13C6 PFDA	*102*		*50 - 200*
13C5 PFHxA	*97*		*50 - 200*
13C4 PFHpA	*94*		*50 - 200*
13C8 PFOA	*97*		*50 - 200*
13C9 PFNA	*92*		*50 - 200*
13C7 PFUnA	*101*		*50 - 200*
13C2 PFDoA	*102*		*50 - 200*
13C4 PFBA	*102*		*50 - 200*
13C5 PFPeA	*105*		*50 - 200*
13C3 PFBS	*105*		*50 - 200*
13C3 PFHxS	*112*		*50 - 200*
13C8 PFOS	*112*		*50 - 200*
13C2-4:2-FTS	*109*		*50 - 200*
13C2-6:2-FTS	*104*		*50 - 200*
13C2-8:2-FTS	*102*		*50 - 200*

Lab Sample ID: MRL 380-262133/21-A
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262133

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)			1.97	2.01	J	ng/L		102	50 - 150		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)			1.97	1.90	J	ng/L		96	50 - 150		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)			1.97	1.91	J	ng/L		97	50 - 150		
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)			1.97	1.79	J	ng/L		91	50 - 150		
Perfluorobutanesulfonic acid (PFBS)			1.97	2.04	J	ng/L		104	50 - 150		
Perfluorodecanoic acid (PFDA)			1.97	2.07	J	ng/L		105	50 - 150		
Perfluorododecanoic acid (PFDoA)			1.97	2.10	J	ng/L		107	50 - 150		
Perfluoroheptanoic acid (PFHpA)			1.97	2.07	J	ng/L		105	50 - 150		
Perfluorohexanesulfonic acid (PFHxS)			1.97	1.86	J	ng/L		94	50 - 150		
Perfluorohexanoic acid (PFHxA)			1.97	1.97	J	ng/L		100	50 - 150		
Perfluorononanoic acid (PFNA)			1.97	2.09	J	ng/L		106	50 - 150		
Perfluorooctanesulfonic acid (PFOS)			1.97	1.98	J	ng/L		101	50 - 150		
Perfluorooctanoic acid (PFOA)			1.97	1.81	J	ng/L		92	50 - 150		
Perfluoroundecanoic acid (PFUnA)			1.97	2.04	J	ng/L		103	50 - 150		
Perfluorobutanoic acid (PFBA)			1.97	2.17	J	ng/L		110	50 - 150		

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-262133/21-A
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262133

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	1.97	2.02	J	ng/L		103	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	1.97	1.96	J	ng/L		99	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	1.97	1.98	J	ng/L		101	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	1.97	1.98	J	ng/L		101	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	1.97	2.14	J	ng/L		109	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	1.97	1.98	J	ng/L		100	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	1.97	1.78	J	ng/L		90	50 - 150
Perfluoropentanoic acid (PFPeA)	1.97	2.16	J	ng/L		110	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	1.97	1.99	J	ng/L		101	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	1.97	1.81	J	ng/L		92	50 - 150

Isotope Dilution	*MRL %Recovery*	*MRL Qualifier*	*Limits*
13C3 HFPO-DA	*92*		*50 - 200*
13C6 PFDA	*106*		*50 - 200*
13C5 PFHxA	*99*		*50 - 200*
13C4 PFHpA	*98*		*50 - 200*
13C8 PFOA	*103*		*50 - 200*
13C9 PFNA	*101*		*50 - 200*
13C7 PFUnA	*111*		*50 - 200*
13C2 PFDoA	*107*		*50 - 200*
13C4 PFBA	*95*		*50 - 200*
13C5 PFPeA	*96*		*50 - 200*
13C3 PFBS	*106*		*50 - 200*
13C3 PFHxS	*114*		*50 - 200*
13C8 PFOS	*112*		*50 - 200*
13C2-4:2-FTS	*113*		*50 - 200*
13C2-6:2-FTS	*105*		*50 - 200*
13C2-8:2-FTS	*103*		*50 - 200*

Lab Sample ID: 380-244988-B-2-A MS
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 262133

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		59.3	56.2		ng/L		95	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		59.3	57.2		ng/L		96	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		59.3	56.4		ng/L		95	70 - 130

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-244988-B-2-A MS
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 262133

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		59.3	56.1		ng/L		95	70 - 130
Perfluorobutanesulfonic acid (PFBS)	2.7		59.3	62.6		ng/L		101	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		59.3	57.3		ng/L		97	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		59.3	55.2		ng/L		93	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		59.3	58.0		ng/L		95	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	2.4		59.3	59.0		ng/L		95	70 - 130
Perfluorohexanoic acid (PFHxA)	7.9		59.3	63.6		ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		59.3	59.4		ng/L		100	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		59.3	56.6		ng/L		95	70 - 130
Perfluorooctanoic acid (PFOA)	2.5		59.3	60.1		ng/L		97	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		59.3	58.3		ng/L		98	70 - 130
Perfluorobutanoic acid (PFBA)	2.5		59.3	61.7		ng/L		100	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		59.3	56.4		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		59.3	55.9		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		59.3	58.2		ng/L		98	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		59.3	70.8		ng/L		119	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		59.3	59.0		ng/L		100	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		59.3	56.8		ng/L		96	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		59.3	59.4		ng/L		100	70 - 130
Perfluoropentanoic acid (PFPeA)	7.2		59.3	65.9		ng/L		99	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		59.3	56.8		ng/L		96	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		59.3	56.9		ng/L		94	70 - 130

Isotope Dilution	*MS %Recovery*	*MS Qualifier*	*Limits*
13C3 HFPO-DA	*103*		*50 - 200*
13C6 PFDA	*103*		*50 - 200*
13C5 PFHxA	*103*		*50 - 200*
13C4 PFHpA	*104*		*50 - 200*
13C8 PFOA	*105*		*50 - 200*
13C9 PFNA	*101*		*50 - 200*
13C7 PFUnA	*110*		*50 - 200*
13C2 PFDoA	*108*		*50 - 200*
13C4 PFBA	*105*		*50 - 200*
13C5 PFPeA	*109*		*50 - 200*
13C3 PFBS	*104*		*50 - 200*
13C3 PFHxS	*113*		*50 - 200*
13C8 PFOS	*112*		*50 - 200*

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-244988-B-2-A MS
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 262133

Isotope Dilution	MS %Recovery	MS Qualifier	Limits
13C2-4:2-FTS	107		50 - 200
13C2-6:2-FTS	100		50 - 200
13C2-8:2-FTS	102		50 - 200

Lab Sample ID: 380-244988-C-2-A MSD
Matrix: Water
Analysis Batch: 262461

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 262133

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		59.2	55.9		ng/L		95	70 - 130	0	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		59.2	56.5		ng/L		95	70 - 130	1	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		59.2	58.4		ng/L		99	70 - 130	3	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		59.2	53.5		ng/L		90	70 - 130	5	30
Perfluorobutanesulfonic acid (PFBS)	2.7		59.2	63.1		ng/L		102	70 - 130	1	30
Perfluorodecanoic acid (PFDA)	<2.0		59.2	60.2		ng/L		102	70 - 130	5	30
Perfluorododecanoic acid (PFDoA)	<2.0		59.2	57.7		ng/L		98	70 - 130	4	30
Perfluoroheptanoic acid (PFHpA)	<2.0		59.2	57.5		ng/L		95	70 - 130	1	30
Perfluorohexanesulfonic acid (PFHxS)	2.4		59.2	60.6		ng/L		98	70 - 130	3	30
Perfluorohexanoic acid (PFHxA)	7.9		59.2	65.4		ng/L		97	70 - 130	3	30
Perfluorononanoic acid (PFNA)	<2.0		59.2	51.2		ng/L		86	70 - 130	15	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		59.2	56.2		ng/L		95	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	2.5		59.2	56.5		ng/L		91	70 - 130	6	30
Perfluoroundecanoic acid (PFUnA)	<2.0		59.2	59.4		ng/L		100	70 - 130	2	30
Perfluorobutanoic acid (PFBA)	2.5		59.2	60.1		ng/L		97	70 - 130	3	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		59.2	56.0		ng/L		95	70 - 130	1	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		59.2	54.0		ng/L		91	70 - 130	4	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		59.2	55.6		ng/L		94	70 - 130	5	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		59.2	59.6		ng/L		101	70 - 130	17	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		59.2	58.6		ng/L		99	70 - 130	1	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		59.2	57.6		ng/L		97	70 - 130	1	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		59.2	58.0		ng/L		98	70 - 130	2	30
Perfluoropentanoic acid (PFPeA)	7.2		59.2	64.6		ng/L		97	70 - 130	2	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		59.2	55.7		ng/L		94	70 - 130	2	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		59.2	58.1		ng/L		96	70 - 130	2	30

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD %Recovery	MSD Qualifier	Limits
13C3 HFPO-DA	116		50 - 200
13C6 PFDA	108		50 - 200
13C5 PFHxA	112		50 - 200
13C4 PFHpA	112		50 - 200
13C8 PFOA	115		50 - 200
13C9 PFNA	110		50 - 200
13C7 PFUnA	116		50 - 200
13C2 PFDoA	117		50 - 200
13C4 PFBA	108		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	106		50 - 200
13C3 PFHxS	111		50 - 200
13C8 PFOS	111		50 - 200
13C2-4:2-FTS	107		50 - 200
13C2-6:2-FTS	105		50 - 200
13C2-8:2-FTS	105		50 - 200

Lab Sample ID: MBL 380-262768/44-A
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 262768

Analyte	MBL Result	MBL Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluorononanoic acid (PFNA)	<0.39		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluorobutanoic acid (PFBA)	<0.68		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.36		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.47		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.46		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.24		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.45		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-262768/44-A
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 262768

Analyte	MBL Result	MBL Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Perfluoropentanoic acid (PFPeA)	<0.37		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.35		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1
Perfluoropentanesulfonic acid (PFPeS)	<0.38		2.0		ng/L		11/02/26 07:35	11/02/26 18:40	1

Isotope Dilution	*MBL %Recovery*	*MBL Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
13C3 HFPO-DA	*94*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C6 PFDA	*103*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C5 PFHxA	*90*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C4 PFHpA	*98*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C8 PFOA	*97*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C9 PFNA	*102*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C7 PFUnA	*103*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C2 PFDoA	*104*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C4 PFBA	*103*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C5 PFPeA	*104*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C3 PFBS	*88*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C3 PFHxS	*95*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C8 PFOS	*97*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C2-4:2-FTS	*83*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C2-6:2-FTS	*83*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*
13C2-8:2-FTS	*86*		*50 - 200*	*11/02/26 07:35*	*11/02/26 18:40*	*1*

Lab Sample ID: LCS 380-262768/46-A
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262768

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)			118	111		ng/L		94	70 - 130		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)			118	111		ng/L		94	70 - 130		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)			118	111		ng/L		94	70 - 130		
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)			118	111		ng/L		94	70 - 130		
Perfluorobutanesulfonic acid (PFBS)			118	110		ng/L		93	70 - 130		
Perfluorodecanoic acid (PFDA)			118	109		ng/L		92	70 - 130		
Perfluorododecanoic acid (PFDoA)			118	112		ng/L		95	70 - 130		
Perfluoroheptanoic acid (PFHpA)			118	107		ng/L		91	70 - 130		
Perfluorohexanesulfonic acid (PFHxS)			118	110		ng/L		93	70 - 130		
Perfluorohexanoic acid (PFHxA)			118	116		ng/L		98	70 - 130		
Perfluorononanoic acid (PFNA)			118	111		ng/L		94	70 - 130		
Perfluorooctanesulfonic acid (PFOS)			118	113		ng/L		96	70 - 130		
Perfluorooctanoic acid (PFOA)			118	110		ng/L		93	70 - 130		

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-262768/46-A
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262768

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoroundecanoic acid (PFUnA)	118	111		ng/L		94	70 - 130
Perfluorobutanoic acid (PFBA)	118	107		ng/L		90	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	118	107		ng/L		91	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	118	106		ng/L		90	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	118	110		ng/L		93	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	118	119		ng/L		100	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	118	106		ng/L		90	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	118	104		ng/L		88	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	118	104		ng/L		88	70 - 130
Perfluoropentanoic acid (PFPeA)	118	115		ng/L		97	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	118	109		ng/L		93	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	118	108		ng/L		91	70 - 130

Isotope Dilution	*LCS %Recovery*	*LCS Qualifier*	*Limits*
13C3 HFPO-DA	*103*		*50 - 200*
13C6 PFDA	*107*		*50 - 200*
13C5 PFHxA	*99*		*50 - 200*
13C4 PFHpA	*101*		*50 - 200*
13C8 PFOA	*102*		*50 - 200*
13C9 PFNA	*107*		*50 - 200*
13C7 PFUnA	*108*		*50 - 200*
13C2 PFDoA	*112*		*50 - 200*
13C4 PFBA	*104*		*50 - 200*
13C5 PFPeA	*115*		*50 - 200*
13C3 PFBS	*96*		*50 - 200*
13C3 PFHxS	*99*		*50 - 200*
13C8 PFOS	*102*		*50 - 200*
13C2-4:2-FTS	*92*		*50 - 200*
13C2-6:2-FTS	*85*		*50 - 200*
13C2-8:2-FTS	*89*		*50 - 200*

Lab Sample ID: MRL 380-262768/45-A
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262768

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.97	2.01	J	ng/L		102	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.97	2.04	J	ng/L		104	50 - 150

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-262768/45-A
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262768

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)			1.97	1.83	J	ng/L		93	50 - 150		
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)			1.97	1.79	J	ng/L		91	50 - 150		
Perfluorobutanesulfonic acid (PFBS)			1.97	1.87	J	ng/L		95	50 - 150		
Perfluorodecanoic acid (PFDA)			1.97	2.03	J	ng/L		103	50 - 150		
Perfluorododecanoic acid (PFDoA)			1.97	1.95	J	ng/L		99	50 - 150		
Perfluoroheptanoic acid (PFHpA)			1.97	1.90	J	ng/L		96	50 - 150		
Perfluorohexanesulfonic acid (PFHxS)			1.97	1.89	J	ng/L		96	50 - 150		
Perfluorohexanoic acid (PFHxA)			1.97	1.99	J	ng/L		101	50 - 150		
Perfluorononanoic acid (PFNA)			1.97	2.01	J	ng/L		102	50 - 150		
Perfluorooctanesulfonic acid (PFOS)			1.97	1.98	J	ng/L		101	50 - 150		
Perfluorooctanoic acid (PFOA)			1.97	1.97	J	ng/L		100	50 - 150		
Perfluoroundecanoic acid (PFUnA)			1.97	1.91	J	ng/L		97	50 - 150		
Perfluorobutanoic acid (PFBA)			1.97	1.94	J	ng/L		98	50 - 150		
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)			1.97	1.86	J	ng/L		95	50 - 150		
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)			1.97	2.04	J	ng/L		103	50 - 150		
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)			1.97	1.98	J	ng/L		101	50 - 150		
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)			1.97	1.88	J	ng/L		95	50 - 150		
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)			1.97	1.88	J	ng/L		96	50 - 150		
Perfluoro-3-methoxypropanoic acid (PFMPA)			1.97	1.90	J	ng/L		96	50 - 150		
Perfluoro-4-methoxybutanoic acid (PFMBA)			1.97	2.02	J	ng/L		103	50 - 150		
Perfluoropentanoic acid (PFPeA)			1.97	2.19	J	ng/L		111	50 - 150		
Perfluoroheptanesulfonic acid (PFHpS)			1.97	1.99	J	ng/L		101	50 - 150		
Perfluoropentanesulfonic acid (PFPeS)			1.97	1.90	J	ng/L		97	50 - 150		

Isotope Dilution	*MRL %Recovery*	*MRL Qualifier*	*Limits*
13C3 HFPO-DA	*98*		*50 - 200*
13C6 PFDA	*111*		*50 - 200*
13C5 PFHxA	*95*		*50 - 200*
13C4 PFHpA	*100*		*50 - 200*
13C8 PFOA	*102*		*50 - 200*
13C9 PFNA	*106*		*50 - 200*
13C7 PFUnA	*114*		*50 - 200*
13C2 PFDoA	*117*		*50 - 200*
13C4 PFBA	*102*		*50 - 200*
13C5 PFPeA	*97*		*50 - 200*
13C3 PFBS	*97*		*50 - 200*
13C3 PFHxS	*103*		*50 - 200*

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-262768/45-A
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262768

Isotope Dilution	MRL %Recovery	MRL Qualifier	Limits
13C8 PFOS	107		50 - 200
13C2-4:2-FTS	92		50 - 200
13C2-6:2-FTS	92		50 - 200
13C2-8:2-FTS	97		50 - 200

Lab Sample ID: 380-245384-B-1-A MS
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 262768

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		118	114		ng/L		96	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		118	114		ng/L		96	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		118	114		ng/L		96	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		118	104		ng/L		88	70 - 130
Perfluorobutanesulfonic acid (PFBS)	<2.0		118	113		ng/L		96	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		118	113		ng/L		96	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		118	115		ng/L		97	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		118	117		ng/L		98	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		118	119		ng/L		101	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		118	111		ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		118	115		ng/L		98	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		118	118		ng/L		99	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		118	115		ng/L		97	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		118	112		ng/L		94	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		118	116		ng/L		98	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		118	111		ng/L		93	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		118	119		ng/L		100	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		118	116		ng/L		98	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		118	118		ng/L		99	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		118	112		ng/L		94	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		118	114		ng/L		96	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		118	121		ng/L		102	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		118	116		ng/L		98	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		118	116		ng/L		98	70 - 130

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-245384-B-1-A MS
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 262768

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	<2.0		118	116		ng/L		98	70 - 130

Isotope Dilution	*MS %Recovery*	*MS Qualifier*	*Limits*
13C3 HFPO-DA	*111*		*50 - 200*
13C6 PFDA	*105*		*50 - 200*
13C5 PFHxA	*100*		*50 - 200*
13C4 PFHpA	*100*		*50 - 200*
13C8 PFOA	*100*		*50 - 200*
13C9 PFNA	*104*		*50 - 200*
13C7 PFUnA	*109*		*50 - 200*
13C2 PFDoA	*109*		*50 - 200*
13C4 PFBA	*104*		*50 - 200*
13C5 PFPeA	*116*		*50 - 200*
13C3 PFBS	*97*		*50 - 200*
13C3 PFHxS	*96*		*50 - 200*
13C8 PFOS	*100*		*50 - 200*
13C2-4:2-FTS	*93*		*50 - 200*
13C2-6:2-FTS	*86*		*50 - 200*
13C2-8:2-FTS	*90*		*50 - 200*

Lab Sample ID: 380-245384-C-1-A MSD
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 262768

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		118	116		ng/L		98	70 - 130	2	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		118	118		ng/L		100	70 - 130	3	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		118	109		ng/L		92	70 - 130	4	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		118	112		ng/L		94	70 - 130	7	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		118	108		ng/L		91	70 - 130	5	30
Perfluorodecanoic acid (PFDA)	<2.0		118	113		ng/L		95	70 - 130	1	30
Perfluorododecanoic acid (PFDoA)	<2.0		118	114		ng/L		97	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		118	112		ng/L		94	70 - 130	4	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		118	117		ng/L		99	70 - 130	2	30
Perfluorohexanoic acid (PFHxA)	<2.0		118	123		ng/L		104	70 - 130	10	30
Perfluorononanoic acid (PFNA)	<2.0		118	117		ng/L		99	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		118	116		ng/L		98	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	<2.0		118	113		ng/L		96	70 - 130	2	30
Perfluoroundecanoic acid (PFUnA)	<2.0		118	114		ng/L		97	70 - 130	2	30
Perfluorobutanoic acid (PFBA)	<2.0		118	116		ng/L		98	70 - 130	0	30

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-245384-C-1-A MSD
Matrix: Water
Analysis Batch: 262921

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 262768

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		118	115		ng/L		97	70 - 130	4	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		118	114		ng/L		96	70 - 130	4	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		118	117		ng/L		99	70 - 130	1	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		118	125		ng/L		105	70 - 130	6	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		118	108		ng/L		91	70 - 130	3	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		118	113		ng/L		95	70 - 130	1	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		118	115		ng/L		97	70 - 130	5	30
Perfluoropentanoic acid (PFPeA)	<2.0		118	123		ng/L		104	70 - 130	6	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		118	116		ng/L		98	70 - 130	0	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		118	116		ng/L		98	70 - 130	0	30

Isotope Dilution	*MSD %Recovery*	*MSD Qualifier*	*Limits*
13C3 HFPO-DA	*105*		*50 - 200*
13C6 PFDA	*110*		*50 - 200*
13C5 PFHxA	*93*		*50 - 200*
13C4 PFHpA	*104*		*50 - 200*
13C8 PFOA	*103*		*50 - 200*
13C9 PFNA	*105*		*50 - 200*
13C7 PFUnA	*110*		*50 - 200*
13C2 PFDoA	*112*		*50 - 200*
13C4 PFBA	*106*		*50 - 200*
13C5 PFPeA	*111*		*50 - 200*
13C3 PFBS	*93*		*50 - 200*
13C3 PFHxS	*97*		*50 - 200*
13C8 PFOS	*103*		*50 - 200*
13C2-4:2-FTS	*99*		*50 - 200*
13C2-6:2-FTS	*90*		*50 - 200*
13C2-8:2-FTS	*90*		*50 - 200*

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-262130/20-A
Matrix: Water
Analysis Batch: 262529

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 262130

Analyte	MBL Result	MBL Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.57		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-262130/20-A
Matrix: Water
Analysis Batch: 262529

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 262130

Analyte	MBL Result	MBL Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.41		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorononanoic acid (PFNA)	<0.39		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorotetradecanoic acid (PFTA)	<0.53		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
Perfluorotridecanoic acid (PFTrDA)	<0.35		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.29		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0		ng/L		10/29/26 10:54	10/30/26 14:49	1

Surrogate	*MBL %Recovery*	*MBL Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
d5-NEtFOSAA	*95*		*70 - 130*	*10/29/26 10:54*	*10/30/26 14:49*	*1*
13C2 PFHxA	*112*		*70 - 130*	*10/29/26 10:54*	*10/30/26 14:49*	*1*
13C2 PFDA	*112*		*70 - 130*	*10/29/26 10:54*	*10/30/26 14:49*	*1*
13C3-GenX	*109*		*70 - 130*	*10/29/26 10:54*	*10/30/26 14:49*	*1*

Lab Sample ID: LCS 380-262130/22-A
Matrix: Water
Analysis Batch: 262529

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262130

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	49.1	48.6		ng/L		99	70 - 130
Perfluorooctanesulfonic acid (PFOS)	49.1	45.5		ng/L		93	70 - 130
Perfluoroundecanoic acid (PFUnA)	49.1	46.7		ng/L		95	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	49.1	47.6		ng/L		97	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	49.1	45.7		ng/L		93	70 - 130
Perfluorohexanoic acid (PFHxA)	49.1	46.7		ng/L		95	70 - 130
Perfluorododecanoic acid (PFDoA)	49.1	47.8		ng/L		97	70 - 130
Perfluorooctanoic acid (PFOA)	49.1	45.4		ng/L		92	70 - 130
Perfluorodecanoic acid (PFDA)	49.1	45.0		ng/L		92	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	49.1	47.1		ng/L		96	70 - 130
Perfluorobutanesulfonic acid (PFBS)	49.1	48.3		ng/L		98	70 - 130
Perfluoroheptanoic acid (PFHpA)	49.1	47.5		ng/L		97	70 - 130
Perfluorononanoic acid (PFNA)	49.1	46.6		ng/L		95	70 - 130

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: LCS 380-262130/22-A
Matrix: Water
Analysis Batch: 262529

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262130

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Perfluorotetradecanoic acid (PFTA)			49.1	46.4		ng/L		95	70 - 130		
Perfluorotridecanoic acid (PFTrDA)			49.1	52.4		ng/L		107	70 - 130		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)			49.1	46.1		ng/L		94	70 - 130		
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)			49.1	43.3		ng/L		88	70 - 130		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)			49.1	47.3		ng/L		96	70 - 130		

Surrogate	*LCS %Recovery*	*LCS Qualifier*	*Limits*
d5-NEtFOSAA	*111*		*70 - 130*
13C2 PFHxA	*109*		*70 - 130*
13C2 PFDA	*101*		*70 - 130*
13C3-GenX	*112*		*70 - 130*

Lab Sample ID: MRL 380-262130/21-A
Matrix: Water
Analysis Batch: 262529

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262130

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)			1.96	1.88	J	ng/L		95	50 - 150		
Perfluorooctanesulfonic acid (PFOS)			1.96	1.93	J	ng/L		98	50 - 150		
Perfluoroundecanoic acid (PFUnA)			1.96	1.77	J	ng/L		90	50 - 150		
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)			1.96	1.93	J	ng/L		98	50 - 150		
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)			1.96	1.95	J	ng/L		99	50 - 150		
Perfluorohexanoic acid (PFHxA)			1.96	1.82	J	ng/L		93	50 - 150		
Perfluorododecanoic acid (PFDoA)			1.96	1.92	J	ng/L		98	50 - 150		
Perfluorooctanoic acid (PFOA)			1.96	1.77	J	ng/L		90	50 - 150		
Perfluorodecanoic acid (PFDA)			1.96	1.77	J	ng/L		90	50 - 150		
Perfluorohexanesulfonic acid (PFHxS)			1.96	1.99	J	ng/L		101	50 - 150		
Perfluorobutanesulfonic acid (PFBS)			1.96	1.95	J	ng/L		99	50 - 150		
Perfluoroheptanoic acid (PFHpA)			1.96	1.83	J	ng/L		93	50 - 150		
Perfluorononanoic acid (PFNA)			1.96	1.90	J	ng/L		96	50 - 150		
Perfluorotetradecanoic acid (PFTA)			1.96	1.91	J	ng/L		97	50 - 150		
Perfluorotridecanoic acid (PFTrDA)			1.96	2.08	J	ng/L		106	50 - 150		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)			1.96	1.77	J	ng/L		90	50 - 150		

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-262130/21-A
Matrix: Water
Analysis Batch: 262529

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 262130

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)			1.96	1.83	J	ng/L		93	50 - 150		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)			1.96	1.86	J	ng/L		95	50 - 150		

Surrogate	*MRL %Recovery*	*MRL Qualifier*	*Limits*
d5-NEtFOSAA	*105*		*70 - 130*
13C2 PFHxA	*98*		*70 - 130*
13C2 PFDA	*104*		*70 - 130*
13C3-GenX	*100*		*70 - 130*

Lab Sample ID: 380-245002-1 MS
Matrix: Water
Analysis Batch: 262529

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)
Prep Type: Total/NA
Prep Batch: 262130

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		24.6	25.4		ng/L		103	70 - 130		
Perfluorooctanesulfonic acid (PFOS)	4.2		24.6	28.5		ng/L		99	70 - 130		
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	23.9		ng/L		97	70 - 130		
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	23.7		ng/L		96	70 - 130		
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.6	22.6		ng/L		92	70 - 130		
Perfluorohexanoic acid (PFHxA)	3.5		24.6	26.6		ng/L		94	70 - 130		
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	24.9		ng/L		101	70 - 130		
Perfluorooctanoic acid (PFOA)	3.5		24.6	27.2		ng/L		96	70 - 130		
Perfluorodecanoic acid (PFDA)	<2.0		24.6	23.9		ng/L		97	70 - 130		
Perfluorohexanesulfonic acid (PFHxS)	3.5		24.6	28.6		ng/L		102	70 - 130		
Perfluorobutanesulfonic acid (PFBS)	2.5		24.6	28.5		ng/L		106	70 - 130		
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	27.2		ng/L		104	70 - 130		
Perfluorononanoic acid (PFNA)	<2.0		24.6	24.6		ng/L		100	70 - 130		
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	25.0		ng/L		102	70 - 130		
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	28.8		ng/L		117	70 - 130		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	24.0		ng/L		98	70 - 130		
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	24.2		ng/L		98	70 - 130		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	25.8		ng/L		105	70 - 130		

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-245002-1 MS
Matrix: Water
Analysis Batch: 262529

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)
Prep Type: Total/NA
Prep Batch: 262130

Surrogate	MS %Recovery	MS Qualifier	Limits
d5-NEtFOSAA	*108*		*70 - 130*
13C2 PFHxA	*104*		*70 - 130*
13C2 PFDA	*106*		*70 - 130*
13C3-GenX	*115*		*70 - 130*

Lab Sample ID: 380-245002-1 MSD
Matrix: Water
Analysis Batch: 262529

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)
Prep Type: Total/NA
Prep Batch: 262130

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		24.6	25.2		ng/L		102	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	4.2		24.6	29.0		ng/L		100	70 - 130	2	30
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	23.4		ng/L		95	70 - 130	2	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	24.4		ng/L		99	70 - 130	3	30
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.6	25.4		ng/L		103	70 - 130	12	30
Perfluorohexanoic acid (PFHxA)	3.5		24.6	26.6		ng/L		94	70 - 130	0	30
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	25.3		ng/L		103	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	3.5		24.6	25.4		ng/L		89	70 - 130	7	30
Perfluorodecanoic acid (PFDA)	<2.0		24.6	23.2		ng/L		94	70 - 130	3	30
Perfluorohexanesulfonic acid (PFHxS)	3.5		24.6	28.4		ng/L		101	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	2.5		24.6	28.1		ng/L		104	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	26.1		ng/L		99	70 - 130	4	30
Perfluorononanoic acid (PFNA)	<2.0		24.6	24.4		ng/L		99	70 - 130	1	30
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	25.1		ng/L		102	70 - 130	0	30
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	28.4		ng/L		115	70 - 130	2	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	24.3		ng/L		99	70 - 130	1	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	24.3		ng/L		99	70 - 130	0	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	24.9		ng/L		101	70 - 130	4	30

Surrogate	MSD %Recovery	MSD Qualifier	Limits
d5-NEtFOSAA	*120*		*70 - 130*
13C2 PFHxA	*104*		*70 - 130*
13C2 PFDA	*104*		*70 - 130*
13C3-GenX	*118*		*70 - 130*

LCMS

Prep Batch: 262130

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-245002-1	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	537.1 DW	
380-245002-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	537.1 DW	
MBL 380-262130/20-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-262130/22-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-262130/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-245002-1 MS	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	537.1 DW	
380-245002-1 MSD	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	537.1 DW	

Prep Batch: 262133

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-245002-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	533	
MBL 380-262133/20-A	Method Blank	Total/NA	Water	533	
LCS 380-262133/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-262133/21-A	Lab Control Sample	Total/NA	Water	533	
380-244988-B-2-A MS	Matrix Spike	Total/NA	Water	533	
380-244988-C-2-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 262461

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-245002-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	533	262133
MBL 380-262133/20-A	Method Blank	Total/NA	Water	533	262133
LCS 380-262133/22-A	Lab Control Sample	Total/NA	Water	533	262133
MRL 380-262133/21-A	Lab Control Sample	Total/NA	Water	533	262133
380-244988-B-2-A MS	Matrix Spike	Total/NA	Water	533	262133
380-244988-C-2-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	262133

Analysis Batch: 262529

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-245002-1	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	EPA 537.1 V2	262130
380-245002-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	EPA 537.1 V2	262130
MBL 380-262130/20-A	Method Blank	Total/NA	Water	EPA 537.1 V2	262130
LCS 380-262130/22-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	262130
MRL 380-262130/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	262130
380-245002-1 MS	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	EPA 537.1 V2	262130
380-245002-1 MSD	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	EPA 537.1 V2	262130

Prep Batch: 262768

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-245002-1	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	533	
MBL 380-262768/44-A	Method Blank	Total/NA	Water	533	
LCS 380-262768/46-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-262768/45-A	Lab Control Sample	Total/NA	Water	533	
380-245384-B-1-A MS	Matrix Spike	Total/NA	Water	533	
380-245384-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 262921

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MBL 380-262768/44-A	Method Blank	Total/NA	Water	533	262768
LCS 380-262768/46-A	Lab Control Sample	Total/NA	Water	533	262768
MRL 380-262768/45-A	Lab Control Sample	Total/NA	Water	533	262768
380-245384-B-1-A MS	Matrix Spike	Total/NA	Water	533	262768

LCMS (Continued)

Analysis Batch: 262921 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-245384-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	262768

Analysis Batch: 263071

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-245002-1	Ka'amilo Wells P2 (331-600-WL085)	Total/NA	Water	533	262768

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Client Sample ID: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-245002-1

Date Collected: 10/26/26 12:53
Matrix: Water
Date Received: 10/28/26 10:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			262768	XTD8	EA POM	11/02/26 07:35
Total/NA	Analysis	533		1	263071	M7ML	EA POM	11/03/26 12:49
Total/NA	Prep	537.1 DW			262130	LM3A	EA POM	10/29/26 10:54
Total/NA	Analysis	EPA 537.1 V2		1	262529	Y5FM	EA POM	10/30/26 15:18

Client Sample ID: FB: Ka'amilo Wells P2 (331-600-WL085)

Lab Sample ID: 380-245002-2

Date Collected: 10/26/26 12:53
Matrix: Water
Date Received: 10/28/26 10:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			262133	XTD8	EA POM	10/29/26 08:10
Total/NA	Analysis	533		1	262461	Y5FM	EA POM	10/30/26 17:17
Total/NA	Prep	537.1 DW			262130	LM3A	EA POM	10/29/26 10:54
Total/NA	Analysis	EPA 537.1 V2		1	262529	Y5FM	EA POM	10/30/26 18:10

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-27

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-245002-1
SDG: PFAS: Ka'amilo Wells P2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-245002-1	Ka'amilo Wells P2 (331-600-WL085)	Water	10/26/26 12:53	10/28/26 10:00	Hawaii
380-245002-2	FB: Ka'amilo Wells P2 (331-600-WL085)	Water	10/26/26 12:53	10/28/26 10:00	Hawaii

Monrovia, CA (Suite 100)
750 Royal Oaks Drive Suite 100
Monrovia, CA 91016
Phone (626) 386-1100

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: bailey	Lab PM: Lopez, Maria	Carrier Tracking No(s):	COC No:
Client Contact: kirk Iwamoto	Phone: +1 808 748 5840	E-Mail: Maria.Lopez@et.eurofinsus.com	State of Origin:	Page:
Company: City & County of Honolulu	PWSID:			Job #:
Address: 630 South Beretania Street; Chemistry Lab	Due Date Requested:			
City: Honolulu	TAT Requested (days): RUSH			
State, Zip: HI, 96843	Compliance Project: Δ No			
Phone: 808-748-5840 (tel)	PO #: C20525101 exp 05312023			
Email: kiwamoto@hbws.org	WO #:			
Project Name: RED-HILL/HBWS sites Event Desc: RUSH Weekly Red Hill	Project #: 38001111			
Site:	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	SUBCONTRACT - 525 PAH Physis LL (EAL) + TICs	8015B_GRO_LL - (MOD) GRO	8015B_DRO_LL_C8 - HNL Ranges: C10-C24/C24-C36/C8-C18	525.2_PREC - (MOD) 525plus PLUS TICs	537.1_DW_PREC - 537.1 Full List	533 - All Analytes	Total Number of containers	Special Instructions/Note:
			Preservation Code:				R	A	Q	QA	Y	I		
Ka'amilo Wells P2 (331-600-WL085)	26-Oct-2026	1253	G	Water							3	3		
FB: Ka'amilo Wells P2 (331-600-WL085)	26-Oct-2026	1253		Water							1	1		

380-245002 COC

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment: FED EX			
[redacted]	Date/Time: 27 October 2026 1400	Company HBWS	Received by:	Date/Time: 10/28/26 10:000	Company EEAP
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.:

Cooler Temperature(s) °C and Other Remarks: (957A) 0.8°-0.2°=0.6° GEL-FROZEN

Ver: 01/16/2019

ORIGIN ID:HIKA (808) 748-5840
BWS CHEMLAB
HONOLULU BOARD OF WATER SUPPLY
630 S. BERETANIA ST.
CHEMICAL LABORATORY
HONOLULU, HI 96843
UNITED STATES US

SHIP DATE: 27OCT26
ACTWGT: 33.00 LB
CAD: 258050552/INET4535

BILL RECIPIENT

TO EUROFINS RECEIVING DEPARTMENT
EUROFINS DRINKING WATER TESTING
941 CORPORATE CENTER DR

POMONA CA 91768
(626) 386-1100 REF:
INV:
PO: DEPT:

58KJ3/A338/484B

FedEx Express

J26X0061015910v

5 of 5

WED - 28 OCT 10:30A
PRIORITY OVERNIGHT

MPS# 8793 1356 2933
0263
Mstr# 8793 1356 2896

0201

91768
ONT

WM ONTA

CA-US

10/28/26 1000

1.4/1.3 BLUE ICE FROZEN
FJDA

After printing this label
CONSIGNEE COPY - PLEASE PLACE IN FRONT OF POUCH
1. Fold the printed page along the horizontal line.
2. Place label in shipping pouch and affix it to your shipment.

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-245002-1
SDG Number: PFAS: Ka'amilo Wells P2

Login Number: 245002
List Number: 1
Creator: Segura, Ryan

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
ClO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	