eurofins | Environment Testing

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 9/28/2026 11:38:33 AM

JOB DESCRIPTION

INTERA - Red-Hill-Incident
Site S1 PFAS 533/537.1

JOB NUMBER

380-238223-1

Eurofins Pomona
941 Corporate Center Drive
Pomona CA 91768-2642

See page two for job notes and contact information.

my EOL

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW,Water matrices)

Authorization

Generated
9/28/2026 11:38:33 AM

Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Table of Contents

Cover Page 1
Table of Contents 3
Definitions/Glossary 4
Case Narrative 5
Detection Summary 6
Client Sample Results 7
Action Limit Summary 11
Surrogate Summary 12
Isotope Dilution Summary 13
QC Sample Results 14
QC Association Summary 25
Lab Chronicle 26
Certification Summary 27
Method Summary 28
Sample Summary 29
Chain of Custody 30
Receipt Checklists 31

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Job Narrative
380-238223-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt
The samples were received on 9/24/2026 9:40 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 3.8°C.

PFAS
No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Client Sample ID: BWS2153-S1-AQ — Lab Sample ID: 380-238223-1

Analyte	Result	Qualifier	RL		Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanesulfonic acid (PFBS)	2.0		2.0		ng/L	1		533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	2.5		2.0		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	16		2.0		ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.5		2.0		ng/L	1		533	Total/NA
Perfluorobutanoic acid (PFBA)	2.2		2.0		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	16		2.0		ng/L	1		EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		2.0		ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.1		2.0		ng/L	1		EPA 537.1 V2	Total/NA
Perfluorobutanesulfonic acid (PFBS)	2.1		2.0		ng/L	1		EPA 537.1 V2	Total/NA

Client Sample ID: BWS2153-S1-FB — Lab Sample ID: 380-238223-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Client Sample ID: BWS2153-S1-AQ

Date Collected: 09/23/26 12:15
Date Received: 09/24/26 09:40

Lab Sample ID: 380-238223-1

Matrix: Water

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluorobutanesulfonic acid (PFBS)	**2.0**		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluorohexanesulfonic acid (PFHxS)	**2.5**		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluorooctanesulfonic acid (PFOS)	**16**		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluorooctanoic acid (PFOA)	**3.5**		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluorobutanoic acid (PFBA)	**2.2**		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 22:45	1

Isotope Dilution	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
13C3 HFPO-DA	*100*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C6 PFDA	*108*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C5 PFHxA	*105*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C4 PFHpA	*109*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C8 PFOA	*107*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C9 PFNA	*111*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C7 PFUnA	*107*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C2 PFDoA	*109*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C4 PFBA	*105*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C5 PFPeA	*104*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C3 PFBS	*106*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*

Client Sample ID: BWS2153-S1-AQ

Lab Sample ID: 380-238223-1

Date Collected: 09/23/26 12:15
Matrix: Water
Date Received: 09/24/26 09:40

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
13C3 PFHxS	*108*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C8 PFOS	*107*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C2-4:2-FTS	*122*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C2-6:2-FTS	*108*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*
13C2-8:2-FTS	*106*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:45*	*1*

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorooctanesulfonic acid (PFOS)	**16**		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorooctanoic acid (PFOA)	**4.0**		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorohexanesulfonic acid (PFHxS)	**3.1**		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorobutanesulfonic acid (PFBS)	**2.1**		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		09/25/26 14:28	09/26/26 15:16	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
d5-NEtFOSAA	*110*		*70 - 130*	*09/25/26 14:28*	*09/26/26 15:16*	*1*
13C2 PFHxA	*101*		*70 - 130*	*09/25/26 14:28*	*09/26/26 15:16*	*1*
13C2 PFDA	*115*		*70 - 130*	*09/25/26 14:28*	*09/26/26 15:16*	*1*
13C3-GenX	*106*		*70 - 130*	*09/25/26 14:28*	*09/26/26 15:16*	*1*

Client Sample ID: BWS2153-S1-FB

Lab Sample ID: 380-238223-2

Date Collected: 09/23/26 12:15
Matrix: Water
Date Received: 09/24/26 09:40

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 23:42	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		09/25/26 07:16	09/25/26 23:42	1

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Client Sample ID: BWS2153-S1-FB

Date Collected: 09/23/26 12:15
Date Received: 09/24/26 09:40

Lab Sample ID: 380-238223-2

Matrix: Water

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluorononanoic acid (PFNA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0		ng/L		09/25/26 07:16	09/25/26 23:42	1

Isotope Dilution	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
13C3 HFPO-DA	*97*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C6 PFDA	*106*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C5 PFHxA	*101*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C4 PFHpA	*104*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C8 PFOA	*104*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C9 PFNA	*105*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C7 PFUnA	*104*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C2 PFDoA	*109*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C4 PFBA	*108*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C5 PFPeA	*101*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C3 PFBS	*103*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C3 PFHxS	*107*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C8 PFOS	*104*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C2-4:2-FTS	*100*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C2-6:2-FTS	*95*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*
13C2-8:2-FTS	*100*		*50 - 200*	*09/25/26 07:16*	*09/25/26 23:42*	*1*

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Client Sample ID: BWS2153-S1-FB

Date Collected: 09/23/26 12:15
Date Received: 09/24/26 09:40

Lab Sample ID: 380-238223-2

Matrix: Water

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorononanoic acid (PFNA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0		ng/L		09/25/26 14:28	09/26/26 16:42	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
d5-NEtFOSAA	*95*		*70 - 130*	*09/25/26 14:28*	*09/26/26 16:42*	*1*
13C2 PFHxA	*93*		*70 - 130*	*09/25/26 14:28*	*09/26/26 16:42*	*1*
13C2 PFDA	*106*		*70 - 130*	*09/25/26 14:28*	*09/26/26 16:42*	*1*
13C3-GenX	*90*		*70 - 130*	*09/25/26 14:28*	*09/26/26 16:42*	*1*

Action Limit Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Client Sample ID: BWS2153-S1-AQ — Lab Sample ID: 380-238223-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	2.5		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	**16**		ng/L	**4**	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	3.5		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	**16**		ng/L	**4**	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.1		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: BWS2153-S1-FB — Lab Sample ID: 380-238223-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS	PFHxA	PFDA	GenX
Lab Sample ID	Client Sample ID	(70-130)	(70-130)	(70-130)	(70-130)
380-238223-1	BWS2153-S1-AQ	110	101	115	106
380-238223-1 MS	BWS2153-S1-AQ	106	99	110	105
380-238223-1 MSD	BWS2153-S1-AQ	109	99	117	103
380-238223-2	BWS2153-S1-FB	95	93	106	90
LCS 380-254815/22-A	Lab Control Sample	94	89	107	82
MBL 380-254815/20-A	Method Blank	99	95	113	91
MRL 380-254815/21-A	Lab Control Sample	97	93	107	88

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
PFHxA = 13C2 PFHxA
PFDA = 13C2 PFDA
GenX = 13C3-GenX

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water **Prep Type: Total/NA**

		Percent Isotope Dilution Recovery (Acceptance Limits)							
		HFPODA	C6PFDA	13C5PHA	C4PFHA	C8PFOA	C9PFNA	13C7PUA	PFDoA
Lab Sample ID	Client Sample ID	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)
380-238223-1	BWS2153-S1-AQ	100	108	105	109	107	111	107	109
380-238223-1 MS	BWS2153-S1-AQ	103	104	105	103	108	109	102	108
380-238223-1 MSD	BWS2153-S1-AQ	103	106	105	109	105	109	103	109
380-238223-2	BWS2153-S1-FB	97	106	101	104	104	105	104	109
LCS 380-254720/22-A	Lab Control Sample	101	105	106	104	106	103	107	108
MBL 380-254720/20-A	Method Blank	91	100	98	97	98	100	99	102
MRL 380-254720/21-A	Lab Control Sample	98	106	105	105	106	107	110	110

		Percent Isotope Dilution Recovery (Acceptance Limits)							
		PFBA	PFPeA	C3PFBS	C3PFHS	C8PFOS	42FTS	62FTS	82FTS
Lab Sample ID	Client Sample ID	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)	(50-200)
380-238223-1	BWS2153-S1-AQ	105	104	106	108	107	122	108	106
380-238223-1 MS	BWS2153-S1-AQ	104	106	105	106	106	126	106	104
380-238223-1 MSD	BWS2153-S1-AQ	106	108	104	107	105	124	107	105
380-238223-2	BWS2153-S1-FB	108	101	103	107	104	100	95	100
LCS 380-254720/22-A	Lab Control Sample	107	106	102	101	104	97	94	97
MBL 380-254720/20-A	Method Blank	102	98	100	103	101	96	94	100
MRL 380-254720/21-A	Lab Control Sample	108	105	100	102	102	101	94	99

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA
13C5PHA = 13C5 PFHxA
C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDoA = 13C2 PFDoA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-254720/20-A
Matrix: Water
Analysis Batch: 254873

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 254720

Analyte	MBL Result	MBL Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluorononanoic acid (PFNA)	<0.39		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluorobutanoic acid (PFBA)	<0.68		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.36		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.47		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.46		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.24		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.45		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluoropentanoic acid (PFPeA)	<0.37		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.35		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1
Perfluoropentanesulfonic acid (PFPeS)	<0.38		2.0		ng/L		09/25/26 07:16	09/25/26 22:16	1

Isotope Dilution	*MBL %Recovery*	*MBL Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
13C3 HFPO-DA	*91*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C6 PFDA	*100*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C5 PFHxA	*98*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C4 PFHpA	*97*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C8 PFOA	*98*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C9 PFNA	*100*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C7 PFUnA	*99*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C2 PFDoA	*102*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C4 PFBA	*102*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C5 PFPeA	*98*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C3 PFBS	*100*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C3 PFHxS	*103*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-254720/20-A — **Client Sample ID: Method Blank**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254873 — **Prep Batch: 254720**

Isotope Dilution	*MBL %Recovery*	*MBL Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
13C8 PFOS	*101*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C2-4:2-FTS	*96*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C2-6:2-FTS	*94*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*
13C2-8:2-FTS	*100*		*50 - 200*	*09/25/26 07:16*	*09/25/26 22:16*	*1*

Lab Sample ID: LCS 380-254720/22-A — **Client Sample ID: Lab Control Sample**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254873 — **Prep Batch: 254720**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	59.1	56.6		ng/L		96	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	59.1	56.6		ng/L		96	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	59.1	56.1		ng/L		95	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	59.1	57.9		ng/L		98	70 - 130
Perfluorobutanesulfonic acid (PFBS)	59.1	58.9		ng/L		100	70 - 130
Perfluorodecanoic acid (PFDA)	59.1	58.7		ng/L		99	70 - 130
Perfluorododecanoic acid (PFDoA)	59.1	57.8		ng/L		98	70 - 130
Perfluoroheptanoic acid (PFHpA)	59.1	57.3		ng/L		97	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	59.1	58.6		ng/L		99	70 - 130
Perfluorohexanoic acid (PFHxA)	59.1	58.9		ng/L		100	70 - 130
Perfluorononanoic acid (PFNA)	59.1	57.1		ng/L		97	70 - 130
Perfluorooctanesulfonic acid (PFOS)	59.1	58.1		ng/L		98	70 - 130
Perfluorooctanoic acid (PFOA)	59.1	58.4		ng/L		99	70 - 130
Perfluoroundecanoic acid (PFUnA)	59.1	60.1		ng/L		102	70 - 130
Perfluorobutanoic acid (PFBA)	59.1	58.2		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	59.1	59.6		ng/L		101	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	59.1	59.8		ng/L		101	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	59.1	57.8		ng/L		98	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	59.1	58.6		ng/L		99	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	59.1	57.8		ng/L		98	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	59.1	55.3		ng/L		94	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	59.1	58.7		ng/L		99	70 - 130
Perfluoropentanoic acid (PFPeA)	59.1	56.6		ng/L		96	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	59.1	57.8		ng/L		98	70 - 130

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-254720/22-A — **Client Sample ID: Lab Control Sample**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254873 — **Prep Batch: 254720**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	59.1	58.5		ng/L		99	70 - 130

Isotope Dilution	*LCS %Recovery*	*LCS Qualifier*	*Limits*
13C3 HFPO-DA	*101*		*50 - 200*
13C6 PFDA	*105*		*50 - 200*
13C5 PFHxA	*106*		*50 - 200*
13C4 PFHpA	*104*		*50 - 200*
13C8 PFOA	*106*		*50 - 200*
13C9 PFNA	*103*		*50 - 200*
13C7 PFUnA	*107*		*50 - 200*
13C2 PFDoA	*108*		*50 - 200*
13C4 PFBA	*107*		*50 - 200*
13C5 PFPeA	*106*		*50 - 200*
13C3 PFBS	*102*		*50 - 200*
13C3 PFHxS	*101*		*50 - 200*
13C8 PFOS	*104*		*50 - 200*
13C2-4:2-FTS	*97*		*50 - 200*
13C2-6:2-FTS	*94*		*50 - 200*
13C2-8:2-FTS	*97*		*50 - 200*

Lab Sample ID: MRL 380-254720/21-A — **Client Sample ID: Lab Control Sample**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254873 — **Prep Batch: 254720**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.97	2.17	J	ng/L		110	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.97	2.05	J	ng/L		104	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.97	2.01	J	ng/L		102	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	1.97	2.10	J	ng/L		106	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.97	2.16	J	ng/L		109	50 - 150
Perfluorodecanoic acid (PFDA)	1.97	2.12	J	ng/L		108	50 - 150
Perfluorododecanoic acid (PFDoA)	1.97	2.06	J	ng/L		105	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.97	2.06	J	ng/L		105	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.97	2.14	J	ng/L		109	50 - 150
Perfluorohexanoic acid (PFHxA)	1.97	2.10	J	ng/L		107	50 - 150
Perfluorononanoic acid (PFNA)	1.97	2.09	J	ng/L		106	50 - 150
Perfluorooctanesulfonic acid (PFOS)	1.97	2.13	J	ng/L		108	50 - 150
Perfluorooctanoic acid (PFOA)	1.97	2.11	J	ng/L		107	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.97	2.21	J	ng/L		112	50 - 150
Perfluorobutanoic acid (PFBA)	1.97	2.09	J	ng/L		106	50 - 150

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-254720/21-A — **Client Sample ID: Lab Control Sample**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254873 — **Prep Batch: 254720**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	1.97	2.09	J	ng/L		106	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	1.97	2.28	J	ng/L		116	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	1.97	2.10	J	ng/L		106	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	1.97	2.28	J	ng/L		116	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	1.97	2.17	J	ng/L		110	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	1.97	2.00	J	ng/L		102	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	1.97	2.14	J	ng/L		109	50 - 150
Perfluoropentanoic acid (PFPeA)	1.97	2.04	J	ng/L		104	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	1.97	2.06	J	ng/L		105	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	1.97	2.05	J	ng/L		104	50 - 150

Isotope Dilution	*MRL %Recovery*	*MRL Qualifier*	*Limits*
13C3 HFPO-DA	*98*		*50 - 200*
13C6 PFDA	*106*		*50 - 200*
13C5 PFHxA	*105*		*50 - 200*
13C4 PFHpA	*105*		*50 - 200*
13C8 PFOA	*106*		*50 - 200*
13C9 PFNA	*107*		*50 - 200*
13C7 PFUnA	*110*		*50 - 200*
13C2 PFDoA	*110*		*50 - 200*
13C4 PFBA	*108*		*50 - 200*
13C5 PFPeA	*105*		*50 - 200*
13C3 PFBS	*100*		*50 - 200*
13C3 PFHxS	*102*		*50 - 200*
13C8 PFOS	*102*		*50 - 200*
13C2-4:2-FTS	*101*		*50 - 200*
13C2-6:2-FTS	*94*		*50 - 200*
13C2-8:2-FTS	*99*		*50 - 200*

Lab Sample ID: 380-238223-1 MS — **Client Sample ID: BWS2153-S1-AQ**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254873 — **Prep Batch: 254720**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		59.3	51.1		ng/L		86	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		59.3	56.4		ng/L		95	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		59.3	57.8		ng/L		97	70 - 130

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-238223-1 MS
Matrix: Water
Analysis Batch: 254873

Client Sample ID: BWS2153-S1-AQ
Prep Type: Total/NA
Prep Batch: 254720

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		59.3	58.1		ng/L		98	70 - 130
Perfluorobutanesulfonic acid (PFBS)	2.0		59.3	64.1		ng/L		105	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		59.3	57.9		ng/L		98	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		59.3	57.9		ng/L		98	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		59.3	59.4		ng/L		100	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	2.5		59.3	61.0		ng/L		99	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		59.3	60.1		ng/L		100	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		59.3	56.5		ng/L		94	70 - 130
Perfluorooctanesulfonic acid (PFOS)	16		59.3	73.0		ng/L		96	70 - 130
Perfluorooctanoic acid (PFOA)	3.5		59.3	60.2		ng/L		96	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		59.3	62.4		ng/L		105	70 - 130
Perfluorobutanoic acid (PFBA)	2.2		59.3	61.6		ng/L		100	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		59.3	57.7		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		59.3	57.6		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		59.3	57.8		ng/L		97	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		59.3	59.4		ng/L		100	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		59.3	58.8		ng/L		99	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		59.3	54.4		ng/L		92	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		59.3	57.7		ng/L		97	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		59.3	58.2		ng/L		97	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		59.3	58.3		ng/L		98	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		59.3	57.4		ng/L		96	70 - 130

Isotope Dilution	*MS %Recovery*	*MS Qualifier*	*Limits*
13C3 HFPO-DA	*103*		*50 - 200*
13C6 PFDA	*104*		*50 - 200*
13C5 PFHxA	*105*		*50 - 200*
13C4 PFHpA	*103*		*50 - 200*
13C8 PFOA	*108*		*50 - 200*
13C9 PFNA	*109*		*50 - 200*
13C7 PFUnA	*102*		*50 - 200*
13C2 PFDoA	*108*		*50 - 200*
13C4 PFBA	*104*		*50 - 200*
13C5 PFPeA	*106*		*50 - 200*
13C3 PFBS	*105*		*50 - 200*
13C3 PFHxS	*106*		*50 - 200*
13C8 PFOS	*106*		*50 - 200*

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-238223-1 MS
Matrix: Water
Analysis Batch: 254873

Client Sample ID: BWS2153-S1-AQ
Prep Type: Total/NA
Prep Batch: 254720

Isotope Dilution	*MS %Recovery*	*MS Qualifier*	*Limits*
13C2-4:2-FTS	*126*		*50 - 200*
13C2-6:2-FTS	*106*		*50 - 200*
13C2-8:2-FTS	*104*		*50 - 200*

Lab Sample ID: 380-238223-1 MSD
Matrix: Water
Analysis Batch: 254873

Client Sample ID: BWS2153-S1-AQ
Prep Type: Total/NA
Prep Batch: 254720

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		59.2	51.7		ng/L		87	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		59.2	56.3		ng/L		95	70 - 130	0	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		59.2	54.6		ng/L		92	70 - 130	6	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		59.2	56.6		ng/L		96	70 - 130	3	30
Perfluorobutanesulfonic acid (PFBS)	2.0		59.2	61.9		ng/L		101	70 - 130	4	30
Perfluorodecanoic acid (PFDA)	<2.0		59.2	56.8		ng/L		96	70 - 130	2	30
Perfluorododecanoic acid (PFDoA)	<2.0		59.2	56.6		ng/L		96	70 - 130	2	30
Perfluoroheptanoic acid (PFHpA)	<2.0		59.2	56.5		ng/L		96	70 - 130	5	30
Perfluorohexanesulfonic acid (PFHxS)	2.5		59.2	60.8		ng/L		98	70 - 130	0	30
Perfluorohexanoic acid (PFHxA)	<2.0		59.2	57.7		ng/L		96	70 - 130	4	30
Perfluorononanoic acid (PFNA)	<2.0		59.2	56.8		ng/L		95	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	16		59.2	72.7		ng/L		96	70 - 130	0	30
Perfluorooctanoic acid (PFOA)	3.5		59.2	60.2		ng/L		96	70 - 130	0	30
Perfluoroundecanoic acid (PFUnA)	<2.0		59.2	60.3		ng/L		102	70 - 130	3	30
Perfluorobutanoic acid (PFBA)	2.2		59.2	58.8		ng/L		96	70 - 130	5	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		59.2	57.8		ng/L		98	70 - 130	0	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		59.2	58.0		ng/L		98	70 - 130	1	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		59.2	56.3		ng/L		95	70 - 130	3	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		59.2	56.2		ng/L		95	70 - 130	6	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		59.2	58.0		ng/L		98	70 - 130	1	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		59.2	55.0		ng/L		93	70 - 130	1	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		59.2	57.0		ng/L		96	70 - 130	1	30
Perfluoropentanoic acid (PFPeA)	<2.0		59.2	57.6		ng/L		96	70 - 130	1	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		59.2	57.6		ng/L		97	70 - 130	1	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		59.2	55.3		ng/L		93	70 - 130	4	30

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD %Recovery	MSD Qualifier	Limits
13C3 HFPO-DA	103		50 - 200
13C6 PFDA	106		50 - 200
13C5 PFHxA	105		50 - 200
13C4 PFHpA	109		50 - 200
13C8 PFOA	105		50 - 200
13C9 PFNA	109		50 - 200
13C7 PFUnA	103		50 - 200
13C2 PFDoA	109		50 - 200
13C4 PFBA	106		50 - 200
13C5 PFPeA	108		50 - 200
13C3 PFBS	104		50 - 200
13C3 PFHxS	107		50 - 200
13C8 PFOS	105		50 - 200
13C2-4:2-FTS	124		50 - 200
13C2-6:2-FTS	107		50 - 200
13C2-8:2-FTS	105		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-254815/20-A
Matrix: Water
Analysis Batch: 254947

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 254815

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.57		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.41		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorotetradecanoic acid (PFTA)	<0.53		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
Perfluorotridecanoic acid (PFTrDA)	<0.35		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.29		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		09/25/26 14:28	09/26/26 14:47	1

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	99		70 - 130	09/25/26 14:28	09/26/26 14:47	1
13C2 PFHxA	95		70 - 130	09/25/26 14:28	09/26/26 14:47	1
13C2 PFDA	113		70 - 130	09/25/26 14:28	09/26/26 14:47	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-254815/20-A
Matrix: Water
Analysis Batch: 254947

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 254815

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	91		70 - 130	09/25/26 14:28	09/26/26 14:47	1

Lab Sample ID: LCS 380-254815/22-A
Matrix: Water
Analysis Batch: 254947

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 254815

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	24.6	20.1		ng/L		82	70 - 130
Perfluorooctanesulfonic acid (PFOS)	24.6	24.9		ng/L		101	70 - 130
Perfluoroundecanoic acid (PFUnA)	24.6	24.8		ng/L		101	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	24.6	22.6		ng/L		92	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	24.6	21.6		ng/L		88	70 - 130
Perfluorohexanoic acid (PFHxA)	24.6	22.4		ng/L		91	70 - 130
Perfluorododecanoic acid (PFDoA)	24.6	24.9		ng/L		102	70 - 130
Perfluorooctanoic acid (PFOA)	24.6	23.1		ng/L		94	70 - 130
Perfluorodecanoic acid (PFDA)	24.6	24.4		ng/L		99	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	24.6	25.7		ng/L		105	70 - 130
Perfluorobutanesulfonic acid (PFBS)	24.6	24.8		ng/L		101	70 - 130
Perfluoroheptanoic acid (PFHpA)	24.6	22.0		ng/L		90	70 - 130
Perfluorononanoic acid (PFNA)	24.6	26.3		ng/L		107	70 - 130
Perfluorotetradecanoic acid (PFTA)	24.6	24.6		ng/L		100	70 - 130
Perfluorotridecanoic acid (PFTrDA)	24.6	25.7		ng/L		104	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	24.6	24.6		ng/L		100	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	24.6	23.7		ng/L		97	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	24.6	21.1		ng/L		86	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	94		70 - 130
13C2 PFHxA	89		70 - 130
13C2 PFDA	107		70 - 130
13C3-GenX	82		70 - 130

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-254815/21-A — **Client Sample ID: Lab Control Sample**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254947 — **Prep Batch: 254815**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	1.96	1.71	J	ng/L		87	50 - 150
Perfluorooctanesulfonic acid (PFOS)	1.96	2.04	J	ng/L		104	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.96	2.22	J	ng/L		113	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	1.96	1.85	J	ng/L		94	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	1.96	2.00	J	ng/L		102	50 - 150
Perfluorohexanoic acid (PFHxA)	1.96	1.86	J	ng/L		95	50 - 150
Perfluorododecanoic acid (PFDoA)	1.96	2.23	J	ng/L		114	50 - 150
Perfluorooctanoic acid (PFOA)	1.96	1.91	J	ng/L		97	50 - 150
Perfluorodecanoic acid (PFDA)	1.96	2.29	J	ng/L		117	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.96	2.05	J	ng/L		104	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.96	1.93	J	ng/L		98	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.96	1.76	J	ng/L		90	50 - 150
Perfluorononanoic acid (PFNA)	1.96	2.22	J	ng/L		113	50 - 150
Perfluorotetradecanoic acid (PFTA)	1.96	2.06	J	ng/L		105	50 - 150
Perfluorotridecanoic acid (PFTrDA)	1.96	1.94	J	ng/L		99	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.96	2.00	J	ng/L		102	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.96	1.93	J	ng/L		98	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.96	1.74	J	ng/L		88	50 - 150

Surrogate	*MRL %Recovery*	*MRL Qualifier*	*Limits*
d5-NEtFOSAA	*97*		*70 - 130*
13C2 PFHxA	*93*		*70 - 130*
13C2 PFDA	*107*		*70 - 130*
13C3-GenX	*88*		*70 - 130*

Lab Sample ID: 380-238223-1 MS — **Client Sample ID: BWS2153-S1-AQ**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254947 — **Prep Batch: 254815**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		24.6	25.2		ng/L		102	70 - 130
Perfluorooctanesulfonic acid (PFOS)	16		24.6	41.3		ng/L		102	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	24.7		ng/L		100	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	24.8		ng/L		101	70 - 130

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-238223-1 MS — **Client Sample ID: BWS2153-S1-AQ**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254947 — **Prep Batch: 254815**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.6	25.2		ng/L		102	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		24.6	26.6		ng/L		106	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	25.5		ng/L		104	70 - 130
Perfluorooctanoic acid (PFOA)	4.0		24.6	28.6		ng/L		100	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		24.6	27.7		ng/L		113	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	3.1		24.6	28.7		ng/L		104	70 - 130
Perfluorobutanesulfonic acid (PFBS)	2.1		24.6	27.2		ng/L		102	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	25.3		ng/L		103	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		24.6	28.6		ng/L		114	70 - 130
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	25.2		ng/L		102	70 - 130
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	27.4		ng/L		111	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	25.3		ng/L		103	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	23.6		ng/L		96	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	25.3		ng/L		103	70 - 130

Surrogate	*MS %Recovery*	*MS Qualifier*	*Limits*
d5-NEtFOSAA	*106*		*70 - 130*
13C2 PFHxA	*99*		*70 - 130*
13C2 PFDA	*110*		*70 - 130*
13C3-GenX	*105*		*70 - 130*

Lab Sample ID: 380-238223-1 MSD — **Client Sample ID: BWS2153-S1-AQ**
Matrix: Water — **Prep Type: Total/NA**
Analysis Batch: 254947 — **Prep Batch: 254815**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		24.6	24.0		ng/L		97	70 - 130	5	30
Perfluorooctanesulfonic acid (PFOS)	16		24.6	41.7		ng/L		104	70 - 130	1	30
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	23.4		ng/L		95	70 - 130	5	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	24.7		ng/L		101	70 - 130	0	30
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.6	25.4		ng/L		103	70 - 130	1	30
Perfluorohexanoic acid (PFHxA)	<2.0		24.6	25.4		ng/L		101	70 - 130	4	30
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	24.5		ng/L		100	70 - 130	4	30
Perfluorooctanoic acid (PFOA)	4.0		24.6	27.9		ng/L		97	70 - 130	2	30
Perfluorodecanoic acid (PFDA)	<2.0		24.6	25.5		ng/L		104	70 - 130	8	30

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-238223-1 MSD
Matrix: Water
Analysis Batch: 254947

Client Sample ID: BWS2153-S1-AQ
Prep Type: Total/NA
Prep Batch: 254815

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorohexanesulfonic acid (PFHxS)	3.1		24.6	28.9		ng/L		105	70 - 130	0	30
Perfluorobutanesulfonic acid (PFBS)	2.1		24.6	27.4		ng/L		103	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	24.1		ng/L		98	70 - 130	5	30
Perfluorononanoic acid (PFNA)	<2.0		24.6	26.9		ng/L		107	70 - 130	6	30
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	24.9		ng/L		101	70 - 130	1	30
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	26.0		ng/L		106	70 - 130	5	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	25.6		ng/L		104	70 - 130	1	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	24.0		ng/L		97	70 - 130	2	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	24.4		ng/L		99	70 - 130	4	30

Surrogate	*MSD %Recovery*	*MSD Qualifier*	*Limits*
d5-NEtFOSAA	*109*		*70 - 130*
13C2 PFHxA	*99*		*70 - 130*
13C2 PFDA	*117*		*70 - 130*
13C3-GenX	*103*		*70 - 130*

QC Association Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

LCMS

Prep Batch: 254720

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-238223-1	BWS2153-S1-AQ	Total/NA	Water	533	
380-238223-2	BWS2153-S1-FB	Total/NA	Water	533	
MBL 380-254720/20-A	Method Blank	Total/NA	Water	533	
LCS 380-254720/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-254720/21-A	Lab Control Sample	Total/NA	Water	533	
380-238223-1 MS	BWS2153-S1-AQ	Total/NA	Water	533	
380-238223-1 MSD	BWS2153-S1-AQ	Total/NA	Water	533	

Prep Batch: 254815

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-238223-1	BWS2153-S1-AQ	Total/NA	Water	537.1 DW	
380-238223-2	BWS2153-S1-FB	Total/NA	Water	537.1 DW	
MBL 380-254815/20-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-254815/22-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-254815/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-238223-1 MS	BWS2153-S1-AQ	Total/NA	Water	537.1 DW	
380-238223-1 MSD	BWS2153-S1-AQ	Total/NA	Water	537.1 DW	

Analysis Batch: 254873

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-238223-1	BWS2153-S1-AQ	Total/NA	Water	533	254720
380-238223-2	BWS2153-S1-FB	Total/NA	Water	533	254720
MBL 380-254720/20-A	Method Blank	Total/NA	Water	533	254720
LCS 380-254720/22-A	Lab Control Sample	Total/NA	Water	533	254720
MRL 380-254720/21-A	Lab Control Sample	Total/NA	Water	533	254720
380-238223-1 MS	BWS2153-S1-AQ	Total/NA	Water	533	254720
380-238223-1 MSD	BWS2153-S1-AQ	Total/NA	Water	533	254720

Analysis Batch: 254947

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-238223-1	BWS2153-S1-AQ	Total/NA	Water	EPA 537.1 V2	254815
380-238223-2	BWS2153-S1-FB	Total/NA	Water	EPA 537.1 V2	254815
MBL 380-254815/20-A	Method Blank	Total/NA	Water	EPA 537.1 V2	254815
LCS 380-254815/22-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	254815
MRL 380-254815/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	254815
380-238223-1 MS	BWS2153-S1-AQ	Total/NA	Water	EPA 537.1 V2	254815
380-238223-1 MSD	BWS2153-S1-AQ	Total/NA	Water	EPA 537.1 V2	254815

Lab Chronicle

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Client Sample ID: BWS2153-S1-AQ

Lab Sample ID: 380-238223-1

Date Collected: 09/23/26 12:15
Matrix: Water
Date Received: 09/24/26 09:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			254720	XTD8	EA POM	09/25/26 07:16
Total/NA	Analysis	533		1	254873	M7ML	EA POM	09/25/26 22:45
Total/NA	Prep	537.1 DW			254815	N8NE	EA POM	09/25/26 14:28
Total/NA	Analysis	EPA 537.1 V2		1	254947	M7ML	EA POM	09/26/26 15:16

Client Sample ID: BWS2153-S1-FB

Lab Sample ID: 380-238223-2

Date Collected: 09/23/26 12:15
Matrix: Water
Date Received: 09/24/26 09:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			254720	XTD8	EA POM	09/25/26 07:16
Total/NA	Analysis	533		1	254873	M7ML	EA POM	09/25/26 23:42
Total/NA	Prep	537.1 DW			254815	N8NE	EA POM	09/25/26 14:28
Total/NA	Analysis	EPA 537.1 V2		1	254947	M7ML	EA POM	09/26/26 16:42

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-27

Method Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Sample Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-238223-1
SDG: Site S1 PFAS 533/537.1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-238223-1	BWS2153-S1-AQ	Water	09/23/26 12:15	09/24/26 09:40	Hawaii
380-238223-2	BWS2153-S1-FB	Water	09/23/26 12:15	09/24/26 09:40	Hawaii

Eurofins Pomona
941 Corporate Center Drive
Pomona, CA 91768-2642
Phone (626) 386-1100

Chain of Custody Record

eurofins | Environment Testing

Client Information	Sampler: H Bentley (808) 321-0683	Lab PM: Lopez, Maria	Carrier Tracking No(s):	COC No:
Client Contact: Mr Erwin Kawata	Phone: 858-205-0730	E-Mail: Maria Lopez@et.eurofinsus.com	State of Origin: Hawaii	Page: Page 1 of 1
Company: City & County of Honolulu	PWSID:			Job #: 380-238223 COC
Address: 630 South Beretania Street	Due Date Requested:			
City: Honolulu	TAT Requested (days): Standard			
State, Zip: HI, 96843	Compliance Project: Δ Yes X No			
Phone: 808-748-5066	PO #:			
Email: ekawata@hbws.org	WO #:			
Project Name: INTERA - Red-Hill-Incident	Project #: 38000861			
Site: S1	SSOW#:			

Analysis Requested

Preservation Codes.
A - HCL
N - None
I - AMMONIUM ACETATE
Y - TRIZMA
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air, DW=Drinking Water)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	533 - All Analytes	537.1_DW_PREC - 537.1 Full List	Total Number of containers	Special Instructions/Note:
			Preservation Code:							
BWS2153-S1-AQ	9/23/26	12:15	G	Water	N	N	3	3	6	
BWS2153-S1-FB	9/23/26	12:15	G	Water	N	N	1	1	2	FIELD BLANK

Possible Hazard Identification
☐ X Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☐ X Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested I, II, III, IV, Other (specify)

Special Instructions/QC Requirements.

Empty Kit Relinquished by:	Date:	Time	Method of Shipment: Fedex 8776 6792 8016

Relinquished by	Date/Time	Company	Received by	Date/Time	Company
[signature]	9/23/26 1400	INTERA, INC	[signature]	9/24/26 940	EEAC

Custody Seals Intact: Δ Yes Δ No	Custody Seal No	Cooler Temperature(s) °C and Other Remarks: (631A) 3.6 3.0.2 = 3.6 ice-frozen

Ver 05/06/2024

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-238223-1
SDG Number: Site S1 PFAS 533/537.1

Login Number: 238223
List Number: 1
Creator: Abaya, Ashton

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
ClO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	