

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 6/15/2026 6:22:58 PM

JOB DESCRIPTION

RED-HILL
PFAS: Moanalua Wells
RUSH Weekly Red Hill

JOB NUMBER

380-219259-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
6/15/2026 6:22:58 PM



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	15
QC Association Summary	26
Lab Chronicle	27
Certification Summary	28
Method Summary	29
Sample Summary	30
Chain of Custody	31
Receipt Checklists	32

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-219259-1

Job ID: 380-219259-1

Eurofins Pomona

Job Narrative 380-219259-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 6/11/2026 10:00 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 5.0°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)
PWSID Number: HI0000331

Lab Sample ID: 380-219259-1

No Detections.

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-2

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

This Detection Summary does not include radiochemical test results.

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-1

Date Collected: 06/09/26 12:25

Matrix: Drinking Water

Date Received: 06/11/26 10:00

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:45	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	82		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C6 PFDA	82		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C5 PFHxA	86		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C4 PFHpA	91		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C8 PFOA	89		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C9 PFNA	88		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C7 PFUnA	87		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C2 PFDoA	90		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C4 PFBA	96		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C5 PFPeA	90		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C3 PFBS	108		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C3 PFHxS	110		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C8 PFOS	110		50 - 200	06/13/26 12:30	06/14/26 16:45	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-1

Date Collected: 06/09/26 12:25

Matrix: Drinking Water

Date Received: 06/11/26 10:00

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2-4:2-FTS	108		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C2-6:2-FTS	99		50 - 200	06/13/26 12:30	06/14/26 16:45	1
13C2-8:2-FTS	93		50 - 200	06/13/26 12:30	06/14/26 16:45	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
11-Chloroeicosafluoro-3-oxadecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 00:09	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	96		70 - 130			06/12/26 06:41	06/13/26 00:09	1
13C2 PFHxA	109		70 - 130			06/12/26 06:41	06/13/26 00:09	1
13C2 PFDA	109		70 - 130			06/12/26 06:41	06/13/26 00:09	1
13C3-GenX	107		70 - 130			06/12/26 06:41	06/13/26 00:09	1

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-2

Date Collected: 06/09/26 12:25

Matrix: Water

Date Received: 06/11/26 10:00

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxadecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-2

Date Collected: 06/09/26 12:25

Matrix: Water

Date Received: 06/11/26 10:00

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:55	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	82		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C6 PFDA	84		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C5 PFHxA	99		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C4 PFHpA	90		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C8 PFOA	89		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C9 PFNA	93		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C7 PFUnA	88		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C2 PFDoA	94		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C4 PFBA	92		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C5 PFPeA	87		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C3 PFBS	105		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C3 PFHxS	104		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C8 PFOS	111		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C2-4:2-FTS	105		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C2-6:2-FTS	96		50 - 200	06/13/26 12:30	06/14/26 16:55	1
13C2-8:2-FTS	91		50 - 200	06/13/26 12:30	06/14/26 16:55	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-2

Date Collected: 06/09/26 12:25

Matrix: Water

Date Received: 06/11/26 10:00

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/12/26 06:41	06/13/26 01:35	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	104		70 - 130	06/12/26 06:41	06/13/26 01:35	1
13C2 PFHxA	113		70 - 130	06/12/26 06:41	06/13/26 01:35	1
13C2 PFDA	114		70 - 130	06/12/26 06:41	06/13/26 01:35	1
13C3-GenX	112		70 - 130	06/12/26 06:41	06/13/26 01:35	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-1

PWSID Number: HI0000331

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-219259-1
 SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-219259-1	MOANALUA WELLS (331-223-TP202)	96	109	109	107
380-219259-1 MS	MOANALUA WELLS (331-223-TP202)	94	102	108	105
380-219259-1 MSD	MOANALUA WELLS (331-223-TP202)	96	111	108	108

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
 PFHxA = 13C2 PFHxA
 PFDA = 13C2 PFDA
 GenX = 13C3-GenX

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-219259-2	FB: MOANALUA WELLS (331-223-TP202)	104	113	114	112
LCS 380-233412/23-A	Lab Control Sample	90	93	107	91
MBL 380-233412/21-A	Method Blank	110	123	118	114
MRL 380-233412/22-A	Lab Control Sample	95	106	112	86

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
 PFHxA = 13C2 PFHxA
 PFDA = 13C2 PFDA
 GenX = 13C3-GenX

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-219259-1	MOANALUA WELLS (331-223-TP20)	82	82	86	91	89	88	87	90

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-219259-1	MOANALUA WELLS (331-223-TP20)	96	90	108	110	110	108	99	93

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDaA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-218914-B-2-A MS	Matrix Spike	109	102	103	107	103	108	106	107
380-218914-C-2-A MSD	Matrix Spike Duplicate	103	99	106	104	106	107	108	109
380-219259-2	FB: MOANALUA WELLS (331-223-TP20)	82	84	99	90	89	93	88	94
LCS 380-233676/22-A	Lab Control Sample	73	75	78	78	80	81	77	79
MBL 380-233676/20-A	Method Blank	76	80	82	80	83	90	85	87
MRL 380-233676/21-A	Lab Control Sample	84	87	91	90	93	96	94	95

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-218914-B-2-A MS	Matrix Spike	106	111	107	106	109	109	95	91
380-218914-C-2-A MSD	Matrix Spike Duplicate	111	111	110	110	114	112	100	95
380-219259-2	FB: MOANALUA WELLS (331-223-TP20)	92	87	105	104	111	105	96	91
LCS 380-233676/22-A	Lab Control Sample	83	79	100	103	107	95	91	92
MBL 380-233676/20-A	Method Blank	89	81	98	101	107	100	88	89
MRL 380-233676/21-A	Lab Control Sample	94	87	104	105	113	100	91	88

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA

Isotope Dilution Summary

Client: City & County of Honolulu

Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

13C5PHA = 13C5 PFHxA
C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDoA = 13C2 PFDoA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-233676/20-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233676

Analyte	MBL	MBL	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	0.496	J	2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.25		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1

Isotope Dilution	MBL	MBL	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C3 HFPO-DA	76		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C6 PFDA	80		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C5 PFHxA	82		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C4 PFHpA	80		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C8 PFOA	83		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C9 PFNA	90		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C7 PFUnA	85		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C2 PFDoA	87		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C4 PFBA	89		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C5 PFPeA	81		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C3 PFBS	98		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C3 PFHxS	101		50 - 200	06/13/26 12:30	06/14/26 13:03	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-233676/20-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233676

<i>Isotope Dilution</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	<i>%Recovery</i>	<i>Qualifier</i>				
13C8 PFOS	107		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C2-4:2-FTS	100		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C2-6:2-FTS	88		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C2-8:2-FTS	89		50 - 200	06/13/26 12:30	06/14/26 13:03	1

Lab Sample ID: LCS 380-233676/22-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>				<i>Limits</i>
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	60.2	57.9		ng/L		96	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	60.2	56.0		ng/L		93	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	60.2	56.2		ng/L		93	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	60.2	57.8		ng/L		96	70 - 130
Perfluorobutanesulfonic acid (PFBS)	60.2	60.7		ng/L		101	70 - 130
Perfluorodecanoic acid (PFDA)	60.2	64.7		ng/L		107	70 - 130
Perfluorododecanoic acid (PFDoA)	60.2	58.4		ng/L		97	70 - 130
Perfluoroheptanoic acid (PFHpA)	60.2	61.6		ng/L		102	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	60.2	59.8		ng/L		99	70 - 130
Perfluorohexanoic acid (PFHxA)	60.2	59.0		ng/L		98	70 - 130
Perfluorononanoic acid (PFNA)	60.2	59.1		ng/L		98	70 - 130
Perfluorooctanesulfonic acid (PFOS)	60.2	57.9		ng/L		96	70 - 130
Perfluorooctanoic acid (PFOA)	60.2	62.2		ng/L		103	70 - 130
Perfluoroundecanoic acid (PFUnA)	60.2	58.3		ng/L		97	70 - 130
Perfluorobutanoic acid (PFBA)	60.2	61.1		ng/L		101	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	60.2	57.4		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	60.2	59.8		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	60.2	61.4		ng/L		102	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	60.2	59.7		ng/L		99	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	60.2	61.7		ng/L		102	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	60.2	65.4		ng/L		109	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	60.2	60.7		ng/L		101	70 - 130
Perfluoropentanoic acid (PFPeA)	60.2	58.7		ng/L		97	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	60.2	60.9		ng/L		101	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-233676/22-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	60.2	58.1		ng/L		96	70 - 130
LCS LCS							
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	73		50 - 200				
13C6 PFDA	75		50 - 200				
13C5 PFHxA	78		50 - 200				
13C4 PFHpA	78		50 - 200				
13C8 PFOA	80		50 - 200				
13C9 PFNA	81		50 - 200				
13C7 PFUnA	77		50 - 200				
13C2 PFDoA	79		50 - 200				
13C4 PFBA	83		50 - 200				
13C5 PFPeA	79		50 - 200				
13C3 PFBS	100		50 - 200				
13C3 PFHxS	103		50 - 200				
13C8 PFOS	107		50 - 200				
13C2-4:2-FTS	95		50 - 200				
13C2-6:2-FTS	91		50 - 200				
13C2-8:2-FTS	92		50 - 200				

Lab Sample ID: MRL 380-233676/21-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	1.96	J	ng/L		98	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	1.83	J	ng/L		91	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	2.04	J	ng/L		102	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	1.95	J	ng/L		97	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	1.97	J	ng/L		98	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.38	J	ng/L		119	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.23	J	ng/L		112	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	1.94	J	ng/L		97	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	1.97	J	ng/L		98	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.01	J	ng/L		100	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.07	J	ng/L		103	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	1.96	J	ng/L		98	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.17	J	ng/L		108	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.20	J	ng/L		110	50 - 150
Perfluorobutanoic acid (PFBA)	2.00	2.40	J	ng/L		120	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-233676/21-A

Matrix: Water

Analysis Batch: 233715

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 233676

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.00	2.14	J	ng/L		107	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.00	2.32	J	ng/L		116	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.00	2.55	J	ng/L		127	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.00	2.02	J	ng/L		101	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.00	1.95	J	ng/L		97	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.00	2.26	J	ng/L		113	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.00	1.99	J	ng/L		99	50 - 150
Perfluoropentanoic acid (PFPeA)	2.00	2.23	J	ng/L		111	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.00	2.00	J	ng/L		100	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.00	1.85	J	ng/L		92	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	84		50 - 200
13C6 PFDA	87		50 - 200
13C5 PFHxA	91		50 - 200
13C4 PFHpA	90		50 - 200
13C8 PFOA	93		50 - 200
13C9 PFNA	96		50 - 200
13C7 PFUnA	94		50 - 200
13C2 PFDoA	95		50 - 200
13C4 PFBA	94		50 - 200
13C5 PFPeA	87		50 - 200
13C3 PFBS	104		50 - 200
13C3 PFHxS	105		50 - 200
13C8 PFOS	113		50 - 200
13C2-4:2-FTS	100		50 - 200
13C2-6:2-FTS	91		50 - 200
13C2-8:2-FTS	88		50 - 200

Lab Sample ID: 380-218914-B-2-A MS

Matrix: Water

Analysis Batch: 233715

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 233676

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	114		ng/L		94	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	110		ng/L		91	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	115		ng/L		96	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-218914-B-2-A MS

Client Sample ID: Matrix Spike

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 233715

Prep Batch: 233676

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
Hexafluoropropylene Oxide	<2.0		120	111		ng/L		92	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	3.3		120	118		ng/L		95	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		120	128		ng/L		106	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		120	118		ng/L		98	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		120	117		ng/L		96	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	5.0		120	119		ng/L		95	70 - 130
Perfluorohexanoic acid (PFHxA)	2.1		120	121		ng/L		99	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		120	117		ng/L		96	70 - 130
Perfluorooctanesulfonic acid (PFOS)	9.6		120	122		ng/L		93	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		120	124		ng/L		102	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		120	118		ng/L		98	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		120	121		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	116		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	111		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	124		ng/L		103	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	120		ng/L		100	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		120	117		ng/L		97	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	123		ng/L		102	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	114		ng/L		94	70 - 130
Perfluoropentanoic acid (PFPeA)	2.3		120	118		ng/L		96	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	116		ng/L		96	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	118		ng/L		97	70 - 130

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	109		50 - 200
13C6 PFDA	102		50 - 200
13C5 PFHxA	103		50 - 200
13C4 PFHpA	107		50 - 200
13C8 PFOA	103		50 - 200
13C9 PFNA	108		50 - 200
13C7 PFUnA	106		50 - 200
13C2 PFDoA	107		50 - 200
13C4 PFBA	106		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	107		50 - 200
13C3 PFHxS	106		50 - 200
13C8 PFOS	109		50 - 200

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-218914-B-2-A MS
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 233676

<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>MS MS Qualifier</i>	<i>Limits</i>
13C2-4:2-FTS	109		50 - 200
13C2-6:2-FTS	95		50 - 200
13C2-8:2-FTS	91		50 - 200

Lab Sample ID: 380-218914-C-2-A MSD
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 233676

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	112		ng/L		93	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	106		ng/L		88	70 - 130	3	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	116		ng/L		96	70 - 130	0	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		120	112		ng/L		93	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	3.3		120	112		ng/L		90	70 - 130	5	30
Perfluorodecanoic acid (PFDA)	<2.0		120	127		ng/L		106	70 - 130	0	30
Perfluorododecanoic acid (PFDoA)	<2.0		120	114		ng/L		95	70 - 130	3	30
Perfluoroheptanoic acid (PFHpA)	<2.0		120	116		ng/L		95	70 - 130	1	30
Perfluorohexanesulfonic acid (PFHxS)	5.0		120	119		ng/L		95	70 - 130	0	30
Perfluorohexanoic acid (PFHxA)	2.1		120	114		ng/L		93	70 - 130	6	30
Perfluorononanoic acid (PFNA)	<2.0		120	113		ng/L		93	70 - 130	3	30
Perfluorooctanesulfonic acid (PFOS)	9.6		120	117		ng/L		90	70 - 130	4	30
Perfluorooctanoic acid (PFOA)	<2.0		120	116		ng/L		95	70 - 130	7	30
Perfluoroundecanoic acid (PFUnA)	<2.0		120	113		ng/L		94	70 - 130	4	30
Perfluorobutanoic acid (PFBA)	<2.0		120	117		ng/L		96	70 - 130	4	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	121		ng/L		101	70 - 130	4	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	111		ng/L		92	70 - 130	0	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	119		ng/L		98	70 - 130	4	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	113		ng/L		94	70 - 130	7	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		120	115		ng/L		96	70 - 130	2	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	126		ng/L		105	70 - 130	2	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	112		ng/L		93	70 - 130	2	30
Perfluoropentanoic acid (PFPeA)	2.3		120	116		ng/L		95	70 - 130	1	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	112		ng/L		93	70 - 130	3	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	115		ng/L		95	70 - 130	3	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	103		50 - 200
13C6 PFDA	99		50 - 200
13C5 PFHxA	106		50 - 200
13C4 PFHpA	104		50 - 200
13C8 PFOA	106		50 - 200
13C9 PFNA	107		50 - 200
13C7 PFUnA	108		50 - 200
13C2 PFDoA	109		50 - 200
13C4 PFBA	111		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	110		50 - 200
13C3 PFHxS	110		50 - 200
13C8 PFOS	114		50 - 200
13C2-4:2-FTS	112		50 - 200
13C2-6:2-FTS	100		50 - 200
13C2-8:2-FTS	95		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-233412/21-A
Matrix: Water
Analysis Batch: 233618

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233412

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
Perfluorotridecanoic acid (PFTTrDA)	<0.36		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/12/26 06:41	06/12/26 23:41	1

Surrogate	MBL MBL		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
d5-NEtFOSAA	110		70 - 130	06/12/26 06:41	06/12/26 23:41	1
13C2 PFHxA	123		70 - 130	06/12/26 06:41	06/12/26 23:41	1
13C2 PFDA	118		70 - 130	06/12/26 06:41	06/12/26 23:41	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-233412/21-A
Matrix: Water
Analysis Batch: 233618

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233412

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	114		70 - 130	06/12/26 06:41	06/12/26 23:41	1

Lab Sample ID: LCS 380-233412/23-A
Matrix: Water
Analysis Batch: 233618

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233412

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	50.2	42.9		ng/L		86	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	50.2	51.1		ng/L		102	70 - 130
Perfluoroundecanoic acid (PFUnA)	50.2	55.7		ng/L		111	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	50.2	44.0		ng/L		88	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	50.2	46.0		ng/L		92	70 - 130
Perfluorohexanoic acid (PFHxA)	50.2	49.7		ng/L		99	70 - 130
Perfluorododecanoic acid (PFDoA)	50.2	53.5		ng/L		107	70 - 130
Perfluorooctanoic acid (PFOA)	50.2	51.1		ng/L		102	70 - 130
Perfluorodecanoic acid (PFDA)	50.2	52.6		ng/L		105	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	50.2	51.4		ng/L		102	70 - 130
Perfluorobutanesulfonic acid (PFBS)	50.2	52.7		ng/L		105	70 - 130
Perfluoroheptanoic acid (PFHpA)	50.2	49.6		ng/L		99	70 - 130
Perfluorononanoic acid (PFNA)	50.2	50.4		ng/L		100	70 - 130
Perfluorotetradecanoic acid (PFTA)	50.2	49.3		ng/L		98	70 - 130
Perfluorotridecanoic acid (PFTrDA)	50.2	53.4		ng/L		106	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	50.2	51.9		ng/L		103	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	50.2	53.6		ng/L		107	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	50.2	45.7		ng/L		91	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	90		70 - 130
13C2 PFHxA	93		70 - 130
13C2 PFDA	107		70 - 130
13C3-GenX	91		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-233412/22-A
Matrix: Water
Analysis Batch: 233618

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233412

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	1.85	J	ng/L		92	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	2.20	J	ng/L		110	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.44	J	ng/L		121	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.01	1.85	J	ng/L		92	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.01	2.01	J	ng/L		100	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	2.09	J	ng/L		104	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	2.31	J	ng/L		115	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	2.18	J	ng/L		109	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.23	J	ng/L		111	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	2.26	J	ng/L		112	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	2.17	J	ng/L		108	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	2.13	J	ng/L		106	50 - 150
Perfluorononanoic acid (PFNA)	2.01	2.20	J	ng/L		109	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.01	2.12	J	ng/L		106	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.01	2.31	J	ng/L		115	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	2.22	J	ng/L		110	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	2.29	J	ng/L		114	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.77	J	ng/L		88	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	95		70 - 130
13C2 PFHxA	106		70 - 130
13C2 PFDA	112		70 - 130
13C3-GenX	86		70 - 130

Lab Sample ID: 380-219259-1 MS
Matrix: Drinking Water
Analysis Batch: 233618

Client Sample ID: MOANALUA WELLS (331-223-TP202)
Prep Type: Total/NA
Prep Batch: 233412

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		50.2	52.8		ng/L		105	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		50.2	55.0		ng/L		106	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		50.2	54.3		ng/L		108	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		50.2	46.3		ng/L		92	70 - 130

Eurofins Pomona

QC Association Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-219259-1
 SDG: PFAS: Moanalua Wells

LCMS

Prep Batch: 233412

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-219259-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	537.1 DW	
380-219259-2	FB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	537.1 DW	
MBL 380-233412/21-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-233412/23-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-233412/22-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-219259-1 MS	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	537.1 DW	
380-219259-1 MSD	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	537.1 DW	

Analysis Batch: 233618

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-219259-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	EPA 537.1 V2	233412
380-219259-2	FB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	EPA 537.1 V2	233412
MBL 380-233412/21-A	Method Blank	Total/NA	Water	EPA 537.1 V2	233412
LCS 380-233412/23-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	233412
MRL 380-233412/22-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	233412
380-219259-1 MS	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	EPA 537.1 V2	233412
380-219259-1 MSD	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	EPA 537.1 V2	233412

Prep Batch: 233676

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-219259-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	533	
380-219259-2	FB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	533	
MBL 380-233676/20-A	Method Blank	Total/NA	Water	533	
LCS 380-233676/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-233676/21-A	Lab Control Sample	Total/NA	Water	533	
380-218914-B-2-A MS	Matrix Spike	Total/NA	Water	533	
380-218914-C-2-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 233715

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-219259-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	533	233676
380-219259-2	FB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	533	233676
MBL 380-233676/20-A	Method Blank	Total/NA	Water	533	233676
LCS 380-233676/22-A	Lab Control Sample	Total/NA	Water	533	233676
MRL 380-233676/21-A	Lab Control Sample	Total/NA	Water	533	233676
380-218914-B-2-A MS	Matrix Spike	Total/NA	Water	533	233676
380-218914-C-2-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	233676

Lab Chronicle

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-219259-1
 SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-1

Date Collected: 06/09/26 12:25

Matrix: Drinking Water

Date Received: 06/11/26 10:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			233676	N8NE	EA POM	06/13/26 12:30
Total/NA	Analysis	533		1	233715	M7ML	EA POM	06/14/26 16:45
Total/NA	Prep	537.1 DW			233412	E9PK	EA POM	06/12/26 06:41
Total/NA	Analysis	EPA 537.1 V2		1	233618	M7ML	EA POM	06/13/26 00:09

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-219259-2

Date Collected: 06/09/26 12:25

Matrix: Water

Date Received: 06/11/26 10:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			233676	N8NE	EA POM	06/13/26 12:30
Total/NA	Analysis	533		1	233715	M7ML	EA POM	06/14/26 16:55
Total/NA	Prep	537.1 DW			233412	E9PK	EA POM	06/12/26 06:41
Total/NA	Analysis	EPA 537.1 V2		1	233618	M7ML	EA POM	06/13/26 01:35

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-219259-1
SDG: PFAS: Moanalua Wells

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-219259-1	MOANALUA WELLS (331-223-TP202)	Drinking Water	06/09/26 12:25	06/11/26 10:00	HI0000331
380-219259-2	FB: MOANALUA WELLS (331-223-TP202)	Water	06/09/26 12:25	06/11/26 10:00	

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Monrovia, CA (Suite 100)

750 Royal Oaks Drive Suite 100
 Monrovia CA 91016
 Phone (626) 386-1100



Chain of Custody Record

Environment Test Prg
 Aime ca

Client Information Client Contact: Kirk Iwamoto Phone: +1 808 748 5840 City & County of Honolulu		Sampler: Patrick Regan Lab PM: Lopez, Maria E-Mail: Maria.Lopez@et.eurofins.com		Camer Tracking No(s): State of Origin:		COC No: Page: Page 1 of 1 Job #:	
Address: 630 South Beretania Street; Chemistry Lab City: Honolulu State Zip: HI 96843 Phone: 808-748-5840 (tel) Email: kiwamoto@hbws.org		Due Date Requested: TAT Requested (days): RUSH Compliance Project: Δ No PO #: C20525101 exp 05312023 WO #:		Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other:	
Project Name: RED-HILL/HBWS sites Event Desc. RUSH Weekly Red Hill Site:		Project #: 38001111 SOW#:		Field Filtered Sample (Yes or No)		Total Number of Containers	
Sample Identification MOANALUA WELLS (331-223-TP202)		Sample Date: 9-Jun-2026 Sample Time: 12:25 Sample Type (C=comp, G=grab): G Matrix (w=water, s=solid, o=wastefl, bt=tissue, a=air): Water		Perform MS/MSD (Yes or No)		Special Instructions/Note	
FB MOANALUA WELLS (331-223-TP202)		Sample Date: 9-Jun-2026 Sample Time: 12:25		Field Filtered Sample (Yes or No)		Special Instructions/Note	
Possible Hazard Identification <input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological							
Deliverable Requested I II III IV Other (specify)							
Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) <input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months							
Special Instructions/QC Requirements.							
Empty Kit Relinquished by:		Date:		Method of Shipment:		Date/Time:	
Relinquished by:		Date/Time: 6/10/26 17:00		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Received by:		Date/Time:	
Custody Seals Intact: Δ Yes Δ No		Custody Seal No.		Cooler Temperature(s) °C and Other Remarks:		Company:	



Ver 01/16/2019

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-219259-1
SDG Number: PFAS: Moanalua Wells

Login Number: 219259

List Number: 1

Creator: Del Rosario, Michael

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
ClO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

