

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 7/6/2026 3:03:19 PM

JOB DESCRIPTION

INTERA - Red-Hill-Incident
Site D2 PFAS 533/537.1

JOB NUMBER

380-222190-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
7/6/2026 3:03:19 PM

Table of Contents

Cover Page 1

Table of Contents 3

Definitions/Glossary 4

Case Narrative 5

Detection Summary 6

Client Sample Results 7

Action Limit Summary 11

Surrogate Summary 12

Isotope Dilution Summary 13

QC Sample Results 14

QC Association Summary 25

Lab Chronicle 26

Certification Summary 27

Method Summary 28

Sample Summary 29

Chain of Custody 30

Receipt Checklists 31



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: INTERA - Red-Hill-Incident

Job ID: 380-222190-1

Job ID: 380-222190-1

Eurofins Pomona

Job Narrative 380-222190-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 6/30/2026 10:18 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 0.8°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-222190-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanesulfonic acid (PFHxS)	9.3		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.9		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	10		2.0	ng/L	1		EPA 537.1 V2	Total/NA

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-222190-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-222190-1

Date Collected: 06/29/26 11:15

Matrix: Water

Date Received: 06/30/26 10:18

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9CI-PF3ONS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluorohexanesulfonic acid (PFHxS)	9.3		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluorooctanoic acid (PFOA)	3.9		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:10	1
Isotope Dilution	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	111		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C6 PFDA	104		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C5 PFHxA	108		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C4 PFHpA	110		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C8 PFOA	106		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C9 PFNA	103		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C7 PFUnA	102		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C2 PFDoA	107		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C4 PFBA	109		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C5 PFPeA	122		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C3 PFBS	113		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C3 PFHxS	111		50 - 200			07/01/26 15:27	07/02/26 10:10	1
13C8 PFOS	108		50 - 200			07/01/26 15:27	07/02/26 10:10	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-222190-1

Date Collected: 06/29/26 11:15

Matrix: Water

Date Received: 06/30/26 10:18

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2-4:2-FTS	115		50 - 200	07/01/26 15:27	07/02/26 10:10	1
13C2-6:2-FTS	106		50 - 200	07/01/26 15:27	07/02/26 10:10	1
13C2-8:2-FTS	100		50 - 200	07/01/26 15:27	07/02/26 10:10	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorooctanoic acid (PFOA)	4.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorohexanesulfonic acid (PFHxS)	10		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Perfluorotridecanoic acid (PFTDA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:19	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	109		70 - 130			07/01/26 10:35	07/02/26 12:19	1
13C2 PFHxA	102		70 - 130			07/01/26 10:35	07/02/26 12:19	1
13C2 PFDA	102		70 - 130			07/01/26 10:35	07/02/26 12:19	1
13C3-GenX	106		70 - 130			07/01/26 10:35	07/02/26 12:19	1

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-222190-2

Date Collected: 06/29/26 11:15

Matrix: Water

Date Received: 06/30/26 10:18

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-222190-2

Date Collected: 06/29/26 11:15

Matrix: Water

Date Received: 06/30/26 10:18

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		07/01/26 15:27	07/02/26 10:20	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	105		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C6 PFDA	105		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C5 PFHxA	107		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C4 PFHpA	106		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C8 PFOA	109		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C9 PFNA	104		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C7 PFUnA	105		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C2 PFDoA	106		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C4 PFBA	110		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C5 PFPeA	110		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C3 PFBS	112		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C3 PFHxS	115		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C8 PFOS	110		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C2-4:2-FTS	110		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C2-6:2-FTS	106		50 - 200	07/01/26 15:27	07/02/26 10:20	1
13C2-8:2-FTS	102		50 - 200	07/01/26 15:27	07/02/26 10:20	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-222190-2

Date Collected: 06/29/26 11:15

Matrix: Water

Date Received: 06/30/26 10:18

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/01/26 10:35	07/02/26 12:28	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	104		70 - 130			07/01/26 10:35	07/02/26 12:28	1
13C2 PFHxA	112		70 - 130			07/01/26 10:35	07/02/26 12:28	1
13C2 PFDA	104		70 - 130			07/01/26 10:35	07/02/26 12:28	1
13C3-GenX	98		70 - 130			07/01/26 10:35	07/02/26 12:28	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-222190-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	9.3		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	3.9		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	10		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-222190-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-222190-1	BWS2254-D2-AQ	109	102	102	106
380-222190-2	BWS2254-D2-FB	104	112	104	98
380-222286-AP-1-A MSD	Matrix Spike Duplicate	104	115	109	110
380-222286-AQ-1-A MS	Matrix Spike	109	112	106	110
LCS 380-237246/21-A	Lab Control Sample	97	105	106	102
MBL 380-237246/19-A	Method Blank	94	99	95	86
MRL 380-237246/20-A	Lab Control Sample	104	112	103	97

Surrogate Legend

d5NEFOS = d5-NEtFOSAA

PFHxA = 13C2 PFHxA

PFDA = 13C2 PFDA

GenX = 13C3-GenX

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-222190-1	BWS2254-D2-AQ	111	104	108	110	106	103	102	107
380-222190-2	BWS2254-D2-FB	105	105	107	106	109	104	105	106
380-222217-A-1-B MS	Matrix Spike	108	103	106	106	110	106	107	106
380-222217-A-1-C MSD	Matrix Spike Duplicate	110	103	109	110	107	109	108	111
LCS 380-237352/22-A	Lab Control Sample	94	90	96	95	95	92	95	96
MBL 380-237352/20-A	Method Blank	105	92	114	107	103	99	92	89
MRL 380-237352/21-A	Lab Control Sample	90	86	95	96	96	94	90	94

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-222190-1	BWS2254-D2-AQ	109	122	113	111	108	115	106	100
380-222190-2	BWS2254-D2-FB	110	110	112	115	110	110	106	102
380-222217-A-1-B MS	Matrix Spike	111	111	104	108	104	99	97	96
380-222217-A-1-C MSD	Matrix Spike Duplicate	111	105	109	107	107	99	98	96
LCS 380-237352/22-A	Lab Control Sample	96	90	104	106	105	102	101	94
MBL 380-237352/20-A	Method Blank	113	112	122	118	113	121	119	105
MRL 380-237352/21-A	Lab Control Sample	92	89	111	117	111	112	108	102

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA
13C5PHA = 13C5 PFHxA
C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDaA = 13C2 PFDaA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-237352/20-A
Matrix: Water
Analysis Batch: 237467

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 237352

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<0.29		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluorobutanoic acid (PFBA)	<0.68		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.37		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.36		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.47		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.46		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.24		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.45		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluoropentanoic acid (PFPeA)	<0.37		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.35		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1
Perfluoropentanesulfonic acid (PFPeS)	<0.38		2.0	ng/L		07/01/26 15:27	07/02/26 07:21	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	105		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C6 PFDA	92		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C5 PFHxA	114		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C4 PFHpA	107		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C8 PFOA	103		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C9 PFNA	99		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C7 PFUnA	92		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C2 PFDoA	89		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C4 PFBA	113		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C5 PFPeA	112		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C3 PFBS	122		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C3 PFHxS	118		50 - 200	07/01/26 15:27	07/02/26 07:21	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-237352/20-A

Matrix: Water

Analysis Batch: 237467

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 237352

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	113		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C2-4:2-FTS	121		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C2-6:2-FTS	119		50 - 200	07/01/26 15:27	07/02/26 07:21	1
13C2-8:2-FTS	105		50 - 200	07/01/26 15:27	07/02/26 07:21	1

Lab Sample ID: LCS 380-237352/22-A

Matrix: Water

Analysis Batch: 237467

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 237352

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	59.1	54.1		ng/L		92	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	59.1	54.4		ng/L		92	70 - 130
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	59.1	54.7		ng/L		93	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	59.1	56.1		ng/L		95	70 - 130
Perfluorobutanesulfonic acid (PFBS)	59.1	58.1		ng/L		98	70 - 130
Perfluorodecanoic acid (PFDA)	59.1	60.4		ng/L		102	70 - 130
Perfluorododecanoic acid (PFDoA)	59.1	54.6		ng/L		92	70 - 130
Perfluoroheptanoic acid (PFHpA)	59.1	59.2		ng/L		100	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	59.1	56.8		ng/L		96	70 - 130
Perfluorohexanoic acid (PFHxA)	59.1	58.8		ng/L		100	70 - 130
Perfluorononanoic acid (PFNA)	59.1	59.1		ng/L		100	70 - 130
Perfluorooctanesulfonic acid (PFOS)	59.1	57.7		ng/L		98	70 - 130
Perfluorooctanoic acid (PFOA)	59.1	58.5		ng/L		99	70 - 130
Perfluoroundecanoic acid (PFUnA)	59.1	55.6		ng/L		94	70 - 130
Perfluorobutanoic acid (PFBA)	59.1	54.5		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	59.1	58.3		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	59.1	55.7		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	59.1	58.0		ng/L		98	70 - 130
Nonfluoro-3,6-dioxahexanoic acid (NFDHA)	59.1	55.1		ng/L		93	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	59.1	59.6		ng/L		101	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	59.1	57.9		ng/L		98	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	59.1	57.2		ng/L		97	70 - 130
Perfluoropentanoic acid (PFPeA)	59.1	58.3		ng/L		99	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	59.1	61.3		ng/L		104	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-237352/22-A

Matrix: Water

Analysis Batch: 237467

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 237352

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	59.1	55.8		ng/L		94	70 - 130
		LCS	LCS				
		%Recovery	Qualifier	Limits			
13C3 HFPO-DA		94		50 - 200			
13C6 PFDA		90		50 - 200			
13C5 PFHxA		96		50 - 200			
13C4 PFHpA		95		50 - 200			
13C8 PFOA		95		50 - 200			
13C9 PFNA		92		50 - 200			
13C7 PFUnA		95		50 - 200			
13C2 PFDoA		96		50 - 200			
13C4 PFBA		96		50 - 200			
13C5 PFPeA		90		50 - 200			
13C3 PFBS		104		50 - 200			
13C3 PFHxS		106		50 - 200			
13C8 PFOS		105		50 - 200			
13C2-4:2-FTS		102		50 - 200			
13C2-6:2-FTS		101		50 - 200			
13C2-8:2-FTS		94		50 - 200			

Lab Sample ID: MRL 380-237352/21-A

Matrix: Water

Analysis Batch: 237467

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 237352

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.97	2.01	J	ng/L		102	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.97	1.90	J	ng/L		97	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.97	1.93	J	ng/L		98	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	1.97	2.08	J	ng/L		106	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.97	1.99	J	ng/L		101	50 - 150
Perfluorodecanoic acid (PFDA)	1.97	2.32	J	ng/L		118	50 - 150
Perfluorododecanoic acid (PFDoA)	1.97	1.99	J	ng/L		101	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.97	2.05	J	ng/L		104	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.97	1.98	J	ng/L		100	50 - 150
Perfluorohexanoic acid (PFHxA)	1.97	1.96	J	ng/L		100	50 - 150
Perfluorononanoic acid (PFNA)	1.97	2.01	J	ng/L		102	50 - 150
Perfluorooctanesulfonic acid (PFOS)	1.97	2.06	J	ng/L		105	50 - 150
Perfluorooctanoic acid (PFOA)	1.97	1.98	J	ng/L		101	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.97	2.09	J	ng/L		106	50 - 150
Perfluorobutanoic acid (PFBA)	1.97	2.10	J	ng/L		107	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-237352/21-A

Matrix: Water

Analysis Batch: 237467

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 237352

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	1.97	2.09	J	ng/L		106	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	1.97	1.93	J	ng/L		98	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	1.97	2.37	J	ng/L		120	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	1.97	2.00	J	ng/L		102	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	1.97	2.05	J	ng/L		104	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	1.97	1.93	J	ng/L		98	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	1.97	1.95	J	ng/L		99	50 - 150
Perfluoropentanoic acid (PFPeA)	1.97	1.95	J	ng/L		99	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	1.97	2.16	J	ng/L		110	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	1.97	2.01	J	ng/L		102	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	Limits
13C3 HFPO-DA	90		50 - 200
13C6 PFDA	86		50 - 200
13C5 PFHxA	95		50 - 200
13C4 PFHpA	96		50 - 200
13C8 PFOA	96		50 - 200
13C9 PFNA	94		50 - 200
13C7 PFUnA	90		50 - 200
13C2 PFDoA	94		50 - 200
13C4 PFBA	92		50 - 200
13C5 PFPeA	89		50 - 200
13C3 PFBS	111		50 - 200
13C3 PFHxS	117		50 - 200
13C8 PFOS	111		50 - 200
13C2-4:2-FTS	112		50 - 200
13C2-6:2-FTS	108		50 - 200
13C2-8:2-FTS	102		50 - 200

Lab Sample ID: 380-222217-A-1-B MS

Matrix: Water

Analysis Batch: 237467

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 237352

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		59.1	56.5		ng/L		96	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		59.1	56.8		ng/L		96	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		59.1	58.3		ng/L		99	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-222217-A-1-B MS

Matrix: Water

Analysis Batch: 237467

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 237352

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		59.1	58.0		ng/L		98	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		59.1	56.2		ng/L		95	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		59.1	56.5		ng/L		96	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		59.1	55.9		ng/L		95	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		59.1	59.4		ng/L		101	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		59.1	55.4		ng/L		94	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		59.1	57.9		ng/L		98	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		59.1	55.4		ng/L		94	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		59.1	57.3		ng/L		97	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		59.1	55.4		ng/L		94	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		59.1	54.6		ng/L		93	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		59.1	54.3		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		59.1	54.9		ng/L		93	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		59.1	57.9		ng/L		98	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		59.1	58.4		ng/L		99	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		59.1	57.8		ng/L		98	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		59.1	55.5		ng/L		94	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		59.1	53.8		ng/L		91	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		59.1	53.4		ng/L		90	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		59.1	55.1		ng/L		93	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		59.1	59.5		ng/L		101	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		59.1	56.7		ng/L		96	70 - 130

Isotope Dilution	MS %Recovery	MS Qualifier	Limits
13C3 HFPO-DA	108		50 - 200
13C6 PFDA	103		50 - 200
13C5 PFHxA	106		50 - 200
13C4 PFHpA	106		50 - 200
13C8 PFOA	110		50 - 200
13C9 PFNA	106		50 - 200
13C7 PFUnA	107		50 - 200
13C2 PFDoA	106		50 - 200
13C4 PFBA	111		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	104		50 - 200
13C3 PFHxS	108		50 - 200
13C8 PFOS	104		50 - 200

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-222217-A-1-B MS

Matrix: Water

Analysis Batch: 237467

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 237352

Isotope Dilution	MS %Recovery	MS Qualifier	Limits
13C2-4:2-FTS	99		50 - 200
13C2-6:2-FTS	97		50 - 200
13C2-8:2-FTS	96		50 - 200

Lab Sample ID: 380-222217-A-1-C MSD

Matrix: Water

Analysis Batch: 237467

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 237352

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		58.9	54.2		ng/L		92	70 - 130	4	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		58.9	55.2		ng/L		94	70 - 130	3	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		58.9	57.8		ng/L		98	70 - 130	1	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		58.9	55.2		ng/L		94	70 - 130	5	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		58.9	51.7		ng/L		88	70 - 130	8	30
Perfluorodecanoic acid (PFDA)	<2.0		58.9	61.0		ng/L		103	70 - 130	8	30
Perfluorododecanoic acid (PFDoA)	<2.0		58.9	53.5		ng/L		91	70 - 130	5	30
Perfluoroheptanoic acid (PFHpA)	<2.0		58.9	55.8		ng/L		95	70 - 130	6	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		58.9	57.4		ng/L		97	70 - 130	3	30
Perfluorohexanoic acid (PFHxA)	<2.0		58.9	55.9		ng/L		95	70 - 130	3	30
Perfluorononanoic acid (PFNA)	<2.0		58.9	57.0		ng/L		97	70 - 130	3	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		58.9	57.8		ng/L		98	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	<2.0		58.9	55.6		ng/L		94	70 - 130	0	30
Perfluoroundecanoic acid (PFUnA)	<2.0		58.9	55.4		ng/L		94	70 - 130	1	30
Perfluorobutanoic acid (PFBA)	<2.0		58.9	53.8		ng/L		91	70 - 130	1	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		58.9	56.5		ng/L		96	70 - 130	3	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		58.9	57.1		ng/L		97	70 - 130	1	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		58.9	55.3		ng/L		94	70 - 130	6	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		58.9	60.2		ng/L		102	70 - 130	4	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		58.9	57.5		ng/L		98	70 - 130	4	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		58.9	55.7		ng/L		94	70 - 130	3	30
Perfluoro-4-methoxybutanoic acid (PFMPBA)	<2.0		58.9	58.5		ng/L		99	70 - 130	9	30
Perfluoropentanoic acid (PFPeA)	<2.0		58.9	57.9		ng/L		98	70 - 130	5	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		58.9	59.7		ng/L		101	70 - 130	0	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		58.9	55.7		ng/L		95	70 - 130	2	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	110		50 - 200
13C6 PFDA	103		50 - 200
13C5 PFHxA	109		50 - 200
13C4 PFHpA	110		50 - 200
13C8 PFOA	107		50 - 200
13C9 PFNA	109		50 - 200
13C7 PFUnA	108		50 - 200
13C2 PFDoA	111		50 - 200
13C4 PFBA	111		50 - 200
13C5 PFPeA	105		50 - 200
13C3 PFBS	109		50 - 200
13C3 PFHxS	107		50 - 200
13C8 PFOS	107		50 - 200
13C2-4:2-FTS	99		50 - 200
13C2-6:2-FTS	98		50 - 200
13C2-8:2-FTS	96		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-237246/19-A
Matrix: Water
Analysis Batch: 237538

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 237246

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.99		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.57		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.41		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorotetradecanoic acid (PFTA)	<0.53		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Perfluorotridecanoic acid (PFTTrDA)	<0.36		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<0.30		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		07/01/26 10:35	07/02/26 11:12	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	94		70 - 130			07/01/26 10:35	07/02/26 11:12	1
13C2 PFHxA	99		70 - 130			07/01/26 10:35	07/02/26 11:12	1
13C2 PFDA	95		70 - 130			07/01/26 10:35	07/02/26 11:12	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-237246/19-A

Matrix: Water

Analysis Batch: 237538

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 237246

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	86		70 - 130	07/01/26 10:35	07/02/26 11:12	1

Lab Sample ID: LCS 380-237246/21-A

Matrix: Water

Analysis Batch: 237538

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 237246

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	49.2	43.1		ng/L		88	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	49.2	51.9		ng/L		105	70 - 130
Perfluoroundecanoic acid (PFUnA)	49.2	47.8		ng/L		97	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	49.2	47.2		ng/L		96	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	49.2	44.8		ng/L		91	70 - 130
Perfluorohexanoic acid (PFHxA)	49.2	45.0		ng/L		92	70 - 130
Perfluorododecanoic acid (PFDoA)	49.2	47.9		ng/L		97	70 - 130
Perfluorooctanoic acid (PFOA)	49.2	50.7		ng/L		103	70 - 130
Perfluorodecanoic acid (PFDA)	49.2	49.3		ng/L		100	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	49.2	51.8		ng/L		105	70 - 130
Perfluorobutanesulfonic acid (PFBS)	49.2	50.1		ng/L		102	70 - 130
Perfluoroheptanoic acid (PFHpA)	49.2	47.9		ng/L		97	70 - 130
Perfluorononanoic acid (PFNA)	49.2	50.9		ng/L		103	70 - 130
Perfluorotetradecanoic acid (PFTA)	49.2	46.2		ng/L		94	70 - 130
Perfluorotridecanoic acid (PFTrDA)	49.2	48.5		ng/L		99	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	49.2	50.8		ng/L		103	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	49.2	50.7		ng/L		103	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	49.2	46.7		ng/L		95	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	97		70 - 130
13C2 PFHxA	105		70 - 130
13C2 PFDA	106		70 - 130
13C3-GenX	102		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-237246/20-A

Matrix: Water

Analysis Batch: 237538

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 237246

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	1.97	1.78	J	ng/L		90	50 - 150
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	1.97	2.16	J	ng/L		110	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.97	2.04	J	ng/L		104	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	1.97	2.04	J	ng/L		103	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	1.97	2.18	J	ng/L		111	50 - 150
Perfluorohexanoic acid (PFHxA)	1.97	2.09	J	ng/L		106	50 - 150
Perfluorododecanoic acid (PFDoA)	1.97	1.97	J	ng/L		100	50 - 150
Perfluorooctanoic acid (PFOA)	1.97	2.06	J	ng/L		105	50 - 150
Perfluorodecanoic acid (PFDA)	1.97	1.99	J	ng/L		101	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.97	2.17	J	ng/L		110	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.97	1.98	J	ng/L		101	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.97	2.15	J	ng/L		109	50 - 150
Perfluorononanoic acid (PFNA)	1.97	2.19	J	ng/L		111	50 - 150
Perfluorotetradecanoic acid (PFTA)	1.97	1.93	J	ng/L		98	50 - 150
Perfluorotridecanoic acid (PFTrDA)	1.97	2.03	J	ng/L		103	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.97	2.15	J	ng/L		109	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.97	1.93	J	ng/L		98	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.97	2.03	J	ng/L		103	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	104		70 - 130
13C2 PFHxA	112		70 - 130
13C2 PFDA	103		70 - 130
13C3-GenX	97		70 - 130

Lab Sample ID: 380-222286-AP-1-A MSD

Matrix: Water

Analysis Batch: 237538

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 237246

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide	<2.0		24.7	24.9		ng/L		101	70 - 130	2	30
Dimer Acid (HFPO-DA/GenX)											
Perfluorooctanesulfonic acid (PFOS)	<2.0		24.7	26.8		ng/L		109	70 - 130	2	30
Perfluoroundecanoic acid (PFUnA)	<2.0		24.7	24.9		ng/L		101	70 - 130	1	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.7	26.1		ng/L		106	70 - 130	1	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-222286-AP-1-A MSD

Matrix: Water

Analysis Batch: 237538

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 237246

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.7	25.5		ng/L		103	70 - 130	0	30
Perfluorohexanoic acid (PFHxA)	<2.0		24.7	25.7		ng/L		104	70 - 130	3	30
Perfluorododecanoic acid (PFDoA)	<2.0		24.7	25.1		ng/L		102	70 - 130	4	30
Perfluorooctanoic acid (PFOA)	<2.0		24.7	26.2		ng/L		106	70 - 130	3	30
Perfluorodecanoic acid (PFDA)	<2.0		24.7	25.4		ng/L		103	70 - 130	1	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		24.7	27.3		ng/L		111	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		24.7	26.9		ng/L		109	70 - 130	7	30
Perfluoroheptanoic acid (PFHpA)	<2.0		24.7	25.5		ng/L		104	70 - 130	4	30
Perfluorononanoic acid (PFNA)	<2.0		24.7	26.4		ng/L		107	70 - 130	0	30
Perfluorotetradecanoic acid (PFTA)	<2.0		24.7	24.9		ng/L		101	70 - 130	6	30
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.7	25.7		ng/L		104	70 - 130	2	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.7	26.8		ng/L		109	70 - 130	3	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.7	25.6		ng/L		104	70 - 130	3	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.7	25.9		ng/L		105	70 - 130	0	30
Surrogate	MSD %Recovery	MSD Qualifier	MSD Limits								
d5-NEtFOSAA	104		70 - 130								
13C2 PFHxA	115		70 - 130								
13C2 PFDA	109		70 - 130								
13C3-GenX	110		70 - 130								

Lab Sample ID: 380-222286-AQ-1-A MS

Matrix: Water

Analysis Batch: 237538

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 237246

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		24.7	24.4		ng/L		99	70 - 130		
Perfluorooctanesulfonic acid (PFOS)	<2.0		24.7	26.2		ng/L		106	70 - 130		
Perfluoroundecanoic acid (PFUnA)	<2.0		24.7	25.2		ng/L		102	70 - 130		
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.7	26.3		ng/L		106	70 - 130		
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.7	25.6		ng/L		104	70 - 130		
Perfluorohexanoic acid (PFHxA)	<2.0		24.7	26.6		ng/L		107	70 - 130		
Perfluorododecanoic acid (PFDoA)	<2.0		24.7	24.1		ng/L		98	70 - 130		
Perfluorooctanoic acid (PFOA)	<2.0		24.7	25.4		ng/L		103	70 - 130		
Perfluorodecanoic acid (PFDA)	<2.0		24.7	25.0		ng/L		101	70 - 130		

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-222286-AQ-1-A MS

Matrix: Water

Analysis Batch: 237538

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 237246

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluorohexanesulfonic acid (PFHxS)	<2.0		24.7	27.5		ng/L		111	70 - 130
Perfluorobutanesulfonic acid (PFBS)	<2.0		24.7	25.1		ng/L		102	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		24.7	26.5		ng/L		107	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		24.7	26.5		ng/L		107	70 - 130
Perfluorotetradecanoic acid (PFTA)	<2.0		24.7	23.4		ng/L		95	70 - 130
Perfluorotridecanoic acid (PFTTrDA)	<2.0		24.7	25.3		ng/L		102	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.7	26.0		ng/L		105	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.7	25.0		ng/L		101	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.7	26.0		ng/L		105	70 - 130
Surrogate	MS %Recovery	MS Qualifier	Limits						
d5-NEtFOSAA	109		70 - 130						
13C2 PFHxA	112		70 - 130						
13C2 PFDA	106		70 - 130						
13C3-GenX	110		70 - 130						

QC Association Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

LCMS

Prep Batch: 237246

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-222190-1	BWS2254-D2-AQ	Total/NA	Water	537.1 DW	
380-222190-2	BWS2254-D2-FB	Total/NA	Water	537.1 DW	
MBL 380-237246/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-237246/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-237246/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-222286-AP-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	
380-222286-AQ-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	

Prep Batch: 237352

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-222190-1	BWS2254-D2-AQ	Total/NA	Water	533	
380-222190-2	BWS2254-D2-FB	Total/NA	Water	533	
MBL 380-237352/20-A	Method Blank	Total/NA	Water	533	
LCS 380-237352/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-237352/21-A	Lab Control Sample	Total/NA	Water	533	
380-222217-A-1-B MS	Matrix Spike	Total/NA	Water	533	
380-222217-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 237467

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-222190-1	BWS2254-D2-AQ	Total/NA	Water	533	237352
380-222190-2	BWS2254-D2-FB	Total/NA	Water	533	237352
MBL 380-237352/20-A	Method Blank	Total/NA	Water	533	237352
LCS 380-237352/22-A	Lab Control Sample	Total/NA	Water	533	237352
MRL 380-237352/21-A	Lab Control Sample	Total/NA	Water	533	237352
380-222217-A-1-B MS	Matrix Spike	Total/NA	Water	533	237352
380-222217-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	533	237352

Analysis Batch: 237538

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-222190-1	BWS2254-D2-AQ	Total/NA	Water	EPA 537.1 V2	237246
380-222190-2	BWS2254-D2-FB	Total/NA	Water	EPA 537.1 V2	237246
MBL 380-237246/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	237246
LCS 380-237246/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	237246
MRL 380-237246/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	237246
380-222286-AP-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	237246
380-222286-AQ-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	237246

Lab Chronicle

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-222190-1

Date Collected: 06/29/26 11:15

Matrix: Water

Date Received: 06/30/26 10:18

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			237352	E2HD	EA POM	07/01/26 15:27
Total/NA	Analysis	533		1	237467	SZ9R	EA POM	07/02/26 10:10
Total/NA	Prep	537.1 DW			237246	LM3A	EA POM	07/01/26 10:35
Total/NA	Analysis	EPA 537.1 V2		1	237538	M7ML	EA POM	07/02/26 12:19

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-222190-2

Date Collected: 06/29/26 11:15

Matrix: Water

Date Received: 06/30/26 10:18

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			237352	E2HD	EA POM	07/01/26 15:27
Total/NA	Analysis	533		1	237467	SZ9R	EA POM	07/02/26 10:20
Total/NA	Prep	537.1 DW			237246	LM3A	EA POM	07/01/26 10:35
Total/NA	Analysis	EPA 537.1 V2		1	237538	M7ML	EA POM	07/02/26 12:28

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Sample Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-222190-1
SDG: Site D2 PFAS 533/537.1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-222190-1	BWS2254-D2-AQ	Water	06/29/26 11:15	06/30/26 10:18	Hawaii
380-222190-2	BWS2254-D2-FB	Water	06/29/26 11:15	06/30/26 10:18	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Environment Testing

[illegible]

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-222190-1
SDG Number: Site D2 PFAS 533/537.1

Login Number: 222190

List Number: 1

Creator: Del Rosario, Michael

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	