

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 6/21/2026 2:58:12 PM

JOB DESCRIPTION

INTERA - Red-Hill-Incident
Site D2 PFAS 533/537.1

JOB NUMBER

380-219978-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
6/21/2026 2:58:12 PM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	14
QC Association Summary	25
Lab Chronicle	26
Certification Summary	27
Method Summary	28
Sample Summary	29
Chain of Custody	30
Receipt Checklists	31



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Qualifiers

LCMS

Qualifier	Qualifier Description
*5-	Isotope dilution analyte is outside acceptance limits, low biased.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: INTERA - Red-Hill-Incident

Job ID: 380-219978-1

Job ID: 380-219978-1

Eurofins Pomona

Job Narrative 380-219978-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 6/16/2026 9:38 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 1.8°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-219978-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanesulfonic acid (PFHxS)	9.4		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	4.2		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	9.6		2.0	ng/L	1		EPA 537.1 V2	Total/NA

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-219978-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-219978-1

Date Collected: 06/15/26 12:00

Matrix: Water

Date Received: 06/16/26 09:38

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9CI-PF3ONS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluorohexanesulfonic acid (PFHxS)	9.4		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluorooctanoic acid (PFOA)	4.2		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 08:50	1
Isotope Dilution	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	81		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C6 PFDA	71		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C5 PFHxA	85		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C4 PFHpA	87		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C8 PFOA	85		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C9 PFNA	85		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C7 PFUnA	77		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C2 PFDoA	79		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C4 PFBA	96		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C5 PFPeA	97		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C3 PFBS	100		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C3 PFHxS	102		50 - 200			06/18/26 15:27	06/19/26 08:50	1
13C8 PFOS	107		50 - 200			06/18/26 15:27	06/19/26 08:50	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-219978-1

Date Collected: 06/15/26 12:00

Matrix: Water

Date Received: 06/16/26 09:38

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2-4:2-FTS	116		50 - 200	06/18/26 15:27	06/19/26 08:50	1
13C2-6:2-FTS	114		50 - 200	06/18/26 15:27	06/19/26 08:50	1
13C2-8:2-FTS	113		50 - 200	06/18/26 15:27	06/19/26 08:50	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorooctanoic acid (PFOA)	4.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorohexanesulfonic acid (PFHxS)	9.6		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Perfluorotridecanoic acid (PFTDA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 20:01	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	106		70 - 130			06/19/26 07:14	06/19/26 20:01	1
13C2 PFHxA	108		70 - 130			06/19/26 07:14	06/19/26 20:01	1
13C2 PFDA	105		70 - 130			06/19/26 07:14	06/19/26 20:01	1
13C3-GenX	104		70 - 130			06/19/26 07:14	06/19/26 20:01	1

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-219978-2

Date Collected: 06/15/26 12:00

Matrix: Water

Date Received: 06/16/26 09:38

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-219978-2

Date Collected: 06/15/26 12:00

Matrix: Water

Date Received: 06/16/26 09:38

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/18/26 15:27	06/19/26 09:10	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	97		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C6 PFDA	95		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C5 PFHxA	101		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C4 PFHpA	102		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C8 PFOA	105		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C9 PFNA	107		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C7 PFUnA	101		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C2 PFDoA	98		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C4 PFBA	106		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C5 PFPeA	104		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C3 PFBS	99		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C3 PFHxS	103		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C8 PFOS	107		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C2-4:2-FTS	105		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C2-6:2-FTS	117		50 - 200	06/18/26 15:27	06/19/26 09:10	1
13C2-8:2-FTS	115		50 - 200	06/18/26 15:27	06/19/26 09:10	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-219978-2

Date Collected: 06/15/26 12:00

Matrix: Water

Date Received: 06/16/26 09:38

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/19/26 07:14	06/19/26 21:07	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	101		70 - 130			06/19/26 07:14	06/19/26 21:07	1
13C2 PFHxA	105		70 - 130			06/19/26 07:14	06/19/26 21:07	1
13C2 PFDA	105		70 - 130			06/19/26 07:14	06/19/26 21:07	1
13C3-GenX	92		70 - 130			06/19/26 07:14	06/19/26 21:07	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-219978-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	9.4		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	4.2		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	9.6		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-219978-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-219978-1	BWS2254-D2-AQ	106	108	105	104
380-219978-1 MS	BWS2254-D2-AQ	102	107	102	104
380-219978-1 MSD	BWS2254-D2-AQ	97	110	108	104
380-219978-2	BWS2254-D2-FB	101	105	105	92
LCS 380-234953/23-A	Lab Control Sample	95	104	102	100
MBL 380-234953/21-A	Method Blank	101	100	107	100
MRL 380-234953/22-A	Lab Control Sample	95	95	96	89

Surrogate Legend

d5NEFOS = d5-NEtFOSAA

PFHxA = 13C2 PFHxA

PFDA = 13C2 PFDA

GenX = 13C3-GenX

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-219952-B-3-A MSD	Matrix Spike Duplicate	47 *5-	69	52	56	60	68	84	86
380-219952-C-3-A MS	Matrix Spike	45 *5-	20 *5-	45 *5-	45 *5-	41 *5-	35 *5-	18 *5-	30 *5-
380-219978-1	BWS2254-D2-AQ	81	71	85	87	85	85	77	79
380-219978-2	BWS2254-D2-FB	97	95	101	102	105	107	101	98
LCS 380-234816/22-A	Lab Control Sample	102	98	99	100	102	107	109	105
MBL 380-234816/20-A	Method Blank	94	92	104	98	106	108	103	99
MRL 380-234816/21-A	Lab Control Sample	84	88	93	89	94	99	95	94

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-219952-B-3-A MSD	Matrix Spike Duplicate	55	49 *5-	103	108	109	107	117	117
380-219952-C-3-A MS	Matrix Spike	39 *5-	41 *5-	101	106	109	104	110	119
380-219978-1	BWS2254-D2-AQ	96	97	100	102	107	116	114	113
380-219978-2	BWS2254-D2-FB	106	104	99	103	107	105	117	115
LCS 380-234816/22-A	Lab Control Sample	99	91	101	101	107	94	102	106
MBL 380-234816/20-A	Method Blank	102	98	104	104	110	113	120	114
MRL 380-234816/21-A	Lab Control Sample	94	92	101	101	109	109	113	109

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA
13C5PHA = 13C5 PFHxA
C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDaA = 13C2 PFDaA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-234816/20-A

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 234816

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.48		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.25		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		06/18/26 15:27	06/19/26 06:36	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	94		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C6 PFDA	92		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C5 PFHxA	104		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C4 PFHpA	98		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C8 PFOA	106		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C9 PFNA	108		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C7 PFUnA	103		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C2 PFDoA	99		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C4 PFBA	102		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C5 PFPeA	98		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C3 PFBS	104		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C3 PFHxS	104		50 - 200	06/18/26 15:27	06/19/26 06:36	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-234816/20-A

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 234816

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	110		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C2-4:2-FTS	113		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C2-6:2-FTS	120		50 - 200	06/18/26 15:27	06/19/26 06:36	1
13C2-8:2-FTS	114		50 - 200	06/18/26 15:27	06/19/26 06:36	1

Lab Sample ID: LCS 380-234816/22-A

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 234816

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	120	107		ng/L		89	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	120	108		ng/L		90	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	120	114		ng/L		95	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	120	109		ng/L		91	70 - 130
Perfluorobutanesulfonic acid (PFBS)	120	111		ng/L		92	70 - 130
Perfluorodecanoic acid (PFDA)	120	121		ng/L		101	70 - 130
Perfluorododecanoic acid (PFDoA)	120	111		ng/L		92	70 - 130
Perfluoroheptanoic acid (PFHpA)	120	114		ng/L		95	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	120	116		ng/L		96	70 - 130
Perfluorohexanoic acid (PFHxA)	120	113		ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	120	111		ng/L		92	70 - 130
Perfluorooctanesulfonic acid (PFOS)	120	112		ng/L		93	70 - 130
Perfluorooctanoic acid (PFOA)	120	116		ng/L		96	70 - 130
Perfluoroundecanoic acid (PFUnA)	120	111		ng/L		92	70 - 130
Perfluorobutanoic acid (PFBA)	120	115		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	120	113		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	120	114		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	120	115		ng/L		96	70 - 130
Nonfluoro-3,6-dioxaheptanoic acid (NFDHA)	120	112		ng/L		93	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	120	114		ng/L		94	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	120	122		ng/L		102	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	120	121		ng/L		100	70 - 130
Perfluoropentanoic acid (PFPeA)	120	126		ng/L		104	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	120	108		ng/L		90	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-234816/22-A

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 234816

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	120	113		ng/L		94	70 - 130
	LCS	LCS					
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	102		50 - 200				
13C6 PFDA	98		50 - 200				
13C5 PFHxA	99		50 - 200				
13C4 PFHpA	100		50 - 200				
13C8 PFOA	102		50 - 200				
13C9 PFNA	107		50 - 200				
13C7 PFUnA	109		50 - 200				
13C2 PFDoA	105		50 - 200				
13C4 PFBA	99		50 - 200				
13C5 PFPeA	91		50 - 200				
13C3 PFBS	101		50 - 200				
13C3 PFHxS	101		50 - 200				
13C8 PFOS	107		50 - 200				
13C2-4:2-FTS	94		50 - 200				
13C2-6:2-FTS	102		50 - 200				
13C2-8:2-FTS	106		50 - 200				

Lab Sample ID: MRL 380-234816/21-A

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 234816

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.85	J	ng/L		92	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	1.93	J	ng/L		96	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.88	J	ng/L		94	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	1.97	J	ng/L		98	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	1.95	J	ng/L		97	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.05	J	ng/L		102	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	2.00	J	ng/L		99	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	2.03	J	ng/L		101	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	2.11	J	ng/L		105	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	1.94	J	ng/L		96	50 - 150
Perfluorononanoic acid (PFNA)	2.01	1.94	J	ng/L		96	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	1.98	J	ng/L		99	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	2.10	J	ng/L		104	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	1.84	J	ng/L		92	50 - 150
Perfluorobutanoic acid (PFBA)	2.01	2.19	J	ng/L		109	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-234816/21-A

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 234816

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.01	2.10	J	ng/L		105	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.01	2.20	J	ng/L		110	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.01	2.06	J	ng/L		102	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.01	1.72	J	ng/L		86	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.01	2.05	J	ng/L		102	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.01	2.03	J	ng/L		101	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.01	1.95	J	ng/L		97	50 - 150
Perfluoropentanoic acid (PFPeA)	2.01	1.98	J	ng/L		99	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.01	1.92	J	ng/L		95	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.01	2.04	J	ng/L		102	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	Limits
13C3 HFPO-DA	84		50 - 200
13C6 PFDA	88		50 - 200
13C5 PFHxA	93		50 - 200
13C4 PFHpA	89		50 - 200
13C8 PFOA	94		50 - 200
13C9 PFNA	99		50 - 200
13C7 PFUnA	95		50 - 200
13C2 PFDoA	94		50 - 200
13C4 PFBA	94		50 - 200
13C5 PFPeA	92		50 - 200
13C3 PFBS	101		50 - 200
13C3 PFHxS	101		50 - 200
13C8 PFOS	109		50 - 200
13C2-4:2-FTS	109		50 - 200
13C2-6:2-FTS	113		50 - 200
13C2-8:2-FTS	109		50 - 200

Lab Sample ID: 380-219952-B-3-A MSD

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 234816

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	106		ng/L		88	70 - 130	3	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	111		ng/L		92	70 - 130	2	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0	*5-	120	99.5		ng/L		83	70 - 130	10	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-219952-B-3-A MSD

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 234816

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide	<2.0	*5-	120	115	*5-	ng/L		96	70 - 130	1	30
Dimer Acid (HFPO-DA/GenX)											
Perfluorobutanesulfonic acid (PFBS)	<2.0		120	113		ng/L		94	70 - 130	0	30
Perfluorodecanoic acid (PFDA)	<2.0	*5-	120	122		ng/L		101	70 - 130	2	30
Perfluorododecanoic acid (PFDoA)	<2.0	*5-	120	115		ng/L		95	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0	*5-	120	114		ng/L		95	70 - 130	2	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		120	112		ng/L		93	70 - 130	4	30
Perfluorohexanoic acid (PFHxA)	<2.0	*5-	120	115		ng/L		95	70 - 130	2	30
Perfluorononanoic acid (PFNA)	<2.0	*5-	120	113		ng/L		94	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		120	112		ng/L		93	70 - 130	2	30
Perfluorooctanoic acid (PFOA)	<2.0	*5-	120	120		ng/L		100	70 - 130	4	30
Perfluoroundecanoic acid (PFUnA)	<2.0	*5-	120	109		ng/L		90	70 - 130	2	30
Perfluorobutanoic acid (PFBA)	<2.0	*5-	120	111		ng/L		92	70 - 130	6	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	113		ng/L		94	70 - 130	4	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	117		ng/L		97	70 - 130	6	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	115		ng/L		95	70 - 130	4	30
Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	<2.0	*5-	120	101		ng/L		84	70 - 130	2	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		120	117		ng/L		97	70 - 130	4	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0	*5-	120	119		ng/L		98	70 - 130	12	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0	*5-	120	114	*5-	ng/L		95	70 - 130	1	30
Perfluoropentanoic acid (PFPeA)	<2.0	*5-	120	117	*5-	ng/L		97	70 - 130	3	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	112		ng/L		93	70 - 130	3	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	110		ng/L		91	70 - 130	3	30

Isotope Dilution	MSD %Recovery	MSD Qualifier	Limits
13C3 HFPO-DA	47	*5-	50 - 200
13C6 PFDA	69		50 - 200
13C5 PFHxA	52		50 - 200
13C4 PFHpA	56		50 - 200
13C8 PFOA	60		50 - 200
13C9 PFNA	68		50 - 200
13C7 PFUnA	84		50 - 200
13C2 PFDoA	86		50 - 200
13C4 PFBA	55		50 - 200
13C5 PFPeA	49	*5-	50 - 200
13C3 PFBS	103		50 - 200
13C3 PFHxS	108		50 - 200
13C8 PFOS	109		50 - 200

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-219952-B-3-A MSD

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 234816

Isotope Dilution	MSD %Recovery	MSD Qualifier	Limits
13C2-4:2-FTS	107		50 - 200
13C2-6:2-FTS	117		50 - 200
13C2-8:2-FTS	117		50 - 200

Lab Sample ID: 380-219952-C-3-A MS

Matrix: Water

Analysis Batch: 234948

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 234816

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	103		ng/L		85	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		120	108		ng/L		90	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0	*5-	120	110	*5-	ng/L		91	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0	*5-	120	116	*5-	ng/L		97	70 - 130
Perfluorobutanesulfonic acid (PFBS)	<2.0		120	113		ng/L		94	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0	*5-	120	124	*5-	ng/L		103	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0	*5-	120	116	*5-	ng/L		96	70 - 130
Perfluorooheptanoic acid (PFHpA)	<2.0	*5-	120	112	*5-	ng/L		93	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		120	116		ng/L		97	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0	*5-	120	113	*5-	ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	<2.0	*5-	120	115	*5-	ng/L		96	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		120	110		ng/L		92	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0	*5-	120	116	*5-	ng/L		96	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0	*5-	120	110	*5-	ng/L		92	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0	*5-	120	119	*5-	ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	109		ng/L		91	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	110		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	111		ng/L		92	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0	*5-	120	103	*5-	ng/L		86	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		120	113		ng/L		94	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0	*5-	120	106	*5-	ng/L		88	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0	*5-	120	116	*5-	ng/L		96	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0	*5-	120	113	*5-	ng/L		94	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	109		ng/L		91	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	106		ng/L		88	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	45	*5-	50 - 200
13C6 PFDA	20	*5-	50 - 200
13C5 PFHxA	45	*5-	50 - 200
13C4 PFHpA	45	*5-	50 - 200
13C8 PFOA	41	*5-	50 - 200
13C9 PFNA	35	*5-	50 - 200
13C7 PFUnA	18	*5-	50 - 200
13C2 PFDoA	30	*5-	50 - 200
13C4 PFBA	39	*5-	50 - 200
13C5 PFPeA	41	*5-	50 - 200
13C3 PFBS	101		50 - 200
13C3 PFHxS	106		50 - 200
13C8 PFOS	109		50 - 200
13C2-4:2-FTS	104		50 - 200
13C2-6:2-FTS	110		50 - 200
13C2-8:2-FTS	119		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-234953/21-A
Matrix: Water
Analysis Batch: 235108

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 234953

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Perfluorotridecanoic acid (PFTTrDA)	<0.36		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<0.30		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/19/26 07:14	06/19/26 19:31	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	101		70 - 130			06/19/26 07:14	06/19/26 19:31	1
13C2 PFHxA	100		70 - 130			06/19/26 07:14	06/19/26 19:31	1
13C2 PFDA	107		70 - 130			06/19/26 07:14	06/19/26 19:31	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-234953/21-A

Matrix: Water

Analysis Batch: 235108

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 234953

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	100		70 - 130	06/19/26 07:14	06/19/26 19:31	1

Lab Sample ID: LCS 380-234953/23-A

Matrix: Water

Analysis Batch: 235108

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 234953

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	25.1	24.2		ng/L		97	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	25.1	25.9		ng/L		103	70 - 130
Perfluoroundecanoic acid (PFUnA)	25.1	26.6		ng/L		106	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	25.1	24.9		ng/L		99	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	25.1	25.0		ng/L		100	70 - 130
Perfluorohexanoic acid (PFHxA)	25.1	26.1		ng/L		104	70 - 130
Perfluorododecanoic acid (PFDoA)	25.1	26.3		ng/L		105	70 - 130
Perfluorooctanoic acid (PFOA)	25.1	26.1		ng/L		104	70 - 130
Perfluorodecanoic acid (PFDA)	25.1	26.1		ng/L		104	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	25.1	26.4		ng/L		105	70 - 130
Perfluorobutanesulfonic acid (PFBS)	25.1	26.4		ng/L		105	70 - 130
Perfluoroheptanoic acid (PFHpA)	25.1	25.8		ng/L		103	70 - 130
Perfluorononanoic acid (PFNA)	25.1	25.5		ng/L		102	70 - 130
Perfluorotetradecanoic acid (PFTA)	25.1	24.4		ng/L		97	70 - 130
Perfluorotridecanoic acid (PFTrDA)	25.1	26.9		ng/L		107	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	25.1	26.1		ng/L		104	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	25.1	25.1		ng/L		100	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	25.1	24.7		ng/L		98	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	95		70 - 130
13C2 PFHxA	104		70 - 130
13C2 PFDA	102		70 - 130
13C3-GenX	100		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-234953/22-A

Matrix: Water

Analysis Batch: 235108

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 234953

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	2.01	1.73	J	ng/L		86	50 - 150
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	2.01	1.94	J	ng/L		96	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.12	J	ng/L		105	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.01	2.05	J	ng/L		102	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.01	2.11	J	ng/L		105	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	2.00	J	ng/L		99	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	1.97	J	ng/L		98	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	2.00	J	ng/L		99	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.05	J	ng/L		102	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	2.01	J	ng/L		100	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	2.01	J	ng/L		100	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	1.98	J	ng/L		99	50 - 150
Perfluorononanoic acid (PFNA)	2.01	1.94	J	ng/L		97	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.01	1.95	J	ng/L		97	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.01	2.26	J	ng/L		112	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	2.09	J	ng/L		104	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.97	J	ng/L		98	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.88	J	ng/L		93	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	95		70 - 130
13C2 PFHxA	95		70 - 130
13C2 PFDA	96		70 - 130
13C3-GenX	89		70 - 130

Lab Sample ID: 380-219978-1 MS

Matrix: Water

Analysis Batch: 235108

Client Sample ID: BWS2254-D2-AQ

Prep Type: Total/NA

Prep Batch: 234953

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		25.2	26.0		ng/L		104	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorooctanesulfonic acid (PFOS)	<2.0		25.2	27.2		ng/L		105	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		25.2	27.9		ng/L		111	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.2	24.7		ng/L		98	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-219978-1 MS

Matrix: Water

Analysis Batch: 235108

Client Sample ID: BWS2254-D2-AQ

Prep Type: Total/NA

Prep Batch: 234953

	Sample	Sample	Spike	MS	MS				%Rec		
Analyte	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec	Limits		
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		25.2	25.3		ng/L		101	70 - 130		
Perfluorohexanoic acid (PFHxA)	<2.0		25.2	27.7		ng/L		107	70 - 130		
Perfluorododecanoic acid (PFDoA)	<2.0		25.2	27.0		ng/L		107	70 - 130		
Perfluorooctanoic acid (PFOA)	4.0		25.2	31.2		ng/L		108	70 - 130		
Perfluorodecanoic acid (PFDA)	<2.0		25.2	25.6		ng/L		102	70 - 130		
Perfluorohexanesulfonic acid (PFHxS)	9.6		25.2	36.2		ng/L		106	70 - 130		
Perfluorobutanesulfonic acid (PFBS)	<2.0		25.2	26.2		ng/L		102	70 - 130		
Perfluoroheptanoic acid (PFHpA)	<2.0		25.2	26.9		ng/L		107	70 - 130		
Perfluorononanoic acid (PFNA)	<2.0		25.2	27.6		ng/L		110	70 - 130		
Perfluorotetradecanoic acid (PFTA)	<2.0		25.2	24.9		ng/L		99	70 - 130		
Perfluorotridecanoic acid (PFTrDA)	<2.0		25.2	28.1		ng/L		112	70 - 130		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		25.2	25.4		ng/L		101	70 - 130		
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		25.2	25.0		ng/L		99	70 - 130		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		25.2	26.8		ng/L		106	70 - 130		

Lab Sample ID: 380-219978-1 MSD

Matrix: Water

Analysis Batch: 235108

Client Sample ID: BWS2254-D2-AQ

Prep Type: Total/NA

Prep Batch: 234953

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		25.2	25.6		ng/L		102	70 - 130	2	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		25.2	25.2		ng/L		97	70 - 130	8	30
Perfluoroundecanoic acid (PFUnA)	<2.0		25.2	26.4		ng/L		105	70 - 130	6	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.2	23.3		ng/L		93	70 - 130	6	30
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		25.2	25.5		ng/L		101	70 - 130	0	30
Perfluorohexanoic acid (PFHxA)	<2.0		25.2	27.4		ng/L		106	70 - 130	1	30
Perfluorododecanoic acid (PFDoA)	<2.0		25.2	25.9		ng/L		103	70 - 130	4	30
Perfluorooctanoic acid (PFOA)	4.0		25.2	30.1		ng/L		104	70 - 130	4	30
Perfluorodecanoic acid (PFDA)	<2.0		25.2	24.9		ng/L		99	70 - 130	3	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-219978-1 MSD

Matrix: Water

Analysis Batch: 235108

Client Sample ID: BWS2254-D2-AQ

Prep Type: Total/NA

Prep Batch: 234953

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorohexanesulfonic acid (PFHxS)	9.6		25.2	36.0		ng/L		105	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		25.2	26.2		ng/L		102	70 - 130	0	30
Perfluoroheptanoic acid (PFHpA)	<2.0		25.2	27.3		ng/L		108	70 - 130	1	30
Perfluorononanoic acid (PFNA)	<2.0		25.2	24.9		ng/L		99	70 - 130	10	30
Perfluorotetradecanoic acid (PFTA)	<2.0		25.2	25.9		ng/L		103	70 - 130	4	30
Perfluorotridecanoic acid (PFTrDA)	<2.0		25.2	27.7		ng/L		110	70 - 130	2	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		25.2	25.3		ng/L		101	70 - 130	0	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		25.2	24.0		ng/L		95	70 - 130	4	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		25.2	26.7		ng/L		106	70 - 130	0	30
Surrogate	MSD %Recovery	MSD Qualifier	Limits								
d5-NEtFOSAA	97		70 - 130								
13C2 PFHxA	110		70 - 130								
13C2 PFDA	108		70 - 130								
13C3-GenX	104		70 - 130								

QC Association Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

LCMS

Prep Batch: 234816

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-219978-1	BWS2254-D2-AQ	Total/NA	Water	533	
380-219978-2	BWS2254-D2-FB	Total/NA	Water	533	
MBL 380-234816/20-A	Method Blank	Total/NA	Water	533	
LCS 380-234816/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-234816/21-A	Lab Control Sample	Total/NA	Water	533	
380-219952-B-3-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	
380-219952-C-3-A MS	Matrix Spike	Total/NA	Water	533	

Analysis Batch: 234948

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-219978-1	BWS2254-D2-AQ	Total/NA	Water	533	234816
380-219978-2	BWS2254-D2-FB	Total/NA	Water	533	234816
MBL 380-234816/20-A	Method Blank	Total/NA	Water	533	234816
LCS 380-234816/22-A	Lab Control Sample	Total/NA	Water	533	234816
MRL 380-234816/21-A	Lab Control Sample	Total/NA	Water	533	234816
380-219952-B-3-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	234816
380-219952-C-3-A MS	Matrix Spike	Total/NA	Water	533	234816

Prep Batch: 234953

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-219978-1	BWS2254-D2-AQ	Total/NA	Water	537.1 DW	
380-219978-2	BWS2254-D2-FB	Total/NA	Water	537.1 DW	
MBL 380-234953/21-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-234953/23-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-234953/22-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-219978-1 MS	BWS2254-D2-AQ	Total/NA	Water	537.1 DW	
380-219978-1 MSD	BWS2254-D2-AQ	Total/NA	Water	537.1 DW	

Analysis Batch: 235108

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-219978-1	BWS2254-D2-AQ	Total/NA	Water	EPA 537.1 V2	234953
380-219978-2	BWS2254-D2-FB	Total/NA	Water	EPA 537.1 V2	234953
MBL 380-234953/21-A	Method Blank	Total/NA	Water	EPA 537.1 V2	234953
LCS 380-234953/23-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	234953
MRL 380-234953/22-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	234953
380-219978-1 MS	BWS2254-D2-AQ	Total/NA	Water	EPA 537.1 V2	234953
380-219978-1 MSD	BWS2254-D2-AQ	Total/NA	Water	EPA 537.1 V2	234953

Lab Chronicle

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-219978-1

Date Collected: 06/15/26 12:00

Matrix: Water

Date Received: 06/16/26 09:38

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			234816	E2HD	EA POM	06/18/26 15:27
Total/NA	Analysis	533		1	234948	SZ9R	EA POM	06/19/26 08:50
Total/NA	Prep	537.1 DW			234953	E9PK	EA POM	06/19/26 07:14
Total/NA	Analysis	EPA 537.1 V2		1	235108	Y5FM	EA POM	06/19/26 20:01

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-219978-2

Date Collected: 06/15/26 12:00

Matrix: Water

Date Received: 06/16/26 09:38

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			234816	E2HD	EA POM	06/18/26 15:27
Total/NA	Analysis	533		1	234948	SZ9R	EA POM	06/19/26 09:10
Total/NA	Prep	537.1 DW			234953	E9PK	EA POM	06/19/26 07:14
Total/NA	Analysis	EPA 537.1 V2		1	235108	Y5FM	EA POM	06/19/26 21:07

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Sample Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-219978-1
SDG: Site D2 PFAS 533/537.1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-219978-1	BWS2254-D2-AQ	Water	06/15/26 12:00	06/16/26 09:38	Hawaii
380-219978-2	BWS2254-D2-FB	Water	06/15/26 12:00	06/16/26 09:38	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Ver- 05/06/2024

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-219978-1
SDG Number: Site D2 PFAS 533/537.1

Login Number: 219978

List Number: 1

Creator: Segura, Ryan

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	