

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 6/15/2026 6:22:58 PM

JOB DESCRIPTION

RED-HILL
PFAS: Aiea Gulch Wells Pump 2
RUSH Weekly Red Hill

JOB NUMBER

380-218939-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
6/15/2026 6:22:58 PM



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	15
QC Association Summary	26
Lab Chronicle	27
Certification Summary	28
Method Summary	29
Sample Summary	30
Chain of Custody	31
Receipt Checklists	33

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-218939-1

Job ID: 380-218939-1

Eurofins Pomona

Job Narrative 380-218939-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 6/10/2026 9:24 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 5.6°C.

Receipt Exceptions

The Chain-of-Custody (COC) was incomplete as received and/or improperly completed. No sample collection time on chain of custody. Sample was logged per the sample time documented on the container labels.

Client was contacted regarding missing collection time, an amended chain of custody was provided 06/12/26.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)
PWSID Number: HI0000331

Lab Sample ID: 380-218939-1

No Detections.

Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)
PWSID Number: HI0000331

Lab Sample ID: 380-218939-2

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

This Detection Summary does not include radiochemical test results.

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-218939-1

Date Collected: 06/08/26 09:00

Matrix: Drinking Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
9-Chlorohexadecafluoro-3-oxanonane e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 15:58	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	87		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C6 PFDA	97		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C5 PFHxA	93		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C4 PFHpA	96		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C8 PFOA	98		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C9 PFNA	103		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C7 PFUnA	101		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C2 PFDoA	107		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C4 PFBA	96		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C5 PFPeA	91		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C3 PFBS	103		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C3 PFHxS	106		50 - 200	06/13/26 12:30	06/14/26 15:58	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-218939-1

Date Collected: 06/08/26 09:00

Matrix: Drinking Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	108		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C2-4:2-FTS	108		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C2-6:2-FTS	93		50 - 200	06/13/26 12:30	06/14/26 15:58	1
13C2-8:2-FTS	92		50 - 200	06/13/26 12:30	06/14/26 15:58	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 17:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	120		70 - 130	06/11/26 11:30	06/12/26 17:37	1
13C2 PFHxA	123		70 - 130	06/11/26 11:30	06/12/26 17:37	1
13C2 PFDA	120		70 - 130	06/11/26 11:30	06/12/26 17:37	1
13C3-GenX	122		70 - 130	06/11/26 11:30	06/12/26 17:37	1

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-218939-2

Date Collected: 06/08/26 09:00

Matrix: Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-218939-2

Date Collected: 06/08/26 09:00

Matrix: Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/13/26 12:30	06/14/26 16:08	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	73		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C6 PFDA	72		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C5 PFHxA	81		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C4 PFHpA	77		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C8 PFOA	81		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C9 PFNA	80		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C7 PFUnA	75		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C2 PFDoA	76		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C4 PFBA	90		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C5 PFPeA	83		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C3 PFBS	104		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C3 PFHxS	106		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C8 PFOS	111		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C2-4:2-FTS	100		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C2-6:2-FTS	95		50 - 200	06/13/26 12:30	06/14/26 16:08	1
13C2-8:2-FTS	92		50 - 200	06/13/26 12:30	06/14/26 16:08	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-218939-2

Date Collected: 06/08/26 09:00

Matrix: Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
N-methylperfluorooctanesulfonamide cetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
N-ethylperfluorooctanesulfonamide cetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/11/26 11:30	06/12/26 08:04	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	114		70 - 130			06/11/26 11:30	06/12/26 08:04	1
13C2 PFHxA	122		70 - 130			06/11/26 11:30	06/12/26 08:04	1
13C2 PFDA	120		70 - 130			06/11/26 11:30	06/12/26 08:04	1
13C3-GenX	118		70 - 130			06/11/26 11:30	06/12/26 08:04	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)
PWSID Number: HI0000331

Lab Sample ID: 380-218939-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)
PWSID Number: HI0000331

Lab Sample ID: 380-218939-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-218939-1
 SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-218939-1	AIEA GULCH WELLS PUMP 2 (331	12	123	120	122

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
 PFHxA = 13C2 PFHxA
 PFDA = 13C2 PFDA
 GenX = 13C3-GenX

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-218939-2	FB AIEA GULCH WELLS PUMP 2 (114	122	120	118
380-219037-B-1-A MS	Matrix Spike	113	123	123	127
380-219037-C-1-A MSD	Matrix Spike Duplicate	117	124	123	125
LCS 380-233180/21-A	Lab Control Sample	105	119	118	120
MBL 380-233180/19-A	Method Blank	112	122	122	116
MRL 380-233180/20-A	Lab Control Sample	123	128	122	124

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
 PFHxA = 13C2 PFHxA
 PFDA = 13C2 PFDA
 GenX = 13C3-GenX

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)							
		HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-218939-1	AIEA GULCH WELLS PUMP 2 (331	87	97	93	96	98	103	101	107

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)							
		PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-218939-1	AIEA GULCH WELLS PUMP 2 (331	96	91	103	106	108	108	93	92

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDaA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)							
		HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-218914-B-2-A MS	Matrix Spike	109	102	103	107	103	108	106	107
380-218914-C-2-A MSD	Matrix Spike Duplicate	103	99	106	104	106	107	108	109
380-218939-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	73	72	81	77	81	80	75	76
LCS 380-233676/22-A	Lab Control Sample	73	75	78	78	80	81	77	79
MBL 380-233676/20-A	Method Blank	76	80	82	80	83	90	85	87
MRL 380-233676/21-A	Lab Control Sample	84	87	91	90	93	96	94	95

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)							
		PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-218914-B-2-A MS	Matrix Spike	106	111	107	106	109	109	95	91
380-218914-C-2-A MSD	Matrix Spike Duplicate	111	111	110	110	114	112	100	95
380-218939-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	90	83	104	106	111	100	95	92
LCS 380-233676/22-A	Lab Control Sample	83	79	100	103	107	95	91	92
MBL 380-233676/20-A	Method Blank	89	81	98	101	107	100	88	89
MRL 380-233676/21-A	Lab Control Sample	94	87	104	105	113	100	91	88

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA

Isotope Dilution Summary

Client: City & County of Honolulu

Project/Site: RED-HILL

13C5PHA = 13C5 PFHxA

C4PFHA = 13C4 PFHpA

C8PFOA = 13C8 PFOA

C9PFNA = 13C9 PFNA

13C7PUA = 13C7 PFUnA

PFD_oA = 13C2 PFD_oA

PFBA = 13C4 PFBA

PFP_eA = 13C5 PFP_eA

C3PFBS = 13C3 PFBS

C3PFHS = 13C3 PFHxS

C8PFOS = 13C8 PFOS

42FTS = 13C2-4:2-FTS

62FTS = 13C2-6:2-FTS

82FTS = 13C2-8:2-FTS

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-233676/20-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233676

Analyte	MBL	MBL	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	0.496	J	2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.25		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		06/13/26 12:30	06/14/26 13:03	1

Isotope Dilution	MBL	MBL	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C3 HFPO-DA	76		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C6 PFDA	80		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C5 PFHxA	82		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C4 PFHpA	80		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C8 PFOA	83		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C9 PFNA	90		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C7 PFUnA	85		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C2 PFDoA	87		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C4 PFBA	89		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C5 PFPeA	81		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C3 PFBS	98		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C3 PFHxS	101		50 - 200	06/13/26 12:30	06/14/26 13:03	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-233676/20-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233676

<i>Isotope Dilution</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	<i>%Recovery</i>	<i>Qualifier</i>				
13C8 PFOS	107		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C2-4:2-FTS	100		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C2-6:2-FTS	88		50 - 200	06/13/26 12:30	06/14/26 13:03	1
13C2-8:2-FTS	89		50 - 200	06/13/26 12:30	06/14/26 13:03	1

Lab Sample ID: LCS 380-233676/22-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>				<i>Limits</i>
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	60.2	57.9		ng/L		96	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	60.2	56.0		ng/L		93	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	60.2	56.2		ng/L		93	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	60.2	57.8		ng/L		96	70 - 130
Perfluorobutanesulfonic acid (PFBS)	60.2	60.7		ng/L		101	70 - 130
Perfluorodecanoic acid (PFDA)	60.2	64.7		ng/L		107	70 - 130
Perfluorododecanoic acid (PFDoA)	60.2	58.4		ng/L		97	70 - 130
Perfluoroheptanoic acid (PFHpA)	60.2	61.6		ng/L		102	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	60.2	59.8		ng/L		99	70 - 130
Perfluorohexanoic acid (PFHxA)	60.2	59.0		ng/L		98	70 - 130
Perfluorononanoic acid (PFNA)	60.2	59.1		ng/L		98	70 - 130
Perfluorooctanesulfonic acid (PFOS)	60.2	57.9		ng/L		96	70 - 130
Perfluorooctanoic acid (PFOA)	60.2	62.2		ng/L		103	70 - 130
Perfluoroundecanoic acid (PFUnA)	60.2	58.3		ng/L		97	70 - 130
Perfluorobutanoic acid (PFBA)	60.2	61.1		ng/L		101	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	60.2	57.4		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	60.2	59.8		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	60.2	61.4		ng/L		102	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	60.2	59.7		ng/L		99	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	60.2	61.7		ng/L		102	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	60.2	65.4		ng/L		109	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	60.2	60.7		ng/L		101	70 - 130
Perfluoropentanoic acid (PFPeA)	60.2	58.7		ng/L		97	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	60.2	60.9		ng/L		101	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-233676/22-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	60.2	58.1		ng/L		96	70 - 130
LCS LCS							
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	73		50 - 200				
13C6 PFDA	75		50 - 200				
13C5 PFHxA	78		50 - 200				
13C4 PFHpA	78		50 - 200				
13C8 PFOA	80		50 - 200				
13C9 PFNA	81		50 - 200				
13C7 PFUnA	77		50 - 200				
13C2 PFDoA	79		50 - 200				
13C4 PFBA	83		50 - 200				
13C5 PFPeA	79		50 - 200				
13C3 PFBS	100		50 - 200				
13C3 PFHxS	103		50 - 200				
13C8 PFOS	107		50 - 200				
13C2-4:2-FTS	95		50 - 200				
13C2-6:2-FTS	91		50 - 200				
13C2-8:2-FTS	92		50 - 200				

Lab Sample ID: MRL 380-233676/21-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	1.96	J	ng/L		98	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	1.83	J	ng/L		91	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	2.04	J	ng/L		102	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	1.95	J	ng/L		97	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	1.97	J	ng/L		98	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.38	J	ng/L		119	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.23	J	ng/L		112	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	1.94	J	ng/L		97	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	1.97	J	ng/L		98	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.01	J	ng/L		100	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.07	J	ng/L		103	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	1.96	J	ng/L		98	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.17	J	ng/L		108	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.20	J	ng/L		110	50 - 150
Perfluorobutanoic acid (PFBA)	2.00	2.40	J	ng/L		120	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-233676/21-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.00	2.14	J	ng/L		107	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.00	2.32	J	ng/L		116	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.00	2.55	J	ng/L		127	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.00	2.02	J	ng/L		101	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.00	1.95	J	ng/L		97	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.00	2.26	J	ng/L		113	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.00	1.99	J	ng/L		99	50 - 150
Perfluoropentanoic acid (PFPeA)	2.00	2.23	J	ng/L		111	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.00	2.00	J	ng/L		100	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.00	1.85	J	ng/L		92	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	84		50 - 200
13C6 PFDA	87		50 - 200
13C5 PFHxA	91		50 - 200
13C4 PFHpA	90		50 - 200
13C8 PFOA	93		50 - 200
13C9 PFNA	96		50 - 200
13C7 PFUnA	94		50 - 200
13C2 PFDoA	95		50 - 200
13C4 PFBA	94		50 - 200
13C5 PFPeA	87		50 - 200
13C3 PFBS	104		50 - 200
13C3 PFHxS	105		50 - 200
13C8 PFOS	113		50 - 200
13C2-4:2-FTS	100		50 - 200
13C2-6:2-FTS	91		50 - 200
13C2-8:2-FTS	88		50 - 200

Lab Sample ID: 380-218914-B-2-A MS
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 233676

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	114		ng/L		94	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	110		ng/L		91	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	115		ng/L		96	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-218914-B-2-A MS

Client Sample ID: Matrix Spike

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 233715

Prep Batch: 233676

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
Hexafluoropropylene Oxide	<2.0		120	111		ng/L		92	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	3.3		120	118		ng/L		95	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		120	128		ng/L		106	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		120	118		ng/L		98	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		120	117		ng/L		96	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	5.0		120	119		ng/L		95	70 - 130
Perfluorohexanoic acid (PFHxA)	2.1		120	121		ng/L		99	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		120	117		ng/L		96	70 - 130
Perfluorooctanesulfonic acid (PFOS)	9.6		120	122		ng/L		93	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		120	124		ng/L		102	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		120	118		ng/L		98	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		120	121		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	116		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	111		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	124		ng/L		103	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	120		ng/L		100	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		120	117		ng/L		97	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	123		ng/L		102	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	114		ng/L		94	70 - 130
Perfluoropentanoic acid (PFPeA)	2.3		120	118		ng/L		96	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	116		ng/L		96	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	118		ng/L		97	70 - 130

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	109		50 - 200
13C6 PFDA	102		50 - 200
13C5 PFHxA	103		50 - 200
13C4 PFHpA	107		50 - 200
13C8 PFOA	103		50 - 200
13C9 PFNA	108		50 - 200
13C7 PFUnA	106		50 - 200
13C2 PFDoA	107		50 - 200
13C4 PFBA	106		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	107		50 - 200
13C3 PFHxS	106		50 - 200
13C8 PFOS	109		50 - 200

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-218914-B-2-A MS
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 233676

<i>Isotope Dilution</i>	<i>MS MS</i> %Recovery	<i>MS MS</i> Qualifier	<i>Limits</i>
13C2-4:2-FTS	109		50 - 200
13C2-6:2-FTS	95		50 - 200
13C2-8:2-FTS	91		50 - 200

Lab Sample ID: 380-218914-C-2-A MSD
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 233676

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	112		ng/L		93	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	106		ng/L		88	70 - 130	3	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	116		ng/L		96	70 - 130	0	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		120	112		ng/L		93	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	3.3		120	112		ng/L		90	70 - 130	5	30
Perfluorodecanoic acid (PFDA)	<2.0		120	127		ng/L		106	70 - 130	0	30
Perfluorododecanoic acid (PFDoA)	<2.0		120	114		ng/L		95	70 - 130	3	30
Perfluoroheptanoic acid (PFHpA)	<2.0		120	116		ng/L		95	70 - 130	1	30
Perfluorohexanesulfonic acid (PFHxS)	5.0		120	119		ng/L		95	70 - 130	0	30
Perfluorohexanoic acid (PFHxA)	2.1		120	114		ng/L		93	70 - 130	6	30
Perfluorononanoic acid (PFNA)	<2.0		120	113		ng/L		93	70 - 130	3	30
Perfluorooctanesulfonic acid (PFOS)	9.6		120	117		ng/L		90	70 - 130	4	30
Perfluorooctanoic acid (PFOA)	<2.0		120	116		ng/L		95	70 - 130	7	30
Perfluoroundecanoic acid (PFUnA)	<2.0		120	113		ng/L		94	70 - 130	4	30
Perfluorobutanoic acid (PFBA)	<2.0		120	117		ng/L		96	70 - 130	4	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	121		ng/L		101	70 - 130	4	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	111		ng/L		92	70 - 130	0	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	119		ng/L		98	70 - 130	4	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	113		ng/L		94	70 - 130	7	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		120	115		ng/L		96	70 - 130	2	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	126		ng/L		105	70 - 130	2	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	112		ng/L		93	70 - 130	2	30
Perfluoropentanoic acid (PFPeA)	2.3		120	116		ng/L		95	70 - 130	1	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	112		ng/L		93	70 - 130	3	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	115		ng/L		95	70 - 130	3	30

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

<i>Isotope Dilution</i>	<i>MSD MSD</i>		<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
13C3 HFPO-DA	103		50 - 200
13C6 PFDA	99		50 - 200
13C5 PFHxA	106		50 - 200
13C4 PFHpA	104		50 - 200
13C8 PFOA	106		50 - 200
13C9 PFNA	107		50 - 200
13C7 PFUnA	108		50 - 200
13C2 PFDoA	109		50 - 200
13C4 PFBA	111		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	110		50 - 200
13C3 PFHxS	110		50 - 200
13C8 PFOS	114		50 - 200
13C2-4:2-FTS	112		50 - 200
13C2-6:2-FTS	100		50 - 200
13C2-8:2-FTS	95		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-233180/19-A
Matrix: Water
Analysis Batch: 233406

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233180

<i>Analyte</i>	<i>MBL MBL</i>		<i>RL</i>	<i>Unit</i>	<i>D</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	<i>Result</i>	<i>Qualifier</i>						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
Perfluorotridecanoic acid (PFTTrDA)	<0.36		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/11/26 11:30	06/12/26 06:38	1

<i>Surrogate</i>	<i>MBL MBL</i>		<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	<i>%Recovery</i>	<i>Qualifier</i>				
d5-NEtFOSAA	112		70 - 130	06/11/26 11:30	06/12/26 06:38	1
13C2 PFHxA	122		70 - 130	06/11/26 11:30	06/12/26 06:38	1
13C2 PFDA	122		70 - 130	06/11/26 11:30	06/12/26 06:38	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-233180/19-A
Matrix: Water
Analysis Batch: 233406

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233180

<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3-GenX	116	Qualifier	70 - 130	06/11/26 11:30	06/12/26 06:38	1

Lab Sample ID: LCS 380-233180/21-A
Matrix: Water
Analysis Batch: 233406

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233180

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>	<i>Limits</i>
<i>Analyte</i>	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>Limits</i>	<i>Limits</i>
Hexafluoropropylene Oxide	50.2	52.6		ng/L		105	70 - 130	
Dimer Acid (HFPO-DA/GenX)								
Perfluorooctanesulfonic acid (PFOS)	50.2	51.9		ng/L		103	70 - 130	
Perfluoroundecanoic acid (PFUnA)	50.2	55.2		ng/L		110	70 - 130	
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	50.2	44.5		ng/L		89	70 - 130	
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	50.2	46.4		ng/L		92	70 - 130	
Perfluorohexanoic acid (PFHxA)	50.2	54.2		ng/L		108	70 - 130	
Perfluorododecanoic acid (PFDoA)	50.2	55.0		ng/L		110	70 - 130	
Perfluorooctanoic acid (PFOA)	50.2	54.6		ng/L		109	70 - 130	
Perfluorodecanoic acid (PFDA)	50.2	52.5		ng/L		105	70 - 130	
Perfluorohexanesulfonic acid (PFHxS)	50.2	52.9		ng/L		105	70 - 130	
Perfluorobutanesulfonic acid (PFBS)	50.2	53.1		ng/L		106	70 - 130	
Perfluoroheptanoic acid (PFHpA)	50.2	52.4		ng/L		104	70 - 130	
Perfluorononanoic acid (PFNA)	50.2	52.6		ng/L		105	70 - 130	
Perfluorotetradecanoic acid (PFTA)	50.2	42.9		ng/L		86	70 - 130	
Perfluorotridecanoic acid (PFTrDA)	50.2	54.9		ng/L		109	70 - 130	
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	50.2	52.1		ng/L		104	70 - 130	
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	50.2	51.8		ng/L		103	70 - 130	
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	50.2	52.3		ng/L		104	70 - 130	

<i>Surrogate</i>	<i>LCS</i>	<i>LCS</i>	<i>Limits</i>
<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>
d5-NEtFOSAA	105		70 - 130
13C2 PFHxA	119		70 - 130
13C2 PFDA	118		70 - 130
13C3-GenX	120		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-233180/20-A
Matrix: Water
Analysis Batch: 233406

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233180

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	2.01	2.10	J	ng/L		105	50 - 150
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	2.01	2.12	J	ng/L		106	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.18	J	ng/L		109	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.01	2.09	J	ng/L		104	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.01	2.22	J	ng/L		110	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	2.24	J	ng/L		111	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	2.14	J	ng/L		107	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	2.09	J	ng/L		104	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.13	J	ng/L		106	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	2.00	J	ng/L		99	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	2.03	J	ng/L		101	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	2.20	J	ng/L		109	50 - 150
Perfluorononanoic acid (PFNA)	2.01	2.30	J	ng/L		114	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.01	1.52	J	ng/L		76	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.01	2.29	J	ng/L		114	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	2.15	J	ng/L		107	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.98	J	ng/L		99	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	2.15	J	ng/L		107	50 - 150
		MRL	MRL				
Surrogate	%Recovery	Qualifier	Limits				
d5-NEtFOSAA	123		70 - 130				
13C2 PFHxA	128		70 - 130				
13C2 PFDA	122		70 - 130				
13C3-GenX	124		70 - 130				

Lab Sample ID: 380-219037-B-1-A MS
Matrix: Water
Analysis Batch: 233406

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 233180

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		25.2	28.2		ng/L		112	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorooctanesulfonic acid (PFOS)	<2.0		25.2	25.9		ng/L		103	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		25.2	27.6		ng/L		110	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.2	24.0		ng/L		96	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-219037-B-1-A MS

Client Sample ID: Matrix Spike

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 233406

Prep Batch: 233180

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
N-ethylperfluorooctanesulfonamide acetic acid (NEtFOSAA)	<2.0		25.2	24.6		ng/L		98	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		25.2	27.6		ng/L		110	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		25.2	27.4		ng/L		109	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		25.2	27.5		ng/L		109	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		25.2	26.5		ng/L		105	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		25.2	25.9		ng/L		103	70 - 130
Perfluorobutanesulfonic acid (PFBS)	<2.0		25.2	26.8		ng/L		107	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		25.2	28.0		ng/L		111	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		25.2	28.8		ng/L		114	70 - 130
Perfluorotetradecanoic acid (PFTA)	<2.0		25.2	21.4		ng/L		85	70 - 130
Perfluorotridecanoic acid (PFTrDA)	<2.0		25.2	28.8		ng/L		115	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		25.2	25.9		ng/L		103	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		25.2	25.2		ng/L		100	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		25.2	28.6		ng/L		114	70 - 130
MS MS									
Surrogate	%Recovery	Qualifier	Limits						
d5-NEtFOSAA	113		70 - 130						
13C2 PFHxA	123		70 - 130						
13C2 PFDA	123		70 - 130						
13C3-GenX	127		70 - 130						

Lab Sample ID: 380-219037-C-1-A MSD

Client Sample ID: Matrix Spike Duplicate

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 233406

Prep Batch: 233180

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec Limits	RPD	
	Result	Qualifier	Added	Result	Qualifier					RPD	Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		25.2	29.6		ng/L		118	70 - 130	5	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		25.2	27.5		ng/L		109	70 - 130	6	30
Perfluoroundecanoic acid (PFUnA)	<2.0		25.2	28.6		ng/L		114	70 - 130	3	30
N-methylperfluorooctanesulfonamide acetic acid (NMeFOSAA)	<2.0		25.2	26.0		ng/L		103	70 - 130	8	30
N-ethylperfluorooctanesulfonamide acetic acid (NEtFOSAA)	<2.0		25.2	26.6		ng/L		106	70 - 130	8	30
Perfluorohexanoic acid (PFHxA)	<2.0		25.2	29.2		ng/L		116	70 - 130	5	30
Perfluorododecanoic acid (PFDoA)	<2.0		25.2	28.4		ng/L		113	70 - 130	3	30
Perfluorooctanoic acid (PFOA)	<2.0		25.2	28.8		ng/L		115	70 - 130	5	30
Perfluorodecanoic acid (PFDA)	<2.0		25.2	27.7		ng/L		110	70 - 130	5	30

Eurofins Pomona

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

LCMS

Prep Batch: 233180

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-218939-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	537.1 DW	
380-218939-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	537.1 DW	
MBL 380-233180/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-233180/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-233180/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-219037-B-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-219037-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

Analysis Batch: 233406

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-218939-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	EPA 537.1 V2	233180
MBL 380-233180/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	233180
LCS 380-233180/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	233180
MRL 380-233180/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	233180
380-219037-B-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	233180
380-219037-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	233180

Analysis Batch: 233464

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-218939-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	EPA 537.1 V2	233180

Prep Batch: 233676

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-218939-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	533	
380-218939-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	533	
MBL 380-233676/20-A	Method Blank	Total/NA	Water	533	
LCS 380-233676/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-233676/21-A	Lab Control Sample	Total/NA	Water	533	
380-218914-B-2-A MS	Matrix Spike	Total/NA	Water	533	
380-218914-C-2-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 233715

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-218939-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	533	233676
380-218939-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	533	233676
MBL 380-233676/20-A	Method Blank	Total/NA	Water	533	233676
LCS 380-233676/22-A	Lab Control Sample	Total/NA	Water	533	233676
MRL 380-233676/21-A	Lab Control Sample	Total/NA	Water	533	233676
380-218914-B-2-A MS	Matrix Spike	Total/NA	Water	533	233676
380-218914-C-2-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	233676

Lab Chronicle

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-218939-1
 SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
 (331-202-TP072)**

Lab Sample ID: 380-218939-1

Date Collected: 06/08/26 09:00

Matrix: Drinking Water

Date Received: 06/10/26 09:24

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			233676	N8NE	EA POM	06/13/26 12:30
Total/NA	Analysis	533		1	233715	M7ML	EA POM	06/14/26 15:58
Total/NA	Prep	537.1 DW			233180	LM3A	EA POM	06/11/26 11:30
Total/NA	Analysis	EPA 537.1 V2		1	233464	Y5FM	EA POM	06/12/26 17:37

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2
 (331-202-TP072)**

Lab Sample ID: 380-218939-2

Date Collected: 06/08/26 09:00

Matrix: Water

Date Received: 06/10/26 09:24

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			233676	N8NE	EA POM	06/13/26 12:30
Total/NA	Analysis	533		1	233715	M7ML	EA POM	06/14/26 16:08
Total/NA	Prep	537.1 DW			233180	LM3A	EA POM	06/11/26 11:30
Total/NA	Analysis	EPA 537.1 V2		1	233406	SZ9R	EA POM	06/12/26 08:04

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218939-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-218939-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Drinking Water	06/08/26 09:00	06/10/26 09:24	HI0000331
380-218939-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Water	06/08/26 09:00	06/10/26 09:24	HI0000331

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Monrovia, CA (Suite 100)
 750 Royal Oaks Drive Suite 100
 Monrovia CA 91016
 Phone (626) 386-1100

Chain of Custody Record



Envir
Ame



COC No 30-218939 C0C

Client Information Client Contact: Kirk Iwamoto Phone: +1 808 748 5840 E-Mail: Maria.Lopez@et.eurofins.com		Lab PM: Lopez, Maria E-Mail: Maria.Lopez@et.eurofins.com		Carrier Tracking No(s): State of Origin:		Page: Page 1 of 1 Job #:	
City & County of Honolulu Address: 630 South Beretania Street, Chemistry Lab City: Honolulu State Zip: HI 96843 Phone: 808-748-5840 (tel) Email: kiwamoto@hbws.org		PWSID Due Date Requested TAT Requested (days): RUSH Compliance Project: Δ No PO #: C20525101 exp 05312023 WO #:		Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other:	
Sample Identification AIEA GULCH WELLS PUMP 2 (331-202-TP072)		Sample Date: 8-Jun-2026 Sample Time:		Sample Type (C=comp, G=grab) G Matrix (Water, Gas, Soil, G=grab) Water		Total Number of Containers:	
FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)		Sample Date: 8-Jun-2026 Sample Time:		Sample Type (C=comp, G=grab) G Matrix (Water, Gas, Soil, G=grab) Water		Special Instructions/Note:	
Possible Hazard Identification <input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological Deliverable Requested I II III IV Other (specify)		Sample Date: 8-Jun-2026 Sample Time:		Sample Type (C=comp, G=grab) G Matrix (Water, Gas, Soil, G=grab) Water		Special Instructions/Note:	
Empty Kit Relinquished by Relinquish: [Redacted] Relinquished by: [Redacted] Relinquished by:		Date: 6/9/26 12:00 Date/Time: 6/9/26 12:00 Date/Time:		Date: 6/10/26 9:24 Date/Time: 6/10/26 9:24 Date/Time:		Method of Shipment: PED 5724 5343 4658 Company: PEAR Company:	
Custody Seals Intact: Δ Yes Δ No Custody Seal No		Cooler Temperature(s) °C and Other Remarks: 18.1A 5.6 15.6 9.01 FROZEN		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) <input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months Special Instructions/QC Requirements:		Special Instructions/QC Requirements:	



Monrovia, CA (Suite 100)
750 Royal Oaks Drive Suite 100
Monrovia CA 91016
Phone (626) 386-1100

Chain of Custody Record



Envir
Ame



COC NO: 30-218939 COC

Client Information Client Contact: Kirk Iwamoto Phone: +1 806 748 5840 E-Mail: Maria.Lopez@et.eurofins.com		Lab PM: Lopez, Maria E-Mail: Maria.Lopez@et.eurofins.com		Carrier Tracking No(s): State of Origin:		Page 1 of 1 Job #:	
City & County of Honolulu Address: 630 South Beretania Street, Chemistry Lab City: Honolulu State Zip: HI 96843 Phone: 808-748-5840 (tel) Email: kiwamoto@hbws.org		PWSID Due Date Requested TAT Requested (days): RUSH Compliance Project: Δ No PO #: C20525101 exp 05312023 WO #:		Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other:	
Sample Identification AIEA GULCH WELLS PUMP 2 (331-202-TP072)		Matrix (W=water, S=solid, G=grab) Sample Type (C=comp, G=grab) Sample Time: 0900 Sample Date: 8-Jun-2026 Preservation Code: G		Perform MS/MSD (Yes or No) Field Filtered Sample (Yes or No) 537 1 DW_PREC - 537 1 Full List 533 - All Analytes Y Z 3 3		Total Number of Containers Special Instructions/Note:	
Possible Hazard Identification <input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant Deliverable Requested I II III IV Other (specify)		<input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) <input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months			
Empty Kit Relinquished by: Relinquished by: <i>Kali Cotton</i> Date/Time: 6/9/26 12:00 Relinquished by: _____ Date/Time: _____ Relinquished by: _____ Date/Time: _____		Method of Shipment: Received by: _____ Date/Time: 6/10/26 9:24 Received by: _____ Date/Time: _____ Received by: _____ Date/Time: _____		Cooler Temperature(s) °C and Other Remarks: 18.1 5.6 15.6 9.1 17.0			



Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-218939-1
SDG Number: PFAS: Aiea Gulch Wells Pump 2

Login Number: 218939

List Number: 1

Creator: Avila, Ivan

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	False	No sample date and/or time on COC, logged in per container labels.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
ClO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

