

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 7/21/2026 6:58:31 PM

JOB DESCRIPTION

RED-HILL
PFAS: Moanalua Wells

JOB NUMBER

380-225258-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Generated
7/21/2026 6:58:31 PM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	15
QC Association Summary	26
Lab Chronicle	27
Certification Summary	28
Method Summary	29
Sample Summary	30
Chain of Custody	31
Receipt Checklists	32



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-225258-1

Job ID: 380-225258-1

Eurofins Pomona

Job Narrative 380-225258-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 7/15/2026 10:10 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 3.1°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-1

No Detections.

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-1

Date Collected: 07/13/26 09:54

Matrix: Drinking Water

Date Received: 07/15/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:20	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	105		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C6 PFDA	108		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C5 PFHxA	106		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C4 PFHpA	108		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C8 PFOA	114		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C9 PFNA	110		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C7 PFUnA	111		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C2 PFDoA	110		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C4 PFBA	112		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C5 PFPeA	109		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C3 PFBS	107		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C3 PFHxS	107		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C8 PFOS	108		50 - 200	07/17/26 13:55	07/18/26 19:20	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-1

Date Collected: 07/13/26 09:54

Matrix: Drinking Water

Date Received: 07/15/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2-4:2-FTS	102		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C2-6:2-FTS	95		50 - 200	07/17/26 13:55	07/18/26 19:20	1
13C2-8:2-FTS	95		50 - 200	07/17/26 13:55	07/18/26 19:20	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:21	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	105		70 - 130			07/18/26 16:04	07/20/26 08:21	1
13C2 PFHxA	113		70 - 130			07/18/26 16:04	07/20/26 08:21	1
13C2 PFDA	111		70 - 130			07/18/26 16:04	07/20/26 08:21	1
13C3-GenX	115		70 - 130			07/18/26 16:04	07/20/26 08:21	1

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-2

Date Collected: 07/13/26 09:54

Matrix: Water

Date Received: 07/15/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-2

Date Collected: 07/13/26 09:54

Matrix: Water

Date Received: 07/15/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		07/17/26 13:55	07/18/26 19:29	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	91		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C6 PFDA	104		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C5 PFHxA	97		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C4 PFHpA	102		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C8 PFOA	101		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C9 PFNA	106		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C7 PFUnA	102		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C2 PFDoA	106		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C4 PFBA	100		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C5 PFPeA	101		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C3 PFBS	106		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C3 PFHxS	109		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C8 PFOS	111		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C2-4:2-FTS	96		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C2-6:2-FTS	94		50 - 200	07/17/26 13:55	07/18/26 19:29	1
13C2-8:2-FTS	98		50 - 200	07/17/26 13:55	07/18/26 19:29	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-2

Date Collected: 07/13/26 09:54

Matrix: Water

Date Received: 07/15/26 10:10

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		07/18/26 16:04	07/20/26 08:30	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	113		70 - 130			07/18/26 16:04	07/20/26 08:30	1
13C2 PFHxA	118		70 - 130			07/18/26 16:04	07/20/26 08:30	1
13C2 PFDA	117		70 - 130			07/18/26 16:04	07/20/26 08:30	1
13C3-GenX	116		70 - 130			07/18/26 16:04	07/20/26 08:30	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-225258-1	MOANALUA WELLS (331-223-TP202)	105	113	111	115
Surrogate Legend					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-225111-B-1-A MS	Matrix Spike	102	101	103	105
380-225111-C-1-A MSD	Matrix Spike Duplicate	104	107	108	102
380-225258-2	FB: MOANALUA WELLS (331-223-TP202)	113	118	117	116
LCS 380-240743/21-A	Lab Control Sample	102	102	106	95
MBL 380-240743/19-A	Method Blank	111	114	118	103
MRL 380-240743/20-A	Lab Control Sample	112	105	110	103
Surrogate Legend					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-225258-1	MOANALUA WELLS (331-223-TP202)	105	108	106	108	114	110	111	110

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-225258-1	MOANALUA WELLS (331-223-TP202)	112	109	107	107	108	102	95	95

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA
13C5PHA = 13C5 PFHxA
C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDaA = 13C2 PFDaA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-225240-B-1-A MS	Matrix Spike	106	110	104	104	107	109	108	108
380-225240-C-1-A MSD	Matrix Spike Duplicate	108	110	107	110	109	109	109	106
380-225258-2	FB: MOANALUA WELLS (331-223-TP202)	91	104	97	102	101	106	102	106

LCS 380-240630/22-A	Lab Control Sample	103	106	106	105	105	108	107	107
MBL 380-240630/20-A	Method Blank	93	105	94	103	103	101	103	100
MRL 380-240630/21-A	Lab Control Sample	82	95	88	91	96	98	97	98

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-225240-B-1-A MS	Matrix Spike	111	111	107	107	108	97	92	91
380-225240-C-1-A MSD	Matrix Spike Duplicate	108	107	108	110	110	97	94	95
380-225258-2	FB: MOANALUA WELLS (331-223-TP202)	100	101	106	109	111	96	94	98
LCS 380-240630/22-A	Lab Control Sample	106	99	105	106	109	93	93	91
MBL 380-240630/20-A	Method Blank	104	102	110	111	108	101	101	96
MRL 380-240630/21-A	Lab Control Sample	96	91	103	104	107	97	93	90

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA

Eurofins Pomona

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFD_oA = 13C2 PFD_oA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-240630/20-A

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 240630

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<0.29		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9CI-PF3ONS)	<0.29		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluorobutanoic acid (PFBA)	<0.68		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.37		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.36		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.47		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.46		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.24		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.45		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluoropentanoic acid (PFPeA)	<0.37		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.35		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Perfluoropentanesulfonic acid (PFPeS)	<0.38		2.0	ng/L		07/17/26 13:55	07/18/26 15:38	1
Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits			Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	93		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C6 PFDA	105		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C5 PFHxA	94		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C4 PFHpA	103		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C8 PFOA	103		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C9 PFNA	101		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C7 PFUnA	103		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C2 PFDoA	100		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C4 PFBA	104		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C5 PFPeA	102		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C3 PFBS	110		50 - 200			07/17/26 13:55	07/18/26 15:38	1
13C3 PFHxS	111		50 - 200			07/17/26 13:55	07/18/26 15:38	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-240630/20-A

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 240630

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	108		50 - 200	07/17/26 13:55	07/18/26 15:38	1
13C2-4:2-FTS	101		50 - 200	07/17/26 13:55	07/18/26 15:38	1
13C2-6:2-FTS	101		50 - 200	07/17/26 13:55	07/18/26 15:38	1
13C2-8:2-FTS	96		50 - 200	07/17/26 13:55	07/18/26 15:38	1

Lab Sample ID: LCS 380-240630/22-A

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240630

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	118	111		ng/L		94	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	118	111		ng/L		94	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	118	108		ng/L		92	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	118	110		ng/L		93	70 - 130
Perfluorobutanesulfonic acid (PFBS)	118	115		ng/L		98	70 - 130
Perfluorodecanoic acid (PFDA)	118	110		ng/L		93	70 - 130
Perfluorododecanoic acid (PFDoA)	118	106		ng/L		90	70 - 130
Perfluoroheptanoic acid (PFHpA)	118	112		ng/L		95	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	118	111		ng/L		94	70 - 130
Perfluorohexanoic acid (PFHxA)	118	107		ng/L		90	70 - 130
Perfluorononanoic acid (PFNA)	118	108		ng/L		91	70 - 130
Perfluorooctanesulfonic acid (PFOS)	118	111		ng/L		94	70 - 130
Perfluorooctanoic acid (PFOA)	118	107		ng/L		91	70 - 130
Perfluoroundecanoic acid (PFUnA)	118	109		ng/L		92	70 - 130
Perfluorobutanoic acid (PFBA)	118	108		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	118	107		ng/L		91	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	118	110		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	118	109		ng/L		92	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	118	111		ng/L		94	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	118	114		ng/L		97	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	118	108		ng/L		92	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	118	112		ng/L		95	70 - 130
Perfluoropentanoic acid (PFPeA)	118	114		ng/L		97	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	118	109		ng/L		93	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-240630/22-A

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240630

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	118	111		ng/L		94	70 - 130
	LCS	LCS					
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	103		50 - 200				
13C6 PFDA	106		50 - 200				
13C5 PFHxA	106		50 - 200				
13C4 PFHpA	105		50 - 200				
13C8 PFOA	105		50 - 200				
13C9 PFNA	108		50 - 200				
13C7 PFUnA	107		50 - 200				
13C2 PFDoA	107		50 - 200				
13C4 PFBA	106		50 - 200				
13C5 PFPeA	99		50 - 200				
13C3 PFBS	105		50 - 200				
13C3 PFHxS	106		50 - 200				
13C8 PFOS	109		50 - 200				
13C2-4:2-FTS	93		50 - 200				
13C2-6:2-FTS	93		50 - 200				
13C2-8:2-FTS	91		50 - 200				

Lab Sample ID: MRL 380-240630/21-A

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240630

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.96	1.89	J	ng/L		96	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.96	1.84	J	ng/L		94	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.96	1.87	J	ng/L		95	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	1.96	1.96	J	ng/L		100	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.96	1.84	J	ng/L		94	50 - 150
Perfluorodecanoic acid (PFDA)	1.96	2.03	J	ng/L		103	50 - 150
Perfluorododecanoic acid (PFDoA)	1.96	1.95	J	ng/L		99	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.96	1.99	J	ng/L		101	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.96	1.89	J	ng/L		96	50 - 150
Perfluorohexanoic acid (PFHxA)	1.96	2.00	J	ng/L		102	50 - 150
Perfluorononanoic acid (PFNA)	1.96	1.96	J	ng/L		100	50 - 150
Perfluorooctanesulfonic acid (PFOS)	1.96	1.92	J	ng/L		98	50 - 150
Perfluorooctanoic acid (PFOA)	1.96	1.87	J	ng/L		95	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.96	2.02	J	ng/L		103	50 - 150
Perfluorobutanoic acid (PFBA)	1.96	2.23	J	ng/L		114	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-240630/21-A

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240630

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	1.96	1.79	J	ng/L		91	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	1.96	1.84	J	ng/L		94	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	1.96	1.98	J	ng/L		101	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	1.96	1.95	J	ng/L		99	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	1.96	1.86	J	ng/L		95	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	1.96	1.75	J	ng/L		89	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	1.96	1.84	J	ng/L		94	50 - 150
Perfluoropentanoic acid (PFPeA)	1.96	1.86	J	ng/L		95	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	1.96	1.80	J	ng/L		92	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	1.96	1.83	J	ng/L		93	50 - 150

Isotope Dilution	%Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	82		50 - 200
13C6 PFDA	95		50 - 200
13C5 PFHxA	88		50 - 200
13C4 PFHpA	91		50 - 200
13C8 PFOA	96		50 - 200
13C9 PFNA	98		50 - 200
13C7 PFUnA	97		50 - 200
13C2 PFDoA	98		50 - 200
13C4 PFBA	96		50 - 200
13C5 PFPeA	91		50 - 200
13C3 PFBS	103		50 - 200
13C3 PFHxS	104		50 - 200
13C8 PFOS	107		50 - 200
13C2-4:2-FTS	97		50 - 200
13C2-6:2-FTS	93		50 - 200
13C2-8:2-FTS	90		50 - 200

Lab Sample ID: 380-225240-B-1-A MS

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240630

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		59.2	53.1		ng/L		90	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		59.2	53.7		ng/L		91	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		59.2	56.8		ng/L		96	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-225240-B-1-A MS

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240630

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		59.2	53.8		ng/L		91	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		59.2	57.6		ng/L		95	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		59.2	56.7		ng/L		96	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		59.2	53.6		ng/L		91	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		59.2	60.0		ng/L		100	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		59.2	57.4		ng/L		95	70 - 130
Perfluorohexanoic acid (PFHxA)	2.0		59.2	56.7		ng/L		92	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		59.2	56.3		ng/L		95	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		59.2	56.0		ng/L		93	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		59.2	56.6		ng/L		93	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		59.2	56.6		ng/L		96	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		59.2	58.0		ng/L		96	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		59.2	54.2		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		59.2	55.9		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		59.2	57.7		ng/L		97	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		59.2	55.2		ng/L		93	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		59.2	57.7		ng/L		98	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		59.2	50.6		ng/L		86	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		59.2	52.9		ng/L		89	70 - 130
Perfluoropentanoic acid (PFPeA)	2.2		59.2	56.7		ng/L		92	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		59.2	56.6		ng/L		96	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		59.2	55.9		ng/L		95	70 - 130

Isotope Dilution	MS %Recovery	MS Qualifier	Limits
13C3 HFPO-DA	106		50 - 200
13C6 PFDA	110		50 - 200
13C5 PFHxA	104		50 - 200
13C4 PFHpA	104		50 - 200
13C8 PFOA	107		50 - 200
13C9 PFNA	109		50 - 200
13C7 PFUnA	108		50 - 200
13C2 PFDoA	108		50 - 200
13C4 PFBA	111		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	107		50 - 200
13C3 PFHxS	107		50 - 200
13C8 PFOS	108		50 - 200

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-225240-B-1-A MS

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240630

Isotope Dilution	MS %Recovery	MS Qualifier	Limits
13C2-4:2-FTS	97		50 - 200
13C2-6:2-FTS	92		50 - 200
13C2-8:2-FTS	91		50 - 200

Lab Sample ID: 380-225240-C-1-A MSD

Matrix: Water

Analysis Batch: 240733

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 240630

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		59.2	52.4		ng/L		89	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		59.2	54.6		ng/L		92	70 - 130	2	30
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	<2.0		59.2	54.0		ng/L		91	70 - 130	5	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		59.2	53.3		ng/L		90	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		59.2	56.1		ng/L		93	70 - 130	3	30
Perfluorodecanoic acid (PFDA)	<2.0		59.2	55.5		ng/L		94	70 - 130	2	30
Perfluorododecanoic acid (PFDoA)	<2.0		59.2	54.5		ng/L		92	70 - 130	2	30
Perfluoroheptanoic acid (PFHpA)	<2.0		59.2	58.6		ng/L		97	70 - 130	2	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		59.2	57.7		ng/L		96	70 - 130	0	30
Perfluorohexanoic acid (PFHxA)	2.0		59.2	57.3		ng/L		93	70 - 130	1	30
Perfluorononanoic acid (PFNA)	<2.0		59.2	56.5		ng/L		96	70 - 130	0	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		59.2	56.1		ng/L		93	70 - 130	0	30
Perfluorooctanoic acid (PFOA)	<2.0		59.2	54.4		ng/L		89	70 - 130	4	30
Perfluoroundecanoic acid (PFUnA)	<2.0		59.2	54.5		ng/L		92	70 - 130	4	30
Perfluorobutanoic acid (PFBA)	<2.0		59.2	57.5		ng/L		95	70 - 130	1	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		59.2	53.8		ng/L		91	70 - 130	1	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		59.2	56.8		ng/L		96	70 - 130	2	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		59.2	58.4		ng/L		99	70 - 130	1	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		59.2	57.1		ng/L		96	70 - 130	3	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		59.2	56.6		ng/L		96	70 - 130	2	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		59.2	52.6		ng/L		89	70 - 130	4	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		59.2	54.4		ng/L		92	70 - 130	3	30
Perfluoropentanoic acid (PFPeA)	2.2		59.2	58.3		ng/L		95	70 - 130	3	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		59.2	55.9		ng/L		95	70 - 130	1	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		59.2	54.1		ng/L		91	70 - 130	3	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	108		50 - 200
13C6 PFDA	110		50 - 200
13C5 PFHxA	107		50 - 200
13C4 PFHpA	110		50 - 200
13C8 PFOA	109		50 - 200
13C9 PFNA	109		50 - 200
13C7 PFUnA	109		50 - 200
13C2 PFDoA	106		50 - 200
13C4 PFBA	108		50 - 200
13C5 PFPeA	107		50 - 200
13C3 PFBS	108		50 - 200
13C3 PFHxS	110		50 - 200
13C8 PFOS	110		50 - 200
13C2-4:2-FTS	97		50 - 200
13C2-6:2-FTS	94		50 - 200
13C2-8:2-FTS	95		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-240743/19-A
Matrix: Water
Analysis Batch: 240777

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 240743

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.57		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.41		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorotetradecanoic acid (PFTA)	<0.53		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Perfluorotridecanoic acid (PFTTrDA)	<0.35		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<0.29		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		07/18/26 16:04	07/20/26 04:49	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	111		70 - 130			07/18/26 16:04	07/20/26 04:49	1
13C2 PFHxA	114		70 - 130			07/18/26 16:04	07/20/26 04:49	1
13C2 PFDA	118		70 - 130			07/18/26 16:04	07/20/26 04:49	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-240743/19-A

Matrix: Water

Analysis Batch: 240777

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 240743

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	103		70 - 130	07/18/26 16:04	07/20/26 04:49	1

Lab Sample ID: LCS 380-240743/21-A

Matrix: Water

Analysis Batch: 240777

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240743

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	49.2	41.2		ng/L		84	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	49.2	45.9		ng/L		93	70 - 130
Perfluoroundecanoic acid (PFUnA)	49.2	48.0		ng/L		98	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	49.2	46.4		ng/L		94	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	49.2	45.7		ng/L		93	70 - 130
Perfluorohexanoic acid (PFHxA)	49.2	45.1		ng/L		92	70 - 130
Perfluorododecanoic acid (PFDoA)	49.2	48.3		ng/L		98	70 - 130
Perfluorooctanoic acid (PFOA)	49.2	44.3		ng/L		90	70 - 130
Perfluorodecanoic acid (PFDA)	49.2	42.6		ng/L		86	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	49.2	48.8		ng/L		99	70 - 130
Perfluorobutanesulfonic acid (PFBS)	49.2	46.8		ng/L		95	70 - 130
Perfluoroheptanoic acid (PFHpA)	49.2	44.0		ng/L		89	70 - 130
Perfluorononanoic acid (PFNA)	49.2	46.9		ng/L		95	70 - 130
Perfluorotetradecanoic acid (PFTA)	49.2	44.6		ng/L		91	70 - 130
Perfluorotridecanoic acid (PFTrDA)	49.2	50.7		ng/L		103	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	49.2	46.9		ng/L		95	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	49.2	47.5		ng/L		96	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	49.2	42.3		ng/L		86	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	102		70 - 130
13C2 PFHxA	102		70 - 130
13C2 PFDA	106		70 - 130
13C3-GenX	95		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-240743/20-A

Matrix: Water

Analysis Batch: 240777

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 240743

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	1.96	1.90	J	ng/L		97	50 - 150
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	1.96	2.16	J	ng/L		110	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.96	2.05	J	ng/L		104	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	1.96	1.96	J	ng/L		100	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	1.96	2.06	J	ng/L		105	50 - 150
Perfluorohexanoic acid (PFHxA)	1.96	1.99	J	ng/L		101	50 - 150
Perfluorododecanoic acid (PFDoA)	1.96	2.05	J	ng/L		104	50 - 150
Perfluorooctanoic acid (PFOA)	1.96	1.99	J	ng/L		101	50 - 150
Perfluorodecanoic acid (PFDA)	1.96	1.96	J	ng/L		100	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.96	2.21	J	ng/L		112	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.96	2.05	J	ng/L		104	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.96	1.91	J	ng/L		97	50 - 150
Perfluorononanoic acid (PFNA)	1.96	1.98	J	ng/L		101	50 - 150
Perfluorotetradecanoic acid (PFTA)	1.96	1.97	J	ng/L		100	50 - 150
Perfluorotridecanoic acid (PFTrDA)	1.96	2.20	J	ng/L		112	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.96	1.96	J	ng/L		100	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.96	2.09	J	ng/L		106	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.96	1.94	J	ng/L		99	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	112		70 - 130
13C2 PFHxA	105		70 - 130
13C2 PFDA	110		70 - 130
13C3-GenX	103		70 - 130

Lab Sample ID: 380-225111-B-1-A MS

Matrix: Water

Analysis Batch: 240777

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240743

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		24.7	24.1		ng/L		98	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorooctanesulfonic acid (PFOS)	<2.0		24.7	26.4		ng/L		104	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		24.7	25.5		ng/L		103	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.7	23.2		ng/L		94	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-225111-B-1-A MS

Matrix: Water

Analysis Batch: 240777

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 240743

	Sample	Sample	Spike	MS	MS				%Rec		
Analyte	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec	Limits		
N-ethylperfluorooctanesulfonami doacetic acid (NEtFOSAA)	<2.0		24.7	24.5		ng/L		100	70 - 130		
Perfluorohexanoic acid (PFHxA)	<2.0		24.7	25.7		ng/L		98	70 - 130		
Perfluorododecanoic acid (PFDoA)	<2.0		24.7	24.3		ng/L		99	70 - 130		
Perfluorooctanoic acid (PFOA)	<2.0		24.7	23.9		ng/L		94	70 - 130		
Perfluorodecanoic acid (PFDA)	<2.0		24.7	23.8		ng/L		96	70 - 130		
Perfluorohexanesulfonic acid (PFHxS)	<2.0		24.7	26.4		ng/L		105	70 - 130		
Perfluorobutanesulfonic acid (PFBS)	<2.0		24.7	28.0		ng/L		110	70 - 130		
Perfluoroheptanoic acid (PFHpA)	<2.0		24.7	24.5		ng/L		97	70 - 130		
Perfluorononanoic acid (PFNA)	<2.0		24.7	25.0		ng/L		101	70 - 130		
Perfluorotetradecanoic acid (PFTA)	<2.0		24.7	23.8		ng/L		97	70 - 130		
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.7	27.2		ng/L		110	70 - 130		
9-Chlorohexadecafluoro-3-oxan onane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.7	24.8		ng/L		100	70 - 130		
11-Chloroeicosafluoro-3-oxaund ecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.7	26.0		ng/L		106	70 - 130		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.7	24.3		ng/L		99	70 - 130		

Lab Sample ID: 380-225111-C-1-A MSD

Matrix: Water

Analysis Batch: 240777

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 240743

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		24.7	19.1		ng/L		78	70 - 130	23	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		24.7	20.6		ng/L		81	70 - 130	25	30
Perfluoroundecanoic acid (PFUnA)	<2.0		24.7	19.8		ng/L		80	70 - 130	25	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.7	18.4		ng/L		75	70 - 130	23	30
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.7	19.8		ng/L		80	70 - 130	21	30
Perfluorohexanoic acid (PFHxA)	<2.0		24.7	21.2		ng/L		80	70 - 130	19	30
Perfluorododecanoic acid (PFDoA)	<2.0		24.7	20.6		ng/L		84	70 - 130	17	30
Perfluorooctanoic acid (PFOA)	<2.0		24.7	20.4		ng/L		80	70 - 130	16	30
Perfluorodecanoic acid (PFDA)	<2.0		24.7	20.0		ng/L		81	70 - 130	17	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-225111-C-1-A MSD

Matrix: Water

Analysis Batch: 240777

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 240743

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorohexanesulfonic acid (PFHxS)	<2.0		24.7	20.8		ng/L		82	70 - 130	24	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		24.7	21.6		ng/L		84	70 - 130	26	30
Perfluoroheptanoic acid (PFHpA)	<2.0		24.7	19.5		ng/L		77	70 - 130	23	30
Perfluorononanoic acid (PFNA)	<2.0		24.7	20.8		ng/L		84	70 - 130	18	30
Perfluorotetradecanoic acid (PFTA)	<2.0		24.7	20.4		ng/L		83	70 - 130	15	30
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.7	21.5		ng/L		87	70 - 130	23	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.7	19.2		ng/L		78	70 - 130	25	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.7	20.1		ng/L		82	70 - 130	26	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.7	18.8		ng/L		76	70 - 130	25	30
Surrogate	MSD %Recovery	MSD Qualifier	Limits								
d5-NEtFOSAA	104		70 - 130								
13C2 PFHxA	107		70 - 130								
13C2 PFDA	108		70 - 130								
13C3-GenX	102		70 - 130								

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

LCMS

Prep Batch: 240630

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225258-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	533	
380-225258-2	FB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	533	
MBL 380-240630/20-A	Method Blank	Total/NA	Water	533	
LCS 380-240630/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-240630/21-A	Lab Control Sample	Total/NA	Water	533	
380-225240-B-1-A MS	Matrix Spike	Total/NA	Water	533	
380-225240-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 240733

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225258-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	533	240630
380-225258-2	FB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	533	240630
MBL 380-240630/20-A	Method Blank	Total/NA	Water	533	240630
LCS 380-240630/22-A	Lab Control Sample	Total/NA	Water	533	240630
MRL 380-240630/21-A	Lab Control Sample	Total/NA	Water	533	240630
380-225240-B-1-A MS	Matrix Spike	Total/NA	Water	533	240630
380-225240-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	240630

Prep Batch: 240743

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225258-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	537.1 DW	
380-225258-2	FB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	537.1 DW	
MBL 380-240743/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-240743/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-240743/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-225111-B-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-225111-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

Analysis Batch: 240777

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225258-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	EPA 537.1 V2	240743
380-225258-2	FB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	EPA 537.1 V2	240743
MBL 380-240743/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	240743
LCS 380-240743/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	240743
MRL 380-240743/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	240743
380-225111-B-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	240743
380-225111-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	240743

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-1

Date Collected: 07/13/26 09:54

Matrix: Drinking Water

Date Received: 07/15/26 10:10

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			240630	N8NE	EA POM	07/17/26 13:55
Total/NA	Analysis	533		1	240733	M7ML	EA POM	07/18/26 19:20
Total/NA	Prep	537.1 DW			240743	LM3A	EA POM	07/18/26 16:04
Total/NA	Analysis	EPA 537.1 V2		1	240777	M7ML	EA POM	07/20/26 08:21

Client Sample ID: FB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-225258-2

Date Collected: 07/13/26 09:54

Matrix: Water

Date Received: 07/15/26 10:10

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			240630	N8NE	EA POM	07/17/26 13:55
Total/NA	Analysis	533		1	240733	M7ML	EA POM	07/18/26 19:29
Total/NA	Prep	537.1 DW			240743	LM3A	EA POM	07/18/26 16:04
Total/NA	Analysis	EPA 537.1 V2		1	240777	M7ML	EA POM	07/20/26 08:30

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-225258-1
SDG: PFAS: Moanalua Wells

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-225258-1	MOANALUA WELLS (331-223-TP202)	Drinking Water	07/13/26 09:54	07/15/26 10:10	Hawaii
380-225258-2	FB: MOANALUA WELLS (331-223-TP202)	Water	07/13/26 09:54	07/15/26 10:10	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Monrovia, CA (Suite 100)
750 Royal Oaks Drive Suite 100
Monrovia, CA 91016
Phone (626) 386-1100

Chain of Custody Record



Environment Testing
America

Client Information		Sampler	Lab PM	Carrier Tracking No(s)	GOC No:
Client Contact: kirk lwamoto		bailey	Lopez, Maria		
Company: City & County of Honolulu		Phone: +1 808 748 5840	E-Mail: Maria.Lopez@et.eurofinsus.com	State of Origin:	Page: Page 1 of 1
Address: 630 South Beretania Street, Chemistry Lab		PWSID		Job #	
City: Honolulu		Due Date Requested		Analysis Requested	
State, Zip: HI, 96843		TAT Requested (days):			
Phone: 808-748-5840 (tel)		Compliance Project: ☐ No			
Email: kiwamoto@hbws.org		PO #: C20525101 exp 05312023			
Project Name: RED-HILL/HBWS sites Event Desc: RUSH Weekly Red Hill		WO #:			
Site:		Project #: 38001111			
		SSOW#:			
Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=other)	Preservation Code:
Moanalua Wells (331-223-TP202)	13-Jul-2026	0954	G	Water	
FB: Moanalua Wells (331-223-TP202)	13-Jul-2026	0954			
Possible Hazard Identification ☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological					
Deliverable Requested I, II, III, IV, Other (specify)					
Empty Kit Relinquished by:					
Date: 7/13/2026 Time: 1400					
Relinquished by: [Signature]					
Relinquished by:					
Custody Seals Intact: ☐ Yes ☐ No					
Custody Seal No					
Cooler Temperature(s) °C and Other Remarks: 3.1-0.0-3.1					
Received by: [Signature]					
Date/Time: 7/15/26 10:10					
Company: EGAO					
Received by:					
Date/Time:					
Company:					
Received by:					
Date/Time:					
Company:					
Method of Shipment: FedEx					
Special Instructions/QC Requirements:					
Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) ☐ Return To Client ☐ Disposal By Lab ☐ Archive For Months					
Total Number of containers: 380-225258 °C					
Special Instructions/Note: chlorinated					

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-225258-1
SDG Number: PFAS: Moanalua Wells

Login Number: 225258

List Number: 1

Creator: Segura, Ryan

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	