

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 7/30/2026 11:37:07 AM

JOB DESCRIPTION

INTERA - Red-Hill-Incident
Site H1 625.1, 8015B_DRO/_GRO, 8260B

JOB NUMBER

380-225332-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Generated
7/30/2026 11:37:07 AM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	12
Surrogate Summary	14
QC Sample Results	16
QC Association Summary	28
Lab Chronicle	30
Certification Summary	31
Method Summary	32
Sample Summary	33
Chain of Custody	34
Receipt Checklists	36



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
*+	LCS and/or LCSD is outside acceptance limits, high biased.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

GC Semi VOA

Qualifier	Qualifier Description
^3+	Reporting Limit Check Standard is outside acceptance limits, high biased

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: INTERA - Red-Hill-Incident

Job ID: 380-225332-1

Job ID: 380-225332-1

Eurofins Pomona

Job Narrative 380-225332-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 7/16/2026 9:52 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 5.8°C.

GC/MS VOA

Method 8260B: The laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) for analytical batch 570-771481 recovered outside control limits for the following analyte: Bromomethane. This analyte was biased high in the LCS and was not detected in the associated samples; therefore, the data have been reported.

Method 8260B: The continuing calibration verification (CCV) associated with batch 570-771481 recovered above the upper control limit for Bromomethane. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported. The associated samples are: BWS2253-H1-AQ (380-225332-1), BWS2253-H1-TB (380-225332-2) and (CCVIS 570-771481/2).

Method 8260B: Insufficient sample volume was available to perform a matrix spike/matrix spike duplicate (MS/MSD) associated with analytical batch 570-771481. The laboratory control sample (LCS) was performed in duplicate (LCSD) to provide precision data for this batch.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

GC/MS Semi VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Gasoline Range Organics

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Diesel Range Organics

Method 8015B: The method reporting limit check (MRL) for preparation batch 570-771057 and analytical batch 570-775508 recovered outside control limits for the following analytes: C10-C28. These analytes were biased high in the MRL and were not detected in the associated samples; therefore, the data have been reported.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2253-H1-AQ

Lab Sample ID: 380-225332-1

No Detections.

Client Sample ID: BWS2253-H1-TB

Lab Sample ID: 380-225332-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2253-H1-AQ

Lab Sample ID: 380-225332-1

Date Collected: 07/15/26 09:00

Matrix: Water

Date Received: 07/16/26 09:52

Method: SW846 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<2.0		2.0	ug/L			07/21/26 01:01	1
1,1,1-Trichloroethane	<1.0		1.0	ug/L			07/21/26 01:01	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	ug/L			07/21/26 01:01	1
1,1,2-Trichloro-1,2,2-trifluoroethane	<10		10	ug/L			07/21/26 01:01	1
1,1,2-Trichloroethane	<1.0		1.0	ug/L			07/21/26 01:01	1
1,1-Dichloroethane	<1.0		1.0	ug/L			07/21/26 01:01	1
1,1-Dichloroethene	<1.0		1.0	ug/L			07/21/26 01:01	1
1,1-Dichloropropene	<1.0		1.0	ug/L			07/21/26 01:01	1
1,2,3-Trichlorobenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
1,2,3-Trichloropropane	<5.0		5.0	ug/L			07/21/26 01:01	1
1,2,4-Trichlorobenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
1,2,4-Trimethylbenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
1,2-Dibromo-3-Chloropropane	<10		10	ug/L			07/21/26 01:01	1
1,2-Dichlorobenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
1,2-Dichloroethane	<0.50		0.50	ug/L			07/21/26 01:01	1
1,2-Dichloropropane	<1.0		1.0	ug/L			07/21/26 01:01	1
1,3,5-Trimethylbenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
1,3-Dichlorobenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
1,3-Dichloropropane	<1.0		1.0	ug/L			07/21/26 01:01	1
1,4-Dichlorobenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
2,2-Dichloropropane	<1.0		1.0	ug/L			07/21/26 01:01	1
2-Butanone	<10		10	ug/L			07/21/26 01:01	1
2-Chlorotoluene	<1.0		1.0	ug/L			07/21/26 01:01	1
2-Hexanone	<10		10	ug/L			07/21/26 01:01	1
4-Chlorotoluene	<1.0		1.0	ug/L			07/21/26 01:01	1
Acetone	<10		10	ug/L			07/21/26 01:01	1
Benzene	<0.50		0.50	ug/L			07/21/26 01:01	1
Bromobenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
Bromochloromethane	<2.0		2.0	ug/L			07/21/26 01:01	1
Bromodichloromethane	<1.0		1.0	ug/L			07/21/26 01:01	1
Bromoform	<5.0		5.0	ug/L			07/21/26 01:01	1
Bromomethane	<10	+	10	ug/L			07/21/26 01:01	1
Carbon disulfide	<10		10	ug/L			07/21/26 01:01	1
Carbon tetrachloride	<0.50		0.50	ug/L			07/21/26 01:01	1
Chlorobenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
Chloroethane	<5.0		5.0	ug/L			07/21/26 01:01	1
Chloroform	<1.0		1.0	ug/L			07/21/26 01:01	1
Chloromethane	<10		10	ug/L			07/21/26 01:01	1
cis-1,2-Dichloroethene	<1.0		1.0	ug/L			07/21/26 01:01	1
cis-1,3-Dichloropropene	<0.50		0.50	ug/L			07/21/26 01:01	1
Dibromochloromethane	<2.0		2.0	ug/L			07/21/26 01:01	1
Dibromomethane	<1.0		1.0	ug/L			07/21/26 01:01	1
Dichlorodifluoromethane	<5.0		5.0	ug/L			07/21/26 01:01	1
Diethyl ether	<10		10	ug/L			07/21/26 01:01	1
Di-isopropyl ether (DIPE)	<2.0		2.0	ug/L			07/21/26 01:01	1
Ethanol	<100		100	ug/L			07/21/26 01:01	1
Ethylbenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
Ethylene Dibromide	<1.0		1.0	ug/L			07/21/26 01:01	1
Ethyl-t-butyl ether (ETBE)	<2.0		2.0	ug/L			07/21/26 01:01	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2253-H1-AQ

Lab Sample ID: 380-225332-1

Date Collected: 07/15/26 09:00

Matrix: Water

Date Received: 07/16/26 09:52

Method: SW846 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexachloro-1,3-butadiene	<10		10	ug/L			07/21/26 01:01	1
Hexane	<5.0		5.0	ug/L			07/21/26 01:01	1
Isobutyl alcohol	<75		75	ug/L			07/21/26 01:01	1
Isopropanol	<75		75	ug/L			07/21/26 01:01	1
Isopropylbenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
m,p-Xylene	<2.0		2.0	ug/L			07/21/26 01:01	1
Methylene Chloride	<10		10	ug/L			07/21/26 01:01	1
Methyl-t-Butyl Ether (MTBE)	<1.0		1.0	ug/L			07/21/26 01:01	1
MIBK	<10		10	ug/L			07/21/26 01:01	1
Naphthalene	<10		10	ug/L			07/21/26 01:01	1
n-Butylbenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
N-Propylbenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
o-Xylene	<1.0		1.0	ug/L			07/21/26 01:01	1
p-Isopropyltoluene	<1.0		1.0	ug/L			07/21/26 01:01	1
sec-Butylbenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
Styrene	<1.0		1.0	ug/L			07/21/26 01:01	1
tert-Amyl alcohol	<50		50	ug/L			07/21/26 01:01	1
Tert-amyl-methyl ether (TAME)	<2.0		2.0	ug/L			07/21/26 01:01	1
tert-Butyl alcohol (TBA)	<10		10	ug/L			07/21/26 01:01	1
tert-Butylbenzene	<1.0		1.0	ug/L			07/21/26 01:01	1
Tetrachloroethene	<1.0		1.0	ug/L			07/21/26 01:01	1
Toluene	<1.0		1.0	ug/L			07/21/26 01:01	1
trans-1,2-Dichloroethene	<1.0		1.0	ug/L			07/21/26 01:01	1
trans-1,3-Dichloropropene	<0.50		0.50	ug/L			07/21/26 01:01	1
Trichloroethene	<1.0		1.0	ug/L			07/21/26 01:01	1
Trichlorofluoromethane	<10		10	ug/L			07/21/26 01:01	1
Vinyl acetate	<10		10	ug/L			07/21/26 01:01	1
Vinyl chloride	<0.50		0.50	ug/L			07/21/26 01:01	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	93		80 - 120		07/21/26 01:01	1
4-Bromofluorobenzene (Surr)	98		80 - 120		07/21/26 01:01	1
Dibromofluoromethane (Surr)	101		80 - 120		07/21/26 01:01	1
Toluene-d8 (Surr)	100		80 - 120		07/21/26 01:01	1

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
2-Methylnaphthalene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Acenaphthene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Acenaphthylene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Anthracene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Benzo[a]anthracene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Benzo[a]pyrene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Benzo[b]fluoranthene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Benzo[g,h,i]perylene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Benzo[k]fluoranthene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Chrysene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Dibenz(a,h)anthracene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Fluoranthene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2253-H1-AQ

Lab Sample ID: 380-225332-1

Date Collected: 07/15/26 09:00

Matrix: Water

Date Received: 07/16/26 09:52

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Indeno[1,2,3-cd]pyrene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Naphthalene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Phenanthrene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1
Pyrene	<0.19		0.19	ug/L		07/19/26 07:42	07/23/26 07:33	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	78		28 - 127	07/19/26 07:42	07/23/26 07:33	1
2-Fluorobiphenyl (Surr)	73		31 - 120	07/19/26 07:42	07/23/26 07:33	1
2-Fluorophenol (Surr)	45		17 - 120	07/19/26 07:42	07/23/26 07:33	1
Nitrobenzene-d5 (Surr)	73		27 - 120	07/19/26 07:42	07/23/26 07:33	1
Phenol-d6 (Surr)	28		10 - 120	07/19/26 07:42	07/23/26 07:33	1
p-Terphenyl-d14 (Surr)	74		45 - 120	07/19/26 07:42	07/23/26 07:33	1

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Butylated Hydroxytoluene	5.6	T J N	ug/L		6.80	128-37-0	07/19/26 07:42	07/28/26 02:03	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	48		33 - 139	07/19/26 07:42	07/28/26 02:03	1
2-Fluorobiphenyl (Surr)	73		33 - 126	07/19/26 07:42	07/28/26 02:03	1
2-Fluorophenol (Surr)	45		12 - 120	07/19/26 07:42	07/28/26 02:03	1
Nitrobenzene-d5 (Surr)	73		36 - 120	07/19/26 07:42	07/28/26 02:03	1
Phenol-d6 (Surr)	27		10 - 120	07/19/26 07:42	07/28/26 02:03	1
p-Terphenyl-d14 (Surr)	71		47 - 131	07/19/26 07:42	07/28/26 02:03	1

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			07/24/26 22:54	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	101		38 - 134		07/24/26 22:54	1

Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26	ug/L		07/19/26 09:04	07/28/26 16:39	1
Motor Oil Range Organics [C24-C36]	<26		26	ug/L		07/19/26 09:04	07/28/26 16:39	1
C8-C18	<26		26	ug/L		07/19/26 09:04	07/28/26 16:39	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	111		60 - 130	07/19/26 09:04	07/28/26 16:39	1

Client Sample ID: BWS2253-H1-TB

Lab Sample ID: 380-225332-2

Date Collected: 07/15/26 09:00

Matrix: Water

Date Received: 07/16/26 09:52

Method: SW846 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<2.0		2.0	ug/L			07/20/26 23:34	1
1,1,1-Trichloroethane	<1.0		1.0	ug/L			07/20/26 23:34	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	ug/L			07/20/26 23:34	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2253-H1-TB

Lab Sample ID: 380-225332-2

Date Collected: 07/15/26 09:00

Matrix: Water

Date Received: 07/16/26 09:52

Method: SW846 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,2-Trichloro-1,2,2-trifluoroethane	<10		10	ug/L			07/20/26 23:34	1
1,1,2-Trichloroethane	<1.0		1.0	ug/L			07/20/26 23:34	1
1,1-Dichloroethane	<1.0		1.0	ug/L			07/20/26 23:34	1
1,1-Dichloroethene	<1.0		1.0	ug/L			07/20/26 23:34	1
1,1-Dichloropropene	<1.0		1.0	ug/L			07/20/26 23:34	1
1,2,3-Trichlorobenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
1,2,3-Trichloropropane	<5.0		5.0	ug/L			07/20/26 23:34	1
1,2,4-Trichlorobenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
1,2,4-Trimethylbenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
1,2-Dibromo-3-Chloropropane	<10		10	ug/L			07/20/26 23:34	1
1,2-Dichlorobenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
1,2-Dichloroethane	<0.50		0.50	ug/L			07/20/26 23:34	1
1,2-Dichloropropane	<1.0		1.0	ug/L			07/20/26 23:34	1
1,3,5-Trimethylbenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
1,3-Dichlorobenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
1,3-Dichloropropane	<1.0		1.0	ug/L			07/20/26 23:34	1
1,4-Dichlorobenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
2,2-Dichloropropane	<1.0		1.0	ug/L			07/20/26 23:34	1
2-Butanone	<10		10	ug/L			07/20/26 23:34	1
2-Chlorotoluene	<1.0		1.0	ug/L			07/20/26 23:34	1
2-Hexanone	<10		10	ug/L			07/20/26 23:34	1
4-Chlorotoluene	<1.0		1.0	ug/L			07/20/26 23:34	1
Acetone	<10		10	ug/L			07/20/26 23:34	1
Benzene	<0.50		0.50	ug/L			07/20/26 23:34	1
Bromobenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
Bromochloromethane	<2.0		2.0	ug/L			07/20/26 23:34	1
Bromodichloromethane	<1.0		1.0	ug/L			07/20/26 23:34	1
Bromoform	<5.0		5.0	ug/L			07/20/26 23:34	1
Bromomethane	<10	+	10	ug/L			07/20/26 23:34	1
Carbon disulfide	<10		10	ug/L			07/20/26 23:34	1
Carbon tetrachloride	<0.50		0.50	ug/L			07/20/26 23:34	1
Chlorobenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
Chloroethane	<5.0		5.0	ug/L			07/20/26 23:34	1
Chloroform	<1.0		1.0	ug/L			07/20/26 23:34	1
Chloromethane	<10		10	ug/L			07/20/26 23:34	1
cis-1,2-Dichloroethene	<1.0		1.0	ug/L			07/20/26 23:34	1
cis-1,3-Dichloropropene	<0.50		0.50	ug/L			07/20/26 23:34	1
Dibromochloromethane	<2.0		2.0	ug/L			07/20/26 23:34	1
Dibromomethane	<1.0		1.0	ug/L			07/20/26 23:34	1
Dichlorodifluoromethane	<5.0		5.0	ug/L			07/20/26 23:34	1
Diethyl ether	<10		10	ug/L			07/20/26 23:34	1
Di-isopropyl ether (DIPE)	<2.0		2.0	ug/L			07/20/26 23:34	1
Ethanol	<100		100	ug/L			07/20/26 23:34	1
Ethylbenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
Ethylene Dibromide	<1.0		1.0	ug/L			07/20/26 23:34	1
Ethyl-t-butyl ether (ETBE)	<2.0		2.0	ug/L			07/20/26 23:34	1
Hexachloro-1,3-butadiene	<10		10	ug/L			07/20/26 23:34	1
Hexane	<5.0		5.0	ug/L			07/20/26 23:34	1
Isobutyl alcohol	<75		75	ug/L			07/20/26 23:34	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2253-H1-TB

Lab Sample ID: 380-225332-2

Date Collected: 07/15/26 09:00

Matrix: Water

Date Received: 07/16/26 09:52

Method: SW846 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Isopropanol	<75		75	ug/L			07/20/26 23:34	1
Isopropylbenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
m,p-Xylene	<2.0		2.0	ug/L			07/20/26 23:34	1
Methylene Chloride	<10		10	ug/L			07/20/26 23:34	1
Methyl-t-Butyl Ether (MTBE)	<1.0		1.0	ug/L			07/20/26 23:34	1
MIBK	<10		10	ug/L			07/20/26 23:34	1
Naphthalene	<10		10	ug/L			07/20/26 23:34	1
n-Butylbenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
N-Propylbenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
o-Xylene	<1.0		1.0	ug/L			07/20/26 23:34	1
p-Isopropyltoluene	<1.0		1.0	ug/L			07/20/26 23:34	1
sec-Butylbenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
Styrene	<1.0		1.0	ug/L			07/20/26 23:34	1
tert-Amyl alcohol	<50		50	ug/L			07/20/26 23:34	1
Tert-amyl-methyl ether (TAME)	<2.0		2.0	ug/L			07/20/26 23:34	1
tert-Butyl alcohol (TBA)	<10		10	ug/L			07/20/26 23:34	1
tert-Butylbenzene	<1.0		1.0	ug/L			07/20/26 23:34	1
Tetrachloroethene	<1.0		1.0	ug/L			07/20/26 23:34	1
Toluene	<1.0		1.0	ug/L			07/20/26 23:34	1
trans-1,2-Dichloroethene	<1.0		1.0	ug/L			07/20/26 23:34	1
trans-1,3-Dichloropropene	<0.50		0.50	ug/L			07/20/26 23:34	1
Trichloroethene	<1.0		1.0	ug/L			07/20/26 23:34	1
Trichlorofluoromethane	<10		10	ug/L			07/20/26 23:34	1
Vinyl acetate	<10		10	ug/L			07/20/26 23:34	1
Vinyl chloride	<0.50		0.50	ug/L			07/20/26 23:34	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	93		80 - 120		07/20/26 23:34	1
4-Bromofluorobenzene (Surr)	98		80 - 120		07/20/26 23:34	1
Dibromofluoromethane (Surr)	101		80 - 120		07/20/26 23:34	1
Toluene-d8 (Surr)	99		80 - 120		07/20/26 23:34	1

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			07/24/26 15:11	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	100		38 - 134		07/24/26 15:11	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2253-H1-AQ

Lab Sample ID: 380-225332-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	HI Org Limit	RL	Method	Prep Type
1,1,1-Trichloroethane	<1.0		ug/L	200	200.0	1.0	8260B	Total/NA
1,1,2-Trichloroethane	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
1,1-Dichloroethene	<1.0		ug/L	7	7.000	1.0	8260B	Total/NA
1,2,3-Trichloropropane	<5.0		ug/L		0.6000	5.0	8260B	Total/NA
1,2,4-Trichlorobenzene	<1.0		ug/L	70	70.00	1.0	8260B	Total/NA
1,2-Dibromo-3-Chloropropane	<10		ug/L	0.2		10	8260B	Total/NA
1,2-Dichlorobenzene	<1.0		ug/L	600	600.0	1.0	8260B	Total/NA
1,2-Dichloroethane	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
1,2-Dichloropropane	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
1,4-Dichlorobenzene	<1.0		ug/L	75	75.000	1.0	8260B	Total/NA
Benzene	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
Bromodichloromethane	<1.0		ug/L	80		1.0	8260B	Total/NA
Bromoform	<5.0		ug/L	80		5.0	8260B	Total/NA
Carbon tetrachloride	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
Chlorobenzene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Chloroform	<1.0		ug/L	80		1.0	8260B	Total/NA
cis-1,2-Dichloroethene	<1.0		ug/L	70	70.00	1.0	8260B	Total/NA
Dibromochloromethane	<2.0		ug/L	80		2.0	8260B	Total/NA
Ethylbenzene	<1.0		ug/L	700	700.0	1.0	8260B	Total/NA
Ethylene Dibromide	<1.0		ug/L	0.05		1.0	8260B	Total/NA
Methylene Chloride	<10		ug/L	5	5.000	10	8260B	Total/NA
Styrene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Tetrachloroethene	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
Toluene	<1.0		ug/L	1000	1000	1.0	8260B	Total/NA
trans-1,2-Dichloroethene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Trichloroethene	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
Vinyl chloride	<0.50		ug/L	2	2.000	0.50	8260B	Total/NA
Benzo[a]pyrene	<0.19		ug/L	0.2		0.19	625.1 SIM	Total/NA

Client Sample ID: BWS2253-H1-TB

Lab Sample ID: 380-225332-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	HI Org Limit	RL	Method	Prep Type
1,1,1-Trichloroethane	<1.0		ug/L	200	200.0	1.0	8260B	Total/NA
1,1,2-Trichloroethane	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
1,1-Dichloroethene	<1.0		ug/L	7	7.000	1.0	8260B	Total/NA
1,2,3-Trichloropropane	<5.0		ug/L		0.6000	5.0	8260B	Total/NA
1,2,4-Trichlorobenzene	<1.0		ug/L	70	70.00	1.0	8260B	Total/NA
1,2-Dibromo-3-Chloropropane	<10		ug/L	0.2		10	8260B	Total/NA
1,2-Dichlorobenzene	<1.0		ug/L	600	600.0	1.0	8260B	Total/NA
1,2-Dichloroethane	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
1,2-Dichloropropane	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
1,4-Dichlorobenzene	<1.0		ug/L	75	75.000	1.0	8260B	Total/NA
Benzene	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA

Eurofins Pomona

Action Limit Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2253-H1-TB (Continued)

Lab Sample ID: 380-225332-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	HI Org	RL	Method	Prep Type
				Limit	Limit			
Bromodichloromethane	<1.0		ug/L	80		1.0	8260B	Total/NA
Bromoform	<5.0		ug/L	80		5.0	8260B	Total/NA
Carbon tetrachloride	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
Chlorobenzene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Chloroform	<1.0		ug/L	80		1.0	8260B	Total/NA
cis-1,2-Dichloroethene	<1.0		ug/L	70	70.00	1.0	8260B	Total/NA
Dibromochloromethane	<2.0		ug/L	80		2.0	8260B	Total/NA
Ethylbenzene	<1.0		ug/L	700	700.0	1.0	8260B	Total/NA
Ethylene Dibromide	<1.0		ug/L	0.05		1.0	8260B	Total/NA
Methylene Chloride	<10		ug/L	5	5.000	10	8260B	Total/NA
Styrene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Tetrachloroethene	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
Toluene	<1.0		ug/L	1000	1000	1.0	8260B	Total/NA
trans-1,2-Dichloroethene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Trichloroethene	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
Vinyl chloride	<0.50		ug/L	2	2.000	0.50	8260B	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		DCA (80-120)	BFB (80-120)	DBFM (80-120)	TOL (80-120)
380-225332-1	BWS2253-H1-AQ	93	98	101	100
380-225332-2	BWS2253-H1-TB	93	98	101	99
LCS 570-771481/1002	Lab Control Sample	98	100	100	98
LCSD 570-771481/3	Lab Control Sample Dup	93	100	99	97
MB 570-771481/5	Method Blank	91	98	100	99

Surrogate Legend

DCA = 1,2-Dichloroethane-d4 (Surr)
BFB = 4-Bromofluorobenzene (Surr)
DBFM = Dibromofluoromethane (Surr)
TOL = Toluene-d8 (Surr)

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
380-225332-1	BWS2253-H1-AQ	48	73	45	73	27	71
MB 570-771023/1-A	Method Blank	57	78	53	83	31	72

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-225006-A-1-A MS	Matrix Spike	89	80	69	70	41	87
380-225006-A-1-B MSD	Matrix Spike Duplicate	81	76	57	67	38	80
380-225332-1	BWS2253-H1-AQ	78	73	45	73	28	74
LCS 570-771023/2-A	Lab Control Sample	89	81	62	73	41	88
LCSD 570-771023/3-A	Lab Control Sample Dup	90	82	64	70	42	93
MB 570-771023/1-A	Method Blank	90	77	56	81	34	77

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Surrogate Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)		
Lab Sample ID	Client Sample ID	BFB1 (38-134)
380-225006-C-1 MS	Matrix Spike	100
380-225006-C-1 MSD	Matrix Spike Duplicate	102
380-225332-1	BWS2253-H1-AQ	101
380-225332-2	BWS2253-H1-TB	100
LCS 570-773807/3	Lab Control Sample	101
LCSD 570-773807/4	Lab Control Sample Dup	99
MB 570-773807/6	Method Blank	99
MRL 570-773807/5	Lab Control Sample	83
Surrogate Legend		
BFB = 4-Bromofluorobenzene (Surr)		

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)		
Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-225332-1	BWS2253-H1-AQ	111
LCS 570-771057/2-A	Lab Control Sample	108
LCSD 570-771057/3-A	Lab Control Sample Dup	110
MB 570-771057/1-A	Method Blank	110
MRL 570-771057/4-A	Lab Control Sample	112
Surrogate Legend		
OTCSN = n-Octacosane (Surr)		

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 570-771481/5

Matrix: Water

Analysis Batch: 771481

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<2.0		2.0	ug/L			07/20/26 19:34	1
1,1,1-Trichloroethane	<1.0		1.0	ug/L			07/20/26 19:34	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	ug/L			07/20/26 19:34	1
1,1,2-Trichloro-1,2,2-trifluoroethane	<10		10	ug/L			07/20/26 19:34	1
1,1,2-Trichloroethane	<1.0		1.0	ug/L			07/20/26 19:34	1
1,1-Dichloroethane	<1.0		1.0	ug/L			07/20/26 19:34	1
1,1-Dichloroethene	<1.0		1.0	ug/L			07/20/26 19:34	1
1,1-Dichloropropene	<1.0		1.0	ug/L			07/20/26 19:34	1
1,2,3-Trichlorobenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
1,2,3-Trichloropropane	<5.0		5.0	ug/L			07/20/26 19:34	1
1,2,4-Trichlorobenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
1,2,4-Trimethylbenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
1,2-Dibromo-3-Chloropropane	<10		10	ug/L			07/20/26 19:34	1
1,2-Dichlorobenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
1,2-Dichloroethane	<0.50		0.50	ug/L			07/20/26 19:34	1
1,2-Dichloropropane	<1.0		1.0	ug/L			07/20/26 19:34	1
1,3,5-Trimethylbenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
1,3-Dichlorobenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
1,3-Dichloropropane	<1.0		1.0	ug/L			07/20/26 19:34	1
1,4-Dichlorobenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
2,2-Dichloropropane	<1.0		1.0	ug/L			07/20/26 19:34	1
2-Butanone	<10		10	ug/L			07/20/26 19:34	1
2-Chlorotoluene	<1.0		1.0	ug/L			07/20/26 19:34	1
2-Hexanone	<10		10	ug/L			07/20/26 19:34	1
4-Chlorotoluene	<1.0		1.0	ug/L			07/20/26 19:34	1
Acetone	<10		10	ug/L			07/20/26 19:34	1
Benzene	<0.50		0.50	ug/L			07/20/26 19:34	1
Bromobenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
Bromochloromethane	<2.0		2.0	ug/L			07/20/26 19:34	1
Bromodichloromethane	<1.0		1.0	ug/L			07/20/26 19:34	1
Bromoform	<5.0		5.0	ug/L			07/20/26 19:34	1
Bromomethane	<10		10	ug/L			07/20/26 19:34	1
Carbon disulfide	<10		10	ug/L			07/20/26 19:34	1
Carbon tetrachloride	<0.50		0.50	ug/L			07/20/26 19:34	1
Chlorobenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
Chloroethane	<5.0		5.0	ug/L			07/20/26 19:34	1
Chloroform	<1.0		1.0	ug/L			07/20/26 19:34	1
Chloromethane	<10		10	ug/L			07/20/26 19:34	1
cis-1,2-Dichloroethene	<1.0		1.0	ug/L			07/20/26 19:34	1
cis-1,3-Dichloropropene	<0.50		0.50	ug/L			07/20/26 19:34	1
Dibromochloromethane	<2.0		2.0	ug/L			07/20/26 19:34	1
Dibromomethane	<1.0		1.0	ug/L			07/20/26 19:34	1
Dichlorodifluoromethane	<5.0		5.0	ug/L			07/20/26 19:34	1
Diethyl ether	<10		10	ug/L			07/20/26 19:34	1
Di-isopropyl ether (DIPE)	<2.0		2.0	ug/L			07/20/26 19:34	1
Ethanol	<100		100	ug/L			07/20/26 19:34	1
Ethylbenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
Ethylene Dibromide	<1.0		1.0	ug/L			07/20/26 19:34	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 570-771481/5

Matrix: Water

Analysis Batch: 771481

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Ethyl-t-butyl ether (ETBE)	<2.0		2.0	ug/L			07/20/26 19:34	1
Hexachloro-1,3-butadiene	<10		10	ug/L			07/20/26 19:34	1
Hexane	<5.0		5.0	ug/L			07/20/26 19:34	1
Isobutyl alcohol	<75		75	ug/L			07/20/26 19:34	1
Isopropanol	<75		75	ug/L			07/20/26 19:34	1
Isopropylbenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
m,p-Xylene	<2.0		2.0	ug/L			07/20/26 19:34	1
Methylene Chloride	<10		10	ug/L			07/20/26 19:34	1
Methyl-t-Butyl Ether (MTBE)	<1.0		1.0	ug/L			07/20/26 19:34	1
MIBK	<10		10	ug/L			07/20/26 19:34	1
Naphthalene	<10		10	ug/L			07/20/26 19:34	1
n-Butylbenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
N-Propylbenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
o-Xylene	<1.0		1.0	ug/L			07/20/26 19:34	1
p-Isopropyltoluene	<1.0		1.0	ug/L			07/20/26 19:34	1
sec-Butylbenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
Styrene	<1.0		1.0	ug/L			07/20/26 19:34	1
tert-Amyl alcohol	<50		50	ug/L			07/20/26 19:34	1
Tert-amyl-methyl ether (TAME)	<2.0		2.0	ug/L			07/20/26 19:34	1
tert-Butyl alcohol (TBA)	<10		10	ug/L			07/20/26 19:34	1
tert-Butylbenzene	<1.0		1.0	ug/L			07/20/26 19:34	1
Tetrachloroethene	<1.0		1.0	ug/L			07/20/26 19:34	1
Toluene	<1.0		1.0	ug/L			07/20/26 19:34	1
trans-1,2-Dichloroethene	<1.0		1.0	ug/L			07/20/26 19:34	1
trans-1,3-Dichloropropene	<0.50		0.50	ug/L			07/20/26 19:34	1
Trichloroethene	<1.0		1.0	ug/L			07/20/26 19:34	1
Trichlorofluoromethane	<10		10	ug/L			07/20/26 19:34	1
Vinyl acetate	<10		10	ug/L			07/20/26 19:34	1
Vinyl chloride	<0.50		0.50	ug/L			07/20/26 19:34	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	91		80 - 120		07/20/26 19:34	1
4-Bromofluorobenzene (Surr)	98		80 - 120		07/20/26 19:34	1
Dibromofluoromethane (Surr)	100		80 - 120		07/20/26 19:34	1
Toluene-d8 (Surr)	99		80 - 120		07/20/26 19:34	1

Lab Sample ID: LCS 570-771481/1002

Matrix: Water

Analysis Batch: 771481

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	20.0	22.6		ug/L		113	83 - 120
1,1,1-Trichloroethane	20.0	19.3		ug/L		96	78 - 123
1,1,2,2-Tetrachloroethane	20.0	20.3		ug/L		101	74 - 125
1,1,2-Trichloro-1,2,2-trifluoroethane	20.0	23.4		ug/L		117	72 - 130
1,1,2-Trichloroethane	20.0	21.0		ug/L		105	82 - 120
1,1-Dichloroethane	20.0	20.4		ug/L		102	79 - 122
1,1-Dichloroethane	20.0	20.7		ug/L		103	74 - 127

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 570-771481/1002

Matrix: Water

Analysis Batch: 771481

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,1-Dichloropropene	20.0	20.1		ug/L		100	75 - 124
1,2,3-Trichlorobenzene	20.0	21.3		ug/L		107	71 - 126
1,2,3-Trichloropropane	20.0	20.9		ug/L		105	73 - 121
1,2,4-Trichlorobenzene	20.0	21.5		ug/L		107	70 - 130
1,2,4-Trimethylbenzene	20.0	22.1		ug/L		110	80 - 125
1,2-Dibromo-3-Chloropropane	20.0	18.6		ug/L		93	64 - 127
1,2-Dichlorobenzene	20.0	22.9		ug/L		115	78 - 122
1,2-Dichloroethane	20.0	19.6		ug/L		98	76 - 123
1,2-Dichloropropane	20.0	20.5		ug/L		102	82 - 120
1,3,5-Trimethylbenzene	20.0	22.1		ug/L		111	79 - 124
1,3-Dichlorobenzene	20.0	21.6		ug/L		108	81 - 120
1,3-Dichloropropane	20.0	20.7		ug/L		103	82 - 120
1,4-Dichlorobenzene	20.0	21.3		ug/L		107	78 - 121
2,2-Dichloropropane	20.0	20.7		ug/L		103	69 - 133
2-Butanone	20.0	16.2		ug/L		81	55 - 142
2-Chlorotoluene	20.0	21.7		ug/L		108	80 - 120
2-Hexanone	20.0	16.1		ug/L		80	54 - 138
4-Chlorotoluene	20.0	21.0		ug/L		105	80 - 121
Acetone	20.0	14.2		ug/L		71	50 - 157
Benzene	20.0	20.9		ug/L		105	80 - 120
Bromobenzene	20.0	22.5		ug/L		113	80 - 120
Bromochloromethane	20.0	20.8		ug/L		104	83 - 123
Bromodichloromethane	20.0	19.7		ug/L		98	83 - 120
Bromoform	20.0	20.6		ug/L		103	75 - 128
Bromomethane	20.0	39.3	*+	ug/L		196	31 - 120
Carbon disulfide	20.0	20.8		ug/L		104	71 - 128
Carbon tetrachloride	20.0	20.5		ug/L		102	72 - 135
Chlorobenzene	20.0	21.4		ug/L		107	84 - 120
Chloroethane	20.0	22.4		ug/L		112	72 - 129
Chloroform	20.0	19.1		ug/L		95	79 - 120
Chloromethane	20.0	26.9		ug/L		134	36 - 148
cis-1,2-Dichloroethene	20.0	20.0		ug/L		100	81 - 120
cis-1,3-Dichloropropene	20.0	20.3		ug/L		101	76 - 125
Dibromochloromethane	20.0	20.2		ug/L		101	82 - 120
Dibromomethane	20.0	20.7		ug/L		103	85 - 120
Dichlorodifluoromethane	20.0	21.4		ug/L		107	52 - 147
Diethyl ether	20.0	18.1		ug/L		90	71 - 127
Di-isopropyl ether (DIPE)	20.0	19.2		ug/L		96	70 - 132
Ethanol	200	271		ug/L		135	48 - 163
Ethylbenzene	20.0	21.5		ug/L		107	81 - 120
Ethylene Dibromide	20.0	21.4		ug/L		107	81 - 120
Ethyl-t-butyl ether (ETBE)	20.0	19.1		ug/L		95	68 - 126
Isopropylbenzene	20.0	21.9		ug/L		110	80 - 122
m,p-Xylene	40.0	44.5		ug/L		111	79 - 122
Methylene Chloride	20.0	20.7		ug/L		104	76 - 120
Methyl-t-Butyl Ether (MTBE)	20.0	17.8		ug/L		89	70 - 124
MIBK	20.0	16.8		ug/L		84	57 - 133
Naphthalene	20.0	18.3		ug/L		92	64 - 124
n-Butylbenzene	20.0	22.1		ug/L		111	78 - 127

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 570-771481/1002

Matrix: Water

Analysis Batch: 771481

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
N-Propylbenzene	20.0	22.5		ug/L		112	80 - 121
o-Xylene	20.0	21.9		ug/L		110	81 - 120
p-Isopropyltoluene	20.0	22.3		ug/L		112	81 - 124
sec-Butylbenzene	20.0	21.6		ug/L		108	80 - 123
Styrene	20.0	22.2		ug/L		111	82 - 120
tert-Amyl alcohol	100	70.3		ug/L		70	30 - 157
Tert-amyl-methyl ether (TAME)	20.0	16.7		ug/L		84	71 - 121
tert-Butyl alcohol (TBA)	100	102		ug/L		102	68 - 128
tert-Butylbenzene	20.0	22.1		ug/L		111	80 - 124
Tetrachloroethene	20.0	21.8		ug/L		109	78 - 126
Toluene	20.0	20.6		ug/L		103	82 - 120
trans-1,2-Dichloroethene	20.0	21.4		ug/L		107	79 - 122
trans-1,3-Dichloropropene	20.0	22.8		ug/L		114	73 - 127
Trichloroethene	20.0	19.6		ug/L		98	83 - 120
Trichlorofluoromethane	20.0	22.9		ug/L		115	74 - 135
Vinyl acetate	20.0	18.0		ug/L		90	56 - 135
Vinyl chloride	20.0	20.7		ug/L		103	68 - 131

Surrogate	LCS %Recovery	LCS Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	98		80 - 120
4-Bromofluorobenzene (Surr)	100		80 - 120
Dibromofluoromethane (Surr)	100		80 - 120
Toluene-d8 (Surr)	98		80 - 120

Lab Sample ID: LCSD 570-771481/3

Matrix: Water

Analysis Batch: 771481

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	20.0	22.7		ug/L		113	83 - 120	0	20
1,1,1-Trichloroethane	20.0	19.4		ug/L		97	78 - 123	1	20
1,1,2,2-Tetrachloroethane	20.0	20.6		ug/L		103	74 - 125	1	20
1,1,2-Trichloro-1,2,2-trifluoroethane	20.0	22.2		ug/L		111	72 - 130	5	20
1,1,2-Trichloroethane	20.0	20.6		ug/L		103	82 - 120	2	20
1,1-Dichloroethane	20.0	20.6		ug/L		103	79 - 122	1	20
1,1-Dichloroethene	20.0	20.4		ug/L		102	74 - 127	2	20
1,1-Dichloropropene	20.0	19.7		ug/L		99	75 - 124	2	20
1,2,3-Trichlorobenzene	20.0	21.7		ug/L		108	71 - 126	2	20
1,2,3-Trichloropropane	20.0	20.9		ug/L		104	73 - 121	0	20
1,2,4-Trichlorobenzene	20.0	22.6		ug/L		113	70 - 130	5	20
1,2,4-Trimethylbenzene	20.0	22.2		ug/L		111	80 - 125	1	20
1,2-Dibromo-3-Chloropropane	20.0	18.1		ug/L		90	64 - 127	3	20
1,2-Dichlorobenzene	20.0	23.4		ug/L		117	78 - 122	2	20
1,2-Dichloroethane	20.0	19.1		ug/L		95	76 - 123	3	20
1,2-Dichloropropane	20.0	20.2		ug/L		101	82 - 120	1	20
1,3,5-Trimethylbenzene	20.0	22.5		ug/L		113	79 - 124	2	20
1,3-Dichlorobenzene	20.0	22.4		ug/L		112	81 - 120	4	20
1,3-Dichloropropane	20.0	20.9		ug/L		105	82 - 120	1	20

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 570-771481/3

Matrix: Water

Analysis Batch: 771481

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1,4-Dichlorobenzene	20.0	21.3		ug/L		107	78 - 121	0	20
2,2-Dichloropropane	20.0	21.4		ug/L		107	69 - 133	4	20
2-Butanone	20.0	15.7		ug/L		79	55 - 142	3	21
2-Chlorotoluene	20.0	21.9		ug/L		109	80 - 120	1	20
2-Hexanone	20.0	16.5		ug/L		82	54 - 138	2	21
4-Chlorotoluene	20.0	21.4		ug/L		107	80 - 121	2	20
Acetone	20.0	13.7		ug/L		68	50 - 157	4	26
Benzene	20.0	20.6		ug/L		103	80 - 120	2	20
Bromobenzene	20.0	22.0		ug/L		110	80 - 120	2	20
Bromochloromethane	20.0	20.7		ug/L		103	83 - 123	1	20
Bromodichloromethane	20.0	19.5		ug/L		98	83 - 120	1	20
Bromoform	20.0	21.1		ug/L		105	75 - 128	2	20
Bromomethane	20.0	38.4	+	ug/L		192	31 - 120	2	22
Carbon disulfide	20.0	20.6		ug/L		103	71 - 128	1	20
Carbon tetrachloride	20.0	20.3		ug/L		101	72 - 135	1	20
Chlorobenzene	20.0	21.4		ug/L		107	84 - 120	0	20
Chloroethane	20.0	23.0		ug/L		115	72 - 129	3	20
Chloroform	20.0	19.2		ug/L		96	79 - 120	1	20
Chloromethane	20.0	26.4		ug/L		132	36 - 148	2	20
cis-1,2-Dichloroethene	20.0	20.0		ug/L		100	81 - 120	0	20
cis-1,3-Dichloropropene	20.0	20.1		ug/L		100	76 - 125	1	20
Dibromochloromethane	20.0	20.5		ug/L		102	82 - 120	1	20
Dibromomethane	20.0	20.5		ug/L		102	85 - 120	1	20
Dichlorodifluoromethane	20.0	23.5		ug/L		118	52 - 147	9	20
Diethyl ether	20.0	17.9		ug/L		89	71 - 127	1	20
Di-isopropyl ether (DIPE)	20.0	19.1		ug/L		96	70 - 132	0	20
Ethanol	200	294		ug/L		147	48 - 163	8	30
Ethylbenzene	20.0	21.3		ug/L		106	81 - 120	1	20
Ethylene Dibromide	20.0	21.3		ug/L		107	81 - 120	0	20
Ethyl-t-butyl ether (ETBE)	20.0	19.6		ug/L		98	68 - 126	3	20
Isopropylbenzene	20.0	21.7		ug/L		108	80 - 122	1	20
m,p-Xylene	40.0	44.0		ug/L		110	79 - 122	1	20
Methylene Chloride	20.0	20.7		ug/L		104	76 - 120	0	20
Methyl-t-Butyl Ether (MTBE)	20.0	17.8		ug/L		89	70 - 124	0	20
MIBK	20.0	16.5		ug/L		82	57 - 133	2	20
Naphthalene	20.0	18.9		ug/L		94	64 - 124	3	20
n-Butylbenzene	20.0	22.5		ug/L		113	78 - 127	2	20
N-Propylbenzene	20.0	22.2		ug/L		111	80 - 121	1	20
o-Xylene	20.0	21.8		ug/L		109	81 - 120	1	20
p-Isopropyltoluene	20.0	22.7		ug/L		113	81 - 124	1	20
sec-Butylbenzene	20.0	22.0		ug/L		110	80 - 123	2	20
Styrene	20.0	22.1		ug/L		111	82 - 120	0	20
tert-Amyl alcohol	100	76.8		ug/L		77	30 - 157	9	30
Tert-amyl-methyl ether (TAME)	20.0	16.8		ug/L		84	71 - 121	1	20
tert-Butyl alcohol (TBA)	100	111		ug/L		111	68 - 128	9	20
tert-Butylbenzene	20.0	22.1		ug/L		111	80 - 124	0	20
Tetrachloroethene	20.0	21.3		ug/L		107	78 - 126	2	20
Toluene	20.0	20.4		ug/L		102	82 - 120	1	20
trans-1,2-Dichloroethene	20.0	21.2		ug/L		106	79 - 122	1	20

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 570-771481/3

Matrix: Water

Analysis Batch: 771481

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
trans-1,3-Dichloropropene	20.0	23.0		ug/L		115	73 - 127	1	20
Trichloroethene	20.0	19.2		ug/L		96	83 - 120	2	20
Trichlorofluoromethane	20.0	23.4		ug/L		117	74 - 135	2	20
Vinyl acetate	20.0	17.7		ug/L		89	56 - 135	1	24
Vinyl chloride	20.0	20.5		ug/L		102	68 - 131	1	20

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	93		80 - 120
4-Bromofluorobenzene (Surr)	100		80 - 120
Dibromofluoromethane (Surr)	99		80 - 120
Toluene-d8 (Surr)	97		80 - 120

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 570-771023/1-A

Matrix: Water

Analysis Batch: 775065

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 771023

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	07/19/26 07:42	07/27/26 20:49	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	57		33 - 139	07/19/26 07:42	07/27/26 20:49	1
2-Fluorobiphenyl (Surr)	78		33 - 126	07/19/26 07:42	07/27/26 20:49	1
2-Fluorophenol (Surr)	53		12 - 120	07/19/26 07:42	07/27/26 20:49	1
Nitrobenzene-d5 (Surr)	83		36 - 120	07/19/26 07:42	07/27/26 20:49	1
Phenol-d6 (Surr)	31		10 - 120	07/19/26 07:42	07/27/26 20:49	1
p-Terphenyl-d14 (Surr)	72		47 - 131	07/19/26 07:42	07/27/26 20:49	1

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: MB 570-771023/1-A

Matrix: Water

Analysis Batch: 771785

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 771023

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
2-Methylnaphthalene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Acenaphthene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Acenaphthylene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Anthracene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Benzo[a]anthracene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Benzo[a]pyrene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Benzo[b]fluoranthene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Benzo[g,h,i]perylene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Benzo[k]fluoranthene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Chrysene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Dibenz(a,h)anthracene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: MB 570-771023/1-A

Matrix: Water

Analysis Batch: 771785

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 771023

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Fluorene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Naphthalene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Phenanthrene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1
Pyrene	<0.20		0.20	ug/L		07/19/26 07:42	07/21/26 07:03	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	90		28 - 127	07/19/26 07:42	07/21/26 07:03	1
2-Fluorobiphenyl (Surr)	77		31 - 120	07/19/26 07:42	07/21/26 07:03	1
2-Fluorophenol (Surr)	56		17 - 120	07/19/26 07:42	07/21/26 07:03	1
Nitrobenzene-d5 (Surr)	81		27 - 120	07/19/26 07:42	07/21/26 07:03	1
Phenol-d6 (Surr)	34		10 - 120	07/19/26 07:42	07/21/26 07:03	1
p-Terphenyl-d14 (Surr)	77		45 - 120	07/19/26 07:42	07/21/26 07:03	1

Lab Sample ID: LCS 570-771023/2-A

Matrix: Water

Analysis Batch: 771785

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 771023

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	20.0	14.7		ug/L		73	47 - 120
2-Methylnaphthalene	20.0	13.1		ug/L		65	43 - 120
Acenaphthene	20.0	16.4		ug/L		82	60 - 132
Acenaphthylene	20.0	16.3		ug/L		81	54 - 126
Anthracene	20.0	16.1		ug/L		81	43 - 120
Benzo[a]anthracene	20.0	17.8		ug/L		89	42 - 133
Benzo[a]pyrene	20.0	17.9		ug/L		90	32 - 148
Benzo[b]fluoranthene	20.0	17.3		ug/L		86	42 - 140
Benzo[g,h,i]perylene	20.0	16.7		ug/L		83	1 - 195
Benzo[k]fluoranthene	20.0	16.2		ug/L		81	25 - 146
Chrysene	20.0	16.8		ug/L		84	44 - 140
Dibenz[a,h]anthracene	20.0	17.1		ug/L		86	1 - 200
Fluoranthene	20.0	17.1		ug/L		85	43 - 121
Fluorene	20.0	17.4		ug/L		87	70 - 120
Indeno[1,2,3-cd]pyrene	20.0	16.6		ug/L		83	1 - 151
Naphthalene	20.0	13.3		ug/L		66	36 - 120
Phenanthrene	20.0	16.8		ug/L		84	65 - 120
Pyrene	20.0	17.8		ug/L		89	70 - 120

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2,4,6-Tribromophenol (Surr)	89		28 - 127
2-Fluorobiphenyl (Surr)	81		31 - 120
2-Fluorophenol (Surr)	62		17 - 120
Nitrobenzene-d5 (Surr)	73		27 - 120
Phenol-d6 (Surr)	41		10 - 120
p-Terphenyl-d14 (Surr)	88		45 - 120

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCSD 570-771023/3-A

Matrix: Water

Analysis Batch: 771785

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 771023

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene	20.0	14.3		ug/L		71	47 - 120	3	20
2-Methylnaphthalene	20.0	12.9		ug/L		64	43 - 120	2	20
Acenaphthene	20.0	16.8		ug/L		84	60 - 132	3	29
Acenaphthylene	20.0	16.6		ug/L		83	54 - 126	2	45
Anthracene	20.0	16.4		ug/L		82	43 - 120	2	40
Benzo[a]anthracene	20.0	18.6		ug/L		93	42 - 133	4	32
Benzo[a]pyrene	20.0	18.2		ug/L		91	32 - 148	2	43
Benzo[b]fluoranthene	20.0	17.3		ug/L		87	42 - 140	0	43
Benzo[g,h,i]perylene	20.0	16.8		ug/L		84	1 - 195	1	61
Benzo[k]fluoranthene	20.0	17.4		ug/L		87	25 - 146	7	38
Chrysene	20.0	17.5		ug/L		88	44 - 140	4	53
Dibenz(a,h)anthracene	20.0	17.5		ug/L		87	1 - 200	2	75
Fluoranthene	20.0	17.3		ug/L		87	43 - 121	2	40
Fluorene	20.0	18.1		ug/L		90	70 - 120	4	23
Indeno[1,2,3-cd]pyrene	20.0	17.0		ug/L		85	1 - 151	2	60
Naphthalene	20.0	13.1		ug/L		66	36 - 120	1	39
Phenanthrene	20.0	17.1		ug/L		85	65 - 120	2	24
Pyrene	20.0	18.7		ug/L		93	70 - 120	5	30

Surrogate	LCSD		Limits
	%Recovery	Qualifier	
2,4,6-Tribromophenol (Surr)	90		28 - 127
2-Fluorobiphenyl (Surr)	82		31 - 120
2-Fluorophenol (Surr)	64		17 - 120
Nitrobenzene-d5 (Surr)	70		27 - 120
Phenol-d6 (Surr)	42		10 - 120
p-Terphenyl-d14 (Surr)	93		45 - 120

Lab Sample ID: 380-225006-A-1-A MS

Matrix: Water

Analysis Batch: 772960

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 771023

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	<0.19		19.4	14.4		ug/L		74	36 - 120
2-Methylnaphthalene	<0.19		19.4	13.2		ug/L		68	32 - 124
Acenaphthene	<0.19		19.4	16.6		ug/L		86	47 - 145
Acenaphthylene	<0.19		19.4	16.1		ug/L		83	33 - 145
Anthracene	<0.19		19.4	15.9		ug/L		82	27 - 133
Benzo[a]anthracene	<0.19		19.4	17.7		ug/L		91	33 - 143
Benzo[a]pyrene	<0.19		19.4	17.7		ug/L		91	17 - 163
Benzo[b]fluoranthene	<0.19		19.4	16.4		ug/L		84	24 - 159
Benzo[g,h,i]perylene	<0.19		19.4	16.5		ug/L		85	1 - 219
Benzo[k]fluoranthene	<0.19		19.4	16.7		ug/L		86	11 - 162
Chrysene	<0.19		19.4	16.6		ug/L		85	17 - 168
Dibenz(a,h)anthracene	<0.19		19.4	16.6		ug/L		86	1 - 227
Fluoranthene	<0.19		19.4	17.1		ug/L		88	26 - 137
Fluorene	<0.19		19.4	17.9		ug/L		92	59 - 121
Indeno[1,2,3-cd]pyrene	<0.19		19.4	16.3		ug/L		84	1 - 171
Naphthalene	<0.19		19.4	13.3		ug/L		69	21 - 133

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: 380-225006-A-1-A MS

Matrix: Water

Analysis Batch: 772960

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 771023

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Phenanthrene	<0.19		19.4	16.6		ug/L		86	54 - 120
Pyrene	<0.19		19.4	17.7		ug/L		92	52 - 120

Surrogate	MS %Recovery	MS Qualifier	Limits
2,4,6-Tribromophenol (Surr)	89		28 - 127
2-Fluorobiphenyl (Surr)	80		31 - 120
2-Fluorophenol (Surr)	69		17 - 120
Nitrobenzene-d5 (Surr)	70		27 - 120
Phenol-d6 (Surr)	41		10 - 120
p-Terphenyl-d14 (Surr)	87		45 - 120

Lab Sample ID: 380-225006-A-1-B MSD

Matrix: Water

Analysis Batch: 772960

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 771023

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene	<0.19		18.9	14.4		ug/L		76	36 - 120	0	30
2-Methylnaphthalene	<0.19		18.9	12.6		ug/L		66	32 - 124	4	30
Acenaphthene	<0.19		18.9	15.6		ug/L		82	47 - 145	6	48
Acenaphthylene	<0.19		18.9	15.3		ug/L		81	33 - 145	6	74
Anthracene	<0.19		18.9	14.9		ug/L		79	27 - 133	6	66
Benzo[a]anthracene	<0.19		18.9	15.9		ug/L		84	33 - 143	11	53
Benzo[a]pyrene	<0.19		18.9	16.0		ug/L		85	17 - 163	10	72
Benzo[b]fluoranthene	<0.19		18.9	14.8		ug/L		78	24 - 159	10	71
Benzo[g,h,i]perylene	<0.19		18.9	15.5		ug/L		82	1 - 219	6	97
Benzo[k]fluoranthene	<0.19		18.9	15.3		ug/L		81	11 - 162	9	63
Chrysene	<0.19		18.9	15.3		ug/L		81	17 - 168	8	87
Dibenz(a,h)anthracene	<0.19		18.9	16.0		ug/L		85	1 - 227	3	126
Fluoranthene	<0.19		18.9	16.0		ug/L		84	26 - 137	7	66
Fluorene	<0.19		18.9	16.7		ug/L		88	59 - 121	7	38
Indeno[1,2,3-cd]pyrene	<0.19		18.9	15.1		ug/L		80	1 - 171	8	99
Naphthalene	<0.19		18.9	12.8		ug/L		68	21 - 133	3	65
Phenanthrene	<0.19		18.9	15.4		ug/L		82	54 - 120	7	39
Pyrene	<0.19		18.9	15.7		ug/L		83	52 - 120	12	49

Surrogate	MSD %Recovery	MSD Qualifier	Limits
2,4,6-Tribromophenol (Surr)	81		28 - 127
2-Fluorobiphenyl (Surr)	76		31 - 120
2-Fluorophenol (Surr)	57		17 - 120
Nitrobenzene-d5 (Surr)	67		27 - 120
Phenol-d6 (Surr)	38		10 - 120
p-Terphenyl-d14 (Surr)	80		45 - 120

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: MB 570-773807/6

Matrix: Water

Analysis Batch: 773807

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			07/24/26 12:18	1
Surrogate	MB %Recovery	MB Qualifier	Limits			Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	99		38 - 134				07/24/26 12:18	1

Lab Sample ID: LCS 570-773807/3

Matrix: Water

Analysis Batch: 773807

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	400	360		ug/L		90	78 - 120
Surrogate	LCS %Recovery	LCS Qualifier	Limits				
4-Bromofluorobenzene (Surr)	101		38 - 134				

Lab Sample ID: LCSD 570-773807/4

Matrix: Water

Analysis Batch: 773807

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	400	381		ug/L		95	78 - 120	6	10
Surrogate	LCSD %Recovery	LCSD Qualifier	Limits						
4-Bromofluorobenzene (Surr)	99		38 - 134						

Lab Sample ID: MRL 570-773807/5

Matrix: Water

Analysis Batch: 773807

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	10.0	12.4		ug/L		124	50 - 150
Surrogate	MRL %Recovery	MRL Qualifier	Limits				
4-Bromofluorobenzene (Surr)	83		38 - 134				

Lab Sample ID: 380-225006-C-1 MS

Matrix: Water

Analysis Batch: 773807

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	<10		400	358		ug/L		89	68 - 122
Surrogate	MS %Recovery	MS Qualifier	Limits						
4-Bromofluorobenzene (Surr)	100		38 - 134						

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: 380-225006-C-1 MSD

Matrix: Water

Analysis Batch: 773807

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	374		ug/L		94	68 - 122	5	18
Surrogate	%Recovery	MSD Qualifier	MSD Limits								
4-Bromofluorobenzene (Surr)	102		38 - 134								

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Lab Sample ID: MB 570-771057/1-A

Matrix: Water

Analysis Batch: 775020

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 771057

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25	ug/L		07/19/26 09:03	07/27/26 18:15	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		07/19/26 09:03	07/27/26 18:15	1
C8-C18	<25		25	ug/L		07/19/26 09:03	07/27/26 18:15	1
Surrogate	%Recovery	MB Qualifier	MB Limits	Prepared	Analyzed	Dil Fac		
n-Octacosane (Surr)	110		60 - 130	07/19/26 09:03	07/27/26 18:15	1		

Lab Sample ID: LCS 570-771057/2-A

Matrix: Water

Analysis Batch: 775020

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 771057

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	RPD
C10-C28	1600	1460		ug/L		92	56 - 127	
Surrogate	%Recovery	LCS Qualifier	LCS Limits					
n-Octacosane (Surr)	108		60 - 130					

Lab Sample ID: LCSD 570-771057/3-A

Matrix: Water

Analysis Batch: 775020

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 771057

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD
C10-C28	1600	1300		ug/L		81	56 - 127	12
Surrogate	%Recovery	LCSD Qualifier	LCSD Limits					
n-Octacosane (Surr)	110		60 - 130					

Lab Sample ID: MRL 570-771057/4-A

Matrix: Water

Analysis Batch: 775508

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 771057

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits	RPD
C10-C28	0.0200	0.0311	^3+	mg/L		155	50 - 150	

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

Lab Sample ID: MRL 570-771057/4-A
Matrix: Water
Analysis Batch: 775508

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 771057

	MRL	MRL	
Surrogate	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	112		60 - 130

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

QC Association Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

GC/MS VOA

Analysis Batch: 771481

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225332-1	BWS2253-H1-AQ	Total/NA	Water	8260B	
380-225332-2	BWS2253-H1-TB	Total/NA	Water	8260B	
MB 570-771481/5	Method Blank	Total/NA	Water	8260B	
LCS 570-771481/1002	Lab Control Sample	Total/NA	Water	8260B	
LCSD 570-771481/3	Lab Control Sample Dup	Total/NA	Water	8260B	

GC/MS Semi VOA

Prep Batch: 771023

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225332-1	BWS2253-H1-AQ	Total/NA	Water	625.1	
MB 570-771023/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-771023/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-771023/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	
380-225006-A-1-A MS	Matrix Spike	Total/NA	Water	625.1	
380-225006-A-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	625.1	

Analysis Batch: 771785

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-771023/1-A	Method Blank	Total/NA	Water	625.1 SIM	771023
LCS 570-771023/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	771023
LCSD 570-771023/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	771023

Analysis Batch: 772960

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225332-1	BWS2253-H1-AQ	Total/NA	Water	625.1 SIM	771023
380-225006-A-1-A MS	Matrix Spike	Total/NA	Water	625.1 SIM	771023
380-225006-A-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	625.1 SIM	771023

Analysis Batch: 775065

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225332-1	BWS2253-H1-AQ	Total/NA	Water	625.1	771023
MB 570-771023/1-A	Method Blank	Total/NA	Water	625.1	771023

GC VOA

Analysis Batch: 773807

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225332-1	BWS2253-H1-AQ	Total/NA	Water	8015B GRO LL	
380-225332-2	BWS2253-H1-TB	Total/NA	Water	8015B GRO LL	
MB 570-773807/6	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-773807/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-773807/4	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-773807/5	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-225006-C-1 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-225006-C-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

GC Semi VOA

Prep Batch: 771057

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225332-1	BWS2253-H1-AQ	Total/NA	Water	3510C	

Eurofins Pomona

QC Association Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

GC Semi VOA (Continued)

Prep Batch: 771057 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-771057/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-771057/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-771057/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-771057/4-A	Lab Control Sample	Total/NA	Water	3510C	

Analysis Batch: 775020

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-771057/1-A	Method Blank	Total/NA	Water	8015B	771057
LCS 570-771057/2-A	Lab Control Sample	Total/NA	Water	8015B	771057
LCSD 570-771057/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	771057

Analysis Batch: 775508

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-225332-1	BWS2253-H1-AQ	Total/NA	Water	8015B	771057
MRL 570-771057/4-A	Lab Control Sample	Total/NA	Water	8015B	771057

Lab Chronicle

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2253-H1-AQ

Lab Sample ID: 380-225332-1

Date Collected: 07/15/26 09:00

Matrix: Water

Date Received: 07/16/26 09:52

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260B		1	771481	GC3Z	EET CAL 4	07/21/26 01:01
Total/NA	Prep	625.1			771023	KLZQ	EET CAL 4	07/19/26 07:42
Total/NA	Analysis	625.1		1	775065	S4EA	EET CAL 4	07/28/26 02:03
Total/NA	Prep	625.1			771023	KLZQ	EET CAL 4	07/19/26 07:42
Total/NA	Analysis	625.1 SIM		1	772960	S4EA	EET CAL 4	07/23/26 07:33
Total/NA	Analysis	8015B GRO LL		1	773807	A9VE	EET CAL 4	07/24/26 22:54
Total/NA	Prep	3510C			771057	TVD6	EET CAL 4	07/19/26 09:04
Total/NA	Analysis	8015B		1	775508	TR8L	EET CAL 4	07/28/26 16:39

Client Sample ID: BWS2253-H1-TB

Lab Sample ID: 380-225332-2

Date Collected: 07/15/26 09:00

Matrix: Water

Date Received: 07/16/26 09:52

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260B		1	771481	GC3Z	EET CAL 4	07/20/26 23:34
Total/NA	Analysis	8015B GRO LL		1	773807	A9VE	EET CAL 4	07/24/26 15:11

Laboratory References:

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	7296.01	11-30-26
A2LA	ISO/IEC 17025	7296.01	11-30-26
Alaska (UST)	State	25-005	03-02-27
Arizona	State	AZ0830	11-17-26
California	Los Angeles County Sanitation Districts	9257304	07-31-26
California	SCAQMD LAP	17LA0919	11-30-26
California	State	3082	07-31-28
Kansas	NELAP	E-10420	07-31-26
Nevada	State	CA00111	07-31-26
Oregon	NELAP	4175	02-02-27
Texas	NELAP	T104704499	07-31-27
USDA	US Federal Programs	525-23-159-97150	09-30-26
Utah	NELAP	CA00111	02-28-27
Washington	State	C916	10-12-26

Method Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Method	Method Description	Protocol	Laboratory
8260B	Volatile Organic Compounds (GC/MS)	SW846	EET CAL 4
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-225332-1
SDG: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-225332-1	BWS2253-H1-AQ	Water	07/15/26 09:00	07/16/26 09:52	Hawaii
380-225332-2	BWS2253-H1-TB	Water	07/15/26 09:00	07/16/26 09:52	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

 eurofins | Environment Testing



380-225332 COC

Chain of Custody Record



Loc: 380
Env **225332**

[illegible]

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-225332-1

SDG Number: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Login Number: 225332

List Source: Eurofins Pomona

List Number: 1

Creator: Edrosa, Rey

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-225332-1

SDG Number: Site H1 625.1, 8015B_DRO/_GRO, 8260B

Login Number: 225332

List Source: Eurofins Calscience

List Number: 2

List Creation: 07/17/26 06:13 PM

Creator: Khana, Piyush

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	1.6
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	fgf5
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	