

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

# ANALYTICAL REPORT

## PREPARED FOR

Attn: Mr. Erwin Kawata  
City & County of Honolulu  
630 South Beretania Street  
Public Service Bldg. Room 310  
Honolulu, Hawaii 96843

Generated 6/8/2026 3:03:25 PM

## JOB DESCRIPTION

RED-HILL  
PFAS: Ka'amilo Wells P1  
RUSH Weekly Red Hill

## JOB NUMBER

380-217760-1

# Eurofins Pomona

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

## Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

## Authorization



Authorized for release by  
Maria Lopez, Project Manager  
[Maria.Lopez@et.eurofinsus.com](mailto:Maria.Lopez@et.eurofinsus.com)  
(626)386-1100

Generated  
6/8/2026 3:03:25 PM



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	7
Action Limit Summary . . . . .	11
Surrogate Summary . . . . .	12
Isotope Dilution Summary . . . . .	13
QC Sample Results . . . . .	14
QC Association Summary . . . . .	25
Lab Chronicle . . . . .	26
Certification Summary . . . . .	27
Method Summary . . . . .	28
Sample Summary . . . . .	29
Chain of Custody . . . . .	30
Receipt Checklists . . . . .	31

# Definitions/Glossary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Qualifiers

### LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: City & County of Honolulu  
Project: RED-HILL

Job ID: 380-217760-1

**Job ID: 380-217760-1**

**Eurofins Pomona**

## Job Narrative 380-217760-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

### Receipt

The samples were received on 6/3/2026 10:05 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 2.0°C.

### PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

## Detection Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-217760-1  
 SDG: PFAS: Ka'amilo Wells P1

**Client Sample ID: KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-1**

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanesulfonic acid (PFBS)	3.2		2.0	ng/L	1		533	Total/NA
Perfluoroheptanoic acid (PFHpA)	2.1		2.0	ng/L	1		533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.7		2.0	ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	4.4		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	5.1		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.8		2.0	ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	4.2		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	5.1		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanoic acid (PFHxA)	4.1		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	4.0		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorobutanesulfonic acid (PFBS)	3.3		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluoroheptanoic acid (PFHpA)	2.2		2.0	ng/L	1		EPA 537.1 V2	Total/NA

**Client Sample ID: FB KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-2**

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona



# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

**Client Sample ID: KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-1**

Date Collected: 06/01/26 11:30

Matrix: Water

Date Received: 06/03/26 10:05

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
<b>Perfluorobutanesulfonic acid (PFBS)</b>	<b>3.2</b>		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
<b>Perfluoroheptanoic acid (PFHpA)</b>	<b>2.1</b>		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
<b>Perfluorohexanesulfonic acid (PFHxS)</b>	<b>3.7</b>		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
<b>Perfluorohexanoic acid (PFHxA)</b>	<b>4.4</b>		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
<b>Perfluorooctanesulfonic acid (PFOS)</b>	<b>5.1</b>		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
<b>Perfluorooctanoic acid (PFOA)</b>	<b>3.8</b>		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
<b>Perfluoropentanoic acid (PFPeA)</b>	<b>4.2</b>		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 14:10	1
<b>Isotope Dilution</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>			<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
13C3 HFPO-DA	92		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C6 PFDA	93		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C5 PFHxA	95		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C4 PFHpA	102		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C8 PFOA	104		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C9 PFNA	101		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C7 PFUnA	101		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C2 PFDoA	101		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C4 PFBA	104		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C5 PFPeA	101		50 - 200			06/06/26 16:06	06/07/26 14:10	1
13C3 PFBS	103		50 - 200			06/06/26 16:06	06/07/26 14:10	1

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

**Client Sample ID: KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-1**

Date Collected: 06/01/26 11:30

Matrix: Water

Date Received: 06/03/26 10:05

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 PFHxS	107		50 - 200	06/06/26 16:06	06/07/26 14:10	1
13C8 PFOS	112		50 - 200	06/06/26 16:06	06/07/26 14:10	1
13C2-4:2-FTS	116		50 - 200	06/06/26 16:06	06/07/26 14:10	1
13C2-6:2-FTS	102		50 - 200	06/06/26 16:06	06/07/26 14:10	1
13C2-8:2-FTS	97		50 - 200	06/06/26 16:06	06/07/26 14:10	1

**Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
<b>Perfluorooctanesulfonic acid (PFOS)</b>	<b>5.1</b>		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
N-methylperfluorooctanesulfonamide cetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
N-ethylperfluorooctanesulfonamide acetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
<b>Perfluorohexanoic acid (PFHxA)</b>	<b>4.1</b>		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
<b>Perfluorooctanoic acid (PFOA)</b>	<b>4.0</b>		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
<b>Perfluorohexanesulfonic acid (PFHxS)</b>	<b>4.0</b>		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
<b>Perfluorobutanesulfonic acid (PFBS)</b>	<b>3.3</b>		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
<b>Perfluoroheptanoic acid (PFHpA)</b>	<b>2.2</b>		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
Perfluorotridecanoic acid (PFTDA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:07	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	97		70 - 130	06/04/26 02:25	06/05/26 04:07	1
13C2 PFHxA	107		70 - 130	06/04/26 02:25	06/05/26 04:07	1
13C2 PFDA	103		70 - 130	06/04/26 02:25	06/05/26 04:07	1
13C3-GenX	101		70 - 130	06/04/26 02:25	06/05/26 04:07	1

**Client Sample ID: FB KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-2**

Date Collected: 06/01/26 11:30

Matrix: Water

Date Received: 06/03/26 10:05

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

**Client Sample ID: FB KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-2**

Date Collected: 06/01/26 11:30

Matrix: Water

Date Received: 06/03/26 10:05

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		06/06/26 16:06	06/07/26 17:12	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	64		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C6 PFDA	72		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C5 PFHxA	77		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C4 PFHpA	77		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C8 PFOA	80		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C9 PFNA	82		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C7 PFUnA	77		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C2 PFDoA	76		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C4 PFBA	89		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C5 PFPeA	83		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C3 PFBS	100		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C3 PFHxS	102		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C8 PFOS	110		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C2-4:2-FTS	103		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C2-6:2-FTS	103		50 - 200	06/06/26 16:06	06/07/26 17:12	1
13C2-8:2-FTS	103		50 - 200	06/06/26 16:06	06/07/26 17:12	1

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

**Client Sample ID: FB KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-2**

Date Collected: 06/01/26 11:30

Matrix: Water

Date Received: 06/03/26 10:05

**Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
N-methylperfluorooctanesulfonamide acetic acid (NMeFOSAA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
N-ethylperfluorooctanesulfonamide acetic acid (NEtFOSAA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		06/04/26 02:25	06/05/26 04:16	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	95		70 - 130	06/04/26 02:25	06/05/26 04:16	1
13C2 PFHxA	102		70 - 130	06/04/26 02:25	06/05/26 04:16	1
13C2 PFDA	98		70 - 130	06/04/26 02:25	06/05/26 04:16	1
13C3-GenX	94		70 - 130	06/04/26 02:25	06/05/26 04:16	1

# Action Limit Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

**Client Sample ID: KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-1**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL		RL	Method	Prep Type
				Limit				
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10		2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.7		ng/L	10		2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10		2.0	533	Total/NA
<b>Perfluorooctanesulfonic acid (PFOS)</b>	<b>5.1</b>		ng/L	<b>4</b>		2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	3.8		ng/L	4		2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10		2.0	EPA 537.1 V2	Total/NA
<b>Perfluorooctanesulfonic acid (PFOS)</b>	<b>5.1</b>		ng/L	<b>4</b>		2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	4.0		ng/L	4		2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	4.0		ng/L	10		2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10		2.0	EPA 537.1 V2	Total/NA

**Client Sample ID: FB KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-2**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL		RL	Method	Prep Type
				Limit				
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10		2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10		2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10		2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4		2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4		2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10		2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4		2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4		2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10		2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10		2.0	EPA 537.1 V2	Total/NA

# Surrogate Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-217760-1  
 SDG: PFAS: Ka'amilo Wells P1

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-217500-A-1-B MS	Matrix Spike	98	107	106	106
380-217500-A-1-C MSD	Matrix Spike Duplicate	101	102	102	96
380-217760-1	KA'AMILO WELLS P1 (331-031-WL008)	97	107	103	101
380-217760-2	FB KA'AMILO WELLS P1 (331-031-WL008)	95	102	98	94
LCS 380-231597/21-A	Lab Control Sample	99	113	104	105
MBL 380-231597/19-A	Method Blank	93	102	99	95
MRL 380-231597/20-A	Lab Control Sample	99	106	98	97

### Surrogate Legend

d5NEFOS = d5-NEtFOSAA  
 PFHxA = 13C2 PFHxA  
 PFDA = 13C2 PFDA  
 GenX = 13C3-GenX



# Isotope Dilution Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-217760-1  
 SDG: PFAS: Ka'amilo Wells P1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

**Matrix: Water**

**Prep Type: Total/NA**

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFD <sub>o</sub> A (50-200)
380-217760-1	KA'AMILO WELLS P1 (331-031-WL)	92	93	95	102	104	101	101	101
380-217760-1 MS	KA'AMILO WELLS P1 (331-031-WL008)	84	87	90	82	92	93	96	95
380-217760-1 MSD	KA'AMILO WELLS P1 (331-031-WL008)	90	94	95	95	97	102	99	100
380-217760-2	FB KA'AMILO WELLS P1 (331-031-WL008)	64	72	77	77	80	82	77	76
LCS 380-232107/22-A	Lab Control Sample	79	81	86	85	86	89	87	86
MBL 380-232107/20-A	Method Blank	74	74	83	82	81	80	80	82
MRL 380-232107/21-A	Lab Control Sample	77	88	87	87	93	96	96	96

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-217760-1	KA'AMILO WELLS P1 (331-031-WL)	104	101	103	107	112	116	102	97
380-217760-1 MS	KA'AMILO WELLS P1 (331-031-WL008)	97	94	108	111	112	109	102	100
380-217760-1 MSD	KA'AMILO WELLS P1 (331-031-WL008)	101	95	106	111	113	100	99	95
380-217760-2	FB KA'AMILO WELLS P1 (331-031-WL008)	89	83	100	102	110	103	103	103
LCS 380-232107/22-A	Lab Control Sample	86	81	107	108	110	99	101	99
MBL 380-232107/20-A	Method Blank	85	86	99	105	109	100	98	95
MRL 380-232107/21-A	Lab Control Sample	93	91	99	105	110	98	101	97

**Surrogate Legend**

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFD<sub>o</sub>A = 13C2 PFD<sub>o</sub>A
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

**Lab Sample ID: MBL 380-232107/20-A**  
**Matrix: Water**  
**Analysis Batch: 232132**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 232107**

Analyte	MBL	MBL	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.48		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.25		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		06/06/26 16:06	06/07/26 13:41	1

Isotope Dilution	MBL	MBL	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C3 HFPO-DA	74		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C6 PFDA	74		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C5 PFHxA	83		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C4 PFHpA	82		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C8 PFOA	81		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C9 PFNA	80		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C7 PFUnA	80		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C2 PFDoA	82		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C4 PFBA	85		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C5 PFPeA	86		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C3 PFBS	99		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C3 PFHxS	105		50 - 200	06/06/26 16:06	06/07/26 13:41	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MBL 380-232107/20-A**  
**Matrix: Water**  
**Analysis Batch: 232132**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 232107**

Isotope Dilution	MBL MBL		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C8 PFOS	109		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C2-4:2-FTS	100		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C2-6:2-FTS	98		50 - 200	06/06/26 16:06	06/07/26 13:41	1
13C2-8:2-FTS	95		50 - 200	06/06/26 16:06	06/07/26 13:41	1

**Lab Sample ID: LCS 380-232107/22-A**  
**Matrix: Water**  
**Analysis Batch: 232132**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 232107**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	120	106		ng/L		88	70 - 130
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	120	110		ng/L		91	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	120	118		ng/L		98	70 - 130
Perfluorobutanesulfonic acid (PFBS)	120	116		ng/L		97	70 - 130
Perfluorodecanoic acid (PFDA)	120	127		ng/L		106	70 - 130
Perfluorododecanoic acid (PFDoA)	120	121		ng/L		101	70 - 130
Perfluoroheptanoic acid (PFHpA)	120	116		ng/L		97	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	120	113		ng/L		94	70 - 130
Perfluorohexanoic acid (PFHxA)	120	115		ng/L		96	70 - 130
Perfluorononanoic acid (PFNA)	120	117		ng/L		97	70 - 130
Perfluorooctanesulfonic acid (PFOS)	120	116		ng/L		96	70 - 130
Perfluorooctanoic acid (PFOA)	120	113		ng/L		94	70 - 130
Perfluoroundecanoic acid (PFUnA)	120	119		ng/L		99	70 - 130
Perfluorobutanoic acid (PFBA)	120	116		ng/L		96	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	120	112		ng/L		93	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	120	117		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	120	112		ng/L		93	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	120	107		ng/L		89	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	120	149		ng/L		124	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	120	116		ng/L		96	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	120	117		ng/L		97	70 - 130
Perfluoropentanoic acid (PFPeA)	120	118		ng/L		98	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	120	114		ng/L		94	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: LCS 380-232107/22-A**  
**Matrix: Water**  
**Analysis Batch: 232132**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 232107**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	120	114		ng/L		94	70 - 130
<b>LCS LCS</b>							
<b>Isotope Dilution</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				
13C3 HFPO-DA	79		50 - 200				
13C6 PFDA	81		50 - 200				
13C5 PFHxA	86		50 - 200				
13C4 PFHpA	85		50 - 200				
13C8 PFOA	86		50 - 200				
13C9 PFNA	89		50 - 200				
13C7 PFUnA	87		50 - 200				
13C2 PFDoA	86		50 - 200				
13C4 PFBA	86		50 - 200				
13C5 PFPeA	81		50 - 200				
13C3 PFBS	107		50 - 200				
13C3 PFHxS	108		50 - 200				
13C8 PFOS	110		50 - 200				
13C2-4:2-FTS	99		50 - 200				
13C2-6:2-FTS	101		50 - 200				
13C2-8:2-FTS	99		50 - 200				

**Lab Sample ID: MRL 380-232107/21-A**  
**Matrix: Water**  
**Analysis Batch: 232132**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 232107**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.98	J	ng/L		99	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	1.85	J	ng/L		92	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	2.11	J	ng/L		105	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	2.00	J	ng/L		99	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	2.15	J	ng/L		107	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.32	J	ng/L		116	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	2.34	J	ng/L		116	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	2.28	J	ng/L		113	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	2.25	J	ng/L		112	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	2.10	J	ng/L		105	50 - 150
Perfluorononanoic acid (PFNA)	2.01	2.18	J	ng/L		108	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	2.08	J	ng/L		103	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	2.08	J	ng/L		104	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.23	J	ng/L		111	50 - 150
Perfluorobutanoic acid (PFBA)	2.01	2.23	J	ng/L		111	50 - 150

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MRL 380-232107/21-A**  
**Matrix: Water**  
**Analysis Batch: 232132**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 232107**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.01	2.23	J	ng/L		111	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.01	2.21	J	ng/L		110	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.01	2.25	J	ng/L		112	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.01	1.93	J	ng/L		96	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.01	2.17	J	ng/L		108	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.01	1.98	J	ng/L		99	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.01	1.93	J	ng/L		96	50 - 150
Perfluoropentanoic acid (PFPeA)	2.01	2.21	J	ng/L		110	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.01	2.07	J	ng/L		103	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.01	2.10	J	ng/L		105	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	77		50 - 200
13C6 PFDA	88		50 - 200
13C5 PFHxA	87		50 - 200
13C4 PFHpA	87		50 - 200
13C8 PFOA	93		50 - 200
13C9 PFNA	96		50 - 200
13C7 PFUnA	96		50 - 200
13C2 PFDoA	96		50 - 200
13C4 PFBA	93		50 - 200
13C5 PFPeA	91		50 - 200
13C3 PFBS	99		50 - 200
13C3 PFHxS	105		50 - 200
13C8 PFOS	110		50 - 200
13C2-4:2-FTS	98		50 - 200
13C2-6:2-FTS	101		50 - 200
13C2-8:2-FTS	97		50 - 200

**Lab Sample ID: 380-217760-1 MS**  
**Matrix: Water**  
**Analysis Batch: 232132**

**Client Sample ID: KA'AMILO WELLS P1 (331-031-WL008)**  
**Prep Type: Total/NA**  
**Prep Batch: 232107**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.5	54.0		ng/L		89	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.5	53.1		ng/L		88	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.5	64.6		ng/L		107	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-217760-1 MS

Client Sample ID: KA'AMILO WELLS P1 (331-031-WL008)

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 232132

Prep Batch: 232107

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
Hexafluoropropylene Oxide	<2.0		60.5	60.5		ng/L		100	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	3.2		60.5	58.8		ng/L		92	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		60.5	66.1		ng/L		109	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		60.5	59.6		ng/L		99	70 - 130
Perfluoroheptanoic acid (PFHpA)	2.1		60.5	68.0		ng/L		109	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	3.7		60.5	61.7		ng/L		96	70 - 130
Perfluorohexanoic acid (PFHxA)	4.4		60.5	63.7		ng/L		98	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		60.5	62.5		ng/L		103	70 - 130
Perfluorooctanesulfonic acid (PFOS)	5.1		60.5	62.5		ng/L		95	70 - 130
Perfluorooctanoic acid (PFOA)	3.8		60.5	63.5		ng/L		99	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		60.5	58.8		ng/L		97	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		60.5	60.0		ng/L		96	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.5	59.6		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.5	57.5		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.5	58.3		ng/L		96	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		60.5	50.2		ng/L		83	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.5	68.1		ng/L		113	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.5	59.4		ng/L		98	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.5	61.0		ng/L		101	70 - 130
Perfluoropentanoic acid (PFPeA)	4.2		60.5	64.0		ng/L		99	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.5	60.1		ng/L		99	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.5	59.4		ng/L		97	70 - 130

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	84		50 - 200
13C6 PFDA	87		50 - 200
13C5 PFHxA	90		50 - 200
13C4 PFHpA	82		50 - 200
13C8 PFOA	92		50 - 200
13C9 PFNA	93		50 - 200
13C7 PFUnA	96		50 - 200
13C2 PFDoA	95		50 - 200
13C4 PFBA	97		50 - 200
13C5 PFPeA	94		50 - 200
13C3 PFBS	108		50 - 200
13C3 PFHxS	111		50 - 200
13C8 PFOS	112		50 - 200

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: 380-217760-1 MS**  
**Matrix: Water**  
**Analysis Batch: 232132**

**Client Sample ID: KA'AMILO WELLS P1 (331-031-WL008)**  
**Prep Type: Total/NA**  
**Prep Batch: 232107**

<i>Isotope Dilution</i>	<i>MS MS</i>	<i>Limits</i>
<i>%Recovery</i>	<i>Qualifier</i>	
13C2-4:2-FTS	109	50 - 200
13C2-6:2-FTS	102	50 - 200
13C2-8:2-FTS	100	50 - 200

**Lab Sample ID: 380-217760-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 232132**

**Client Sample ID: KA'AMILO WELLS P1 (331-031-WL008)**  
**Prep Type: Total/NA**  
**Prep Batch: 232107**

<i>Analyte</i>	<i>Sample Result</i>	<i>Sample Qualifier</i>	<i>Spike Added</i>	<i>MSD Result</i>	<i>MSD Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec Limits</i>	<i>RPD</i>	<i>RPD Limit</i>
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.5	54.5		ng/L		90	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.5	53.6		ng/L		89	70 - 130	1	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.5	59.7		ng/L		99	70 - 130	8	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		60.5	58.8		ng/L		97	70 - 130	3	30
Perfluorobutanesulfonic acid (PFBS)	3.2		60.5	62.1		ng/L		97	70 - 130	5	30
Perfluorodecanoic acid (PFDA)	<2.0		60.5	64.0		ng/L		106	70 - 130	3	30
Perfluorododecanoic acid (PFDoA)	<2.0		60.5	61.2		ng/L		101	70 - 130	3	30
Perfluoroheptanoic acid (PFHpA)	2.1		60.5	62.4		ng/L		100	70 - 130	9	30
Perfluorohexanesulfonic acid (PFHxS)	3.7		60.5	59.4		ng/L		92	70 - 130	4	30
Perfluorohexanoic acid (PFHxA)	4.4		60.5	63.0		ng/L		97	70 - 130	1	30
Perfluorononanoic acid (PFNA)	<2.0		60.5	59.1		ng/L		98	70 - 130	5	30
Perfluorooctanesulfonic acid (PFOS)	5.1		60.5	61.8		ng/L		94	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	3.8		60.5	63.1		ng/L		98	70 - 130	1	30
Perfluoroundecanoic acid (PFUnA)	<2.0		60.5	61.1		ng/L		101	70 - 130	4	30
Perfluorobutanoic acid (PFBA)	<2.0		60.5	60.1		ng/L		97	70 - 130	0	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.5	64.1		ng/L		106	70 - 130	7	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.5	60.2		ng/L		100	70 - 130	5	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.5	59.7		ng/L		99	70 - 130	2	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		60.5	49.8		ng/L		82	70 - 130	1	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.5	68.5		ng/L		113	70 - 130	1	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.5	60.9		ng/L		101	70 - 130	3	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.5	63.0		ng/L		104	70 - 130	3	30
Perfluoropentanoic acid (PFPeA)	4.2		60.5	64.4		ng/L		100	70 - 130	1	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.5	58.6		ng/L		97	70 - 130	2	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.5	59.0		ng/L		97	70 - 130	1	30

## QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

### Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	90		50 - 200
13C6 PFDA	94		50 - 200
13C5 PFHxA	95		50 - 200
13C4 PFHpA	95		50 - 200
13C8 PFOA	97		50 - 200
13C9 PFNA	102		50 - 200
13C7 PFUnA	99		50 - 200
13C2 PFDoA	100		50 - 200
13C4 PFBA	101		50 - 200
13C5 PFPeA	95		50 - 200
13C3 PFBS	106		50 - 200
13C3 PFHxS	111		50 - 200
13C8 PFOS	113		50 - 200
13C2-4:2-FTS	100		50 - 200
13C2-6:2-FTS	99		50 - 200
13C2-8:2-FTS	95		50 - 200

### Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-231597/19-A  
Matrix: Water  
Analysis Batch: 231722

Client Sample ID: Method Blank  
Prep Type: Total/NA  
Prep Batch: 231597

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
Perfluorotridecanoic acid (PFTTrDA)	<0.36		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		06/04/26 02:25	06/05/26 01:13	1

  

Surrogate	MBL MBL		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
d5-NEtFOSAA	93		70 - 130	06/04/26 02:25	06/05/26 01:13	1
13C2 PFHxA	102		70 - 130	06/04/26 02:25	06/05/26 01:13	1
13C2 PFDA	99		70 - 130	06/04/26 02:25	06/05/26 01:13	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

**Lab Sample ID: MBL 380-231597/19-A**  
**Matrix: Water**  
**Analysis Batch: 231722**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 231597**

<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3-GenX	95	Qualifier	70 - 130	06/04/26 02:25	06/05/26 01:13	1

**Lab Sample ID: LCS 380-231597/21-A**  
**Matrix: Water**  
**Analysis Batch: 231722**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 231597**

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>			<i>Limits</i>	<i>Limits</i>
Hexafluoropropylene Oxide	25.1	25.7		ng/L		103	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	25.1	25.8		ng/L		103	70 - 130
Perfluoroundecanoic acid (PFUnA)	25.1	25.3		ng/L		101	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	25.1	24.1		ng/L		96	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	25.1	22.9		ng/L		91	70 - 130
Perfluorohexanoic acid (PFHxA)	25.1	25.8		ng/L		103	70 - 130
Perfluorododecanoic acid (PFDoA)	25.1	25.2		ng/L		100	70 - 130
Perfluorooctanoic acid (PFOA)	25.1	25.5		ng/L		102	70 - 130
Perfluorodecanoic acid (PFDA)	25.1	25.7		ng/L		102	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	25.1	26.7		ng/L		106	70 - 130
Perfluorobutanesulfonic acid (PFBS)	25.1	25.2		ng/L		100	70 - 130
Perfluoroheptanoic acid (PFHpA)	25.1	26.0		ng/L		104	70 - 130
Perfluorononanoic acid (PFNA)	25.1	25.8		ng/L		103	70 - 130
Perfluorotetradecanoic acid (PFTA)	25.1	19.9		ng/L		79	70 - 130
Perfluorotridecanoic acid (PFTrDA)	25.1	24.7		ng/L		98	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	25.1	24.4		ng/L		97	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	25.1	24.3		ng/L		97	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	25.1	24.4		ng/L		97	70 - 130

<i>Surrogate</i>	<i>LCS</i>	<i>LCS</i>	<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
d5-NEtFOSAA	99		70 - 130
13C2 PFHxA	113		70 - 130
13C2 PFDA	104		70 - 130
13C3-GenX	105		70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

**Lab Sample ID: MRL 380-231597/20-A**  
**Matrix: Water**  
**Analysis Batch: 231722**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 231597**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	1.94	J	ng/L		97	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	1.94	J	ng/L		96	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.06	J	ng/L		103	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.01	1.84	J	ng/L		92	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.01	2.00	J	ng/L		100	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	2.03	J	ng/L		101	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	1.96	J	ng/L		97	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	2.05	J	ng/L		102	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	1.90	J	ng/L		94	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	2.06	J	ng/L		103	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	2.04	J	ng/L		102	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	2.13	J	ng/L		106	50 - 150
Perfluorononanoic acid (PFNA)	2.01	2.03	J	ng/L		101	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.01	1.76	J	ng/L		88	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.01	2.07	J	ng/L		103	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	1.88	J	ng/L		94	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.87	J	ng/L		93	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.97	J	ng/L		98	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	99		70 - 130
13C2 PFHxA	106		70 - 130
13C2 PFDA	98		70 - 130
13C3-GenX	97		70 - 130

**Lab Sample ID: 380-217500-A-1-B MS**  
**Matrix: Water**  
**Analysis Batch: 231722**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 231597**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		25.2	26.1		ng/L		104	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		25.2	26.3		ng/L		103	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		25.2	26.9		ng/L		107	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.2	25.0		ng/L		99	70 - 130

Eurofins Pomona





# QC Association Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-217760-1  
 SDG: PFAS: Ka'amilo Wells P1

## LCMS

### Prep Batch: 231597

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-217760-1	KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	537.1 DW	
380-217760-2	FB KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	537.1 DW	
MBL 380-231597/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-231597/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-231597/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-217500-A-1-B MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-217500-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

### Analysis Batch: 231722

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-217760-1	KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	EPA 537.1 V2	231597
380-217760-2	FB KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	EPA 537.1 V2	231597
MBL 380-231597/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	231597
LCS 380-231597/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	231597
MRL 380-231597/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	231597
380-217500-A-1-B MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	231597
380-217500-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	231597

### Prep Batch: 232107

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-217760-1	KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	533	
380-217760-2	FB KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	533	
MBL 380-232107/20-A	Method Blank	Total/NA	Water	533	
LCS 380-232107/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-232107/21-A	Lab Control Sample	Total/NA	Water	533	
380-217760-1 MS	KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	533	
380-217760-1 MSD	KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	533	

### Analysis Batch: 232132

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-217760-1	KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	533	232107
380-217760-2	FB KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	533	232107
MBL 380-232107/20-A	Method Blank	Total/NA	Water	533	232107
LCS 380-232107/22-A	Lab Control Sample	Total/NA	Water	533	232107
MRL 380-232107/21-A	Lab Control Sample	Total/NA	Water	533	232107
380-217760-1 MS	KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	533	232107
380-217760-1 MSD	KA'AMILO WELLS P1 (331-031-WL008)	Total/NA	Water	533	232107

## Lab Chronicle

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-217760-1  
 SDG: PFAS: Ka'amilo Wells P1

**Client Sample ID: KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-1**

Date Collected: 06/01/26 11:30

Matrix: Water

Date Received: 06/03/26 10:05

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			232107	N8NE	EA POM	06/06/26 16:06
Total/NA	Analysis	533		1	232132	M7ML	EA POM	06/07/26 14:10
Total/NA	Prep	537.1 DW			231597	G9MN	EA POM	06/04/26 02:25
Total/NA	Analysis	EPA 537.1 V2		1	231722	Y5FM	EA POM	06/05/26 04:07

**Client Sample ID: FB KA'AMILO WELLS P1 (331-031-WL008)**

**Lab Sample ID: 380-217760-2**

Date Collected: 06/01/26 11:30

Matrix: Water

Date Received: 06/03/26 10:05

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			232107	N8NE	EA POM	06/06/26 16:06
Total/NA	Analysis	533		1	232132	M7ML	EA POM	06/07/26 17:12
Total/NA	Prep	537.1 DW			231597	G9MN	EA POM	06/04/26 02:25
Total/NA	Analysis	EPA 537.1 V2		1	231722	Y5FM	EA POM	06/05/26 04:16

**Laboratory References:**

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

# Accreditation/Certification Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

## Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

# Method Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



# Sample Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-217760-1  
SDG: PFAS: Ka'amilo Wells P1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-217760-1	KA'AMILO WELLS P1 (331-031-WL008)	Water	06/01/26 11:30	06/03/26 10:05	Hawaii
380-217760-2	FB KA'AMILO WELLS P1 (331-031-WL008)	Water	06/01/26 11:30	06/03/26 10:05	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17



## Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-217760-1  
SDG Number: PFAS: Ka'amilo Wells P1

**Login Number: 217760**

**List Number: 1**

**Creator: Ngo, Theodore**

**List Source: Eurofins Pomona**

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

