

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 8/24/2026 5:18:47 PM

JOB DESCRIPTION

RED-HILL
Weekly: Aiea Gulch Wells Pump 2
RUSH Weekly Red Hill

JOB NUMBER

380-230425-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Generated
8/24/2026 5:18:47 PM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
QC Sample Results	15
QC Association Summary	29
Lab Chronicle	31
Certification Summary	32
Method Summary	34
Sample Summary	35
Chain of Custody	36
Receipt Checklists	39



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Qualifiers

GC/MS Semi VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-230425-1

Job ID: 380-230425-1

Eurofins Pomona

Job Narrative 380-230425-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 8/12/2026 9:50 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 2 coolers at receipt time were 1.5°C and 2.5°C.

GC/MS Semi VOA

625.1 and 625.1 SIM results for AIEA GULCH WELLS PUMP 2 (331-202-TP072) (380-230425-1) collected on 08/10/26 are a resample for AIEA GULCH WELLS PUMP 2 (331-202-TP072) (380-228887-1) collected on 08/03/26. (XWB4)

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Gasoline Range Organics

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Diesel Range Organics

8015B_DRO results for AIEA GULCH WELLS PUMP 2 (331-202-TP072) (380-230425-1) collected on 08/10/26 are a resample for AIEA GULCH WELLS PUMP 2 (331-202-TP072) (380-228887-1) collected on 08/03/26. (XWB4)

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**
PWSID Number: HI0000331

Lab Sample ID: 380-230425-1

☐ No Detections.

**Client Sample ID: TB: AIEA GULCH WELLS P2
(331-202-TP072)**

Lab Sample ID: 380-230425-2

☐ No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-230425-1

Date Collected: 08/10/26 11:20

Matrix: Drinking Water

Date Received: 08/12/26 09:50

PWSID Number: HI0000331

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
2,4'-DDD	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
2,4'-DDE	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
2,4'-DDT	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
2,4-Dinitrotoluene	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
2,6-Dinitrotoluene	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
2-Methylnaphthalene	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
4,4'-DDD	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
4,4'-DDE	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
4,4'-DDT	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Acenaphthene	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Acenaphthylene	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Acetochlor	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Alachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
alpha-BHC	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
alpha-Chlordane	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Anthracene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 15:06	1
Atrazine	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Benz(a)anthracene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Benzo[a]pyrene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 15:06	1
Benzo[b]fluoranthene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 15:06	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Benzo[k]fluoranthene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 15:06	1
beta-BHC	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59	ug/L		08/13/26 14:50	08/16/26 15:06	1
Bromacil	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Butachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Butylbenzylphthalate	<0.49		0.49	ug/L		08/13/26 14:50	08/16/26 15:06	1
Chlorobenzilate	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Chloroneb	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Chlorothalonil (Draconil, Bravo)	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Chlorpyrifos	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Chrysene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 15:06	1
delta-BHC	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Di(2-ethylhexyl)adipate	<0.59		0.59	ug/L		08/13/26 14:50	08/16/26 15:06	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Dieldrin	<0.0099		0.0099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Diethylphthalate	<0.49		0.49	ug/L		08/13/26 14:50	08/16/26 15:06	1
Dimethylphthalate	<0.49		0.49	ug/L		08/13/26 14:50	08/16/26 15:06	1
Di-n-butyl phthalate	<0.99		0.99	ug/L		08/13/26 14:50	08/16/26 15:06	1
Di-n-octyl phthalate	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Endosulfan I (Alpha)	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Endosulfan II (Beta)	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Endosulfan sulfate	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Endrin	<0.0099		0.0099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Endrin aldehyde	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
EPTC	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-230425-1

Date Collected: 08/10/26 11:20

Matrix: Drinking Water

Date Received: 08/12/26 09:50

PWSID Number: HI0000331

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Fluorene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
gamma-Chlordane	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Heptachlor	<0.0099		0.0099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Heptachlor epoxide (isomer B)	<0.0099		0.0099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Hexachlorobenzene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Isophorone	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Lindane	<0.0099		0.0099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Malathion	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Methoxychlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Metolachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Molinate	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Naphthalene	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Parathion	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Pendimethalin (Penoxaline)	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Phenanthrene	<0.040		0.040	ug/L		08/13/26 14:50	08/16/26 15:06	1
Propachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Pyrene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Simazine	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Terbacil	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Terbutylazine	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Thiobencarb	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L		08/13/26 14:50	08/16/26 15:06	1
trans-Nonachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 15:06	1
Trifluralin	<0.099		0.099	ug/L		08/13/26 14:50	08/16/26 15:06	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	08/13/26 14:50	08/16/26 15:06	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	98		70 - 130	08/13/26 14:50	08/16/26 15:06	1
Perylene-d12	93		70 - 130	08/13/26 14:50	08/16/26 15:06	1
Triphenylphosphate	104		70 - 130	08/13/26 14:50	08/16/26 15:06	1

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
2-Methylnaphthalene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Acenaphthene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Acenaphthylene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Anthracene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Benzo[a]anthracene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Benzo[a]pyrene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Benzo[b]fluoranthene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Benzo[g,h,i]perylene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Benzo[k]fluoranthene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Chrysene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-230425-1

Date Collected: 08/10/26 11:20

Matrix: Drinking Water

Date Received: 08/12/26 09:50

PWSID Number: HI0000331

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Dibenz(a,h)anthracene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Fluoranthene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Fluorene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Naphthalene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Phenanthrene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1
Pyrene	<0.20		0.20	ug/L		08/15/26 13:10	08/19/26 10:47	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	86		28 - 127	08/15/26 13:10	08/19/26 10:47	1
2-Fluorobiphenyl (Surr)	81		31 - 120	08/15/26 13:10	08/19/26 10:47	1
2-Fluorophenol (Surr)	47		17 - 120	08/15/26 13:10	08/19/26 10:47	1
Nitrobenzene-d5 (Surr)	82		27 - 120	08/15/26 13:10	08/19/26 10:47	1
Phenol-d6 (Surr)	29		10 - 120	08/15/26 13:10	08/19/26 10:47	1
p-Terphenyl-d14 (Surr)	72		45 - 120	08/15/26 13:10	08/19/26 10:47	1

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	08/15/26 13:10	08/19/26 13:43	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	70		33 - 139	08/15/26 13:10	08/19/26 13:43	1
2-Fluorobiphenyl (Surr)	86		33 - 126	08/15/26 13:10	08/19/26 13:43	1
2-Fluorophenol (Surr)	50		12 - 120	08/15/26 13:10	08/19/26 13:43	1
Nitrobenzene-d5 (Surr)	89		36 - 120	08/15/26 13:10	08/19/26 13:43	1
Phenol-d6 (Surr)	28		10 - 120	08/15/26 13:10	08/19/26 13:43	1
p-Terphenyl-d14 (Surr)	88		47 - 131	08/15/26 13:10	08/19/26 13:43	1

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			08/20/26 16:00	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	100		38 - 134		08/20/26 16:00	1

Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26	ug/L		08/14/26 06:12	08/23/26 04:47	1
Motor Oil Range Organics [C24-C36]	<26		26	ug/L		08/14/26 06:12	08/23/26 04:47	1
C8-C18	<26		26	ug/L		08/14/26 06:12	08/23/26 04:47	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	103		60 - 130	08/14/26 06:12	08/23/26 04:47	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

**Client Sample ID: TB: AIEA GULCH WELLS P2
(331-202-TP072)**

Lab Sample ID: 380-230425-2

Date Collected: 08/10/26 11:20

Matrix: Water

Date Received: 08/12/26 09:50

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			08/20/26 20:44	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	90		38 - 134				08/20/26 20:44	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)
PWSID Number: HI0000331

Lab Sample ID: 380-230425-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Alachlor	<0.049		ug/L	2	0.049	525.2	Total/NA
Atrazine	<0.049		ug/L	3	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.020		ug/L	0.2	0.020	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.59		ug/L	6	0.59	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.59		ug/L	400	0.59	525.2	Total/NA
Endrin	<0.0099		ug/L	2	0.0099	525.2	Total/NA
Heptachlor	<0.0099		ug/L	0.4	0.0099	525.2	Total/NA
Heptachlor epoxide (isomer B)	<0.0099		ug/L	0.2	0.0099	525.2	Total/NA
Hexachlorobenzene	<0.049		ug/L	1	0.049	525.2	Total/NA
Hexachlorocyclopentadiene	<0.049		ug/L	50	0.049	525.2	Total/NA
Lindane	<0.0099		ug/L	0.2	0.0099	525.2	Total/NA
Methoxychlor	<0.049		ug/L	40	0.049	525.2	Total/NA
Simazine	<0.049		ug/L	4	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.20		ug/L	0.2	0.20	625.1 SIM	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

		Percent Surrogate Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	2NMX	PRY	TPP					
		(70-130)	(70-130)	(70-130)					
380-230425-1	AIEA GULCH WELLS PUMP 2 (	98	93	104					
Surrogate Legend									
2NMX = 2-Nitro-m-xylene									
PRY = Perylene-d12									
TPP = Triphenylphosphate									

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

		Percent Surrogate Recovery (Acceptance Limits)						
Lab Sample ID	Client Sample ID	2NMX	PRY	TPP				
		(70-130)	(70-130)	(70-130)				
380-229848-BM-1-A MS	Matrix Spike	99	97	103				
380-230422-I-1-A DU	Duplicate	98	91	102				
LCS 380-246318/23-A	Lab Control Sample	96	96	104				
MB 380-246318/21-A	Method Blank	97	94	100				
MRL 380-246318/22-A	Lab Control Sample	98	93	104				
Surrogate Legend								
2NMX = 2-Nitro-m-xylene								
PRY = Perylene-d12								
TPP = Triphenylphosphate								

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

		Percent Surrogate Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)		
380-230425-1	AIEA GULCH WELLS PUMP 2 (	70	86	50	89	28	88		
Surrogate Legend									
TBP = 2,4,6-Tribromophenol (Surr)									
FBP = 2-Fluorobiphenyl (Surr)									
2FP = 2-Fluorophenol (Surr)									
NBZ = Nitrobenzene-d5 (Surr)									
PHL6 = Phenol-d6 (Surr)									
TPHd14 = p-Terphenyl-d14 (Surr)									

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

		Percent Surrogate Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)		
MB 570-784853/1-A	Method Blank	77	91	57	100	33	90		
Surrogate Legend									
TBP = 2,4,6-Tribromophenol (Surr)									
FBP = 2-Fluorobiphenyl (Surr)									
2FP = 2-Fluorophenol (Surr)									
NBZ = Nitrobenzene-d5 (Surr)									

Eurofins Pomona

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-230425-1	AIEA GULCH WELLS PUMP 2 (	86	81	47	82	29	72

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
LCS 570-784853/2-A	Lab Control Sample	89	89	71	68	46	95
LCSD 570-784853/3-A	Lab Control Sample Dup	86	84	66	66	44	94
MB 570-784853/1-A	Method Blank	88	79	55	90	33	74

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB1 (38-134)
380-230425-1	AIEA GULCH WELLS PUMP 2 (	100

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB1 (38-134)
380-230425-2	TB: AIEA GULCH WELLS P2 (3:	90
380-230428-C-1 MS	Matrix Spike	91
380-230428-C-1 MSD	Matrix Spike Duplicate	103
LCS 570-787520/3	Lab Control Sample	98
LCSD 570-787520/4	Lab Control Sample Dup	97

Eurofins Pomona

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB1 (38-134)
MB 570-787520/5	Method Blank	85
MRL 570-787520/6	Lab Control Sample	99

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-230425-1	AIEA GULCH WELLS PUMP 2 (	103

Surrogate Legend

OTCSN = n-Octacosane (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-230428-B-1-A MS	Matrix Spike	88
380-230428-B-1-B MSD	Matrix Spike Duplicate	92
LCS 570-783767/2-A	Lab Control Sample	101
LCSD 570-783767/3-A	Lab Control Sample Dup	108
MB 570-783767/1-A	Method Blank	104
MRL 570-783767/4-A	Lab Control Sample	105

Surrogate Legend

OTCSN = n-Octacosane (Surr)

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-246318/21-A

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 246318

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
2,4'-DDD	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
2,4'-DDE	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
2,4'-DDT	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
2,4-Dinitrotoluene	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
2,6-Dinitrotoluene	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
2-Methylnaphthalene	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
4,4'-DDD	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
4,4'-DDE	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
4,4'-DDT	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Acenaphthene	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Acenaphthylene	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Acetochlor	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Alachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
alpha-BHC	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
alpha-Chlordane	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Anthracene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 10:17	1
Atrazine	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Benz(a)anthracene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Benzo[a]pyrene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 10:17	1
Benzo[b]fluoranthene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 10:17	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Benzo[k]fluoranthene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 10:17	1
beta-BHC	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59	ug/L		08/13/26 14:50	08/16/26 10:17	1
Bromacil	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Butachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Butylbenzylphthalate	<0.49		0.49	ug/L		08/13/26 14:50	08/16/26 10:17	1
Chlorobenzilate	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Chloroneb	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Chlorothalonil (Draconil, Bravo)	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Chlorpyrifos	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Chrysene	<0.020		0.020	ug/L		08/13/26 14:50	08/16/26 10:17	1
delta-BHC	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Di(2-ethylhexyl)adipate	<0.59		0.59	ug/L		08/13/26 14:50	08/16/26 10:17	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Dieldrin	<0.0098		0.0098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Diethylphthalate	<0.49		0.49	ug/L		08/13/26 14:50	08/16/26 10:17	1
Dimethylphthalate	<0.49		0.49	ug/L		08/13/26 14:50	08/16/26 10:17	1
Di-n-butyl phthalate	<0.98		0.98	ug/L		08/13/26 14:50	08/16/26 10:17	1
Di-n-octyl phthalate	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Endosulfan I (Alpha)	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Endosulfan II (Beta)	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Endosulfan sulfate	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Endrin	<0.0098		0.0098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Endrin aldehyde	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
EPTC	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-246318/21-A

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 246318

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Fluorene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
gamma-Chlordane	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Heptachlor	<0.0098		0.0098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Heptachlor epoxide (isomer B)	<0.0098		0.0098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Hexachlorobenzene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Isophorone	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Lindane	<0.0098		0.0098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Malathion	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Methoxychlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Metolachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Molinate	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Naphthalene	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Parathion	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Pendimethalin (Penoxaline)	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Phenanthrene	<0.039		0.039	ug/L		08/13/26 14:50	08/16/26 10:17	1
Propachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Pyrene	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Simazine	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Terbacil	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Terbutylazine	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Thiobencarb	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L		08/13/26 14:50	08/16/26 10:17	1
trans-Nonachlor	<0.049		0.049	ug/L		08/13/26 14:50	08/16/26 10:17	1
Trifluralin	<0.098		0.098	ug/L		08/13/26 14:50	08/16/26 10:17	1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Undecane	6.31	T J N	ug/L		3.03	1120-21-4	08/13/26 14:50	08/16/26 10:17	1
9-Octadecenamide, (Z)-	2.09	T J N	ug/L		7.72	301-02-0	08/13/26 14:50	08/16/26 10:17	1
13-Docosenamide, (Z)-	0.911	T J N	ug/L		10.19	112-84-5	08/13/26 14:50	08/16/26 10:17	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	97		70 - 130	08/13/26 14:50	08/16/26 10:17	1
Perylene-d12	94		70 - 130	08/13/26 14:50	08/16/26 10:17	1
Triphenylphosphate	100		70 - 130	08/13/26 14:50	08/16/26 10:17	1

Lab Sample ID: LCS 380-246318/23-A

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	1.96	1.97		ug/L		100	70 - 130
2,4'-DDD	1.96	2.13		ug/L		109	70 - 130
2,4'-DDE	1.96	2.00		ug/L		102	70 - 130
2,4'-DDT	1.96	2.08		ug/L		106	70 - 130
2,4-Dinitrotoluene	1.96	2.05		ug/L		105	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-246318/23-A

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
2,6-Dinitrotoluene	1.96	2.00		ug/L		102	70 - 130
2-Methylnaphthalene	1.96	1.98		ug/L		101	70 - 130
4,4'-DDD	1.96	2.12		ug/L		108	70 - 130
4,4'-DDE	1.96	2.07		ug/L		106	70 - 130
4,4'-DDT	1.96	2.04		ug/L		105	70 - 130
Acenaphthene	1.96	2.05		ug/L		105	70 - 130
Acenaphthylene	1.96	2.04		ug/L		104	70 - 130
Acetochlor	1.96	2.15		ug/L		110	70 - 130
Alachlor	1.96	2.17		ug/L		111	70 - 130
alpha-BHC	1.96	2.09		ug/L		107	70 - 130
alpha-Chlordane	1.96	2.02		ug/L		103	70 - 130
Anthracene	1.96	1.87		ug/L		96	70 - 130
Atrazine	1.96	2.17		ug/L		111	70 - 130
Benz(a)anthracene	1.96	2.07		ug/L		106	70 - 130
Benzo[a]pyrene	1.96	2.06		ug/L		105	70 - 130
Benzo[b]fluoranthene	1.96	2.14		ug/L		109	70 - 130
Benzo[g,h,i]perylene	1.96	1.98		ug/L		101	70 - 130
Benzo[k]fluoranthene	1.96	2.12		ug/L		108	70 - 130
beta-BHC	1.96	2.09		ug/L		107	70 - 130
Bis(2-ethylhexyl) phthalate	1.96	2.12		ug/L		108	70 - 130
Bromacil	1.96	1.84		ug/L		94	70 - 130
Butachlor	1.96	2.22		ug/L		114	70 - 130
Butylbenzylphthalate	1.96	2.21		ug/L		113	70 - 130
Chlorobenzilate	1.96	2.05		ug/L		105	70 - 130
Chloroneb	1.96	2.03		ug/L		104	70 - 130
Chlorothalonil (Draconil, Bravo)	1.96	2.05		ug/L		105	70 - 130
Chlorpyrifos	1.96	2.11		ug/L		108	70 - 130
Chrysene	1.96	2.11		ug/L		108	70 - 130
delta-BHC	1.96	2.07		ug/L		106	70 - 130
Di(2-ethylhexyl)adipate	1.96	2.16		ug/L		110	70 - 130
Dibenz(a,h)anthracene	1.96	1.87		ug/L		95	70 - 130
Diclorvos (DDVP)	1.96	1.90		ug/L		97	70 - 130
Dieldrin	1.96	2.09		ug/L		107	70 - 130
Diethylphthalate	1.96	2.19		ug/L		112	70 - 130
Dimethylphthalate	1.96	2.07		ug/L		106	70 - 130
Di-n-butyl phthalate	3.91	4.26		ug/L		109	70 - 130
Di-n-octyl phthalate	1.96	2.06		ug/L		105	70 - 130
Endosulfan I (Alpha)	1.96	2.05		ug/L		105	70 - 130
Endosulfan II (Beta)	1.96	2.11		ug/L		108	70 - 130
Endosulfan sulfate	1.96	2.05		ug/L		105	70 - 130
Endrin	1.96	2.13		ug/L		109	70 - 130
Endrin aldehyde	1.96	2.00		ug/L		102	60 - 130
EPTC	1.96	2.03		ug/L		104	70 - 130
Fluoranthene	1.96	2.24		ug/L		114	70 - 130
Fluorene	1.96	2.10		ug/L		107	70 - 130
gamma-Chlordane	1.96	2.07		ug/L		106	70 - 130
Heptachlor	1.96	1.99		ug/L		102	70 - 130
Heptachlor epoxide (isomer B)	1.96	2.09		ug/L		107	70 - 130
Hexachlorobenzene	1.96	1.98		ug/L		101	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-246318/23-A

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexachlorocyclopentadiene	1.96	1.88		ug/L		96	70 - 130
Indeno[1,2,3-cd]pyrene	1.96	1.88		ug/L		96	70 - 130
Isophorone	1.96	1.94		ug/L		99	70 - 130
Lindane	1.96	2.12		ug/L		108	70 - 130
Malathion	1.96	2.20		ug/L		113	70 - 130
Methoxychlor	1.96	2.27		ug/L		116	70 - 130
Metolachlor	1.96	2.18		ug/L		111	70 - 130
Molinate	1.96	2.08		ug/L		107	70 - 130
Naphthalene	1.96	1.94		ug/L		99	70 - 130
Parathion	1.96	2.30		ug/L		118	70 - 130
Pendimethalin (Penoxaline)	1.96	2.17		ug/L		111	70 - 130
Phenanthrene	1.96	2.02		ug/L		103	70 - 130
Propachlor	1.96	2.20		ug/L		112	70 - 130
Pyrene	1.96	2.17		ug/L		111	70 - 130
Simazine	1.96	2.06		ug/L		105	70 - 130
Terbacil	1.96	1.96		ug/L		100	70 - 130
Terbutylazine	1.96	2.25		ug/L		115	70 - 130
Thiobencarb	1.96	2.10		ug/L		107	70 - 130
trans-Nonachlor	1.96	2.05		ug/L		105	70 - 130
Trifluralin	1.96	2.12		ug/L		109	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2-Nitro-m-xylene	96		70 - 130
Perylene-d12	96		70 - 130
Triphenylphosphate	104		70 - 130

Lab Sample ID: MRL 380-246318/22-A

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	0.0984	0.0969	J	ug/L		98	50 - 150
2,4'-DDD	0.0984	0.0940	J	ug/L		95	50 - 150
2,4'-DDE	0.0984	0.0985		ug/L		100	50 - 150
2,4'-DDT	0.0984	0.119		ug/L		121	50 - 150
2,4-Dinitrotoluene	0.0984	0.112		ug/L		114	50 - 150
2,6-Dinitrotoluene	0.0984	0.109		ug/L		111	50 - 150
2-Methylnaphthalene	0.0984	0.0975	J	ug/L		99	50 - 150
4,4'-DDD	0.0984	0.109		ug/L		110	50 - 150
4,4'-DDE	0.0984	0.101		ug/L		102	50 - 150
4,4'-DDT	0.0984	0.117		ug/L		119	50 - 150
Acenaphthene	0.0984	0.0964	J	ug/L		98	50 - 150
Acenaphthylene	0.0984	0.0804	J	ug/L		82	50 - 150
Acetochlor	0.0984	0.109		ug/L		110	50 - 150
Alachlor	0.0492	0.0578		ug/L		117	50 - 150
alpha-BHC	0.0984	0.103		ug/L		105	50 - 150
alpha-Chlordane	0.0246	<0.029		ug/L		111	50 - 150
Anthracene	0.0197	0.0249		ug/L		126	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-246318/22-A

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Atrazine	0.0492	0.0596		ug/L		121	50 - 150
Benz(a)anthracene	0.0492	0.0559		ug/L		114	50 - 150
Benzo[a]pyrene	0.0197	0.0244		ug/L		124	50 - 150
Benzo[b]fluoranthene	0.0197	0.0233		ug/L		118	50 - 150
Benzo[g,h,i]perylene	0.0492	0.0485	J	ug/L		98	50 - 150
Benzo[k]fluoranthene	0.0197	0.0234		ug/L		119	50 - 150
beta-BHC	0.0984	0.111		ug/L		113	50 - 150
Bis(2-ethylhexyl) phthalate	0.591	0.707		ug/L		120	50 - 150
Bromacil	0.0984	0.113		ug/L		115	50 - 150
Butachlor	0.0492	0.0584		ug/L		119	50 - 150
Butylbenzylphthalate	0.492	0.548		ug/L		111	50 - 150
Chlorobenzilate	0.0984	0.105		ug/L		106	50 - 150
Chloroneb	0.0984	0.0921	J	ug/L		94	50 - 150
Chlorothalonil (Draconil, Bravo)	0.0984	0.105		ug/L		107	50 - 150
Chlorpyrifos	0.0492	0.0507		ug/L		103	50 - 150
Chrysene	0.0197	0.0240		ug/L		122	50 - 150
delta-BHC	0.0984	0.113		ug/L		115	50 - 150
Di(2-ethylhexyl)adipate	0.591	0.672		ug/L		114	50 - 150
Dibenz(a,h)anthracene	0.0492	0.0531		ug/L		108	50 - 150
Diclorvos (DDVP)	0.0492	0.0499		ug/L		101	50 - 150
Dieldrin	0.00984	0.00947	J	ug/L		96	50 - 150
Diethylphthalate	0.492	0.551		ug/L		112	50 - 150
Dimethylphthalate	0.492	0.509		ug/L		103	50 - 150
Di-n-butyl phthalate	0.492	0.550	J	ug/L		112	49 - 243
Di-n-octyl phthalate	0.0984	0.116		ug/L		117	50 - 150
Endosulfan I (Alpha)	0.0984	0.0822	J	ug/L		83	50 - 150
Endosulfan II (Beta)	0.0984	0.107		ug/L		108	50 - 150
Endosulfan sulfate	0.0984	0.109		ug/L		111	50 - 150
Endrin	0.00984	0.0113		ug/L		114	50 - 150
Endrin aldehyde	0.0984	0.118		ug/L		120	50 - 150
EPTC	0.0984	0.0987		ug/L		100	50 - 150
Fluoranthene	0.0984	0.104		ug/L		106	50 - 150
Fluorene	0.0492	0.0539		ug/L		109	50 - 150
gamma-Chlordane	0.0246	0.0250	J	ug/L		101	50 - 150
Heptachlor	0.00984	0.0111		ug/L		113	50 - 150
Heptachlor epoxide (isomer B)	0.00984	0.0126		ug/L		128	50 - 150
Hexachlorobenzene	0.0492	0.0511		ug/L		104	50 - 150
Hexachlorocyclopentadiene	0.0492	0.0507		ug/L		103	50 - 150
Indeno[1,2,3-cd]pyrene	0.0492	0.0529		ug/L		108	50 - 150
Isophorone	0.0984	0.0927	J	ug/L		94	50 - 150
Lindane	0.00984	0.0104		ug/L		106	50 - 150
Malathion	0.0984	0.113		ug/L		115	50 - 150
Methoxychlor	0.0492	0.0640		ug/L		130	50 - 150
Metolachlor	0.0492	0.0564		ug/L		115	50 - 150
Molinate	0.0984	0.102		ug/L		104	50 - 150
Naphthalene	0.0984	0.105		ug/L		106	50 - 150
Parathion	0.0984	0.111		ug/L		113	50 - 150
Pendimethalin (Penoxaline)	0.0984	0.113		ug/L		115	50 - 150
Phenanthrene	0.0394	0.0425		ug/L		108	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-246318/22-A

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Propachlor	0.0492	0.0562		ug/L		114	50 - 150
Pyrene	0.0492	0.0549		ug/L		112	50 - 150
Simazine	0.0492	0.0474	J	ug/L		96	50 - 150
Terbacil	0.0984	0.121		ug/L		123	50 - 150
Terbutylazine	0.0984	0.110		ug/L		111	50 - 150
Thiobencarb	0.0984	0.104		ug/L		106	50 - 150
trans-Nonachlor	0.0246	0.0301	J	ug/L		122	50 - 150
Trifluralin	0.0984	0.108		ug/L		110	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
2-Nitro-m-xylene	98		70 - 130
Perylene-d12	93		70 - 130
Triphenylphosphate	104		70 - 130

Lab Sample ID: 380-229848-BM-1-A MS

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	<0.097		1.94	1.99		ug/L		103	70 - 130
2,4'-DDD	<0.097		1.94	2.14		ug/L		110	70 - 130
2,4'-DDE	<0.097		1.94	1.98		ug/L		102	70 - 130
2,4'-DDT	<0.097		1.94	2.10		ug/L		108	70 - 130
2,4-Dinitrotoluene	<0.097		1.94	2.18		ug/L		112	70 - 130
2,6-Dinitrotoluene	<0.097		1.94	2.11		ug/L		109	70 - 130
2-Methylnaphthalene	<0.097		1.94	2.00		ug/L		103	70 - 130
4,4'-DDD	<0.097		1.94	2.11		ug/L		109	70 - 130
4,4'-DDE	<0.097		1.94	2.06		ug/L		106	70 - 130
4,4'-DDT	<0.097		1.94	2.09		ug/L		107	70 - 130
Acenaphthene	<0.097		1.94	2.09		ug/L		108	70 - 130
Acenaphthylene	<0.097		1.94	2.08		ug/L		107	70 - 130
Acetochlor	<0.097		1.94	2.18		ug/L		112	70 - 130
Alachlor	<0.048		1.94	2.15		ug/L		111	70 - 130
alpha-BHC	<0.097		1.94	2.08		ug/L		107	70 - 130
alpha-Chlordane	<0.048		1.94	2.03		ug/L		104	70 - 130
Anthracene	<0.019		1.94	1.89		ug/L		98	70 - 130
Atrazine	<0.048		1.94	2.14		ug/L		110	70 - 130
Benz(a)anthracene	<0.048		1.94	2.10		ug/L		108	70 - 130
Benzo[a]pyrene	<0.019		1.94	2.09		ug/L		108	70 - 130
Benzo[b]fluoranthene	<0.019		1.94	2.15		ug/L		111	70 - 130
Benzo[g,h,i]perylene	<0.048		1.94	1.96		ug/L		101	70 - 130
Benzo[k]fluoranthene	<0.019		1.94	2.15		ug/L		111	70 - 130
beta-BHC	<0.097		1.94	2.07		ug/L		106	70 - 130
Bis(2-ethylhexyl) phthalate	<0.58		1.94	2.20		ug/L		113	70 - 130
Bromacil	<0.097		1.94	1.97		ug/L		101	70 - 130
Butachlor	<0.048		1.94	2.24		ug/L		115	70 - 130
Butylbenzylphthalate	<0.48		1.94	2.26		ug/L		116	70 - 130
Chlorobenzilate	<0.097		1.94	2.06		ug/L		106	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-229848-BM-1-A MS

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Chloroneb	<0.097		1.94	2.02		ug/L		104	70 - 130
Chlorothalonil (Draconil, Bravo)	<0.097		1.94	2.08		ug/L		107	70 - 130
Chlorpyrifos	<0.048		1.94	2.10		ug/L		108	70 - 130
Chrysene	<0.019		1.94	2.11		ug/L		109	70 - 130
delta-BHC	<0.097		1.94	2.03		ug/L		105	70 - 130
Di(2-ethylhexyl)adipate	<0.58		1.94	2.20		ug/L		113	70 - 130
Dibenz(a,h)anthracene	<0.048		1.94	1.94		ug/L		100	70 - 130
Diclorvos (DDVP)	<0.048		1.94	2.01		ug/L		104	70 - 130
Dieldrin	<0.0097		1.94	2.09		ug/L		108	70 - 130
Diethylphthalate	<0.48		1.94	2.21		ug/L		114	70 - 130
Dimethylphthalate	<0.48		1.94	2.09		ug/L		108	70 - 130
Di-n-butyl phthalate	<0.97		3.88	4.26		ug/L		110	70 - 130
Di-n-octyl phthalate	<0.097		1.94	2.17		ug/L		112	70 - 130
Endosulfan I (Alpha)	<0.097		1.94	2.05		ug/L		106	70 - 130
Endosulfan II (Beta)	<0.097		1.94	2.12		ug/L		109	70 - 130
Endosulfan sulfate	<0.097		1.94	2.05		ug/L		105	70 - 130
Endrin	<0.0097		1.94	2.13		ug/L		110	70 - 130
Endrin aldehyde	<0.097		1.94	2.00		ug/L		103	60 - 130
EPTC	<0.097		1.94	2.07		ug/L		107	70 - 130
Fluoranthene	<0.097		1.94	2.22		ug/L		114	70 - 130
Fluorene	<0.048		1.94	2.12		ug/L		109	70 - 130
gamma-Chlordane	<0.048		1.94	2.04		ug/L		105	70 - 130
Heptachlor	<0.0097		1.94	2.04		ug/L		105	70 - 130
Heptachlor epoxide (isomer B)	<0.0097		1.94	2.11		ug/L		109	70 - 130
Hexachlorobenzene	<0.048		1.94	2.03		ug/L		105	70 - 130
Hexachlorocyclopentadiene	<0.048		1.94	1.89		ug/L		97	70 - 130
Indeno[1,2,3-cd]pyrene	<0.048		1.94	1.94		ug/L		100	70 - 130
Isophorone	<0.097		1.94	2.01		ug/L		104	70 - 130
Lindane	<0.0097		1.94	2.07		ug/L		107	70 - 130
Malathion	<0.097		1.94	2.19		ug/L		113	70 - 130
Methoxychlor	<0.048		1.94	2.32		ug/L		120	70 - 130
Metolachlor	<0.048		1.94	2.16		ug/L		111	70 - 130
Molinate	<0.097		1.94	2.16		ug/L		111	70 - 130
Naphthalene	<0.097		1.94	1.99		ug/L		102	70 - 130
Parathion	<0.097		1.94	2.32		ug/L		120	70 - 130
Pendimethalin (Penoxaline)	<0.097		1.94	2.18		ug/L		113	70 - 130
Phenanthrene	<0.039		1.94	2.01		ug/L		104	70 - 130
Propachlor	<0.048		1.94	2.20		ug/L		113	70 - 130
Pyrene	<0.048		1.94	2.15		ug/L		111	70 - 130
Simazine	<0.048		1.94	2.02		ug/L		104	70 - 130
Terbacil	<0.097		1.94	2.11		ug/L		109	70 - 130
Terbutylazine	<0.097		1.94	2.25		ug/L		116	70 - 130
Thiobencarb	<0.097		1.94	2.11		ug/L		108	70 - 130
trans-Nonachlor	<0.048		1.94	2.06		ug/L		106	70 - 130
Trifluralin	<0.097		1.94	2.15		ug/L		111	70 - 130

Surrogate	MS %Recovery	MS Qualifier	Limits
2-Nitro-m-xylene	99		70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-229848-BM-1-A MS

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 246318

Surrogate	MS %Recovery	MS Qualifier	Limits
Perylene-d12	97		70 - 130
Triphenylphosphate	103		70 - 130

Lab Sample ID: 380-230422-I-1-A DU

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Duplicate

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
1-Methylnaphthalene	<0.097		<0.098		ug/L		NC	20
2,4'-DDD	<0.097		<0.098		ug/L		NC	20
2,4'-DDE	<0.097		<0.098		ug/L		NC	20
2,4'-DDT	<0.097		<0.098		ug/L		NC	20
2,4-Dinitrotoluene	<0.097		<0.098		ug/L		NC	20
2,6-Dinitrotoluene	<0.097		<0.098		ug/L		NC	20
2-Methylnaphthalene	<0.097		<0.098		ug/L		NC	20
4,4'-DDD	<0.097		<0.098		ug/L		NC	20
4,4'-DDE	<0.097		<0.098		ug/L		NC	20
4,4'-DDT	<0.097		<0.098		ug/L		NC	20
Acenaphthene	<0.097		<0.098		ug/L		NC	20
Acenaphthylene	<0.097		<0.098		ug/L		NC	20
Acetochlor	<0.097		<0.098		ug/L		NC	20
Alachlor	<0.049		<0.049		ug/L		NC	20
alpha-BHC	<0.097		<0.098		ug/L		NC	20
alpha-Chlordane	<0.049		<0.049		ug/L		NC	20
Anthracene	<0.019		<0.020		ug/L		NC	20
Atrazine	<0.049		<0.049		ug/L		NC	20
Benz(a)anthracene	<0.049		<0.049		ug/L		NC	20
Benzo[a]pyrene	<0.019		<0.020		ug/L		NC	20
Benzo[b]fluoranthene	<0.019		<0.020		ug/L		NC	20
Benzo[g,h,i]perylene	<0.049		<0.049		ug/L		NC	20
Benzo[k]fluoranthene	<0.019		<0.020		ug/L		NC	20
beta-BHC	<0.097		<0.098		ug/L		NC	20
Bis(2-ethylhexyl) phthalate	<0.58		<0.59		ug/L		NC	20
Bromacil	<0.097		<0.098		ug/L		NC	20
Butachlor	<0.049		<0.049		ug/L		NC	20
Butylbenzylphthalate	<0.49		<0.49		ug/L		NC	20
Chlorobenzilate	<0.097		<0.098		ug/L		NC	20
Chloroneb	<0.097		<0.098		ug/L		NC	20
Chlorothalonil (Draconil, Bravo)	<0.097		<0.098		ug/L		NC	20
Chlorpyrifos	<0.049		<0.049		ug/L		NC	20
Chrysene	<0.019		<0.020		ug/L		NC	20
delta-BHC	<0.097		<0.098		ug/L		NC	20
Di(2-ethylhexyl)adipate	<0.58		<0.59		ug/L		NC	20
Dibenz(a,h)anthracene	<0.049		<0.049		ug/L		NC	20
Diclorvos (DDVP)	<0.049		<0.049		ug/L		NC	20
Dieldrin	0.096		0.0812		ug/L		17	20
Diethylphthalate	<0.49		<0.49		ug/L		NC	20
Dimethylphthalate	<0.49		<0.49		ug/L		NC	20

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-230422-I-1-A DU

Matrix: Water

Analysis Batch: 246679

Client Sample ID: Duplicate

Prep Type: Total/NA

Prep Batch: 246318

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
Di-n-butyl phthalate	<0.97		<0.98		ug/L		NC	20
Di-n-octyl phthalate	<0.097		<0.098		ug/L		NC	20
Endosulfan I (Alpha)	<0.097		<0.098		ug/L		NC	20
Endosulfan II (Beta)	<0.097		<0.098		ug/L		NC	20
Endosulfan sulfate	<0.097		<0.098		ug/L		NC	20
Endrin	<0.0097		<0.0098		ug/L		NC	20
Endrin aldehyde	<0.097		<0.098		ug/L		NC	20
EPTC	<0.097		<0.098		ug/L		NC	20
Fluoranthene	<0.097		<0.098		ug/L		NC	20
Fluorene	<0.049		<0.049		ug/L		NC	20
gamma-Chlordane	<0.049		<0.049		ug/L		NC	20
Heptachlor	<0.0097		<0.0098		ug/L		NC	20
Heptachlor epoxide (isomer B)	0.016		0.0159		ug/L		0.3	20
Hexachlorobenzene	<0.049		<0.049		ug/L		NC	20
Hexachlorocyclopentadiene	<0.049		<0.049		ug/L		NC	20
Indeno[1,2,3-cd]pyrene	<0.049		<0.049		ug/L		NC	20
Isophorone	<0.097		<0.098		ug/L		NC	20
Lindane	<0.0097		<0.0098		ug/L		NC	20
Malathion	<0.097		<0.098		ug/L		NC	20
Methoxychlor	<0.049		<0.049		ug/L		NC	20
Metolachlor	<0.049		<0.049		ug/L		NC	20
Molinate	<0.097		<0.098		ug/L		NC	20
Naphthalene	<0.097		<0.098		ug/L		NC	20
Parathion	<0.097		<0.098		ug/L		NC	20
Pendimethalin (Penoxaline)	<0.097		<0.098		ug/L		NC	20
Phenanthrene	<0.039		<0.039		ug/L		NC	20
Propachlor	<0.049		<0.049		ug/L		NC	20
Pyrene	<0.049		<0.049		ug/L		NC	20
Simazine	<0.049		<0.049		ug/L		NC	20
Terbacil	<0.097		<0.098		ug/L		NC	20
Terbutylazine	<0.097		<0.098		ug/L		NC	20
Thiobencarb	<0.097		<0.098		ug/L		NC	20
Total Permethrin (mixed isomers)	<0.19		<0.20		ug/L		NC	20
trans-Nonachlor	<0.049		<0.049		ug/L		NC	20
Trifluralin	<0.097		<0.098		ug/L		NC	20

Surrogate	DU %Recovery	DU Qualifier	Limits
2-Nitro-m-xylene	98		70 - 130
Perylene-d12	91		70 - 130
Triphenylphosphate	102		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 570-784853/1-A
Matrix: Water
Analysis Batch: 786745

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 784853

<i>Tentatively Identified Compound</i>	<i>Est. Result</i>	<i>MB MB</i> <i>Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>RT</i>	<i>CAS No.</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
<i>Tentatively Identified Compound</i>	<i>None</i>		<i>ug/L</i>			<i>N/A</i>	<i>08/15/26 08:02</i>	<i>08/19/26 08:29</i>	<i>1</i>
<i>Surrogate</i>	<i>%Recovery</i>	<i>MB MB</i> <i>Qualifier</i>	<i>Limits</i>				<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
2,4,6-Tribromophenol (Surr)	77		33 - 139				08/15/26 08:02	08/19/26 08:29	1
2-Fluorobiphenyl (Surr)	91		33 - 126				08/15/26 08:02	08/19/26 08:29	1
2-Fluorophenol (Surr)	57		12 - 120				08/15/26 08:02	08/19/26 08:29	1
Nitrobenzene-d5 (Surr)	100		36 - 120				08/15/26 08:02	08/19/26 08:29	1
Phenol-d6 (Surr)	33		10 - 120				08/15/26 08:02	08/19/26 08:29	1
p-Terphenyl-d14 (Surr)	90		47 - 131				08/15/26 08:02	08/19/26 08:29	1

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: MB 570-784853/1-A
Matrix: Water
Analysis Batch: 786738

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 784853

<i>Analyte</i>	<i>Result</i>	<i>MB MB</i> <i>Qualifier</i>	<i>RL</i>	<i>Unit</i>	<i>D</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
1-Methylnaphthalene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
2-Methylnaphthalene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Acenaphthene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Acenaphthylene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Anthracene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Benzo[a]anthracene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Benzo[a]pyrene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Benzo[b]fluoranthene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Benzo[g,h,i]perylene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Benzo[k]fluoranthene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Chrysene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Dibenz(a,h)anthracene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Fluoranthene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Fluorene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Naphthalene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Phenanthrene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
Pyrene	<0.20		0.20	ug/L		08/15/26 08:02	08/19/26 07:27	1
<i>Surrogate</i>	<i>%Recovery</i>	<i>MB MB</i> <i>Qualifier</i>	<i>Limits</i>			<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
2,4,6-Tribromophenol (Surr)	88		28 - 127			08/15/26 08:02	08/19/26 07:27	1
2-Fluorobiphenyl (Surr)	79		31 - 120			08/15/26 08:02	08/19/26 07:27	1
2-Fluorophenol (Surr)	55		17 - 120			08/15/26 08:02	08/19/26 07:27	1
Nitrobenzene-d5 (Surr)	90		27 - 120			08/15/26 08:02	08/19/26 07:27	1
Phenol-d6 (Surr)	33		10 - 120			08/15/26 08:02	08/19/26 07:27	1
p-Terphenyl-d14 (Surr)	74		45 - 120			08/15/26 08:02	08/19/26 07:27	1

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCS 570-784853/2-A

Matrix: Water

Analysis Batch: 786738

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 784853

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	20.0	12.4		ug/L		62	47 - 120
2-Methylnaphthalene	20.0	12.2		ug/L		61	43 - 120
Acenaphthene	20.0	17.2		ug/L		86	60 - 132
Acenaphthylene	20.0	17.5		ug/L		87	54 - 126
Anthracene	20.0	17.3		ug/L		86	43 - 120
Benzo[a]anthracene	20.0	19.4		ug/L		97	42 - 133
Benzo[a]pyrene	20.0	22.5		ug/L		113	32 - 148
Benzo[b]fluoranthene	20.0	20.0		ug/L		100	42 - 140
Benzo[g,h,i]perylene	20.0	19.2		ug/L		96	1 - 195
Benzo[k]fluoranthene	20.0	19.3		ug/L		97	25 - 146
Chrysene	20.0	18.1		ug/L		90	44 - 140
Dibenz(a,h)anthracene	20.0	19.7		ug/L		99	1 - 200
Fluoranthene	20.0	18.1		ug/L		90	43 - 121
Fluorene	20.0	17.5		ug/L		87	70 - 120
Indeno[1,2,3-cd]pyrene	20.0	18.6		ug/L		93	1 - 151
Naphthalene	20.0	11.6		ug/L		58	36 - 120
Phenanthrene	20.0	17.4		ug/L		87	65 - 120
Pyrene	20.0	19.9		ug/L		100	70 - 120

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2,4,6-Tribromophenol (Surr)	89		28 - 127
2-Fluorobiphenyl (Surr)	89		31 - 120
2-Fluorophenol (Surr)	71		17 - 120
Nitrobenzene-d5 (Surr)	68		27 - 120
Phenol-d6 (Surr)	46		10 - 120
p-Terphenyl-d14 (Surr)	95		45 - 120

Lab Sample ID: LCSD 570-784853/3-A

Matrix: Water

Analysis Batch: 786738

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 784853

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene	20.0	12.1		ug/L		60	47 - 120	3	20
2-Methylnaphthalene	20.0	12.0		ug/L		60	43 - 120	1	20
Acenaphthene	20.0	16.8		ug/L		84	60 - 132	3	29
Acenaphthylene	20.0	16.8		ug/L		84	54 - 126	4	45
Anthracene	20.0	16.7		ug/L		84	43 - 120	3	40
Benzo[a]anthracene	20.0	19.2		ug/L		96	42 - 133	1	32
Benzo[a]pyrene	20.0	22.5		ug/L		113	32 - 148	0	43
Benzo[b]fluoranthene	20.0	20.2		ug/L		101	42 - 140	1	43
Benzo[g,h,i]perylene	20.0	19.1		ug/L		95	1 - 195	1	61
Benzo[k]fluoranthene	20.0	19.2		ug/L		96	25 - 146	1	38
Chrysene	20.0	17.9		ug/L		89	44 - 140	1	53
Dibenz(a,h)anthracene	20.0	19.9		ug/L		100	1 - 200	1	75
Fluoranthene	20.0	18.0		ug/L		90	43 - 121	1	40
Fluorene	20.0	17.2		ug/L		86	70 - 120	1	23
Indeno[1,2,3-cd]pyrene	20.0	18.5		ug/L		93	1 - 151	1	60
Naphthalene	20.0	11.4		ug/L		57	36 - 120	2	39

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCSD 570-784853/3-A

Matrix: Water

Analysis Batch: 786738

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 784853

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Phenanthrene	20.0	17.2		ug/L		86	65 - 120	2	24
Pyrene	20.0	19.6		ug/L		98	70 - 120	2	30

Surrogate	LCSD %Recovery	LCSD Qualifier	LCSD Limits
2,4,6-Tribromophenol (Surr)	86		28 - 127
2-Fluorobiphenyl (Surr)	84		31 - 120
2-Fluorophenol (Surr)	66		17 - 120
Nitrobenzene-d5 (Surr)	66		27 - 120
Phenol-d6 (Surr)	44		10 - 120
p-Terphenyl-d14 (Surr)	94		45 - 120

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: MB 570-787520/5

Matrix: Water

Analysis Batch: 787520

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			08/20/26 10:52	1

Surrogate	MB %Recovery	MB Qualifier	MB Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	85		38 - 134		08/20/26 10:52	1

Lab Sample ID: LCS 570-787520/3

Matrix: Water

Analysis Batch: 787520

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	400	329		ug/L		82	78 - 120

Surrogate	LCS %Recovery	LCS Qualifier	LCS Limits
4-Bromofluorobenzene (Surr)	98		38 - 134

Lab Sample ID: LCSD 570-787520/4

Matrix: Water

Analysis Batch: 787520

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	400	326		ug/L		82	78 - 120	1	10

Surrogate	LCSD %Recovery	LCSD Qualifier	LCSD Limits
4-Bromofluorobenzene (Surr)	97		38 - 134

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Lab Sample ID: MRL 570-787520/6

Matrix: Water

Analysis Batch: 787520

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)			10.0	11.8		ug/L		118	50 - 150		
Surrogate	MRL %Recovery	MRL Qualifier	Limits								
4-Bromofluorobenzene (Surr)	99		38 - 134								

Lab Sample ID: 380-230428-C-1 MS

Matrix: Water

Analysis Batch: 787520

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)	<10		400	371		ug/L		93	68 - 122		
Surrogate	MS %Recovery	MS Qualifier	Limits								
4-Bromofluorobenzene (Surr)	91		38 - 134								

Lab Sample ID: 380-230428-C-1 MSD

Matrix: Water

Analysis Batch: 787520

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	374		ug/L		93	68 - 122	1	18
Surrogate	MSD %Recovery	MSD Qualifier	Limits								
4-Bromofluorobenzene (Surr)	103		38 - 134								

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Lab Sample ID: MB 570-783767/1-A

Matrix: Water

Analysis Batch: 788809

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 783767

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Diesel Range Organics (C10-C24)	<25		25	ug/L		08/13/26 10:21	08/23/26 01:11	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		08/13/26 10:21	08/23/26 01:11	1
C8-C18	<25		25	ug/L		08/13/26 10:21	08/23/26 01:11	1
Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac		
%Recovery	Qualifier							
n-Octacosane (Surr)	104		60 - 130	08/13/26 10:21	08/23/26 01:11	1		

Lab Sample ID: LCS 570-783767/2-A

Matrix: Water

Analysis Batch: 788809

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 783767

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
C10-C28	1600	1550		ug/L		97	56 - 127

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

Lab Sample ID: LCS 570-783767/2-A

Matrix: Water

Analysis Batch: 788809

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 783767

	LCS	LCS	
Surrogate	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	101		60 - 130

Lab Sample ID: LCSD 570-783767/3-A

Matrix: Water

Analysis Batch: 788809

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 783767

			Spike	LCSD	LCSD							
Analyte			Added	Result	Qualifier	Unit	D	%Rec	%Rec	Limits	RPD	Limit
C10-C28			1600	1570		ug/L		98		56 - 127	1	23

	LCSD	LCSD	
Surrogate	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	108		60 - 130

Lab Sample ID: MRL 570-783767/4-A

Matrix: Water

Analysis Batch: 788809

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 783767

			Spike	MRL	MRL							
Analyte			Added	Result	Qualifier	Unit	D	%Rec	%Rec	Limits		
C10-C28			0.0200	0.0286		mg/L		143		50 - 150		

	MRL	MRL	
Surrogate	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	105		60 - 130

Lab Sample ID: 380-230428-B-1-A MS

Matrix: Water

Analysis Batch: 788809

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 783767

	Sample	Sample	Spike	MS	MS							
Analyte	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec	%Rec	Limits		
C10-C28	<26		1650	1320		ug/L		80		70 - 130		

	MS	MS	
Surrogate	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	88		60 - 130

Lab Sample ID: 380-230428-B-1-B MSD

Matrix: Water

Analysis Batch: 788809

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 783767

	Sample	Sample	Spike	MSD	MSD							
Analyte	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec	%Rec	Limits	RPD	Limit
C10-C28	<26		1660	1530		ug/L		92		70 - 130	15	20

	MSD	MSD	
Surrogate	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	92		60 - 130

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

GC/MS Semi VOA

Prep Batch: 246318

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230425-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	525.2	
MB 380-246318/21-A	Method Blank	Total/NA	Water	525.2	
LCS 380-246318/23-A	Lab Control Sample	Total/NA	Water	525.2	
MRL 380-246318/22-A	Lab Control Sample	Total/NA	Water	525.2	
380-229848-BM-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-230422-I-1-A DU	Duplicate	Total/NA	Water	525.2	

Analysis Batch: 246679

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230425-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	525.2	246318
MB 380-246318/21-A	Method Blank	Total/NA	Water	525.2	246318
LCS 380-246318/23-A	Lab Control Sample	Total/NA	Water	525.2	246318
MRL 380-246318/22-A	Lab Control Sample	Total/NA	Water	525.2	246318
380-229848-BM-1-A MS	Matrix Spike	Total/NA	Water	525.2	246318
380-230422-I-1-A DU	Duplicate	Total/NA	Water	525.2	246318

Prep Batch: 784853

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230425-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	625.1	
MB 570-784853/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-784853/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-784853/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	

Analysis Batch: 786738

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230425-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	625.1 SIM	784853
MB 570-784853/1-A	Method Blank	Total/NA	Water	625.1 SIM	784853
LCS 570-784853/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	784853
LCSD 570-784853/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	784853

Analysis Batch: 786745

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230425-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	625.1	784853
MB 570-784853/1-A	Method Blank	Total/NA	Water	625.1	784853

GC VOA

Analysis Batch: 787520

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230425-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	8015B GRO LL	
380-230425-2	TB: AIEA GULCH WELLS P2 (331-202-TP072)	Total/NA	Water	8015B GRO LL	
MB 570-787520/5	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-787520/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-787520/4	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-787520/6	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-230428-C-1 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-230428-C-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

GC Semi VOA

Prep Batch: 783767

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230425-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	3510C	
MB 570-783767/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-783767/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-783767/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-783767/4-A	Lab Control Sample	Total/NA	Water	3510C	
380-230428-B-1-A MS	Matrix Spike	Total/NA	Water	3510C	
380-230428-B-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	3510C	

Analysis Batch: 788809

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230425-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	8015B	783767
MB 570-783767/1-A	Method Blank	Total/NA	Water	8015B	783767
LCS 570-783767/2-A	Lab Control Sample	Total/NA	Water	8015B	783767
LCSD 570-783767/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	783767
MRL 570-783767/4-A	Lab Control Sample	Total/NA	Water	8015B	783767
380-230428-B-1-A MS	Matrix Spike	Total/NA	Water	8015B	783767
380-230428-B-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	8015B	783767

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-230425-1

Date Collected: 08/10/26 11:20

Matrix: Drinking Water

Date Received: 08/12/26 09:50

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			246318	IQ42	EA POM	08/13/26 14:50
Total/NA	Analysis	525.2		1	246679	Q8LA	EA POM	08/16/26 15:06
Total/NA	Prep	625.1			784853	KLZQ	EET CAL 4	08/15/26 13:10
Total/NA	Analysis	625.1		1	786745	PQS1	EET CAL 4	08/19/26 13:43
Total/NA	Prep	625.1			784853	KLZQ	EET CAL 4	08/15/26 13:10
Total/NA	Analysis	625.1 SIM		1	786738	PQS1	EET CAL 4	08/19/26 10:47
Total/NA	Analysis	8015B GRO LL		1	787520	W4LC	EET CAL 4	08/20/26 16:00
Total/NA	Prep	3510C			783767	EP2G	EET CAL 4	08/14/26 06:12
Total/NA	Analysis	8015B		1	788809	H6FE	EET CAL 4	08/23/26 04:47

**Client Sample ID: TB: AIEA GULCH WELLS P2
(331-202-TP072)**

Lab Sample ID: 380-230425-2

Date Collected: 08/10/26 11:20

Matrix: Water

Date Received: 08/12/26 09:50

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	787520	W4LC	EET CAL 4	08/20/26 20:44

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100
EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Laboratory: Eurofins Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *
The following analytes are included in this report, but the laboratory is not certified by Hawaii State CA00006. This list may include analytes for which the agency does not offer certification:			
Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Drinking Water	1-Methylnaphthalene
525.2	525.2	Drinking Water	2,4'-DDD
525.2	525.2	Drinking Water	2,4'-DDE
525.2	525.2	Drinking Water	2,4'-DDT
525.2	525.2	Drinking Water	2,4-Dinitrotoluene
525.2	525.2	Drinking Water	2,6-Dinitrotoluene
525.2	525.2	Drinking Water	2-Methylnaphthalene
525.2	525.2	Drinking Water	4,4'-DDD
525.2	525.2	Drinking Water	4,4'-DDE
525.2	525.2	Drinking Water	4,4'-DDT
525.2	525.2	Drinking Water	Acetochlor
525.2	525.2	Drinking Water	alpha-BHC
525.2	525.2	Drinking Water	alpha-Chlordane
525.2	525.2	Drinking Water	beta-BHC
525.2	525.2	Drinking Water	Chlorobenzilate
525.2	525.2	Drinking Water	Chloroneb
525.2	525.2	Drinking Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Drinking Water	Chlorpyrifos
525.2	525.2	Drinking Water	delta-BHC
525.2	525.2	Drinking Water	Diclorvos (DDVP)
525.2	525.2	Drinking Water	Endosulfan I (Alpha)
525.2	525.2	Drinking Water	Endosulfan II (Beta)
525.2	525.2	Drinking Water	Endosulfan sulfate
525.2	525.2	Drinking Water	Endrin aldehyde
525.2	525.2	Drinking Water	EPTC
525.2	525.2	Drinking Water	gamma-Chlordane
525.2	525.2	Drinking Water	Isophorone
525.2	525.2	Drinking Water	Malathion
525.2	525.2	Drinking Water	Parathion
525.2	525.2	Drinking Water	Pendimethalin (Penoxaline)
525.2	525.2	Drinking Water	Terbacil
525.2	525.2	Drinking Water	Terbuthylazine
525.2	525.2	Drinking Water	Total Permethrin (mixed isomers)
525.2	525.2	Drinking Water	trans-Nonachlor

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	7296.01	11-30-26
A2LA	ISO/IEC 17025	7296.01	11-30-26
Alaska (UST)	State	25-005	03-02-27
Arizona	State	AZ0830	11-17-26
California	Los Angeles County Sanitation Districts	9257304	07-31-28
California	SCAQMD LAP	17LA0919	11-30-26

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Eurofins Pomona

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Laboratory: Eurofins Calscience (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
California	State	3082	07-31-28
Kansas	NELAP	E-10420	07-31-27
Nevada	State	CA00111	07-31-27
Oregon	NELAP	4175	02-02-27
Texas	NELAP	T104704499	07-31-27
USDA	US Federal Programs	525-23-159-97150	09-30-26
Utah	NELAP	CA00111	02-28-27
Washington	State	C916	10-12-26

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Method	Method Description	Protocol	Laboratory
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA POM
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
525.2	Extraction of Semivolatile Compounds	EPA	EA POM
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-230425-1
SDG: Weekly: Aiea Gulch Wells Pump 2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-230425-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Drinking Water	08/10/26 11:20	08/12/26 09:50	HI0000331
380-230425-2	TB: AIEA GULCH WELLS P2 (331-202-TP072)	Water	08/10/26 11:20	08/12/26 09:50	

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Ver- 04/02/2024

ORIGIN ID-HIKA (808) 748-5840
BWS CHEMLAB
HONOLULU BOARD OF WATER SUPPLY
630 S. BERETANIA ST.
CHEMICAL LABORATORY
HONOLULU, HI 96843
UNITED STATES US

SHIP DATE 11AUG26
ACTWGT 57.00 LB
CAD 258050552INET4535

BILL RECIPIENT

TO EUROFINS RECEIVING DEPARTMENT
EUROFINS DRINKING WATER TESTING
941 CORPORATE CENTER DR

POMONA CA 91768

(626) 386-1100 REF-

58KJ6/C457/484B

PC

DEPT.



FedEx
Express



WED - 12 AUG 10:30A

2 of 6

MPS# 8756 4353 0977


0263

Mstr# 8756 4353 0966

91768

WM ONTA

CA-US ONT



(634) 23+0.2=2.5 gpl - frozen

Plant Mark Urtia
8/12/26 950

After printing this label
1 Fold the printed page along the horizontal line
2 Place label in shipping pouch and affix it to your shipment

8/24/2026

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-230425-1

SDG Number: Weekly: Aiea Gulch Wells Pump 2

Login Number: 230425

List Number: 1

Creator: Ngo, Theodore

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-230425-1

SDG Number: Weekly: Aiea Gulch Wells Pump 2

Login Number: 230425

List Number: 2

Creator: Khana, Piyush

List Source: Eurofins Calscience

List Creation: 08/13/26 03:50 PM

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	1.8
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	fgf5
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	