

| |
|----|
| 1 |
| 2 |
| 3 |
| 4 |
| 5 |
| 6 |
| 7 |
| 8 |
| 9 |
| 10 |
| 11 |
| 12 |
| 13 |
| 14 |
| 15 |
| 16 |
| 17 |

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 6/17/2026 1:13:37 PM

JOB DESCRIPTION

RED-HILL
Weekly: Aiea Gulch Wells Pump 1

JOB NUMBER

380-218956-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
6/17/2026 1:13:37 PM



Table of Contents

| | |
|------------------------------------|----|
| Cover Page | 1 |
| Table of Contents | 3 |
| Definitions/Glossary | 4 |
| Case Narrative | 5 |
| Detection Summary | 6 |
| Client Sample Results | 7 |
| Action Limit Summary | 11 |
| Surrogate Summary | 12 |
| Isotope Dilution Summary | 13 |
| QC Sample Results | 15 |
| QC Association Summary | 32 |
| Lab Chronicle | 34 |
| Certification Summary | 35 |
| Method Summary | 36 |
| Sample Summary | 37 |
| Chain of Custody | 38 |
| Receipt Checklists | 39 |

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Qualifiers

LCMS

| Qualifier | Qualifier Description |
|-----------|--|
| J | Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value. |

Glossary

| Abbreviation | These commonly used abbreviations may or may not be present in this report. |
|----------------|---|
| ☼ | Listed under the "D" column to designate that the result is reported on a dry weight basis |
| %R | Percent Recovery |
| CFL | Contains Free Liquid |
| CFU | Colony Forming Unit |
| CNF | Contains No Free Liquid |
| DER | Duplicate Error Ratio (normalized absolute difference) |
| Dil Fac | Dilution Factor |
| DL | Detection Limit (DoD/DOE) |
| DL, RA, RE, IN | Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample |
| DLC | Decision Level Concentration (Radiochemistry) |
| EDL | Estimated Detection Limit (Dioxin) |
| LOD | Limit of Detection (DoD/DOE) |
| LOQ | Limit of Quantitation (DoD/DOE) |
| MCL | EPA recommended "Maximum Contaminant Level" |
| MDA | Minimum Detectable Activity (Radiochemistry) |
| MDC | Minimum Detectable Concentration (Radiochemistry) |
| MDL | Method Detection Limit |
| ML | Minimum Level (Dioxin) |
| MPN | Most Probable Number |
| MQL | Method Quantitation Limit |
| NC | Not Calculated |
| ND | Not Detected at the reporting limit (or MDL or EDL if shown) |
| NEG | Negative / Absent |
| POS | Positive / Present |
| PQL | Practical Quantitation Limit |
| PRES | Presumptive |
| QC | Quality Control |
| RER | Relative Error Ratio (Radiochemistry) |
| RL | Reporting Limit or Requested Limit (Radiochemistry) |
| RPD | Relative Percent Difference, a measure of the relative difference between two points |
| TEF | Toxicity Equivalent Factor (Dioxin) |
| TEQ | Toxicity Equivalent Quotient (Dioxin) |
| TNTC | Too Numerous To Count |

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-218956-1

Job ID: 380-218956-1

Eurofins Pomona

Job Narrative 380-218956-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 6/10/2026 9:24 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 5.2°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Client Sample ID: AIEA GULCH WELLS PUMP 1
(331-201-TP071)
PWSID Number: HI0000331

Lab Sample ID: 380-218956-1

No Detections.

Client Sample ID: FB: AIEA GULCH WELLS PUMP 1
(331-201-TP071)
PWSID Number: HI0000331

Lab Sample ID: 380-218956-2

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

This Detection Summary does not include radiochemical test results.

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

**Client Sample ID: AIEA GULCH WELLS PUMP 1
(331-201-TP071)**

Lab Sample ID: 380-218956-1

Date Collected: 06/08/26 09:30

Matrix: Drinking Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

| Analyte | Result | Qualifier | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|--|------------------|------------------|---------------|------|---|-----------------|-----------------|----------------|
| 11-Chloroeicosafluoro-3-oxaundecane e-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 9-Chlorohexadecafluoro-3-oxanonane e-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluorohexanoic acid (PFHxA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluorononanoic acid (PFNA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluorobutanoic acid (PFBA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluoropentanoic acid (PFPeA) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluoroheptanesulfonic acid (PFHpS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Perfluoropentanesulfonic acid (PFPeS) | <2.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| Isotope Dilution | %Recovery | Qualifier | Limits | | | Prepared | Analyzed | Dil Fac |
| 13C3 HFPO-DA | 94 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C6 PFDA | 97 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C5 PFHxA | 99 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C4 PFHpA | 100 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C8 PFOA | 102 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C9 PFNA | 106 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C7 PFUnA | 105 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C2 PFDoA | 108 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C4 PFBA | 103 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C5 PFPeA | 100 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C3 PFBS | 96 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C3 PFHxS | 100 | | 50 - 200 | | | 06/15/26 15:23 | 06/16/26 12:22 | 1 |

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

**Client Sample ID: AIEA GULCH WELLS PUMP 1
(331-201-TP071)**

Lab Sample ID: 380-218956-1

Date Collected: 06/08/26 09:30

Matrix: Drinking Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

| Isotope Dilution | %Recovery | Qualifier | Limits | Prepared | Analyzed | Dil Fac |
|------------------|-----------|-----------|----------|----------------|----------------|---------|
| 13C8 PFOS | 104 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C2-4:2-FTS | 96 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C2-6:2-FTS | 87 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 12:22 | 1 |
| 13C2-8:2-FTS | 84 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 12:22 | 1 |

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

| Analyte | Result | Qualifier | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|--|--------|-----------|-----|------|---|----------------|----------------|---------|
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorohexanoic acid (PFHxA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorononanoic acid (PFNA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorotetradecanoic acid (PFTA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| Perfluorotridecanoic acid (PFTTrDA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 08:32 | 1 |

| Surrogate | %Recovery | Qualifier | Limits | Prepared | Analyzed | Dil Fac |
|-------------|-----------|-----------|----------|----------------|----------------|---------|
| d5-NEtFOSAA | 111 | | 70 - 130 | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| 13C2 PFHxA | 120 | | 70 - 130 | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| 13C2 PFDA | 121 | | 70 - 130 | 06/11/26 11:30 | 06/12/26 08:32 | 1 |
| 13C3-GenX | 112 | | 70 - 130 | 06/11/26 11:30 | 06/12/26 08:32 | 1 |

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1
(331-201-TP071)**

Lab Sample ID: 380-218956-2

Date Collected: 06/08/26 09:30

Matrix: Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

| Analyte | Result | Qualifier | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|--|--------|-----------|-----|------|---|----------------|----------------|---------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1
(331-201-TP071)**

Lab Sample ID: 380-218956-2

Date Collected: 06/08/26 09:30

Matrix: Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

| Analyte | Result | Qualifier | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|---|--------|-----------|-----|------|---|----------------|----------------|---------|
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluorohexanoic acid (PFHxA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluorononanoic acid (PFNA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluorobutanoic acid (PFBA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluoropentanoic acid (PFPeA) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluoroheptanesulfonic acid (PFHpS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| Perfluoropentanesulfonic acid (PFPeS) | <2.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 16:26 | 1 |

| Isotope Dilution | %Recovery | Qualifier | Limits | Prepared | Analyzed | Dil Fac |
|------------------|-----------|-----------|----------|----------------|----------------|---------|
| 13C3 HFPO-DA | 88 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C6 PFDA | 94 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C5 PFHxA | 91 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C4 PFHpA | 96 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C8 PFOA | 94 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C9 PFNA | 103 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C7 PFUnA | 102 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C2 PFDoA | 106 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C4 PFBA | 98 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C5 PFPeA | 90 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C3 PFBS | 103 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C3 PFHxS | 106 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C8 PFOS | 109 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C2-4:2-FTS | 103 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C2-6:2-FTS | 91 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |
| 13C2-8:2-FTS | 88 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 16:26 | 1 |

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1
(331-201-TP071)**

Lab Sample ID: 380-218956-2

Date Collected: 06/08/26 09:30

Matrix: Water

Date Received: 06/10/26 09:24

PWSID Number: HI0000331

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

| Analyte | Result | Qualifier | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|--|------------------|------------------|---------------|------|---|-----------------|-----------------|----------------|
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| N-methylperfluorooctanesulfonamide cetic acid (NMeFOSAA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| N-ethylperfluorooctanesulfonamide cetic acid (NEtFOSAA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorohexanoic acid (PFHxA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorononanoic acid (PFNA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorotetradecanoic acid (PFTA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Perfluorotridecanoic acid (PFTTrDA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| Surrogate | %Recovery | Qualifier | Limits | | | Prepared | Analyzed | Dil Fac |
| d5-NEtFOSAA | 112 | | 70 - 130 | | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| 13C2 PFHxA | 123 | | 70 - 130 | | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| 13C2 PFDA | 122 | | 70 - 130 | | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |
| 13C3-GenX | 109 | | 70 - 130 | | | 06/11/26 11:30 | 06/12/26 17:47 | 1 |

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Client Sample ID: AIEA GULCH WELLS PUMP 1
(331-201-TP071)
PWSID Number: HI0000331

Lab Sample ID: 380-218956-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

| Analyte | Result | Qualifier | Unit | EPAMCL | RL | Method | Prep Type |
|---|--------|-----------|------|--------|-----|--------------|-----------|
| | | | | Limit | | | |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | ng/L | 10 | 2.0 | 533 | Total/NA |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | ng/L | 10 | 2.0 | 533 | Total/NA |
| Perfluorononanoic acid (PFNA) | <2.0 | | ng/L | 10 | 2.0 | 533 | Total/NA |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | ng/L | 4 | 2.0 | 533 | Total/NA |
| Perfluorooctanoic acid (PFOA) | <2.0 | | ng/L | 4 | 2.0 | 533 | Total/NA |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | ng/L | 10 | 2.0 | EPA 537.1 V2 | Total/NA |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | ng/L | 4 | 2.0 | EPA 537.1 V2 | Total/NA |
| Perfluorooctanoic acid (PFOA) | <2.0 | | ng/L | 4 | 2.0 | EPA 537.1 V2 | Total/NA |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | ng/L | 10 | 2.0 | EPA 537.1 V2 | Total/NA |
| Perfluorononanoic acid (PFNA) | <2.0 | | ng/L | 10 | 2.0 | EPA 537.1 V2 | Total/NA |

Client Sample ID: FB: AIEA GULCH WELLS PUMP 1
(331-201-TP071)
PWSID Number: HI0000331

Lab Sample ID: 380-218956-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

| Analyte | Result | Qualifier | Unit | EPAMCL | RL | Method | Prep Type |
|---|--------|-----------|------|--------|-----|--------------|-----------|
| | | | | Limit | | | |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | ng/L | 10 | 2.0 | 533 | Total/NA |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | ng/L | 10 | 2.0 | 533 | Total/NA |
| Perfluorononanoic acid (PFNA) | <2.0 | | ng/L | 10 | 2.0 | 533 | Total/NA |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | ng/L | 4 | 2.0 | 533 | Total/NA |
| Perfluorooctanoic acid (PFOA) | <2.0 | | ng/L | 4 | 2.0 | 533 | Total/NA |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | ng/L | 10 | 2.0 | EPA 537.1 V2 | Total/NA |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | ng/L | 4 | 2.0 | EPA 537.1 V2 | Total/NA |
| Perfluorooctanoic acid (PFOA) | <2.0 | | ng/L | 4 | 2.0 | EPA 537.1 V2 | Total/NA |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | ng/L | 10 | 2.0 | EPA 537.1 V2 | Total/NA |
| Perfluorononanoic acid (PFNA) | <2.0 | | ng/L | 10 | 2.0 | EPA 537.1 V2 | Total/NA |

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

| Lab Sample ID | Client Sample ID | Percent Surrogate Recovery (Acceptance Limits) | | | |
|-------------------------|------------------------------|--|-------------------|------------------|------------------|
| | | d5NEFOS (70-130) | PFHxA (70-130) | PFDA (70-130) | GenX (70-130) |
| 380-218956-1 | AIEA GULCH WELLS PUMP 1 (331 | 111 | 120 | 121 | 112 |
| Surrogate Legend | | | | | |
| d5NEFOS = d5-NEtFOSAA | | | | | |
| PFHxA = 13C2 PFHxA | | | | | |
| PFDA = 13C2 PFDA | | | | | |
| GenX = 13C3-GenX | | | | | |

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

| Lab Sample ID | Client Sample ID | Percent Surrogate Recovery (Acceptance Limits) | | | |
|-------------------------|-------------------------------|--|-------------------|------------------|------------------|
| | | d5NEFOS (70-130) | PFHxA (70-130) | PFDA (70-130) | GenX (70-130) |
| 380-218956-2 | FB: AIEA GULCH WELLS PUMP 1 (| 112 | 123 | 122 | 109 |
| 380-219037-B-1-A MS | Matrix Spike | 113 | 123 | 123 | 127 |
| 380-219037-C-1-A MSD | Matrix Spike Duplicate | 117 | 124 | 123 | 125 |
| LCS 380-233180/21-A | Lab Control Sample | 105 | 119 | 118 | 120 |
| MBL 380-233180/19-A | Method Blank | 112 | 122 | 122 | 116 |
| MRL 380-233180/20-A | Lab Control Sample | 123 | 128 | 122 | 124 |
| Surrogate Legend | | | | | |
| d5NEFOS = d5-NEtFOSAA | | | | | |
| PFHxA = 13C2 PFHxA | | | | | |
| PFDA = 13C2 PFDA | | | | | |
| GenX = 13C3-GenX | | | | | |

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

| | | Percent Isotope Dilution Recovery (Acceptance Limits) | | | | | | | |
|---------------|------------------------------|---|--------------------|---------------------|--------------------|--------------------|--------------------|---------------------|-------------------|
| Lab Sample ID | Client Sample ID | HFPODA (50-200) | C6PFDA (50-200) | 13C5PHA (50-200) | C4PFHA (50-200) | C8PFOA (50-200) | C9PFNA (50-200) | 13C7PUA (50-200) | PFDoA (50-200) |
| 380-218956-1 | AIEA GULCH WELLS PUMP 1 (331 | 94 | 97 | 99 | 100 | 102 | 106 | 105 | 108 |

| | | Percent Isotope Dilution Recovery (Acceptance Limits) | | | | | | | |
|---------------|------------------------------|---|-------------------|--------------------|--------------------|--------------------|-------------------|-------------------|-------------------|
| Lab Sample ID | Client Sample ID | PFBA (50-200) | PFPeA (50-200) | C3PFBS (50-200) | C3PFHS (50-200) | C8PFOS (50-200) | 42FTS (50-200) | 62FTS (50-200) | 82FTS (50-200) |
| 380-218956-1 | AIEA GULCH WELLS PUMP 1 (331 | 103 | 100 | 96 | 100 | 104 | 96 | 87 | 84 |

Surrogate Legend

HFPODA = 13C3 HFPO-DA
 C6PFDA = 13C6 PFDA
 13C5PHA = 13C5 PFHxA
 C4PFHA = 13C4 PFHpA
 C8PFOA = 13C8 PFOA
 C9PFNA = 13C9 PFNA
 13C7PUA = 13C7 PFUnA
 PFDoA = 13C2 PFDoA
 PFBA = 13C4 PFBA
 PFPeA = 13C5 PFPeA
 C3PFBS = 13C3 PFBS
 C3PFHS = 13C3 PFHxS
 C8PFOS = 13C8 PFOS
 42FTS = 13C2-4:2-FTS
 62FTS = 13C2-6:2-FTS
 82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

| | | Percent Isotope Dilution Recovery (Acceptance Limits) | | | | | | | |
|-----------------------|--|---|--------------------|---------------------|--------------------|--------------------|--------------------|---------------------|-------------------|
| Lab Sample ID | Client Sample ID | HFPODA (50-200) | C6PFDA (50-200) | 13C5PHA (50-200) | C4PFHA (50-200) | C8PFOA (50-200) | C9PFNA (50-200) | 13C7PUA (50-200) | PFDoA (50-200) |
| 380-218914-B-2-A MS | Matrix Spike | 109 | 102 | 103 | 107 | 103 | 108 | 106 | 107 |
| 380-218914-C-2-A MSD | Matrix Spike Duplicate | 103 | 99 | 106 | 104 | 106 | 107 | 108 | 109 |
| 380-218956-2 | FB: AIEA GULCH WELLS PUMP 1 (331-201-TP071) | 88 | 94 | 91 | 96 | 94 | 103 | 102 | 106 |
| 380-219143-B-13-A MS | Matrix Spike | 80 | 87 | 86 | 85 | 83 | 89 | 94 | 101 |
| 380-219143-C-13-A MSD | Matrix Spike Duplicate | 76 | 78 | 83 | 79 | 77 | 82 | 86 | 98 |
| LCS 380-233676/22-A | Lab Control Sample | 73 | 75 | 78 | 78 | 80 | 81 | 77 | 79 |
| LCS 380-233929/22-A | Lab Control Sample | 71 | 83 | 74 | 77 | 79 | 84 | 87 | 93 |
| MBL 380-233676/20-A | Method Blank | 76 | 80 | 82 | 80 | 83 | 90 | 85 | 87 |
| MBL 380-233929/20-A | Method Blank | 87 | 95 | 94 | 94 | 97 | 105 | 103 | 109 |
| MRL 380-233676/21-A | Lab Control Sample | 84 | 87 | 91 | 90 | 93 | 96 | 94 | 95 |
| MRL 380-233929/21-A | Lab Control Sample | 67 | 79 | 74 | 73 | 78 | 83 | 86 | 92 |

| | | Percent Isotope Dilution Recovery (Acceptance Limits) | | | | | | | |
|----------------------|--|---|-------------------|--------------------|--------------------|--------------------|-------------------|-------------------|-------------------|
| Lab Sample ID | Client Sample ID | PFBA (50-200) | PFPeA (50-200) | C3PFBS (50-200) | C3PFHS (50-200) | C8PFOS (50-200) | 42FTS (50-200) | 62FTS (50-200) | 82FTS (50-200) |
| 380-218914-B-2-A MS | Matrix Spike | 106 | 111 | 107 | 106 | 109 | 109 | 95 | 91 |
| 380-218914-C-2-A MSD | Matrix Spike Duplicate | 111 | 111 | 110 | 110 | 114 | 112 | 100 | 95 |
| 380-218956-2 | FB: AIEA GULCH WELLS PUMP 1 (331-201-TP071) | 98 | 90 | 103 | 106 | 109 | 103 | 91 | 88 |
| 380-219143-B-13-A MS | Matrix Spike | 89 | 87 | 99 | 100 | 109 | 103 | 88 | 89 |

Eurofins Pomona

Isotope Dilution Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-218956-1
 SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Matrix: Water

Prep Type: Total/NA

| Lab Sample ID | Client Sample ID | Percent Isotope Dilution Recovery (Acceptance Limits) | | | | | | | |
|-----------------------|------------------------|---|-------------------|--------------------|--------------------|--------------------|-------------------|-------------------|-------------------|
| | | PFBA (50-200) | PFPeA (50-200) | C3PFBS (50-200) | C3PFHS (50-200) | C8PFOS (50-200) | 42FTS (50-200) | 62FTS (50-200) | 82FTS (50-200) |
| 380-219143-C-13-A MSD | Matrix Spike Duplicate | 85 | 84 | 101 | 100 | 108 | 105 | 92 | 89 |
| LCS 380-233676/22-A | Lab Control Sample | 83 | 79 | 100 | 103 | 107 | 95 | 91 | 92 |
| LCS 380-233929/22-A | Lab Control Sample | 82 | 75 | 93 | 101 | 104 | 101 | 83 | 87 |
| MBL 380-233676/20-A | Method Blank | 89 | 81 | 98 | 101 | 107 | 100 | 88 | 89 |
| MBL 380-233929/20-A | Method Blank | 95 | 89 | 98 | 100 | 107 | 107 | 93 | 94 |
| MRL 380-233676/21-A | Lab Control Sample | 94 | 87 | 104 | 105 | 113 | 100 | 91 | 88 |
| MRL 380-233929/21-A | Lab Control Sample | 79 | 74 | 98 | 102 | 107 | 97 | 88 | 91 |

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDoA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-233676/20-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233676

| Analyte | MBL | MBL | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|--|--------|-----------|-----|------|---|----------------|----------------|---------|
| | Result | Qualifier | | | | | | |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <0.30 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <0.30 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <0.60 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <1.0 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | <0.37 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluorodecanoic acid (PFDA) | <0.31 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluorododecanoic acid (PFDoA) | <0.54 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluoroheptanoic acid (PFHpA) | <0.39 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | <0.32 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluorohexanoic acid (PFHxA) | <0.46 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluorononanoic acid (PFNA) | <0.40 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | <0.43 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluorooctanoic acid (PFOA) | <0.38 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluoroundecanoic acid (PFUnA) | <0.42 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluorobutanoic acid (PFBA) | <0.69 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | <0.38 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | <0.37 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | 0.496 | J | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | <0.47 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA) | <0.25 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | <0.46 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | <0.15 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluoropentanoic acid (PFPeA) | <0.38 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluoroheptanesulfonic acid (PFHpS) | <0.36 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| Perfluoropentanesulfonic acid (PFPeS) | <0.39 | | 2.0 | ng/L | | 06/13/26 12:30 | 06/14/26 13:03 | 1 |

| Isotope Dilution | MBL | MBL | Limits | Prepared | Analyzed | Dil Fac |
|------------------|-----------|-----------|----------|----------------|----------------|---------|
| | %Recovery | Qualifier | | | | |
| 13C3 HFPO-DA | 76 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C6 PFDA | 80 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C5 PFHxA | 82 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C4 PFHpA | 80 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C8 PFOA | 83 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C9 PFNA | 90 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C7 PFUnA | 85 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C2 PFDoA | 87 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C4 PFBA | 89 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C5 PFPeA | 81 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C3 PFBS | 98 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C3 PFHxS | 101 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-233676/20-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233676

| <i>Isotope Dilution</i> | <i>MBL</i> | <i>MBL</i> | <i>Limits</i> | <i>Prepared</i> | <i>Analyzed</i> | <i>Dil Fac</i> |
|-------------------------|------------------|------------------|---------------|-----------------|-----------------|----------------|
| | <i>%Recovery</i> | <i>Qualifier</i> | | | | |
| 13C8 PFOS | 107 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C2-4:2-FTS | 100 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C2-6:2-FTS | 88 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |
| 13C2-8:2-FTS | 89 | | 50 - 200 | 06/13/26 12:30 | 06/14/26 13:03 | 1 |

Lab Sample ID: LCS 380-233676/22-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

| <i>Analyte</i> | <i>Spike</i> | <i>LCS</i> | <i>LCS</i> | <i>Unit</i> | <i>D</i> | <i>%Rec</i> | <i>%Rec</i> |
|--|--------------|---------------|------------------|-------------|----------|-------------|---------------|
| | <i>Added</i> | <i>Result</i> | <i>Qualifier</i> | | | | <i>Limits</i> |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | 60.2 | 57.9 | | ng/L | | 96 | 70 - 130 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | 60.2 | 56.0 | | ng/L | | 93 | 70 - 130 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | 60.2 | 56.2 | | ng/L | | 93 | 70 - 130 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | 60.2 | 57.8 | | ng/L | | 96 | 70 - 130 |
| Perfluorobutanesulfonic acid (PFBS) | 60.2 | 60.7 | | ng/L | | 101 | 70 - 130 |
| Perfluorodecanoic acid (PFDA) | 60.2 | 64.7 | | ng/L | | 107 | 70 - 130 |
| Perfluorododecanoic acid (PFDoA) | 60.2 | 58.4 | | ng/L | | 97 | 70 - 130 |
| Perfluoroheptanoic acid (PFHpA) | 60.2 | 61.6 | | ng/L | | 102 | 70 - 130 |
| Perfluorohexanesulfonic acid (PFHxS) | 60.2 | 59.8 | | ng/L | | 99 | 70 - 130 |
| Perfluorohexanoic acid (PFHxA) | 60.2 | 59.0 | | ng/L | | 98 | 70 - 130 |
| Perfluorononanoic acid (PFNA) | 60.2 | 59.1 | | ng/L | | 98 | 70 - 130 |
| Perfluorooctanesulfonic acid (PFOS) | 60.2 | 57.9 | | ng/L | | 96 | 70 - 130 |
| Perfluorooctanoic acid (PFOA) | 60.2 | 62.2 | | ng/L | | 103 | 70 - 130 |
| Perfluoroundecanoic acid (PFUnA) | 60.2 | 58.3 | | ng/L | | 97 | 70 - 130 |
| Perfluorobutanoic acid (PFBA) | 60.2 | 61.1 | | ng/L | | 101 | 70 - 130 |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | 60.2 | 57.4 | | ng/L | | 95 | 70 - 130 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | 60.2 | 59.8 | | ng/L | | 99 | 70 - 130 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | 60.2 | 61.4 | | ng/L | | 102 | 70 - 130 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | 60.2 | 59.7 | | ng/L | | 99 | 70 - 130 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | 60.2 | 61.7 | | ng/L | | 102 | 70 - 130 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | 60.2 | 65.4 | | ng/L | | 109 | 70 - 130 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | 60.2 | 60.7 | | ng/L | | 101 | 70 - 130 |
| Perfluoropentanoic acid (PFPeA) | 60.2 | 58.7 | | ng/L | | 97 | 70 - 130 |
| Perfluoroheptanesulfonic acid (PFHpS) | 60.2 | 60.9 | | ng/L | | 101 | 70 - 130 |

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-233676/22-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

| Analyte | Spike Added | LCS Result | LCS Qualifier | Unit | D | %Rec | %Rec Limits |
|---------------------------------------|------------------|------------------|---------------|------|---|------|-------------|
| Perfluoropentanesulfonic acid (PFPeS) | 60.2 | 58.1 | | ng/L | | 96 | 70 - 130 |
| LCS LCS | | | | | | | |
| Isotope Dilution | %Recovery | Qualifier | Limits | | | | |
| 13C3 HFPO-DA | 73 | | 50 - 200 | | | | |
| 13C6 PFDA | 75 | | 50 - 200 | | | | |
| 13C5 PFHxA | 78 | | 50 - 200 | | | | |
| 13C4 PFHpA | 78 | | 50 - 200 | | | | |
| 13C8 PFOA | 80 | | 50 - 200 | | | | |
| 13C9 PFNA | 81 | | 50 - 200 | | | | |
| 13C7 PFUnA | 77 | | 50 - 200 | | | | |
| 13C2 PFDoA | 79 | | 50 - 200 | | | | |
| 13C4 PFBA | 83 | | 50 - 200 | | | | |
| 13C5 PFPeA | 79 | | 50 - 200 | | | | |
| 13C3 PFBS | 100 | | 50 - 200 | | | | |
| 13C3 PFHxS | 103 | | 50 - 200 | | | | |
| 13C8 PFOS | 107 | | 50 - 200 | | | | |
| 13C2-4:2-FTS | 95 | | 50 - 200 | | | | |
| 13C2-6:2-FTS | 91 | | 50 - 200 | | | | |
| 13C2-8:2-FTS | 92 | | 50 - 200 | | | | |

Lab Sample ID: MRL 380-233676/21-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

| Analyte | Spike Added | MRL Result | MRL Qualifier | Unit | D | %Rec | %Rec Limits |
|--|-------------|------------|---------------|------|---|------|-------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | 2.00 | 1.96 | J | ng/L | | 98 | 50 - 150 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | 2.00 | 1.83 | J | ng/L | | 91 | 50 - 150 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | 2.00 | 2.04 | J | ng/L | | 102 | 50 - 150 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | 2.00 | 1.95 | J | ng/L | | 97 | 50 - 150 |
| Perfluorobutanesulfonic acid (PFBS) | 2.00 | 1.97 | J | ng/L | | 98 | 50 - 150 |
| Perfluorodecanoic acid (PFDA) | 2.00 | 2.38 | J | ng/L | | 119 | 50 - 150 |
| Perfluorododecanoic acid (PFDoA) | 2.00 | 2.23 | J | ng/L | | 112 | 50 - 150 |
| Perfluoroheptanoic acid (PFHpA) | 2.00 | 1.94 | J | ng/L | | 97 | 50 - 150 |
| Perfluorohexanesulfonic acid (PFHxS) | 2.00 | 1.97 | J | ng/L | | 98 | 50 - 150 |
| Perfluorohexanoic acid (PFHxA) | 2.00 | 2.01 | J | ng/L | | 100 | 50 - 150 |
| Perfluorononanoic acid (PFNA) | 2.00 | 2.07 | J | ng/L | | 103 | 50 - 150 |
| Perfluorooctanesulfonic acid (PFOS) | 2.00 | 1.96 | J | ng/L | | 98 | 50 - 150 |
| Perfluorooctanoic acid (PFOA) | 2.00 | 2.17 | J | ng/L | | 108 | 50 - 150 |
| Perfluoroundecanoic acid (PFUnA) | 2.00 | 2.20 | J | ng/L | | 110 | 50 - 150 |
| Perfluorobutanoic acid (PFBA) | 2.00 | 2.40 | J | ng/L | | 120 | 50 - 150 |

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-233676/21-A
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233676

| Analyte | Spike Added | MRL Result | MRL Qualifier | Unit | D | %Rec | %Rec Limits |
|---|-------------|------------|---------------|------|---|------|-------------|
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | 2.00 | 2.14 | J | ng/L | | 107 | 50 - 150 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | 2.00 | 2.32 | J | ng/L | | 116 | 50 - 150 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | 2.00 | 2.55 | J | ng/L | | 127 | 50 - 150 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | 2.00 | 2.02 | J | ng/L | | 101 | 50 - 150 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | 2.00 | 1.95 | J | ng/L | | 97 | 50 - 150 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | 2.00 | 2.26 | J | ng/L | | 113 | 50 - 150 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | 2.00 | 1.99 | J | ng/L | | 99 | 50 - 150 |
| Perfluoropentanoic acid (PFPeA) | 2.00 | 2.23 | J | ng/L | | 111 | 50 - 150 |
| Perfluoroheptanesulfonic acid (PFHpS) | 2.00 | 2.00 | J | ng/L | | 100 | 50 - 150 |
| Perfluoropentanesulfonic acid (PFPeS) | 2.00 | 1.85 | J | ng/L | | 92 | 50 - 150 |

| Isotope Dilution | MRL %Recovery | MRL Qualifier | MRL Limits |
|------------------|---------------|---------------|------------|
| 13C3 HFPO-DA | 84 | | 50 - 200 |
| 13C6 PFDA | 87 | | 50 - 200 |
| 13C5 PFHxA | 91 | | 50 - 200 |
| 13C4 PFHpA | 90 | | 50 - 200 |
| 13C8 PFOA | 93 | | 50 - 200 |
| 13C9 PFNA | 96 | | 50 - 200 |
| 13C7 PFUnA | 94 | | 50 - 200 |
| 13C2 PFDoA | 95 | | 50 - 200 |
| 13C4 PFBA | 94 | | 50 - 200 |
| 13C5 PFPeA | 87 | | 50 - 200 |
| 13C3 PFBS | 104 | | 50 - 200 |
| 13C3 PFHxS | 105 | | 50 - 200 |
| 13C8 PFOS | 113 | | 50 - 200 |
| 13C2-4:2-FTS | 100 | | 50 - 200 |
| 13C2-6:2-FTS | 91 | | 50 - 200 |
| 13C2-8:2-FTS | 88 | | 50 - 200 |

Lab Sample ID: 380-218914-B-2-A MS
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 233676

| Analyte | Sample Result | Sample Qualifier | Spike Added | MS Result | MS Qualifier | Unit | D | %Rec | %Rec Limits |
|--|---------------|------------------|-------------|-----------|--------------|------|---|------|-------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 120 | 114 | | ng/L | | 94 | 70 - 130 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 120 | 110 | | ng/L | | 91 | 70 - 130 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 120 | 115 | | ng/L | | 96 | 70 - 130 |

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-218914-B-2-A MS

Client Sample ID: Matrix Spike

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 233715

Prep Batch: 233676

| Analyte | Sample | Sample | Spike | MS | MS | Unit | D | %Rec | %Rec Limits |
|---|--------|-----------|-------|--------|-----------|------|---|------|-------------|
| | Result | Qualifier | Added | Result | Qualifier | | | | |
| Hexafluoropropylene Oxide | <2.0 | | 120 | 111 | | ng/L | | 92 | 70 - 130 |
| Dimer Acid (HFPO-DA/GenX) | | | | | | | | | |
| Perfluorobutanesulfonic acid (PFBS) | 3.3 | | 120 | 118 | | ng/L | | 95 | 70 - 130 |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 120 | 128 | | ng/L | | 106 | 70 - 130 |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 120 | 118 | | ng/L | | 98 | 70 - 130 |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 120 | 117 | | ng/L | | 96 | 70 - 130 |
| Perfluorohexanesulfonic acid (PFHxS) | 5.0 | | 120 | 119 | | ng/L | | 95 | 70 - 130 |
| Perfluorohexanoic acid (PFHxA) | 2.1 | | 120 | 121 | | ng/L | | 99 | 70 - 130 |
| Perfluorononanoic acid (PFNA) | <2.0 | | 120 | 117 | | ng/L | | 96 | 70 - 130 |
| Perfluorooctanesulfonic acid (PFOS) | 9.6 | | 120 | 122 | | ng/L | | 93 | 70 - 130 |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 120 | 124 | | ng/L | | 102 | 70 - 130 |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 120 | 118 | | ng/L | | 98 | 70 - 130 |
| Perfluorobutanoic acid (PFBA) | <2.0 | | 120 | 121 | | ng/L | | 99 | 70 - 130 |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | <2.0 | | 120 | 116 | | ng/L | | 97 | 70 - 130 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | <2.0 | | 120 | 111 | | ng/L | | 92 | 70 - 130 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | <2.0 | | 120 | 124 | | ng/L | | 103 | 70 - 130 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | <2.0 | | 120 | 120 | | ng/L | | 100 | 70 - 130 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | <2.0 | | 120 | 117 | | ng/L | | 97 | 70 - 130 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | <2.0 | | 120 | 123 | | ng/L | | 102 | 70 - 130 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | <2.0 | | 120 | 114 | | ng/L | | 94 | 70 - 130 |
| Perfluoropentanoic acid (PFPeA) | 2.3 | | 120 | 118 | | ng/L | | 96 | 70 - 130 |
| Perfluoroheptanesulfonic acid (PFHpS) | <2.0 | | 120 | 116 | | ng/L | | 96 | 70 - 130 |
| Perfluoropentanesulfonic acid (PFPeS) | <2.0 | | 120 | 118 | | ng/L | | 97 | 70 - 130 |

| Isotope Dilution | MS MS | | Limits |
|------------------|-----------|-----------|----------|
| | %Recovery | Qualifier | |
| 13C3 HFPO-DA | 109 | | 50 - 200 |
| 13C6 PFDA | 102 | | 50 - 200 |
| 13C5 PFHxA | 103 | | 50 - 200 |
| 13C4 PFHpA | 107 | | 50 - 200 |
| 13C8 PFOA | 103 | | 50 - 200 |
| 13C9 PFNA | 108 | | 50 - 200 |
| 13C7 PFUnA | 106 | | 50 - 200 |
| 13C2 PFDoA | 107 | | 50 - 200 |
| 13C4 PFBA | 106 | | 50 - 200 |
| 13C5 PFPeA | 111 | | 50 - 200 |
| 13C3 PFBS | 107 | | 50 - 200 |
| 13C3 PFHxS | 106 | | 50 - 200 |
| 13C8 PFOS | 109 | | 50 - 200 |

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-218914-B-2-A MS
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 233676

| <i>Isotope Dilution</i> | <i>MS MS</i> | <i>Qualifier</i> | <i>Limits</i> |
|-------------------------|------------------|------------------|---------------|
| | <i>%Recovery</i> | | |
| 13C2-4:2-FTS | 109 | | 50 - 200 |
| 13C2-6:2-FTS | 95 | | 50 - 200 |
| 13C2-8:2-FTS | 91 | | 50 - 200 |

Lab Sample ID: 380-218914-C-2-A MSD
Matrix: Water
Analysis Batch: 233715

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 233676

| <i>Analyte</i> | <i>Sample</i> | <i>Sample</i> | <i>Spike</i> | <i>MSD MSD</i> | | <i>Unit</i> | <i>D</i> | <i>%Rec</i> | <i>%Rec</i> | <i>RPD</i> | <i>RPD</i> |
|--|---------------|------------------|--------------|----------------|------------------|-------------|----------|-------------|---------------|------------|--------------|
| | <i>Result</i> | <i>Qualifier</i> | <i>Added</i> | <i>Result</i> | <i>Qualifier</i> | | | | <i>Limits</i> | | <i>Limit</i> |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 120 | 112 | | ng/L | | 93 | 70 - 130 | 1 | 30 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 120 | 106 | | ng/L | | 88 | 70 - 130 | 3 | 30 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 120 | 116 | | ng/L | | 96 | 70 - 130 | 0 | 30 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | 120 | 112 | | ng/L | | 93 | 70 - 130 | 1 | 30 |
| Perfluorobutanesulfonic acid (PFBS) | 3.3 | | 120 | 112 | | ng/L | | 90 | 70 - 130 | 5 | 30 |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 120 | 127 | | ng/L | | 106 | 70 - 130 | 0 | 30 |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 120 | 114 | | ng/L | | 95 | 70 - 130 | 3 | 30 |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 120 | 116 | | ng/L | | 95 | 70 - 130 | 1 | 30 |
| Perfluorohexanesulfonic acid (PFHxS) | 5.0 | | 120 | 119 | | ng/L | | 95 | 70 - 130 | 0 | 30 |
| Perfluorohexanoic acid (PFHxA) | 2.1 | | 120 | 114 | | ng/L | | 93 | 70 - 130 | 6 | 30 |
| Perfluorononanoic acid (PFNA) | <2.0 | | 120 | 113 | | ng/L | | 93 | 70 - 130 | 3 | 30 |
| Perfluorooctanesulfonic acid (PFOS) | 9.6 | | 120 | 117 | | ng/L | | 90 | 70 - 130 | 4 | 30 |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 120 | 116 | | ng/L | | 95 | 70 - 130 | 7 | 30 |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 120 | 113 | | ng/L | | 94 | 70 - 130 | 4 | 30 |
| Perfluorobutanoic acid (PFBA) | <2.0 | | 120 | 117 | | ng/L | | 96 | 70 - 130 | 4 | 30 |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | <2.0 | | 120 | 121 | | ng/L | | 101 | 70 - 130 | 4 | 30 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | <2.0 | | 120 | 111 | | ng/L | | 92 | 70 - 130 | 0 | 30 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | <2.0 | | 120 | 119 | | ng/L | | 98 | 70 - 130 | 4 | 30 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | <2.0 | | 120 | 113 | | ng/L | | 94 | 70 - 130 | 7 | 30 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | <2.0 | | 120 | 115 | | ng/L | | 96 | 70 - 130 | 2 | 30 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | <2.0 | | 120 | 126 | | ng/L | | 105 | 70 - 130 | 2 | 30 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | <2.0 | | 120 | 112 | | ng/L | | 93 | 70 - 130 | 2 | 30 |
| Perfluoropentanoic acid (PFPeA) | 2.3 | | 120 | 116 | | ng/L | | 95 | 70 - 130 | 1 | 30 |
| Perfluoroheptanesulfonic acid (PFHpS) | <2.0 | | 120 | 112 | | ng/L | | 93 | 70 - 130 | 3 | 30 |
| Perfluoropentanesulfonic acid (PFPeS) | <2.0 | | 120 | 115 | | ng/L | | 95 | 70 - 130 | 3 | 30 |

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

| Isotope Dilution | MSD MSD | | Limits |
|------------------|-----------|-----------|----------|
| | %Recovery | Qualifier | |
| 13C3 HFPO-DA | 103 | | 50 - 200 |
| 13C6 PFDA | 99 | | 50 - 200 |
| 13C5 PFHxA | 106 | | 50 - 200 |
| 13C4 PFHpA | 104 | | 50 - 200 |
| 13C8 PFOA | 106 | | 50 - 200 |
| 13C9 PFNA | 107 | | 50 - 200 |
| 13C7 PFUnA | 108 | | 50 - 200 |
| 13C2 PFDoA | 109 | | 50 - 200 |
| 13C4 PFBA | 111 | | 50 - 200 |
| 13C5 PFPeA | 111 | | 50 - 200 |
| 13C3 PFBS | 110 | | 50 - 200 |
| 13C3 PFHxS | 110 | | 50 - 200 |
| 13C8 PFOS | 114 | | 50 - 200 |
| 13C2-4:2-FTS | 112 | | 50 - 200 |
| 13C2-6:2-FTS | 100 | | 50 - 200 |
| 13C2-8:2-FTS | 95 | | 50 - 200 |

Lab Sample ID: MBL 380-233929/20-A

Matrix: Water

Analysis Batch: 234115

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 233929

| Analyte | MBL MBL | | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|--|---------|-----------|-----|------|---|----------------|----------------|---------|
| | Result | Qualifier | | | | | | |
| 11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS) | <0.30 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS) | <0.30 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <0.60 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <1.0 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | <0.37 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluorodecanoic acid (PFDA) | <0.31 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluorododecanoic acid (PFDoA) | <0.54 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluoroheptanoic acid (PFHpA) | <0.39 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | <0.32 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluorohexanoic acid (PFHxA) | <0.46 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluorononanoic acid (PFNA) | <0.40 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | <0.43 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluorooctanoic acid (PFOA) | <0.38 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluoroundecanoic acid (PFUnA) | <0.42 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluorobutanoic acid (PFBA) | <0.69 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | <0.38 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | <0.37 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | <0.48 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | <0.47 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA) | <0.25 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | <0.46 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | <0.15 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-233929/20-A
Matrix: Water
Analysis Batch: 234115

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 233929

| Analyte | MBL Result | MBL Qualifier | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|---------------------------------------|------------|---------------|-----|------|---|----------------|----------------|---------|
| Perfluoropentanoic acid (PFPeA) | <0.38 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluoroheptanesulfonic acid (PFHpS) | <0.36 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| Perfluoropentanesulfonic acid (PFPeS) | <0.39 | | 2.0 | ng/L | | 06/15/26 15:23 | 06/16/26 11:15 | 1 |

| Isotope Dilution | MBL %Recovery | MBL Qualifier | Limits | Prepared | Analyzed | Dil Fac |
|------------------|---------------|---------------|----------|----------------|----------------|---------|
| 13C3 HFPO-DA | 87 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C6 PFDA | 95 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C5 PFHxA | 94 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C4 PFHpA | 94 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C8 PFOA | 97 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C9 PFNA | 105 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C7 PFUnA | 103 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C2 PFDoA | 109 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C4 PFBA | 95 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C5 PFPeA | 89 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C3 PFBS | 98 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C3 PFHxS | 100 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C8 PFOS | 107 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C2-4:2-FTS | 107 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C2-6:2-FTS | 93 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |
| 13C2-8:2-FTS | 94 | | 50 - 200 | 06/15/26 15:23 | 06/16/26 11:15 | 1 |

Lab Sample ID: LCS 380-233929/22-A
Matrix: Water
Analysis Batch: 234115

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233929

| Analyte | Spike Added | LCS Result | LCS Qualifier | Unit | D | %Rec | %Rec Limits |
|--|-------------|------------|---------------|------|---|------|-------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | 60.2 | 56.0 | | ng/L | | 93 | 70 - 130 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | 60.2 | 53.8 | | ng/L | | 89 | 70 - 130 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | 60.2 | 55.5 | | ng/L | | 92 | 70 - 130 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | 60.2 | 56.9 | | ng/L | | 94 | 70 - 130 |
| Perfluorobutanesulfonic acid (PFBS) | 60.2 | 60.5 | | ng/L | | 100 | 70 - 130 |
| Perfluorodecanoic acid (PFDA) | 60.2 | 61.6 | | ng/L | | 102 | 70 - 130 |
| Perfluorododecanoic acid (PFDoA) | 60.2 | 58.5 | | ng/L | | 97 | 70 - 130 |
| Perfluoroheptanoic acid (PFHpA) | 60.2 | 57.7 | | ng/L | | 96 | 70 - 130 |
| Perfluorohexanesulfonic acid (PFHxS) | 60.2 | 55.7 | | ng/L | | 93 | 70 - 130 |
| Perfluorohexanoic acid (PFHxA) | 60.2 | 59.5 | | ng/L | | 99 | 70 - 130 |
| Perfluorononanoic acid (PFNA) | 60.2 | 57.4 | | ng/L | | 95 | 70 - 130 |
| Perfluorooctanesulfonic acid (PFOS) | 60.2 | 55.6 | | ng/L | | 92 | 70 - 130 |
| Perfluorooctanoic acid (PFOA) | 60.2 | 59.8 | | ng/L | | 99 | 70 - 130 |

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-233929/22-A
Matrix: Water
Analysis Batch: 234115

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233929

| Analyte | Spike Added | LCS Result | LCS Qualifier | Unit | D | %Rec | %Rec Limits |
|---|-------------|------------|---------------|------|---|------|-------------|
| Perfluoroundecanoic acid (PFUnA) | 60.2 | 58.9 | | ng/L | | 98 | 70 - 130 |
| Perfluorobutanoic acid (PFBA) | 60.2 | 58.4 | | ng/L | | 97 | 70 - 130 |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | 60.2 | 58.3 | | ng/L | | 97 | 70 - 130 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | 60.2 | 57.2 | | ng/L | | 95 | 70 - 130 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | 60.2 | 64.0 | | ng/L | | 106 | 70 - 130 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | 60.2 | 56.4 | | ng/L | | 94 | 70 - 130 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | 60.2 | 60.5 | | ng/L | | 100 | 70 - 130 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | 60.2 | 62.5 | | ng/L | | 104 | 70 - 130 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | 60.2 | 54.1 | | ng/L | | 90 | 70 - 130 |
| Perfluoropentanoic acid (PFPeA) | 60.2 | 55.2 | | ng/L | | 92 | 70 - 130 |
| Perfluoroheptanesulfonic acid (PFHpS) | 60.2 | 57.0 | | ng/L | | 95 | 70 - 130 |
| Perfluoropentanesulfonic acid (PFPeS) | 60.2 | 56.2 | | ng/L | | 93 | 70 - 130 |

| Isotope Dilution | LCS LCS | | Limits |
|------------------|-----------|-----------|----------|
| | %Recovery | Qualifier | |
| 13C3 HFPO-DA | 71 | | 50 - 200 |
| 13C6 PFDA | 83 | | 50 - 200 |
| 13C5 PFHxA | 74 | | 50 - 200 |
| 13C4 PFHpA | 77 | | 50 - 200 |
| 13C8 PFOA | 79 | | 50 - 200 |
| 13C9 PFNA | 84 | | 50 - 200 |
| 13C7 PFUnA | 87 | | 50 - 200 |
| 13C2 PFDoA | 93 | | 50 - 200 |
| 13C4 PFBA | 82 | | 50 - 200 |
| 13C5 PFPeA | 75 | | 50 - 200 |
| 13C3 PFBS | 93 | | 50 - 200 |
| 13C3 PFHxS | 101 | | 50 - 200 |
| 13C8 PFOS | 104 | | 50 - 200 |
| 13C2-4:2-FTS | 101 | | 50 - 200 |
| 13C2-6:2-FTS | 83 | | 50 - 200 |
| 13C2-8:2-FTS | 87 | | 50 - 200 |

Lab Sample ID: MRL 380-233929/21-A
Matrix: Water
Analysis Batch: 234115

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233929

| Analyte | Spike Added | MRL Result | MRL Qualifier | Unit | D | %Rec | %Rec Limits |
|--|-------------|------------|---------------|------|---|------|-------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | 2.01 | 1.95 | J | ng/L | | 97 | 50 - 150 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | 2.01 | 1.88 | J | ng/L | | 93 | 50 - 150 |

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-218956-1
 SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-233929/21-A

Matrix: Water

Analysis Batch: 234115

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 233929

| Analyte | Spike Added | MRL | MRL | Unit | D | %Rec | %Rec Limits |
|---|-------------|--------|-----------|------|---|------|-------------|
| | | Result | Qualifier | | | | |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | 2.01 | 1.94 | J | ng/L | | 96 | 50 - 150 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | 2.01 | 2.13 | J | ng/L | | 106 | 50 - 150 |
| Perfluorobutanesulfonic acid (PFBS) | 2.01 | 2.02 | J | ng/L | | 100 | 50 - 150 |
| Perfluorodecanoic acid (PFDA) | 2.01 | 2.16 | J | ng/L | | 107 | 50 - 150 |
| Perfluorododecanoic acid (PFDoA) | 2.01 | 2.05 | J | ng/L | | 102 | 50 - 150 |
| Perfluoroheptanoic acid (PFHpA) | 2.01 | 2.12 | J | ng/L | | 106 | 50 - 150 |
| Perfluorohexanesulfonic acid (PFHxS) | 2.01 | 2.03 | J | ng/L | | 101 | 50 - 150 |
| Perfluorohexanoic acid (PFHxA) | 2.01 | 2.09 | J | ng/L | | 104 | 50 - 150 |
| Perfluorononanoic acid (PFNA) | 2.01 | 2.22 | J | ng/L | | 110 | 50 - 150 |
| Perfluorooctanesulfonic acid (PFOS) | 2.01 | 1.99 | J | ng/L | | 99 | 50 - 150 |
| Perfluorooctanoic acid (PFOA) | 2.01 | 2.21 | J | ng/L | | 110 | 50 - 150 |
| Perfluoroundecanoic acid (PFUnA) | 2.01 | 2.17 | J | ng/L | | 108 | 50 - 150 |
| Perfluorobutanoic acid (PFBA) | 2.01 | 2.24 | J | ng/L | | 111 | 50 - 150 |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | 2.01 | 1.86 | J | ng/L | | 92 | 50 - 150 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | 2.01 | 2.33 | J | ng/L | | 116 | 50 - 150 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | 2.01 | 2.60 | J | ng/L | | 129 | 50 - 150 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | 2.01 | 2.08 | J | ng/L | | 104 | 50 - 150 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | 2.01 | 2.07 | J | ng/L | | 103 | 50 - 150 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | 2.01 | 2.13 | J | ng/L | | 106 | 50 - 150 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | 2.01 | 1.91 | J | ng/L | | 95 | 50 - 150 |
| Perfluoropentanoic acid (PFPeA) | 2.01 | 2.06 | J | ng/L | | 102 | 50 - 150 |
| Perfluoroheptanesulfonic acid (PFHpS) | 2.01 | 1.99 | J | ng/L | | 99 | 50 - 150 |
| Perfluoropentanesulfonic acid (PFPeS) | 2.01 | 1.91 | J | ng/L | | 95 | 50 - 150 |

| Isotope Dilution | MRL | | Limits |
|------------------|-----------|-----------|----------|
| | %Recovery | Qualifier | |
| 13C3 HFPO-DA | 67 | | 50 - 200 |
| 13C6 PFDA | 79 | | 50 - 200 |
| 13C5 PFHxA | 74 | | 50 - 200 |
| 13C4 PFHpA | 73 | | 50 - 200 |
| 13C8 PFOA | 78 | | 50 - 200 |
| 13C9 PFNA | 83 | | 50 - 200 |
| 13C7 PFUnA | 86 | | 50 - 200 |
| 13C2 PFDoA | 92 | | 50 - 200 |
| 13C4 PFBA | 79 | | 50 - 200 |
| 13C5 PFPeA | 74 | | 50 - 200 |
| 13C3 PFBS | 98 | | 50 - 200 |
| 13C3 PFHxS | 102 | | 50 - 200 |

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-233929/21-A
Matrix: Water
Analysis Batch: 234115

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 233929

| Isotope Dilution | MRL | | Limits |
|------------------|-----------|-----------|----------|
| | %Recovery | Qualifier | |
| 13C8 PFOS | 107 | | 50 - 200 |
| 13C2-4:2-FTS | 97 | | 50 - 200 |
| 13C2-6:2-FTS | 88 | | 50 - 200 |
| 13C2-8:2-FTS | 91 | | 50 - 200 |

Lab Sample ID: 380-219143-B-13-A MS
Matrix: Water
Analysis Batch: 234115

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 233929

| Analyte | Sample | Sample | Spike | MS | | Unit | D | %Rec | %Rec | Limits |
|--|--------|-----------|-------|--------|-----------|------|---|------|----------|--------|
| | Result | Qualifier | | Result | Qualifier | | | | | |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 60.2 | 53.9 | | ng/L | | 90 | 70 - 130 | |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 60.2 | 52.4 | | ng/L | | 87 | 70 - 130 | |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 60.2 | 54.5 | | ng/L | | 90 | 70 - 130 | |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | 60.2 | 57.3 | | ng/L | | 95 | 70 - 130 | |
| Perfluorobutanesulfonic acid (PFBS) | <2.0 | | 60.2 | 57.6 | | ng/L | | 96 | 70 - 130 | |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 60.2 | 63.6 | | ng/L | | 106 | 70 - 130 | |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 60.2 | 55.0 | | ng/L | | 91 | 70 - 130 | |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 60.2 | 58.5 | | ng/L | | 97 | 70 - 130 | |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | 60.2 | 54.9 | | ng/L | | 91 | 70 - 130 | |
| Perfluorohexanoic acid (PFHxA) | <2.0 | | 60.2 | 57.8 | | ng/L | | 94 | 70 - 130 | |
| Perfluorononanoic acid (PFNA) | <2.0 | | 60.2 | 58.8 | | ng/L | | 98 | 70 - 130 | |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | 60.2 | 53.7 | | ng/L | | 89 | 70 - 130 | |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 60.2 | 61.8 | | ng/L | | 103 | 70 - 130 | |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 60.2 | 57.3 | | ng/L | | 95 | 70 - 130 | |
| Perfluorobutanoic acid (PFBA) | <2.0 | | 60.2 | 58.1 | | ng/L | | 95 | 70 - 130 | |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | <2.0 | | 60.2 | 56.8 | | ng/L | | 94 | 70 - 130 | |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | <2.0 | | 60.2 | 59.3 | | ng/L | | 98 | 70 - 130 | |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | <2.0 | | 60.2 | 63.5 | | ng/L | | 105 | 70 - 130 | |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDHA) | <2.0 | | 60.2 | 55.1 | | ng/L | | 91 | 70 - 130 | |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | <2.0 | | 60.2 | 58.3 | | ng/L | | 97 | 70 - 130 | |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | <2.0 | | 60.2 | 63.4 | | ng/L | | 105 | 70 - 130 | |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | <2.0 | | 60.2 | 54.7 | | ng/L | | 91 | 70 - 130 | |
| Perfluoropentanoic acid (PFPeA) | <2.0 | | 60.2 | 58.0 | | ng/L | | 95 | 70 - 130 | |
| Perfluoroheptanesulfonic acid (PFHpS) | <2.0 | | 60.2 | 55.1 | | ng/L | | 91 | 70 - 130 | |

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-219143-B-13-A MS

Client Sample ID: Matrix Spike

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 234115

Prep Batch: 233929

| Analyte | Sample | Sample | Spike | MS | MS | Unit | D | %Rec | %Rec Limits |
|---------------------------------------|------------------|------------------|---------------|--------|-----------|------|---|------|-------------|
| | Result | Qualifier | Added | Result | Qualifier | | | | |
| Perfluoropentanesulfonic acid (PFPeS) | <2.0 | | 60.2 | 57.5 | | ng/L | | 96 | 70 - 130 |
| MS MS | | | | | | | | | |
| Isotope Dilution | %Recovery | Qualifier | Limits | | | | | | |
| 13C3 HFPO-DA | 80 | | 50 - 200 | | | | | | |
| 13C6 PFDA | 87 | | 50 - 200 | | | | | | |
| 13C5 PFHxA | 86 | | 50 - 200 | | | | | | |
| 13C4 PFHpA | 85 | | 50 - 200 | | | | | | |
| 13C8 PFOA | 83 | | 50 - 200 | | | | | | |
| 13C9 PFNA | 89 | | 50 - 200 | | | | | | |
| 13C7 PFUnA | 94 | | 50 - 200 | | | | | | |
| 13C2 PFDoA | 101 | | 50 - 200 | | | | | | |
| 13C4 PFBA | 89 | | 50 - 200 | | | | | | |
| 13C5 PFPeA | 87 | | 50 - 200 | | | | | | |
| 13C3 PFBS | 99 | | 50 - 200 | | | | | | |
| 13C3 PFHxS | 100 | | 50 - 200 | | | | | | |
| 13C8 PFOS | 109 | | 50 - 200 | | | | | | |
| 13C2-4:2-FTS | 103 | | 50 - 200 | | | | | | |
| 13C2-6:2-FTS | 88 | | 50 - 200 | | | | | | |
| 13C2-8:2-FTS | 89 | | 50 - 200 | | | | | | |

Lab Sample ID: 380-219143-C-13-A MSD

Client Sample ID: Matrix Spike Duplicate

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 234115

Prep Batch: 233929

| Analyte | Sample | Sample | Spike | MSD | MSD | Unit | D | %Rec | %Rec Limits | RPD | RPD Limit |
|--|--------|-----------|-------|--------|-----------|------|---|------|-------------|-----|-----------|
| | Result | Qualifier | Added | Result | Qualifier | | | | | | |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 60.2 | 55.4 | | ng/L | | 92 | 70 - 130 | 3 | 30 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 60.2 | 53.1 | | ng/L | | 88 | 70 - 130 | 1 | 30 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 60.2 | 54.5 | | ng/L | | 90 | 70 - 130 | 0 | 30 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | 60.2 | 57.4 | | ng/L | | 95 | 70 - 130 | 0 | 30 |
| Perfluorobutanesulfonic acid (PFBS) | <2.0 | | 60.2 | 58.9 | | ng/L | | 98 | 70 - 130 | 2 | 30 |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 60.2 | 64.0 | | ng/L | | 106 | 70 - 130 | 1 | 30 |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 60.2 | 54.4 | | ng/L | | 90 | 70 - 130 | 1 | 30 |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 60.2 | 58.8 | | ng/L | | 98 | 70 - 130 | 0 | 30 |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | 60.2 | 58.0 | | ng/L | | 96 | 70 - 130 | 5 | 30 |
| Perfluorohexanoic acid (PFHxA) | <2.0 | | 60.2 | 59.1 | | ng/L | | 97 | 70 - 130 | 2 | 30 |
| Perfluorononanoic acid (PFNA) | <2.0 | | 60.2 | 57.1 | | ng/L | | 95 | 70 - 130 | 3 | 30 |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | 60.2 | 54.5 | | ng/L | | 91 | 70 - 130 | 1 | 30 |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 60.2 | 61.9 | | ng/L | | 103 | 70 - 130 | 0 | 30 |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 60.2 | 57.9 | | ng/L | | 96 | 70 - 130 | 1 | 30 |
| Perfluorobutanoic acid (PFBA) | <2.0 | | 60.2 | 59.9 | | ng/L | | 98 | 70 - 130 | 3 | 30 |

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-219143-C-13-A MSD

Client Sample ID: Matrix Spike Duplicate

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 234115

Prep Batch: 233929

| Analyte | Sample | Sample | Spike | MSD | MSD | Unit | D | %Rec | %Rec | RPD | RPD |
|---|--------|-----------|-------|--------|-----------|------|---|------|----------|-----|-----|
| | Result | Qualifier | Added | Result | Qualifier | | | | Limits | | |
| 1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS) | <2.0 | | 60.2 | 58.3 | | ng/L | | 97 | 70 - 130 | 3 | 30 |
| 1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS) | <2.0 | | 60.2 | 60.6 | | ng/L | | 101 | 70 - 130 | 2 | 30 |
| 1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS) | <2.0 | | 60.2 | 61.2 | | ng/L | | 102 | 70 - 130 | 4 | 30 |
| Nonafluoro-3,6-dioxahexanoic acid (NFDHA) | <2.0 | | 60.2 | 54.9 | | ng/L | | 91 | 70 - 130 | 0 | 30 |
| Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | <2.0 | | 60.2 | 56.4 | | ng/L | | 94 | 70 - 130 | 3 | 30 |
| Perfluoro-3-methoxypropanoic acid (PFMPA) | <2.0 | | 60.2 | 61.6 | | ng/L | | 102 | 70 - 130 | 3 | 30 |
| Perfluoro-4-methoxybutanoic acid (PFMBA) | <2.0 | | 60.2 | 54.2 | | ng/L | | 90 | 70 - 130 | 1 | 30 |
| Perfluoropentanoic acid (PFPeA) | <2.0 | | 60.2 | 55.6 | | ng/L | | 91 | 70 - 130 | 4 | 30 |
| Perfluoroheptanesulfonic acid (PFHpS) | <2.0 | | 60.2 | 56.4 | | ng/L | | 94 | 70 - 130 | 2 | 30 |
| Perfluoropentanesulfonic acid (PFPeS) | <2.0 | | 60.2 | 57.3 | | ng/L | | 95 | 70 - 130 | 0 | 30 |

| Isotope Dilution | MSD | MSD | Limits |
|------------------|-----------|-----------|----------|
| | %Recovery | Qualifier | |
| 13C3 HFPO-DA | 76 | | 50 - 200 |
| 13C6 PFDA | 78 | | 50 - 200 |
| 13C5 PFHxA | 83 | | 50 - 200 |
| 13C4 PFHpA | 79 | | 50 - 200 |
| 13C8 PFOA | 77 | | 50 - 200 |
| 13C9 PFNA | 82 | | 50 - 200 |
| 13C7 PFUnA | 86 | | 50 - 200 |
| 13C2 PFDoA | 98 | | 50 - 200 |
| 13C4 PFBA | 85 | | 50 - 200 |
| 13C5 PFPeA | 84 | | 50 - 200 |
| 13C3 PFBS | 101 | | 50 - 200 |
| 13C3 PFHxS | 100 | | 50 - 200 |
| 13C8 PFOS | 108 | | 50 - 200 |
| 13C2-4:2-FTS | 105 | | 50 - 200 |
| 13C2-6:2-FTS | 92 | | 50 - 200 |
| 13C2-8:2-FTS | 89 | | 50 - 200 |

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-233180/19-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 233406

Prep Batch: 233180

| Analyte | MBL | MBL | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|--|--------|-----------|-----|------|---|----------------|----------------|---------|
| | Result | Qualifier | | | | | | |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <1.0 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorooctanesulfonic acid (PFOS) | <0.43 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluoroundecanoic acid (PFUnA) | <0.42 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | <0.58 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-233180/19-A

Matrix: Water

Analysis Batch: 233406

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 233180

| Analyte | MBL | MBL | RL | Unit | D | Prepared | Analyzed | Dil Fac |
|--|--------|-----------|-----|------|---|----------------|----------------|---------|
| | Result | Qualifier | | | | | | |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | <0.42 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorohexanoic acid (PFHxA) | <0.46 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorododecanoic acid (PFDoA) | <0.54 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorooctanoic acid (PFOA) | <0.38 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorodecanoic acid (PFDA) | <0.31 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorohexanesulfonic acid (PFHxS) | <0.32 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorobutanesulfonic acid (PFBS) | <0.37 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluoroheptanoic acid (PFHpA) | <0.39 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorononanoic acid (PFNA) | <0.40 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorotetradecanoic acid (PFTA) | <0.54 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| Perfluorotridecanoic acid (PFTTrDA) | <0.36 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS) | <0.30 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <0.30 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| 4,8-Dioxo-3H-perfluorononanoic acid (ADONA) | <0.60 | | 2.0 | ng/L | | 06/11/26 11:30 | 06/12/26 06:38 | 1 |

| Surrogate | MBL | MBL | Limits | Prepared | Analyzed | Dil Fac |
|-------------|-----------|-----------|----------|----------------|----------------|---------|
| | %Recovery | Qualifier | | | | |
| d5-NEtFOSAA | 112 | | 70 - 130 | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| 13C2 PFHxA | 122 | | 70 - 130 | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| 13C2 PFDA | 122 | | 70 - 130 | 06/11/26 11:30 | 06/12/26 06:38 | 1 |
| 13C3-GenX | 116 | | 70 - 130 | 06/11/26 11:30 | 06/12/26 06:38 | 1 |

Lab Sample ID: LCS 380-233180/21-A

Matrix: Water

Analysis Batch: 233406

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 233180

| Analyte | Spike Added | LCS Result | LCS Qualifier | Unit | D | %Rec | %Rec Limits |
|--|-------------|------------|---------------|------|---|------|-------------|
| | | | | | | | |
| Perfluorooctanesulfonic acid (PFOS) | 50.2 | 51.9 | | ng/L | | 103 | 70 - 130 |
| Perfluoroundecanoic acid (PFUnA) | 50.2 | 55.2 | | ng/L | | 110 | 70 - 130 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | 50.2 | 44.5 | | ng/L | | 89 | 70 - 130 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | 50.2 | 46.4 | | ng/L | | 92 | 70 - 130 |
| Perfluorohexanoic acid (PFHxA) | 50.2 | 54.2 | | ng/L | | 108 | 70 - 130 |
| Perfluorododecanoic acid (PFDoA) | 50.2 | 55.0 | | ng/L | | 110 | 70 - 130 |
| Perfluorooctanoic acid (PFOA) | 50.2 | 54.6 | | ng/L | | 109 | 70 - 130 |
| Perfluorodecanoic acid (PFDA) | 50.2 | 52.5 | | ng/L | | 105 | 70 - 130 |
| Perfluorohexanesulfonic acid (PFHxS) | 50.2 | 52.9 | | ng/L | | 105 | 70 - 130 |
| Perfluorobutanesulfonic acid (PFBS) | 50.2 | 53.1 | | ng/L | | 106 | 70 - 130 |
| Perfluoroheptanoic acid (PFHpA) | 50.2 | 52.4 | | ng/L | | 104 | 70 - 130 |
| Perfluorononanoic acid (PFNA) | 50.2 | 52.6 | | ng/L | | 105 | 70 - 130 |

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: LCS 380-233180/21-A

Matrix: Water

Analysis Batch: 233406

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 233180

| Analyte | Spike Added | LCS Result | LCS Qualifier | Unit | D | %Rec | %Rec Limits |
|--|-------------|------------|---------------|------|---|------|-------------|
| | | | | | | | |
| Perfluorotetradecanoic acid (PFTA) | 50.2 | 42.9 | | ng/L | | 86 | 70 - 130 |
| Perfluorotridecanoic acid (PFTrDA) | 50.2 | 54.9 | | ng/L | | 109 | 70 - 130 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | 50.2 | 52.1 | | ng/L | | 104 | 70 - 130 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | 50.2 | 51.8 | | ng/L | | 103 | 70 - 130 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | 50.2 | 52.3 | | ng/L | | 104 | 70 - 130 |

| Surrogate | LCS | | Limits |
|-------------|-----------|-----------|----------|
| | %Recovery | Qualifier | |
| d5-NEtFOSAA | 105 | | 70 - 130 |
| 13C2 PFHxA | 119 | | 70 - 130 |
| 13C2 PFDA | 118 | | 70 - 130 |
| 13C3-GenX | 120 | | 70 - 130 |

Lab Sample ID: MRL 380-233180/20-A

Matrix: Water

Analysis Batch: 233406

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 233180

| Analyte | Spike Added | MRL Result | MRL Qualifier | Unit | D | %Rec | %Rec Limits |
|--|-------------|------------|---------------|------|---|------|-------------|
| | | | | | | | |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | 2.01 | 2.10 | J | ng/L | | 105 | 50 - 150 |
| Perfluorooctanesulfonic acid (PFOS) | 2.01 | 2.12 | J | ng/L | | 106 | 50 - 150 |
| Perfluoroundecanoic acid (PFUnA) | 2.01 | 2.18 | J | ng/L | | 109 | 50 - 150 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | 2.01 | 2.09 | J | ng/L | | 104 | 50 - 150 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | 2.01 | 2.22 | J | ng/L | | 110 | 50 - 150 |
| Perfluorohexanoic acid (PFHxA) | 2.01 | 2.24 | J | ng/L | | 111 | 50 - 150 |
| Perfluorododecanoic acid (PFDoA) | 2.01 | 2.14 | J | ng/L | | 107 | 50 - 150 |
| Perfluorooctanoic acid (PFOA) | 2.01 | 2.09 | J | ng/L | | 104 | 50 - 150 |
| Perfluorodecanoic acid (PFDA) | 2.01 | 2.13 | J | ng/L | | 106 | 50 - 150 |
| Perfluorohexanesulfonic acid (PFHxS) | 2.01 | 2.00 | J | ng/L | | 99 | 50 - 150 |
| Perfluorobutanesulfonic acid (PFBS) | 2.01 | 2.03 | J | ng/L | | 101 | 50 - 150 |
| Perfluoroheptanoic acid (PFHpA) | 2.01 | 2.20 | J | ng/L | | 109 | 50 - 150 |
| Perfluorononanoic acid (PFNA) | 2.01 | 2.30 | J | ng/L | | 114 | 50 - 150 |
| Perfluorotetradecanoic acid (PFTA) | 2.01 | 1.52 | J | ng/L | | 76 | 50 - 150 |
| Perfluorotridecanoic acid (PFTrDA) | 2.01 | 2.29 | J | ng/L | | 114 | 50 - 150 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | 2.01 | 2.15 | J | ng/L | | 107 | 50 - 150 |

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-233180/20-A

Matrix: Water

Analysis Batch: 233406

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 233180

| Analyte | Spike Added | MRL Result | MRL Qualifier | Unit | D | %Rec | %Rec Limits |
|--|----------------------|----------------------|---------------|------|---|------|-------------|
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | 2.01 | 1.98 | J | ng/L | | 99 | 50 - 150 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | 2.01 | 2.15 | J | ng/L | | 107 | 50 - 150 |
| Surrogate | MRL %Recovery | MRL Qualifier | Limits | | | | |
| d5-NEtFOSAA | 123 | | 70 - 130 | | | | |
| 13C2 PFHxA | 128 | | 70 - 130 | | | | |
| 13C2 PFDA | 122 | | 70 - 130 | | | | |
| 13C3-GenX | 124 | | 70 - 130 | | | | |

Lab Sample ID: 380-219037-B-1-A MS

Matrix: Water

Analysis Batch: 233406

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 233180

| Analyte | Sample Result | Sample Qualifier | Spike Added | MS Result | MS Qualifier | Unit | D | %Rec | %Rec Limits |
|--|---------------|------------------|-------------|-----------|--------------|------|---|------|-------------|
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) | <2.0 | | 25.2 | 28.2 | | ng/L | | 112 | 70 - 130 |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | 25.2 | 25.9 | | ng/L | | 103 | 70 - 130 |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 25.2 | 27.6 | | ng/L | | 110 | 70 - 130 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | <2.0 | | 25.2 | 24.0 | | ng/L | | 96 | 70 - 130 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | <2.0 | | 25.2 | 24.6 | | ng/L | | 98 | 70 - 130 |
| Perfluorohexanoic acid (PFHxA) | <2.0 | | 25.2 | 27.6 | | ng/L | | 110 | 70 - 130 |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 25.2 | 27.4 | | ng/L | | 109 | 70 - 130 |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 25.2 | 27.5 | | ng/L | | 109 | 70 - 130 |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 25.2 | 26.5 | | ng/L | | 105 | 70 - 130 |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | 25.2 | 25.9 | | ng/L | | 103 | 70 - 130 |
| Perfluorobutanesulfonic acid (PFBS) | <2.0 | | 25.2 | 26.8 | | ng/L | | 107 | 70 - 130 |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 25.2 | 28.0 | | ng/L | | 111 | 70 - 130 |
| Perfluorononanoic acid (PFNA) | <2.0 | | 25.2 | 28.8 | | ng/L | | 114 | 70 - 130 |
| Perfluorotetradecanoic acid (PFTA) | <2.0 | | 25.2 | 21.4 | | ng/L | | 85 | 70 - 130 |
| Perfluorotridecanoic acid (PFTTrDA) | <2.0 | | 25.2 | 28.8 | | ng/L | | 115 | 70 - 130 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 25.2 | 25.9 | | ng/L | | 103 | 70 - 130 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 25.2 | 25.2 | | ng/L | | 100 | 70 - 130 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 25.2 | 28.6 | | ng/L | | 114 | 70 - 130 |

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-219037-B-1-A MS

Matrix: Water

Analysis Batch: 233406

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 233180

| Surrogate | MS MS | | Limits |
|-------------|-----------|-----------|----------|
| | %Recovery | Qualifier | |
| d5-NEtFOSAA | 113 | | 70 - 130 |
| 13C2 PFHxA | 123 | | 70 - 130 |
| 13C2 PFDA | 123 | | 70 - 130 |
| 13C3-GenX | 127 | | 70 - 130 |

Lab Sample ID: 380-219037-C-1-A MSD

Matrix: Water

Analysis Batch: 233406

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 233180

| Analyte | Sample | Sample | Spike | MSD MSD | | Unit | D | %Rec | %Rec | | RPD | |
|--|--------|-----------|-------|---------|-----------|------|---|------|----------|-----|-------|--|
| | Result | Qualifier | Added | Result | Qualifier | | | | Limits | RPD | Limit | |
| Hexafluoropropylene Oxide | <2.0 | | 25.2 | 29.6 | | ng/L | | 118 | 70 - 130 | 5 | 30 | |
| Dimer Acid (HFPO-DA/GenX) | | | | | | | | | | | | |
| Perfluorooctanesulfonic acid (PFOS) | <2.0 | | 25.2 | 27.5 | | ng/L | | 109 | 70 - 130 | 6 | 30 | |
| Perfluoroundecanoic acid (PFUnA) | <2.0 | | 25.2 | 28.6 | | ng/L | | 114 | 70 - 130 | 3 | 30 | |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | <2.0 | | 25.2 | 26.0 | | ng/L | | 103 | 70 - 130 | 8 | 30 | |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | <2.0 | | 25.2 | 26.6 | | ng/L | | 106 | 70 - 130 | 8 | 30 | |
| Perfluorohexanoic acid (PFHxA) | <2.0 | | 25.2 | 29.2 | | ng/L | | 116 | 70 - 130 | 5 | 30 | |
| Perfluorododecanoic acid (PFDoA) | <2.0 | | 25.2 | 28.4 | | ng/L | | 113 | 70 - 130 | 3 | 30 | |
| Perfluorooctanoic acid (PFOA) | <2.0 | | 25.2 | 28.8 | | ng/L | | 115 | 70 - 130 | 5 | 30 | |
| Perfluorodecanoic acid (PFDA) | <2.0 | | 25.2 | 27.7 | | ng/L | | 110 | 70 - 130 | 5 | 30 | |
| Perfluorohexanesulfonic acid (PFHxS) | <2.0 | | 25.2 | 28.4 | | ng/L | | 113 | 70 - 130 | 9 | 30 | |
| Perfluorobutanesulfonic acid (PFBS) | <2.0 | | 25.2 | 27.9 | | ng/L | | 111 | 70 - 130 | 4 | 30 | |
| Perfluoroheptanoic acid (PFHpA) | <2.0 | | 25.2 | 29.6 | | ng/L | | 118 | 70 - 130 | 5 | 30 | |
| Perfluorononanoic acid (PFNA) | <2.0 | | 25.2 | 30.2 | | ng/L | | 120 | 70 - 130 | 5 | 30 | |
| Perfluorotetradecanoic acid (PFTA) | <2.0 | | 25.2 | 22.6 | | ng/L | | 90 | 70 - 130 | 5 | 30 | |
| Perfluorotridecanoic acid (PFTrDA) | <2.0 | | 25.2 | 30.0 | | ng/L | | 119 | 70 - 130 | 4 | 30 | |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS) | <2.0 | | 25.2 | 27.6 | | ng/L | | 110 | 70 - 130 | 6 | 30 | |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS) | <2.0 | | 25.2 | 27.1 | | ng/L | | 108 | 70 - 130 | 7 | 30 | |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | <2.0 | | 25.2 | 29.6 | | ng/L | | 118 | 70 - 130 | 3 | 30 | |

| Surrogate | MSD MSD | | Limits |
|-------------|-----------|-----------|----------|
| | %Recovery | Qualifier | |
| d5-NEtFOSAA | 117 | | 70 - 130 |
| 13C2 PFHxA | 124 | | 70 - 130 |
| 13C2 PFDA | 123 | | 70 - 130 |
| 13C3-GenX | 125 | | 70 - 130 |

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

LCMS

Prep Batch: 233180

| Lab Sample ID | Client Sample ID | Prep Type | Matrix | Method | Prep Batch |
|----------------------|---|-----------|----------------|----------|------------|
| 380-218956-1 | AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Total/NA | Drinking Water | 537.1 DW | |
| 380-218956-2 | FB: AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Total/NA | Water | 537.1 DW | |
| MBL 380-233180/19-A | Method Blank | Total/NA | Water | 537.1 DW | |
| LCS 380-233180/21-A | Lab Control Sample | Total/NA | Water | 537.1 DW | |
| MRL 380-233180/20-A | Lab Control Sample | Total/NA | Water | 537.1 DW | |
| 380-219037-B-1-A MS | Matrix Spike | Total/NA | Water | 537.1 DW | |
| 380-219037-C-1-A MSD | Matrix Spike Duplicate | Total/NA | Water | 537.1 DW | |

Analysis Batch: 233406

| Lab Sample ID | Client Sample ID | Prep Type | Matrix | Method | Prep Batch |
|----------------------|---|-----------|----------------|--------------|------------|
| 380-218956-1 | AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Total/NA | Drinking Water | EPA 537.1 V2 | 233180 |
| MBL 380-233180/19-A | Method Blank | Total/NA | Water | EPA 537.1 V2 | 233180 |
| LCS 380-233180/21-A | Lab Control Sample | Total/NA | Water | EPA 537.1 V2 | 233180 |
| MRL 380-233180/20-A | Lab Control Sample | Total/NA | Water | EPA 537.1 V2 | 233180 |
| 380-219037-B-1-A MS | Matrix Spike | Total/NA | Water | EPA 537.1 V2 | 233180 |
| 380-219037-C-1-A MSD | Matrix Spike Duplicate | Total/NA | Water | EPA 537.1 V2 | 233180 |

Analysis Batch: 233464

| Lab Sample ID | Client Sample ID | Prep Type | Matrix | Method | Prep Batch |
|---------------|---|-----------|--------|--------------|------------|
| 380-218956-2 | FB: AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Total/NA | Water | EPA 537.1 V2 | 233180 |

Prep Batch: 233676

| Lab Sample ID | Client Sample ID | Prep Type | Matrix | Method | Prep Batch |
|----------------------|---|-----------|--------|--------|------------|
| 380-218956-2 | FB: AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Total/NA | Water | 533 | |
| MBL 380-233676/20-A | Method Blank | Total/NA | Water | 533 | |
| LCS 380-233676/22-A | Lab Control Sample | Total/NA | Water | 533 | |
| MRL 380-233676/21-A | Lab Control Sample | Total/NA | Water | 533 | |
| 380-218914-B-2-A MS | Matrix Spike | Total/NA | Water | 533 | |
| 380-218914-C-2-A MSD | Matrix Spike Duplicate | Total/NA | Water | 533 | |

Analysis Batch: 233715

| Lab Sample ID | Client Sample ID | Prep Type | Matrix | Method | Prep Batch |
|----------------------|---|-----------|--------|--------|------------|
| 380-218956-2 | FB: AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Total/NA | Water | 533 | 233676 |
| MBL 380-233676/20-A | Method Blank | Total/NA | Water | 533 | 233676 |
| LCS 380-233676/22-A | Lab Control Sample | Total/NA | Water | 533 | 233676 |
| MRL 380-233676/21-A | Lab Control Sample | Total/NA | Water | 533 | 233676 |
| 380-218914-B-2-A MS | Matrix Spike | Total/NA | Water | 533 | 233676 |
| 380-218914-C-2-A MSD | Matrix Spike Duplicate | Total/NA | Water | 533 | 233676 |

Prep Batch: 233929

| Lab Sample ID | Client Sample ID | Prep Type | Matrix | Method | Prep Batch |
|-----------------------|---|-----------|----------------|--------|------------|
| 380-218956-1 | AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Total/NA | Drinking Water | 533 | |
| MBL 380-233929/20-A | Method Blank | Total/NA | Water | 533 | |
| LCS 380-233929/22-A | Lab Control Sample | Total/NA | Water | 533 | |
| MRL 380-233929/21-A | Lab Control Sample | Total/NA | Water | 533 | |
| 380-219143-B-13-A MS | Matrix Spike | Total/NA | Water | 533 | |
| 380-219143-C-13-A MSD | Matrix Spike Duplicate | Total/NA | Water | 533 | |

Analysis Batch: 234115

| Lab Sample ID | Client Sample ID | Prep Type | Matrix | Method | Prep Batch |
|---------------|---|-----------|----------------|--------|------------|
| 380-218956-1 | AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Total/NA | Drinking Water | 533 | 233929 |

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

LCMS (Continued)

Analysis Batch: 234115 (Continued)

| Lab Sample ID | Client Sample ID | Prep Type | Matrix | Method | Prep Batch |
|-----------------------|------------------------|-----------|--------|--------|------------|
| MBL 380-233929/20-A | Method Blank | Total/NA | Water | 533 | 233929 |
| LCS 380-233929/22-A | Lab Control Sample | Total/NA | Water | 533 | 233929 |
| MRL 380-233929/21-A | Lab Control Sample | Total/NA | Water | 533 | 233929 |
| 380-219143-B-13-A MS | Matrix Spike | Total/NA | Water | 533 | 233929 |
| 380-219143-C-13-A MSD | Matrix Spike Duplicate | Total/NA | Water | 533 | 233929 |

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

**Client Sample ID: AIEA GULCH WELLS PUMP 1
(331-201-TP071)**

Lab Sample ID: 380-218956-1

Date Collected: 06/08/26 09:30

Matrix: Drinking Water

Date Received: 06/10/26 09:24

| Prep Type | Batch Type | Batch Method | Run | Dilution Factor | Batch Number | Batch Analyst | Lab | Prepared or Analyzed |
|-----------|------------|--------------|-----|-----------------|--------------|---------------|--------|----------------------|
| Total/NA | Prep | 533 | | | 233929 | E2HD | EA POM | 06/15/26 15:23 |
| Total/NA | Analysis | 533 | | 1 | 234115 | Y5FM | EA POM | 06/16/26 12:22 |
| Total/NA | Prep | 537.1 DW | | | 233180 | LM3A | EA POM | 06/11/26 11:30 |
| Total/NA | Analysis | EPA 537.1 V2 | | 1 | 233406 | SZ9R | EA POM | 06/12/26 08:32 |

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 1
(331-201-TP071)**

Lab Sample ID: 380-218956-2

Date Collected: 06/08/26 09:30

Matrix: Water

Date Received: 06/10/26 09:24

| Prep Type | Batch Type | Batch Method | Run | Dilution Factor | Batch Number | Batch Analyst | Lab | Prepared or Analyzed |
|-----------|------------|--------------|-----|-----------------|--------------|---------------|--------|----------------------|
| Total/NA | Prep | 533 | | | 233676 | N8NE | EA POM | 06/13/26 12:30 |
| Total/NA | Analysis | 533 | | 1 | 233715 | M7ML | EA POM | 06/14/26 16:26 |
| Total/NA | Prep | 537.1 DW | | | 233180 | LM3A | EA POM | 06/11/26 11:30 |
| Total/NA | Analysis | EPA 537.1 V2 | | 1 | 233464 | Y5FM | EA POM | 06/12/26 17:47 |

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

| Authority | Program | Identification Number | Expiration Date |
|-----------|---------|-----------------------|-----------------|
| Hawaii | State | CA00006 | 01-31-26 * |

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

| Method | Method Description | Protocol | Laboratory |
|--------------|---|----------|------------|
| 533 | Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water | EPA | EA POM |
| EPA 537.1 V2 | EPA 537.1 Ver. 2.0 March 2020 | EPA | EA POM |
| 533 | Extraction of Perfluorinated and Polyfluorinated Alkyl Acids | EPA | EA POM |
| 537.1 DW | Extraction of Perfluorinated Alkyl Acids | EPA | EA POM |

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-218956-1
SDG: Weekly: Aiea Gulch Wells Pump 1

| Lab Sample ID | Client Sample ID | Matrix | Collected | Received | PWSID Number |
|---------------|---|----------------|----------------|----------------|--------------|
| 380-218956-1 | AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Drinking Water | 06/08/26 09:30 | 06/10/26 09:24 | HI0000331 |
| 380-218956-2 | FB: AIEA GULCH WELLS PUMP 1 (331-201-TP071) | Water | 06/08/26 09:30 | 06/10/26 09:24 | HI0000331 |

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Monrovia, CA (Suite 100)
 750 Royal Oaks Drive Suite 100
 Monrovia CA 91016
 Phone (626) 386-1100

Chain of Custody Record



Environment Testing
 America

| | | | | | | | |
|---|--|-------------------------------------|--|--|--|--|--|
| Client Information | | Lab PM Lopez, Maria | | Carrier Tracking No(s): | | COC No | |
| Client Contact: Kirk Iwamoto | | Phone: +1 808 748 5840 | | State of Origin: | | Page: Page 1 of 1 | |
| Company: City & County of Honolulu | | E-Mail: Maria.Lopez@eurofins.com | | PWSID: | | Job #: | |
| Address: 630 South Beretania Street, Chemistry Lab Honolulu | | Due Date Requested | | Analysis Requested | | Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other M - Hexane N - None O - AsNaO2 P - Na2CO3 Q - Na2SO3 R - Na2S2O3 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 Y - Trizma Z - other (specify) NH4 Acetate | |
| City: State Zip: HI 96843 | | TAT Requested (days): RUSH | | | | | |
| Phone: 808-748-5840 (tel) | | Compliance Project: Δ No | | | | | |
| Email: kiwamoto@hbws.org | | PO #: C20525101 exp 05312023 | | | | | |
| Project Name: RED-HILL/HBWS sites Event Desc: RUSH Weekly Red Hill | | WO #: 38001111 | | | | | |
| Site: 38001111 | | SSOW#: | | Field Filtered Sample (Yes or No) | | 533 - All Analytes | |
| Sample Identification | | Sample Date | | Sample Time | | Sample Type (C=comp, G=grab) | |
| AIEA GULCH WELLS PUMP 1 (331-201-TP071) | | 8-Jun-2026 | | 9:30 | | G | |
| Matrix (Water, Solid, Other) | | Preservation Code: | | 537 1 DW_PREC - 537 1 Full List | | Perform MS/MSD (Yes or No) | |
| Water | | G | | Y | | X | |
| FB AIEA GULCH WELLS PUMP 1 (331-201-TP071) | | 8-Jun-2026 | | 9:30 | | G | |
| Water | | G | | I | | I | |
| Total Number of Containers | | Special Instructions/Note: | | 537 1 DW_PREC - 537 1 Full List | | 380-218956 COC | |
| Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) | | Return To Client | | Disposal By Lab | | Archive For | |
| Special Instructions/QC Requirements: | | Poison B | | Skin Irritant | | Flammable | |
| Deliverable Requested I II III IV Other (specify) | | Unknown | | Radiological | | Months | |
| Empty Kit Relinquished by: | | Date | | Method of Shipment: | | FED EX | |
| Relinquished by: | | 6/9/26 12:00 | | Received by: | | Date/Time: 6/10/26 09:24 | |
| Relinquished by: | | Date/Time: | | Received by: | | Date/Time: | |
| Relinquished by: | | Date/Time: | | Received by: | | Date/Time: | |
| Custody Seals Intact: Δ Yes Δ No | | Custody Seal No. | | Cooler Temperature(s) °C and Other Remarks: 6300 53-0-1-5 26C | | Company: HBWS | |



Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-218956-1
SDG Number: Weekly: Aiea Gulch Wells Pump 1

Login Number: 218956

List Number: 1

Creator: Segura, Ryan

List Source: Eurofins Pomona

| Question | Answer | Comment |
|--|--------|---------|
| The coolers custody seal, if present, is intact. | N/A | |
| Sample custody seals, if present, are intact. | N/A | |
| Samples were received on ice. | True | |
| Cooler(s) Temperature is acceptable. | True | |
| Cooler(s) Temperature is recorded. | True | |
| COC is present. | True | |
| COC is filled out in ink and is legible. | True | |
| COC is filled out with all pertinent information. | True | |
| There are no discrepancies between the containers received and the COC. | True | |
| Samples are received within Holding Time (excluding tests with immediate HTs) | True | |
| Sample containers have legible labels. | True | |
| Containers are not broken or leaking. | True | |
| Sample collection date/times are provided. | True | |
| There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs | True | |
| Containers requiring zero headspace have no headspace or bubble is <6mm (1/4"). | True | |
| CIO4 headspace requirement met (>50% for CA, >30% for other states). | True | |
| Samples do not require splitting or compositing. | True | |
| Container provided by EEA | True | |

