

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 8/14/2026 2:58:34 PM

JOB DESCRIPTION

INTERA - Red-Hill-Incident
Site D2 PFAS 533/537.1

JOB NUMBER

380-230135-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Generated
8/14/2026 2:58:34 PM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	14
QC Association Summary	25
Lab Chronicle	26
Certification Summary	27
Method Summary	28
Sample Summary	29
Chain of Custody	30
Receipt Checklists	31



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: INTERA - Red-Hill-Incident

Job ID: 380-230135-1

Job ID: 380-230135-1

Eurofins Pomona

Job Narrative 380-230135-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 8/11/2026 10:10 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 1.5°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-230135-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanesulfonic acid (PFHxS)	8.9		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.9		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.9		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	10		2.0	ng/L	1		EPA 537.1 V2	Total/NA

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-230135-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-230135-1

Date Collected: 08/10/26 10:45

Matrix: Water

Date Received: 08/11/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9CI-PF3ONS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluorohexanesulfonic acid (PFHxS)	8.9		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluorooctanoic acid (PFOA)	3.9		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 12:40	1
Isotope Dilution	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	114		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C6 PFDA	100		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C5 PFHxA	121		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C4 PFHpA	115		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C8 PFOA	116		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C9 PFNA	108		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C7 PFUnA	95		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C2 PFDoA	93		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C4 PFBA	110		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C5 PFPeA	118		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C3 PFBS	125		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C3 PFHxS	120		50 - 200			08/12/26 17:50	08/13/26 12:40	1
13C8 PFOS	114		50 - 200			08/12/26 17:50	08/13/26 12:40	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-230135-1

Date Collected: 08/10/26 10:45

Matrix: Water

Date Received: 08/11/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2-4:2-FTS	127		50 - 200	08/12/26 17:50	08/13/26 12:40	1
13C2-6:2-FTS	101		50 - 200	08/12/26 17:50	08/13/26 12:40	1
13C2-8:2-FTS	86		50 - 200	08/12/26 17:50	08/13/26 12:40	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorooctanoic acid (PFOA)	3.9		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorohexanesulfonic acid (PFHxS)	10		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Perfluorotridecanoic acid (PFTDA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 11:55	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	105		70 - 130			08/12/26 13:10	08/13/26 11:55	1
13C2 PFHxA	103		70 - 130			08/12/26 13:10	08/13/26 11:55	1
13C2 PFDA	105		70 - 130			08/12/26 13:10	08/13/26 11:55	1
13C3-GenX	99		70 - 130			08/12/26 13:10	08/13/26 11:55	1

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-230135-2

Date Collected: 08/10/26 10:45

Matrix: Water

Date Received: 08/11/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-230135-2

Date Collected: 08/10/26 10:45

Matrix: Water

Date Received: 08/11/26 10:10

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		08/12/26 17:50	08/13/26 13:01	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	114		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C6 PFDA	101		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C5 PFHxA	118		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C4 PFHpA	113		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C8 PFOA	111		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C9 PFNA	104		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C7 PFUnA	99		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C2 PFDoA	98		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C4 PFBA	114		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C5 PFPeA	107		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C3 PFBS	116		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C3 PFHxS	109		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C8 PFOS	107		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C2-4:2-FTS	114		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C2-6:2-FTS	103		50 - 200	08/12/26 17:50	08/13/26 13:01	1
13C2-8:2-FTS	85		50 - 200	08/12/26 17:50	08/13/26 13:01	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-230135-2

Date Collected: 08/10/26 10:45

Matrix: Water

Date Received: 08/11/26 10:10

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		08/12/26 13:10	08/13/26 12:05	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	95		70 - 130			08/12/26 13:10	08/13/26 12:05	1
13C2 PFHxA	94		70 - 130			08/12/26 13:10	08/13/26 12:05	1
13C2 PFDA	101		70 - 130			08/12/26 13:10	08/13/26 12:05	1
13C3-GenX	92		70 - 130			08/12/26 13:10	08/13/26 12:05	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-230135-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	8.9		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	3.9		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	3.9		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	10		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-230135-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-230135-1	BWS2254-D2-AQ	105	103	105	99
380-230135-2	BWS2254-D2-FB	95	94	101	92
380-230140-B-1-A MS	Matrix Spike	99	104	107	102
380-230140-C-1-A MSD	Matrix Spike Duplicate	98	100	103	100
LCS 380-245997/22-A	Lab Control Sample	119	122	128	120
MBL 380-245997/20-A	Method Blank	100	103	109	99
MRL 380-245997/21-A	Lab Control Sample	98	106	108	100

Surrogate Legend

d5NEFOS = d5-NEtFOSAA

PFHxA = 13C2 PFHxA

PFDA = 13C2 PFDA

GenX = 13C3-GenX

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-230103-B-1-A MSD	Matrix Spike Duplicate	121	106	125	119	117	111	103	102
380-230103-C-1-A MS	Matrix Spike	122	103	125	118	110	110	101	100
380-230135-1	BWS2254-D2-AQ	114	100	121	115	116	108	95	93
380-230135-2	BWS2254-D2-FB	114	101	118	113	111	104	99	98
LCS 380-246061/22-A	Lab Control Sample	123	104	118	118	111	108	98	100
MBL 380-246061/20-A	Method Blank	111	106	118	111	112	110	102	104
MRL 380-246061/21-A	Lab Control Sample	114	98	119	115	112	104	93	94
		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-230103-B-1-A MSD	Matrix Spike Duplicate	76	108	117	116	109	115	98	89
380-230103-C-1-A MS	Matrix Spike	106	115	119	115	110	115	98	87
380-230135-1	BWS2254-D2-AQ	110	118	125	120	114	127	101	86
380-230135-2	BWS2254-D2-FB	114	107	116	109	107	114	103	85
LCS 380-246061/22-A	Lab Control Sample	112	115	121	116	111	116	98	89
MBL 380-246061/20-A	Method Blank	106	109	116	113	114	110	97	91
MRL 380-246061/21-A	Lab Control Sample	98	110	123	116	111	118	96	84
Surrogate Legend									
HFPODA = 13C3 HFPO-DA									
C6PFDA = 13C6 PFDA									
13C5PHA = 13C5 PFHxA									
C4PFHA = 13C4 PFHpA									
C8PFOA = 13C8 PFOA									
C9PFNA = 13C9 PFNA									
13C7PUA = 13C7 PFUnA									
PFDaA = 13C2 PFDaA									
PFBA = 13C4 PFBA									
PFPeA = 13C5 PFPeA									
C3PFBS = 13C3 PFBS									
C3PFHS = 13C3 PFHxS									
C8PFOS = 13C8 PFOS									
42FTS = 13C2-4:2-FTS									
62FTS = 13C2-6:2-FTS									
82FTS = 13C2-8:2-FTS									

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-246061/20-A

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 246061

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<0.29		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9CI-PF3ONS)	<0.30		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<0.98		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluorobutanoic acid (PFBA)	<0.68		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.36		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.47		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.46		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.24		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.45		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluoropentanoic acid (PFPeA)	<0.37		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.35		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1
Perfluoropentanesulfonic acid (PFPeS)	<0.38		2.0	ng/L		08/12/26 17:50	08/13/26 10:24	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	111		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C6 PFDA	106		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C5 PFHxA	118		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C4 PFHpA	111		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C8 PFOA	112		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C9 PFNA	110		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C7 PFUnA	102		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C2 PFDoA	104		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C4 PFBA	106		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C5 PFPeA	109		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C3 PFBS	116		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C3 PFHxS	113		50 - 200	08/12/26 17:50	08/13/26 10:24	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-246061/20-A

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 246061

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	114		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C2-4:2-FTS	110		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C2-6:2-FTS	97		50 - 200	08/12/26 17:50	08/13/26 10:24	1
13C2-8:2-FTS	91		50 - 200	08/12/26 17:50	08/13/26 10:24	1

Lab Sample ID: LCS 380-246061/22-A

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246061

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	118	108		ng/L		91	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	118	112		ng/L		95	70 - 130
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	118	108		ng/L		91	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	118	106		ng/L		90	70 - 130
Perfluorobutanesulfonic acid (PFBS)	118	107		ng/L		90	70 - 130
Perfluorodecanoic acid (PFDA)	118	106		ng/L		90	70 - 130
Perfluorododecanoic acid (PFDoA)	118	108		ng/L		91	70 - 130
Perfluorooheptanoic acid (PFHpA)	118	105		ng/L		89	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	118	111		ng/L		94	70 - 130
Perfluorohexanoic acid (PFHxA)	118	111		ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	118	110		ng/L		93	70 - 130
Perfluorooctanesulfonic acid (PFOS)	118	109		ng/L		92	70 - 130
Perfluorooctanoic acid (PFOA)	118	107		ng/L		90	70 - 130
Perfluoroundecanoic acid (PFUnA)	118	111		ng/L		94	70 - 130
Perfluorobutanoic acid (PFBA)	118	102		ng/L		86	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	118	109		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	118	108		ng/L		91	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	118	111		ng/L		94	70 - 130
Nonfluoro-3,6-dioxahexanoic acid (NFDHA)	118	112		ng/L		95	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	118	110		ng/L		93	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	118	106		ng/L		90	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	118	107		ng/L		90	70 - 130
Perfluoropentanoic acid (PFPeA)	118	110		ng/L		93	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	118	110		ng/L		94	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-246061/22-A

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246061

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	118	112		ng/L		94	70 - 130
	LCS	LCS					
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	123		50 - 200				
13C6 PFDA	104		50 - 200				
13C5 PFHxA	118		50 - 200				
13C4 PFHpA	118		50 - 200				
13C8 PFOA	111		50 - 200				
13C9 PFNA	108		50 - 200				
13C7 PFUnA	98		50 - 200				
13C2 PFDoA	100		50 - 200				
13C4 PFBA	112		50 - 200				
13C5 PFPeA	115		50 - 200				
13C3 PFBS	121		50 - 200				
13C3 PFHxS	116		50 - 200				
13C8 PFOS	111		50 - 200				
13C2-4:2-FTS	116		50 - 200				
13C2-6:2-FTS	98		50 - 200				
13C2-8:2-FTS	89		50 - 200				

Lab Sample ID: MRL 380-246061/21-A

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246061

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.97	1.87	J	ng/L		95	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.97	1.91	J	ng/L		97	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.97	1.86	J	ng/L		95	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	1.97	1.89	J	ng/L		96	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.97	1.74	J	ng/L		88	50 - 150
Perfluorodecanoic acid (PFDA)	1.97	1.88	J	ng/L		96	50 - 150
Perfluorododecanoic acid (PFDoA)	1.97	1.82	J	ng/L		92	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.97	1.81	J	ng/L		92	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.97	2.00	J	ng/L		102	50 - 150
Perfluorohexanoic acid (PFHxA)	1.97	1.68	J	ng/L		85	50 - 150
Perfluorononanoic acid (PFNA)	1.97	1.93	J	ng/L		98	50 - 150
Perfluorooctanesulfonic acid (PFOS)	1.97	1.69	J	ng/L		86	50 - 150
Perfluorooctanoic acid (PFOA)	1.97	1.80	J	ng/L		91	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.97	1.92	J	ng/L		98	50 - 150
Perfluorobutanoic acid (PFBA)	1.97	1.80	J	ng/L		91	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-246061/21-A

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 246061

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	1.97	1.87	J	ng/L		95	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	1.97	1.87	J	ng/L		95	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	1.97	1.96	J	ng/L		100	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	1.97	1.78	J	ng/L		91	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	1.97	1.83	J	ng/L		93	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	1.97	1.78	J	ng/L		91	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	1.97	1.84	J	ng/L		93	50 - 150
Perfluoropentanoic acid (PFPeA)	1.97	1.93	J	ng/L		98	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	1.97	1.85	J	ng/L		94	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	1.97	1.99	J	ng/L		101	50 - 150

Isotope Dilution	%Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	114		50 - 200
13C6 PFDA	98		50 - 200
13C5 PFHxA	119		50 - 200
13C4 PFHpA	115		50 - 200
13C8 PFOA	112		50 - 200
13C9 PFNA	104		50 - 200
13C7 PFUnA	93		50 - 200
13C2 PFDoA	94		50 - 200
13C4 PFBA	98		50 - 200
13C5 PFPeA	110		50 - 200
13C3 PFBS	123		50 - 200
13C3 PFHxS	116		50 - 200
13C8 PFOS	111		50 - 200
13C2-4:2-FTS	118		50 - 200
13C2-6:2-FTS	96		50 - 200
13C2-8:2-FTS	84		50 - 200

Lab Sample ID: 380-230103-B-1-A MSD

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 246061

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		118	110		ng/L		93	70 - 130	3	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		118	113		ng/L		96	70 - 130	1	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		118	107		ng/L		91	70 - 130	2	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-230103-B-1-A MSD

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 246061

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide	<2.0		118	116		ng/L		98	70 - 130	9	30
Dimer Acid (HFPO-DA/GenX)											
Perfluorobutanesulfonic acid (PFBS)	<2.0		118	112		ng/L		95	70 - 130	3	30
Perfluorodecanoic acid (PFDA)	<2.0		118	113		ng/L		96	70 - 130	6	30
Perfluorododecanoic acid (PFDoA)	<2.0		118	109		ng/L		93	70 - 130	5	30
Perfluoroheptanoic acid (PFHpA)	<2.0		118	111		ng/L		94	70 - 130	6	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		118	109		ng/L		93	70 - 130	3	30
Perfluorohexanoic acid (PFHxA)	<2.0		118	106		ng/L		90	70 - 130	3	30
Perfluorononanoic acid (PFNA)	<2.0		118	109		ng/L		92	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		118	109		ng/L		92	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	<2.0		118	106		ng/L		90	70 - 130	4	30
Perfluoroundecanoic acid (PFUnA)	<2.0		118	111		ng/L		94	70 - 130	3	30
Perfluorobutanoic acid (PFBA)	<2.0		118	114		ng/L		96	70 - 130	4	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		118	110		ng/L		93	70 - 130	0	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		118	107		ng/L		90	70 - 130	4	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		118	113		ng/L		96	70 - 130	5	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		118	106		ng/L		90	70 - 130	6	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		118	110		ng/L		93	70 - 130	2	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		118	110		ng/L		93	70 - 130	2	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		118	110		ng/L		93	70 - 130	1	30
Perfluoropentanoic acid (PFPeA)	<2.0		118	110		ng/L		94	70 - 130	0	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		118	115		ng/L		98	70 - 130	5	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		118	114		ng/L		96	70 - 130	5	30

Isotope Dilution	MSD %Recovery	MSD Qualifier	MSD Limits
13C3 HFPO-DA	121		50 - 200
13C6 PFDA	106		50 - 200
13C5 PFHxA	125		50 - 200
13C4 PFHpA	119		50 - 200
13C8 PFOA	117		50 - 200
13C9 PFNA	111		50 - 200
13C7 PFUnA	103		50 - 200
13C2 PFDoA	102		50 - 200
13C4 PFBA	76		50 - 200
13C5 PFPeA	108		50 - 200
13C3 PFBS	117		50 - 200
13C3 PFHxS	116		50 - 200
13C8 PFOS	109		50 - 200

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-230103-B-1-A MSD

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 246061

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C2-4:2-FTS	115		50 - 200
13C2-6:2-FTS	98		50 - 200
13C2-8:2-FTS	89		50 - 200

Lab Sample ID: 380-230103-C-1-A MS

Matrix: Water

Analysis Batch: 246229

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 246061

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		118	107		ng/L		90	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		118	112		ng/L		95	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		118	109		ng/L		92	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		118	107		ng/L		90	70 - 130
Perfluorobutanesulfonic acid (PFBS)	<2.0		118	108		ng/L		92	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		118	106		ng/L		90	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		118	104		ng/L		88	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		118	104		ng/L		88	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		118	113		ng/L		96	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		118	103		ng/L		88	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		118	110		ng/L		93	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		118	108		ng/L		91	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		118	111		ng/L		94	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		118	108		ng/L		91	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		118	109		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		118	110		ng/L		93	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		118	103		ng/L		87	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		118	108		ng/L		91	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		118	100		ng/L		85	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		118	112		ng/L		95	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		118	108		ng/L		91	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		118	110		ng/L		93	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		118	111		ng/L		94	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		118	109		ng/L		93	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		118	119		ng/L		101	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	122		50 - 200
13C6 PFDA	103		50 - 200
13C5 PFHxA	125		50 - 200
13C4 PFHpA	118		50 - 200
13C8 PFOA	110		50 - 200
13C9 PFNA	110		50 - 200
13C7 PFUnA	101		50 - 200
13C2 PFDoA	100		50 - 200
13C4 PFBA	106		50 - 200
13C5 PFPeA	115		50 - 200
13C3 PFBS	119		50 - 200
13C3 PFHxS	115		50 - 200
13C8 PFOS	110		50 - 200
13C2-4:2-FTS	115		50 - 200
13C2-6:2-FTS	98		50 - 200
13C2-8:2-FTS	87		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-245997/20-A
Matrix: Water
Analysis Batch: 246221

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 245997

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer	<0.98		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Acid (HFPO-DA/GenX)								
Perfluorooctanesulfonic acid (PFOS)	<0.42		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluoroundecanoic acid (PFUnA)	<0.41		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.57		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.41		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluorohexanoic acid (PFHxA)	<0.45		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluorododecanoic acid (PFDoA)	<0.53		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluorooctanoic acid (PFOA)	<0.37		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluorodecanoic acid (PFDA)	<0.30		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluorohexanesulfonic acid (PFHxS)	<0.31		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluorobutanesulfonic acid (PFBS)	<0.36		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluoroheptanoic acid (PFHpA)	<0.38		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluorononanoic acid (PFNA)	<0.39		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluorotetradecanoic acid (PFTA)	<0.53		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Perfluorotridecanoic acid (PFTrDA)	<0.35		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<0.29		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.29		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.59		2.0	ng/L		08/12/26 13:10	08/13/26 10:10	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	100		70 - 130			08/12/26 13:10	08/13/26 10:10	1
13C2 PFHxA	103		70 - 130			08/12/26 13:10	08/13/26 10:10	1
13C2 PFDA	109		70 - 130			08/12/26 13:10	08/13/26 10:10	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-245997/20-A

Matrix: Water

Analysis Batch: 246221

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 245997

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	99		70 - 130	08/12/26 13:10	08/13/26 10:10	1

Lab Sample ID: LCS 380-245997/22-A

Matrix: Water

Analysis Batch: 246221

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 245997

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	49.1	43.6		ng/L		89	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	49.1	48.7		ng/L		99	70 - 130
Perfluoroundecanoic acid (PFUnA)	49.1	46.7		ng/L		95	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	49.1	46.9		ng/L		96	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	49.1	44.5		ng/L		91	70 - 130
Perfluorohexanoic acid (PFHxA)	49.1	46.5		ng/L		95	70 - 130
Perfluorododecanoic acid (PFDoA)	49.1	47.1		ng/L		96	70 - 130
Perfluorooctanoic acid (PFOA)	49.1	47.5		ng/L		97	70 - 130
Perfluorodecanoic acid (PFDA)	49.1	46.3		ng/L		94	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	49.1	48.7		ng/L		99	70 - 130
Perfluorobutanesulfonic acid (PFBS)	49.1	47.8		ng/L		97	70 - 130
Perfluoroheptanoic acid (PFHpA)	49.1	46.3		ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	49.1	48.0		ng/L		98	70 - 130
Perfluorotetradecanoic acid (PFTA)	49.1	42.4		ng/L		86	70 - 130
Perfluorotridecanoic acid (PFTrDA)	49.1	47.9		ng/L		98	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	49.1	48.7		ng/L		99	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	49.1	46.4		ng/L		94	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	49.1	45.5		ng/L		93	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	119		70 - 130
13C2 PFHxA	122		70 - 130
13C2 PFDA	128		70 - 130
13C3-GenX	120		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-245997/21-A

Matrix: Water

Analysis Batch: 246221

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 245997

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	1.96	1.73	J	ng/L		88	50 - 150
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	1.96	1.89	J	ng/L		96	50 - 150
Perfluoroundecanoic acid (PFUnA)	1.96	1.96	J	ng/L		100	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	1.96	1.90	J	ng/L		97	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	1.96	1.87	J	ng/L		95	50 - 150
Perfluorohexanoic acid (PFHxA)	1.96	1.94	J	ng/L		99	50 - 150
Perfluorododecanoic acid (PFDoA)	1.96	1.99	J	ng/L		101	50 - 150
Perfluorooctanoic acid (PFOA)	1.96	1.88	J	ng/L		96	50 - 150
Perfluorodecanoic acid (PFDA)	1.96	1.93	J	ng/L		98	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.96	2.00	J	ng/L		102	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.96	1.99	J	ng/L		101	50 - 150
Perfluoroheptanoic acid (PFHpA)	1.96	1.85	J	ng/L		94	50 - 150
Perfluorononanoic acid (PFNA)	1.96	1.96	J	ng/L		100	50 - 150
Perfluorotetradecanoic acid (PFTA)	1.96	1.82	J	ng/L		93	50 - 150
Perfluorotridecanoic acid (PFTrDA)	1.96	1.94	J	ng/L		99	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	1.96	1.90	J	ng/L		97	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	1.96	1.71	J	ng/L		87	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.96	1.82	J	ng/L		93	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	98		70 - 130
13C2 PFHxA	106		70 - 130
13C2 PFDA	108		70 - 130
13C3-GenX	100		70 - 130

Lab Sample ID: 380-230140-B-1-A MS

Matrix: Water

Analysis Batch: 246221

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 245997

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		24.6	24.4		ng/L		99	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorooctanesulfonic acid (PFOS)	<2.0		24.6	26.9		ng/L		106	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	24.9		ng/L		101	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	25.5		ng/L		104	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-230140-B-1-A MS

Matrix: Water

Analysis Batch: 246221

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 245997

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits		
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.6	24.5		ng/L		100	70 - 130		
Perfluorohexanoic acid (PFHxA)	2.4		24.6	27.9		ng/L		104	70 - 130		
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	25.5		ng/L		104	70 - 130		
Perfluorooctanoic acid (PFOA)	<2.0		24.6	26.3		ng/L		101	70 - 130		
Perfluorodecanoic acid (PFDA)	<2.0		24.6	25.2		ng/L		102	70 - 130		
Perfluorohexanesulfonic acid (PFHxS)	4.2		24.6	30.7		ng/L		108	70 - 130		
Perfluorobutanesulfonic acid (PFBS)	4.1		24.6	30.4		ng/L		107	70 - 130		
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	26.9		ng/L		105	70 - 130		
Perfluorononanoic acid (PFNA)	<2.0		24.6	26.3		ng/L		107	70 - 130		
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	24.3		ng/L		99	70 - 130		
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	26.7		ng/L		108	70 - 130		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	25.5		ng/L		104	70 - 130		
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	25.5		ng/L		104	70 - 130		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	24.9		ng/L		101	70 - 130		

Lab Sample ID: 380-230140-C-1-A MSD

Matrix: Water

Analysis Batch: 246221

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 245997

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		24.6	23.3		ng/L		95	70 - 130	4	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		24.6	27.0		ng/L		106	70 - 130	0	30
Perfluoroundecanoic acid (PFUnA)	<2.0		24.6	24.5		ng/L		100	70 - 130	1	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		24.6	25.1		ng/L		102	70 - 130	1	30
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		24.6	24.9		ng/L		101	70 - 130	2	30
Perfluorohexanoic acid (PFHxA)	2.4		24.6	27.2		ng/L		101	70 - 130	2	30
Perfluorododecanoic acid (PFDoA)	<2.0		24.6	25.2		ng/L		102	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	<2.0		24.6	26.0		ng/L		100	70 - 130	1	30
Perfluorodecanoic acid (PFDA)	<2.0		24.6	24.8		ng/L		101	70 - 130	2	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-230140-C-1-A MSD

Matrix: Water

Analysis Batch: 246221

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 245997

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorohexanesulfonic acid (PFHxS)	4.2		24.6	30.8		ng/L		108	70 - 130	0	30
Perfluorobutanesulfonic acid (PFBS)	4.1		24.6	29.8		ng/L		104	70 - 130	2	30
Perfluoroheptanoic acid (PFHpA)	<2.0		24.6	25.6		ng/L		100	70 - 130	5	30
Perfluorononanoic acid (PFNA)	<2.0		24.6	25.2		ng/L		103	70 - 130	4	30
Perfluorotetradecanoic acid (PFTA)	<2.0		24.6	23.8		ng/L		97	70 - 130	2	30
Perfluorotridecanoic acid (PFTrDA)	<2.0		24.6	26.2		ng/L		107	70 - 130	2	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		24.6	25.3		ng/L		103	70 - 130	1	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		24.6	25.9		ng/L		105	70 - 130	2	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		24.6	24.5		ng/L		99	70 - 130	2	30
Surrogate	MSD %Recovery	MSD Qualifier	Limits								
d5-NEtFOSAA	98		70 - 130								
13C2 PFHxA	100		70 - 130								
13C2 PFDA	103		70 - 130								
13C3-GenX	100		70 - 130								

QC Association Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

LCMS

Prep Batch: 245997

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230135-1	BWS2254-D2-AQ	Total/NA	Water	537.1 DW	
380-230135-2	BWS2254-D2-FB	Total/NA	Water	537.1 DW	
MBL 380-245997/20-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-245997/22-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-245997/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-230140-B-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-230140-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

Prep Batch: 246061

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230135-1	BWS2254-D2-AQ	Total/NA	Water	533	
380-230135-2	BWS2254-D2-FB	Total/NA	Water	533	
MBL 380-246061/20-A	Method Blank	Total/NA	Water	533	
LCS 380-246061/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-246061/21-A	Lab Control Sample	Total/NA	Water	533	
380-230103-B-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	
380-230103-C-1-A MS	Matrix Spike	Total/NA	Water	533	

Analysis Batch: 246221

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230135-1	BWS2254-D2-AQ	Total/NA	Water	EPA 537.1 V2	245997
380-230135-2	BWS2254-D2-FB	Total/NA	Water	EPA 537.1 V2	245997
MBL 380-245997/20-A	Method Blank	Total/NA	Water	EPA 537.1 V2	245997
LCS 380-245997/22-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	245997
MRL 380-245997/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	245997
380-230140-B-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	245997
380-230140-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	245997

Analysis Batch: 246229

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-230135-1	BWS2254-D2-AQ	Total/NA	Water	533	246061
380-230135-2	BWS2254-D2-FB	Total/NA	Water	533	246061
MBL 380-246061/20-A	Method Blank	Total/NA	Water	533	246061
LCS 380-246061/22-A	Lab Control Sample	Total/NA	Water	533	246061
MRL 380-246061/21-A	Lab Control Sample	Total/NA	Water	533	246061
380-230103-B-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	246061
380-230103-C-1-A MS	Matrix Spike	Total/NA	Water	533	246061

Lab Chronicle

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Client Sample ID: BWS2254-D2-AQ

Lab Sample ID: 380-230135-1

Date Collected: 08/10/26 10:45

Matrix: Water

Date Received: 08/11/26 10:10

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			246061	E2HD	EA POM	08/12/26 17:50
Total/NA	Analysis	533		1	246229	M7ML	EA POM	08/13/26 12:40
Total/NA	Prep	537.1 DW			245997	LM3A	EA POM	08/12/26 13:10
Total/NA	Analysis	EPA 537.1 V2		1	246221	Y5FM	EA POM	08/13/26 11:55

Client Sample ID: BWS2254-D2-FB

Lab Sample ID: 380-230135-2

Date Collected: 08/10/26 10:45

Matrix: Water

Date Received: 08/11/26 10:10

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			246061	E2HD	EA POM	08/12/26 17:50
Total/NA	Analysis	533		1	246229	M7ML	EA POM	08/13/26 13:01
Total/NA	Prep	537.1 DW			245997	LM3A	EA POM	08/12/26 13:10
Total/NA	Analysis	EPA 537.1 V2		1	246221	Y5FM	EA POM	08/13/26 12:05

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Sample Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-230135-1
SDG: Site D2 PFAS 533/537.1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-230135-1	BWS2254-D2-AQ	Water	08/10/26 10:45	08/11/26 10:10	Hawaii
380-230135-2	BWS2254-D2-FB	Water	08/10/26 10:45	08/11/26 10:10	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Ver 05/06/2024

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-230135-1
SDG Number: Site D2 PFAS 533/537.1

Login Number: 230135

List Number: 1

Creator: Ngo, Theodore

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	