

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 7/1/2026 4:43:36 PM

JOB DESCRIPTION

INTERA - Red-Hill-Incident
Site S1 625.1, 8015B_DRO/_GRO, 8260B

JOB NUMBER

380-220504-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
7/1/2026 4:43:36 PM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	12
Surrogate Summary	14
QC Sample Results	16
QC Association Summary	29
Lab Chronicle	31
Certification Summary	32
Method Summary	33
Sample Summary	34
Chain of Custody	35
Receipt Checklists	37



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
F2	MS/MSD RPD exceeds control limits

GC Semi VOA

Qualifier	Qualifier Description
^3+	Reporting Limit Check Standard is outside acceptance limits, high biased

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: INTERA - Red-Hill-Incident

Job ID: 380-220504-1

Job ID: 380-220504-1

Eurofins Pomona

Job Narrative 380-220504-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 6/18/2026 9:43 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.9°C.

GC/MS VOA

Method 8260B: The matrix spike / matrix spike duplicate (MS/MSD) precision for analytical batch 570-761520 was outside control limits. Sample matrix interference is suspected.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

GC/MS Semi VOA

Method 625.1: The laboratory control sample (LCS) was performed in duplicate (LCSD) to provide precision data for this batch. Insufficient sample volume was available to perform a matrix spike/matrix spike duplicate (MS/MSD) associated with preparation batch 570-757352.

Method 625.1 SIM: The laboratory control sample (LCS) was performed in duplicate (LCSD) to provide precision data for this batch. Insufficient sample volume was available to perform a matrix spike/matrix spike duplicate (MS/MSD) associated with preparation batch 570-757352.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Gasoline Range Organics

Method 8015B GRO LL: Insufficient sample volume was available to perform a matrix spike/matrix spike duplicate (MS/MSD) associated with analytical batch 570-761708. The laboratory control sample (LCS) was performed in duplicate (LCSD) to provide precision data for this batch.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Diesel Range Organics

Method 8015B: The method reporting limit check (MRL) for preparation batch 570-758469 and analytical batch 570-762707 recovered outside control limits for the following analytes: C10-C28. These analytes were biased high in the MRL and were not detected in the associated samples; therefore, the data have been reported.

Method: 8015B_DRO_LL_CS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2153-S1-AQ

Lab Sample ID: 380-220504-1

No Detections.

Client Sample ID: BWS2153-S1-TB

Lab Sample ID: 380-220504-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2153-S1-AQ

Lab Sample ID: 380-220504-1

Date Collected: 06/17/26 09:00

Matrix: Water

Date Received: 06/18/26 09:43

Method: SW846 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<2.0		2.0	ug/L			06/29/26 12:50	1
1,1,1-Trichloroethane	<1.0		1.0	ug/L			06/29/26 12:50	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	ug/L			06/29/26 12:50	1
1,1,2-Trichloro-1,2,2-trifluoroethane	<10		10	ug/L			06/29/26 12:50	1
1,1,2-Trichloroethane	<1.0		1.0	ug/L			06/29/26 12:50	1
1,1-Dichloroethane	<1.0		1.0	ug/L			06/29/26 12:50	1
1,1-Dichloroethene	<1.0		1.0	ug/L			06/29/26 12:50	1
1,1-Dichloropropene	<1.0		1.0	ug/L			06/29/26 12:50	1
1,2,3-Trichlorobenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
1,2,3-Trichloropropane	<5.0		5.0	ug/L			06/29/26 12:50	1
1,2,4-Trichlorobenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
1,2,4-Trimethylbenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
1,2-Dibromo-3-Chloropropane	<10		10	ug/L			06/29/26 12:50	1
1,2-Dichlorobenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
1,2-Dichloroethane	<0.50		0.50	ug/L			06/29/26 12:50	1
1,2-Dichloropropane	<1.0		1.0	ug/L			06/29/26 12:50	1
1,3,5-Trimethylbenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
1,3-Dichlorobenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
1,3-Dichloropropane	<1.0		1.0	ug/L			06/29/26 12:50	1
1,4-Dichlorobenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
2,2-Dichloropropane	<1.0		1.0	ug/L			06/29/26 12:50	1
2-Butanone	<10		10	ug/L			06/29/26 12:50	1
2-Chlorotoluene	<1.0		1.0	ug/L			06/29/26 12:50	1
2-Hexanone	<10		10	ug/L			06/29/26 12:50	1
4-Chlorotoluene	<1.0		1.0	ug/L			06/29/26 12:50	1
Acetone	<10		10	ug/L			06/29/26 12:50	1
Benzene	<0.50		0.50	ug/L			06/29/26 12:50	1
Bromobenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
Bromochloromethane	<2.0		2.0	ug/L			06/29/26 12:50	1
Bromodichloromethane	<1.0		1.0	ug/L			06/29/26 12:50	1
Bromoform	<5.0		5.0	ug/L			06/29/26 12:50	1
Bromomethane	<10		10	ug/L			06/29/26 12:50	1
Carbon disulfide	<10		10	ug/L			06/29/26 12:50	1
Carbon tetrachloride	<0.50		0.50	ug/L			06/29/26 12:50	1
Chlorobenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
Chloroethane	<5.0		5.0	ug/L			06/29/26 12:50	1
Chloroform	<1.0		1.0	ug/L			06/29/26 12:50	1
Chloromethane	<10		10	ug/L			06/29/26 12:50	1
cis-1,2-Dichloroethene	<1.0		1.0	ug/L			06/29/26 12:50	1
cis-1,3-Dichloropropene	<0.50		0.50	ug/L			06/29/26 12:50	1
Dibromochloromethane	<2.0		2.0	ug/L			06/29/26 12:50	1
Dibromomethane	<1.0		1.0	ug/L			06/29/26 12:50	1
Dichlorodifluoromethane	<5.0		5.0	ug/L			06/29/26 12:50	1
Diethyl ether	<10		10	ug/L			06/29/26 12:50	1
Di-isopropyl ether (DIPE)	<2.0		2.0	ug/L			06/29/26 12:50	1
Ethanol	<100		100	ug/L			06/29/26 12:50	1
Ethylbenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
Ethylene Dibromide	<1.0		1.0	ug/L			06/29/26 12:50	1
Ethyl-t-butyl ether (ETBE)	<2.0		2.0	ug/L			06/29/26 12:50	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2153-S1-AQ

Lab Sample ID: 380-220504-1

Date Collected: 06/17/26 09:00

Matrix: Water

Date Received: 06/18/26 09:43

Method: SW846 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexachloro-1,3-butadiene	<10		10	ug/L			06/29/26 12:50	1
Hexane	<5.0		5.0	ug/L			06/29/26 12:50	1
Isobutyl alcohol	<75		75	ug/L			06/29/26 12:50	1
Isopropanol	<75		75	ug/L			06/29/26 12:50	1
Isopropylbenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
m,p-Xylene	<2.0		2.0	ug/L			06/29/26 12:50	1
Methylene Chloride	<10		10	ug/L			06/29/26 12:50	1
Methyl-t-Butyl Ether (MTBE)	<1.0		1.0	ug/L			06/29/26 12:50	1
MIBK	<10		10	ug/L			06/29/26 12:50	1
Naphthalene	<10		10	ug/L			06/29/26 12:50	1
n-Butylbenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
N-Propylbenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
o-Xylene	<1.0		1.0	ug/L			06/29/26 12:50	1
p-Isopropyltoluene	<1.0		1.0	ug/L			06/29/26 12:50	1
sec-Butylbenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
Styrene	<1.0		1.0	ug/L			06/29/26 12:50	1
tert-Amyl alcohol	<50		50	ug/L			06/29/26 12:50	1
Tert-amyl-methyl ether (TAME)	<2.0		2.0	ug/L			06/29/26 12:50	1
tert-Butyl alcohol (TBA)	<10		10	ug/L			06/29/26 12:50	1
tert-Butylbenzene	<1.0		1.0	ug/L			06/29/26 12:50	1
Tetrachloroethene	<1.0		1.0	ug/L			06/29/26 12:50	1
Toluene	<1.0		1.0	ug/L			06/29/26 12:50	1
trans-1,2-Dichloroethene	<1.0		1.0	ug/L			06/29/26 12:50	1
trans-1,3-Dichloropropene	<0.50		0.50	ug/L			06/29/26 12:50	1
Trichloroethene	<1.0		1.0	ug/L			06/29/26 12:50	1
Trichlorofluoromethane	<10		10	ug/L			06/29/26 12:50	1
Vinyl acetate	<10		10	ug/L			06/29/26 12:50	1
Vinyl chloride	<0.50		0.50	ug/L			06/29/26 12:50	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	117		80 - 120		06/29/26 12:50	1
4-Bromofluorobenzene (Surr)	104		80 - 120		06/29/26 12:50	1
Dibromofluoromethane (Surr)	116		80 - 120		06/29/26 12:50	1
Toluene-d8 (Surr)	100		80 - 120		06/29/26 12:50	1

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
2-Methylnaphthalene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Acenaphthene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Acenaphthylene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Anthracene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Benzo[a]anthracene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Benzo[a]pyrene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Benzo[b]fluoranthene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Benzo[g,h,i]perylene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Benzo[k]fluoranthene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Chrysene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Dibenz[a,h]anthracene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Fluoranthene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2153-S1-AQ

Lab Sample ID: 380-220504-1

Date Collected: 06/17/26 09:00

Matrix: Water

Date Received: 06/18/26 09:43

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Indeno[1,2,3-cd]pyrene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Naphthalene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Phenanthrene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1
Pyrene	<0.19		0.19	ug/L		06/21/26 08:48	06/24/26 11:58	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	87		28 - 127	06/21/26 08:48	06/24/26 11:58	1
2-Fluorobiphenyl (Surr)	86		31 - 120	06/21/26 08:48	06/24/26 11:58	1
2-Fluorophenol (Surr)	70		17 - 120	06/21/26 08:48	06/24/26 11:58	1
Nitrobenzene-d5 (Surr)	82		27 - 120	06/21/26 08:48	06/24/26 11:58	1
Phenol-d6 (Surr)	47		10 - 120	06/21/26 08:48	06/24/26 11:58	1
p-Terphenyl-d14 (Surr)	84		45 - 120	06/21/26 08:48	06/24/26 11:58	1

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	06/21/26 08:48	06/29/26 19:37	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	80		33 - 139	06/21/26 08:48	06/29/26 19:37	1
2-Fluorobiphenyl (Surr)	82		33 - 126	06/21/26 08:48	06/29/26 19:37	1
2-Fluorophenol (Surr)	59		12 - 120	06/21/26 08:48	06/29/26 19:37	1
Nitrobenzene-d5 (Surr)	97		36 - 120	06/21/26 08:48	06/29/26 19:37	1
Phenol-d6 (Surr)	39		10 - 120	06/21/26 08:48	06/29/26 19:37	1
p-Terphenyl-d14 (Surr)	83		47 - 131	06/21/26 08:48	06/29/26 19:37	1

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			06/29/26 13:48	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	89		38 - 134		06/29/26 13:48	1

Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25	ug/L		06/23/26 09:43	07/01/26 12:06	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		06/23/26 09:43	07/01/26 12:06	1
C8-C18	<25		25	ug/L		06/23/26 09:43	07/01/26 12:06	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	92		60 - 130	06/23/26 09:43	07/01/26 12:06	1

Client Sample ID: BWS2153-S1-TB

Lab Sample ID: 380-220504-2

Date Collected: 06/17/26 09:00

Matrix: Water

Date Received: 06/18/26 09:43

Method: SW846 8260B - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<2.0		2.0	ug/L			06/29/26 11:46	1
1,1,1-Trichloroethane	<1.0		1.0	ug/L			06/29/26 11:46	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	ug/L			06/29/26 11:46	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2153-S1-TB

Lab Sample ID: 380-220504-2

Date Collected: 06/17/26 09:00

Matrix: Water

Date Received: 06/18/26 09:43

Method: SW846 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,2-Trichloro-1,2,2-trifluoroethane	<10		10	ug/L			06/29/26 11:46	1
1,1,2-Trichloroethane	<1.0		1.0	ug/L			06/29/26 11:46	1
1,1-Dichloroethane	<1.0		1.0	ug/L			06/29/26 11:46	1
1,1-Dichloroethene	<1.0		1.0	ug/L			06/29/26 11:46	1
1,1-Dichloropropene	<1.0		1.0	ug/L			06/29/26 11:46	1
1,2,3-Trichlorobenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
1,2,3-Trichloropropane	<5.0		5.0	ug/L			06/29/26 11:46	1
1,2,4-Trichlorobenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
1,2,4-Trimethylbenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
1,2-Dibromo-3-Chloropropane	<10		10	ug/L			06/29/26 11:46	1
1,2-Dichlorobenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
1,2-Dichloroethane	<0.50		0.50	ug/L			06/29/26 11:46	1
1,2-Dichloropropane	<1.0		1.0	ug/L			06/29/26 11:46	1
1,3,5-Trimethylbenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
1,3-Dichlorobenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
1,3-Dichloropropane	<1.0		1.0	ug/L			06/29/26 11:46	1
1,4-Dichlorobenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
2,2-Dichloropropane	<1.0		1.0	ug/L			06/29/26 11:46	1
2-Butanone	<10		10	ug/L			06/29/26 11:46	1
2-Chlorotoluene	<1.0		1.0	ug/L			06/29/26 11:46	1
2-Hexanone	<10		10	ug/L			06/29/26 11:46	1
4-Chlorotoluene	<1.0		1.0	ug/L			06/29/26 11:46	1
Acetone	<10		10	ug/L			06/29/26 11:46	1
Benzene	<0.50		0.50	ug/L			06/29/26 11:46	1
Bromobenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
Bromochloromethane	<2.0		2.0	ug/L			06/29/26 11:46	1
Bromodichloromethane	<1.0		1.0	ug/L			06/29/26 11:46	1
Bromoform	<5.0		5.0	ug/L			06/29/26 11:46	1
Bromomethane	<10		10	ug/L			06/29/26 11:46	1
Carbon disulfide	<10		10	ug/L			06/29/26 11:46	1
Carbon tetrachloride	<0.50		0.50	ug/L			06/29/26 11:46	1
Chlorobenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
Chloroethane	<5.0		5.0	ug/L			06/29/26 11:46	1
Chloroform	<1.0		1.0	ug/L			06/29/26 11:46	1
Chloromethane	<10		10	ug/L			06/29/26 11:46	1
cis-1,2-Dichloroethene	<1.0		1.0	ug/L			06/29/26 11:46	1
cis-1,3-Dichloropropene	<0.50		0.50	ug/L			06/29/26 11:46	1
Dibromochloromethane	<2.0		2.0	ug/L			06/29/26 11:46	1
Dibromomethane	<1.0		1.0	ug/L			06/29/26 11:46	1
Dichlorodifluoromethane	<5.0		5.0	ug/L			06/29/26 11:46	1
Diethyl ether	<10		10	ug/L			06/29/26 11:46	1
Di-isopropyl ether (DIPE)	<2.0		2.0	ug/L			06/29/26 11:46	1
Ethanol	<100		100	ug/L			06/29/26 11:46	1
Ethylbenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
Ethylene Dibromide	<1.0		1.0	ug/L			06/29/26 11:46	1
Ethyl-t-butyl ether (ETBE)	<2.0		2.0	ug/L			06/29/26 11:46	1
Hexachloro-1,3-butadiene	<10		10	ug/L			06/29/26 11:46	1
Hexane	<5.0		5.0	ug/L			06/29/26 11:46	1
Isobutyl alcohol	<75		75	ug/L			06/29/26 11:46	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2153-S1-TB

Lab Sample ID: 380-220504-2

Date Collected: 06/17/26 09:00

Matrix: Water

Date Received: 06/18/26 09:43

Method: SW846 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Isopropanol	<75		75	ug/L			06/29/26 11:46	1
Isopropylbenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
m,p-Xylene	<2.0		2.0	ug/L			06/29/26 11:46	1
Methylene Chloride	<10		10	ug/L			06/29/26 11:46	1
Methyl-t-Butyl Ether (MTBE)	<1.0		1.0	ug/L			06/29/26 11:46	1
MIBK	<10		10	ug/L			06/29/26 11:46	1
Naphthalene	<10		10	ug/L			06/29/26 11:46	1
n-Butylbenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
N-Propylbenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
o-Xylene	<1.0		1.0	ug/L			06/29/26 11:46	1
p-Isopropyltoluene	<1.0		1.0	ug/L			06/29/26 11:46	1
sec-Butylbenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
Styrene	<1.0		1.0	ug/L			06/29/26 11:46	1
tert-Amyl alcohol	<50		50	ug/L			06/29/26 11:46	1
Tert-amyl-methyl ether (TAME)	<2.0		2.0	ug/L			06/29/26 11:46	1
tert-Butyl alcohol (TBA)	<10		10	ug/L			06/29/26 11:46	1
tert-Butylbenzene	<1.0		1.0	ug/L			06/29/26 11:46	1
Tetrachloroethene	<1.0		1.0	ug/L			06/29/26 11:46	1
Toluene	<1.0		1.0	ug/L			06/29/26 11:46	1
trans-1,2-Dichloroethene	<1.0		1.0	ug/L			06/29/26 11:46	1
trans-1,3-Dichloropropene	<0.50		0.50	ug/L			06/29/26 11:46	1
Trichloroethene	<1.0		1.0	ug/L			06/29/26 11:46	1
Trichlorofluoromethane	<10		10	ug/L			06/29/26 11:46	1
Vinyl acetate	<10		10	ug/L			06/29/26 11:46	1
Vinyl chloride	<0.50		0.50	ug/L			06/29/26 11:46	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	111		80 - 120		06/29/26 11:46	1
4-Bromofluorobenzene (Surr)	104		80 - 120		06/29/26 11:46	1
Dibromofluoromethane (Surr)	113		80 - 120		06/29/26 11:46	1
Toluene-d8 (Surr)	99		80 - 120		06/29/26 11:46	1

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			06/29/26 18:13	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	99		38 - 134		06/29/26 18:13	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2153-S1-AQ

Lab Sample ID: 380-220504-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	HI Org Limit	RL	Method	Prep Type
1,1,1-Trichloroethane	<1.0		ug/L	200	200.0	1.0	8260B	Total/NA
1,1,2-Trichloroethane	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
1,1-Dichloroethene	<1.0		ug/L	7	7.000	1.0	8260B	Total/NA
1,2,3-Trichloropropane	<5.0		ug/L		0.6000	5.0	8260B	Total/NA
1,2,4-Trichlorobenzene	<1.0		ug/L	70	70.00	1.0	8260B	Total/NA
1,2-Dibromo-3-Chloropropane	<10		ug/L	0.2		10	8260B	Total/NA
1,2-Dichlorobenzene	<1.0		ug/L	600	600.0	1.0	8260B	Total/NA
1,2-Dichloroethane	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
1,2-Dichloropropane	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
1,4-Dichlorobenzene	<1.0		ug/L	75	75.000	1.0	8260B	Total/NA
Benzene	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
Bromodichloromethane	<1.0		ug/L	80		1.0	8260B	Total/NA
Bromoform	<5.0		ug/L	80		5.0	8260B	Total/NA
Carbon tetrachloride	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
Chlorobenzene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Chloroform	<1.0		ug/L	80		1.0	8260B	Total/NA
cis-1,2-Dichloroethene	<1.0		ug/L	70	70.00	1.0	8260B	Total/NA
Dibromochloromethane	<2.0		ug/L	80		2.0	8260B	Total/NA
Ethylbenzene	<1.0		ug/L	700	700.0	1.0	8260B	Total/NA
Ethylene Dibromide	<1.0		ug/L	0.05		1.0	8260B	Total/NA
Methylene Chloride	<10		ug/L	5	5.000	10	8260B	Total/NA
Styrene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Tetrachloroethene	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
Toluene	<1.0		ug/L	1000	1000	1.0	8260B	Total/NA
trans-1,2-Dichloroethene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Trichloroethene	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
Vinyl chloride	<0.50		ug/L	2	2.000	0.50	8260B	Total/NA
Benzo[a]pyrene	<0.19		ug/L	0.2		0.19	625.1 SIM	Total/NA

Client Sample ID: BWS2153-S1-TB

Lab Sample ID: 380-220504-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	HI Org Limit	RL	Method	Prep Type
1,1,1-Trichloroethane	<1.0		ug/L	200	200.0	1.0	8260B	Total/NA
1,1,2-Trichloroethane	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
1,1-Dichloroethene	<1.0		ug/L	7	7.000	1.0	8260B	Total/NA
1,2,3-Trichloropropane	<5.0		ug/L		0.6000	5.0	8260B	Total/NA
1,2,4-Trichlorobenzene	<1.0		ug/L	70	70.00	1.0	8260B	Total/NA
1,2-Dibromo-3-Chloropropane	<10		ug/L	0.2		10	8260B	Total/NA
1,2-Dichlorobenzene	<1.0		ug/L	600	600.0	1.0	8260B	Total/NA
1,2-Dichloroethane	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
1,2-Dichloropropane	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
1,4-Dichlorobenzene	<1.0		ug/L	75	75.000	1.0	8260B	Total/NA
Benzene	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA

Eurofins Pomona

Action Limit Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2153-S1-TB (Continued)

Lab Sample ID: 380-220504-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	HI Org	RL	Method	Prep Type
				Limit	Limit			
Bromodichloromethane	<1.0		ug/L	80		1.0	8260B	Total/NA
Bromoform	<5.0		ug/L	80		5.0	8260B	Total/NA
Carbon tetrachloride	<0.50		ug/L	5	5.000	0.50	8260B	Total/NA
Chlorobenzene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Chloroform	<1.0		ug/L	80		1.0	8260B	Total/NA
cis-1,2-Dichloroethene	<1.0		ug/L	70	70.00	1.0	8260B	Total/NA
Dibromochloromethane	<2.0		ug/L	80		2.0	8260B	Total/NA
Ethylbenzene	<1.0		ug/L	700	700.0	1.0	8260B	Total/NA
Ethylene Dibromide	<1.0		ug/L	0.05		1.0	8260B	Total/NA
Methylene Chloride	<10		ug/L	5	5.000	10	8260B	Total/NA
Styrene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Tetrachloroethene	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
Toluene	<1.0		ug/L	1000	1000	1.0	8260B	Total/NA
trans-1,2-Dichloroethene	<1.0		ug/L	100	100.0	1.0	8260B	Total/NA
Trichloroethene	<1.0		ug/L	5	5.000	1.0	8260B	Total/NA
Vinyl chloride	<0.50		ug/L	2	2.000	0.50	8260B	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		DCA (80-120)	BFB (80-120)	DBFM (80-120)	TOL (80-120)
380-220504-1	BWS2153-S1-AQ	117	104	116	100
380-220504-2	BWS2153-S1-TB	111	104	113	99
570-284379-A-1 MS	Matrix Spike	111	96	110	99
570-284379-A-1 MSD	Matrix Spike Duplicate	111	100	110	99
LCS 570-761520/1003	Lab Control Sample	110	101	109	97
LCSD 570-761520/4	Lab Control Sample Dup	109	100	109	98
MB 570-761520/7	Method Blank	113	103	112	99

Surrogate Legend

DCA = 1,2-Dichloroethane-d4 (Surr)
BFB = 4-Bromofluorobenzene (Surr)
DBFM = Dibromofluoromethane (Surr)
TOL = Toluene-d8 (Surr)

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
380-220504-1	BWS2153-S1-AQ	80	82	59	97	39	83

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-220504-1	BWS2153-S1-AQ	87	86	70	82	47	84
LCS 570-757352/2-A	Lab Control Sample	82	82	73	77	47	88
LCSD 570-757352/3-A	Lab Control Sample Dup	83	78	71	74	45	88
MB 570-757352/1-A	Method Blank	92	93	70	90	43	90

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Surrogate Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)		
Lab Sample ID	Client Sample ID	BFB1 (38-134)
380-220504-1	BWS2153-S1-AQ	89
380-220504-2	BWS2153-S1-TB	99
LCS 570-761708/3	Lab Control Sample	106
LCSD 570-761708/4	Lab Control Sample Dup	105
MB 570-761708/6	Method Blank	103
MRL 570-761708/5	Lab Control Sample	103
Surrogate Legend		
BFB = 4-Bromofluorobenzene (Surr)		

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)		
Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-220504-1	BWS2153-S1-AQ	92
380-220504-1 MS	BWS2153-S1-AQ	102
380-220504-1 MSD	BWS2153-S1-AQ	102
LCS 570-758469/2-A	Lab Control Sample	104
LCSD 570-758469/3-A	Lab Control Sample Dup	93
MB 570-758469/1-A	Method Blank	90
MRL 570-758469/4-A	Lab Control Sample	101
Surrogate Legend		
OTCSN = n-Octacosane (Surr)		

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 570-761520/7

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<2.0		2.0	ug/L			06/29/26 08:55	1
1,1,1-Trichloroethane	<1.0		1.0	ug/L			06/29/26 08:55	1
1,1,2,2-Tetrachloroethane	<1.0		1.0	ug/L			06/29/26 08:55	1
1,1,2-Trichloro-1,2,2-trifluoroethane	<10		10	ug/L			06/29/26 08:55	1
1,1,2-Trichloroethane	<1.0		1.0	ug/L			06/29/26 08:55	1
1,1-Dichloroethane	<1.0		1.0	ug/L			06/29/26 08:55	1
1,1-Dichloroethene	<1.0		1.0	ug/L			06/29/26 08:55	1
1,1-Dichloropropene	<1.0		1.0	ug/L			06/29/26 08:55	1
1,2,3-Trichlorobenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
1,2,3-Trichloropropane	<5.0		5.0	ug/L			06/29/26 08:55	1
1,2,4-Trichlorobenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
1,2,4-Trimethylbenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
1,2-Dibromo-3-Chloropropane	<10		10	ug/L			06/29/26 08:55	1
1,2-Dichlorobenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
1,2-Dichloroethane	<0.50		0.50	ug/L			06/29/26 08:55	1
1,2-Dichloropropane	<1.0		1.0	ug/L			06/29/26 08:55	1
1,3,5-Trimethylbenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
1,3-Dichlorobenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
1,3-Dichloropropane	<1.0		1.0	ug/L			06/29/26 08:55	1
1,4-Dichlorobenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
2,2-Dichloropropane	<1.0		1.0	ug/L			06/29/26 08:55	1
2-Butanone	<10		10	ug/L			06/29/26 08:55	1
2-Chlorotoluene	<1.0		1.0	ug/L			06/29/26 08:55	1
2-Hexanone	<10		10	ug/L			06/29/26 08:55	1
4-Chlorotoluene	<1.0		1.0	ug/L			06/29/26 08:55	1
Acetone	<10		10	ug/L			06/29/26 08:55	1
Benzene	<0.50		0.50	ug/L			06/29/26 08:55	1
Bromobenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
Bromochloromethane	<2.0		2.0	ug/L			06/29/26 08:55	1
Bromodichloromethane	<1.0		1.0	ug/L			06/29/26 08:55	1
Bromoform	<5.0		5.0	ug/L			06/29/26 08:55	1
Bromomethane	<10		10	ug/L			06/29/26 08:55	1
Carbon disulfide	<10		10	ug/L			06/29/26 08:55	1
Carbon tetrachloride	<0.50		0.50	ug/L			06/29/26 08:55	1
Chlorobenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
Chloroethane	<5.0		5.0	ug/L			06/29/26 08:55	1
Chloroform	<1.0		1.0	ug/L			06/29/26 08:55	1
Chloromethane	<10		10	ug/L			06/29/26 08:55	1
cis-1,2-Dichloroethene	<1.0		1.0	ug/L			06/29/26 08:55	1
cis-1,3-Dichloropropene	<0.50		0.50	ug/L			06/29/26 08:55	1
Dibromochloromethane	<2.0		2.0	ug/L			06/29/26 08:55	1
Dibromomethane	<1.0		1.0	ug/L			06/29/26 08:55	1
Dichlorodifluoromethane	<5.0		5.0	ug/L			06/29/26 08:55	1
Diethyl ether	<10		10	ug/L			06/29/26 08:55	1
Di-isopropyl ether (DIPE)	<2.0		2.0	ug/L			06/29/26 08:55	1
Ethanol	<100		100	ug/L			06/29/26 08:55	1
Ethylbenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
Ethylene Dibromide	<1.0		1.0	ug/L			06/29/26 08:55	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 570-761520/7

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Ethyl-t-butyl ether (ETBE)	<2.0		2.0	ug/L			06/29/26 08:55	1
Hexachloro-1,3-butadiene	<10		10	ug/L			06/29/26 08:55	1
Hexane	<5.0		5.0	ug/L			06/29/26 08:55	1
Isobutyl alcohol	<75		75	ug/L			06/29/26 08:55	1
Isopropanol	<75		75	ug/L			06/29/26 08:55	1
Isopropylbenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
m,p-Xylene	<2.0		2.0	ug/L			06/29/26 08:55	1
Methylene Chloride	<10		10	ug/L			06/29/26 08:55	1
Methyl-t-Butyl Ether (MTBE)	<1.0		1.0	ug/L			06/29/26 08:55	1
MIBK	<10		10	ug/L			06/29/26 08:55	1
Naphthalene	<10		10	ug/L			06/29/26 08:55	1
n-Butylbenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
N-Propylbenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
o-Xylene	<1.0		1.0	ug/L			06/29/26 08:55	1
p-Isopropyltoluene	<1.0		1.0	ug/L			06/29/26 08:55	1
sec-Butylbenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
Styrene	<1.0		1.0	ug/L			06/29/26 08:55	1
tert-Amyl alcohol	<50		50	ug/L			06/29/26 08:55	1
Tert-amyl-methyl ether (TAME)	<2.0		2.0	ug/L			06/29/26 08:55	1
tert-Butyl alcohol (TBA)	<10		10	ug/L			06/29/26 08:55	1
tert-Butylbenzene	<1.0		1.0	ug/L			06/29/26 08:55	1
Tetrachloroethene	<1.0		1.0	ug/L			06/29/26 08:55	1
Toluene	<1.0		1.0	ug/L			06/29/26 08:55	1
trans-1,2-Dichloroethene	<1.0		1.0	ug/L			06/29/26 08:55	1
trans-1,3-Dichloropropene	<0.50		0.50	ug/L			06/29/26 08:55	1
Trichloroethene	<1.0		1.0	ug/L			06/29/26 08:55	1
Trichlorofluoromethane	<10		10	ug/L			06/29/26 08:55	1
Vinyl acetate	<10		10	ug/L			06/29/26 08:55	1
Vinyl chloride	<0.50		0.50	ug/L			06/29/26 08:55	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	113		80 - 120		06/29/26 08:55	1
4-Bromofluorobenzene (Surr)	103		80 - 120		06/29/26 08:55	1
Dibromofluoromethane (Surr)	112		80 - 120		06/29/26 08:55	1
Toluene-d8 (Surr)	99		80 - 120		06/29/26 08:55	1

Lab Sample ID: LCS 570-761520/1003

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	20.0	20.8		ug/L		104	83 - 120
1,1,1-Trichloroethane	20.0	18.6		ug/L		93	78 - 123
1,1,1,2,2-Tetrachloroethane	20.0	21.3		ug/L		107	74 - 125
1,1,2-Trichloro-1,2,2-trifluoroethane	20.0	15.8		ug/L		79	72 - 130
1,1,2-Trichloroethane	20.0	21.9		ug/L		109	82 - 120
1,1-Dichloroethane	20.0	20.4		ug/L		102	79 - 122
1,1-Dichloroethene	20.0	17.1		ug/L		86	74 - 127

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 570-761520/1003

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,1-Dichloropropene	20.0	17.9		ug/L		89	75 - 124
1,2,3-Trichlorobenzene	20.0	19.0		ug/L		95	71 - 126
1,2,3-Trichloropropane	20.0	22.6		ug/L		113	73 - 121
1,2,4-Trichlorobenzene	20.0	18.5		ug/L		93	70 - 130
1,2,4-Trimethylbenzene	20.0	19.9		ug/L		99	80 - 125
1,2-Dibromo-3-Chloropropane	20.0	22.7		ug/L		113	64 - 127
1,2-Dichlorobenzene	20.0	19.7		ug/L		99	78 - 122
1,2-Dichloroethane	20.0	20.8		ug/L		104	76 - 123
1,2-Dichloropropane	20.0	21.3		ug/L		107	82 - 120
1,3,5-Trimethylbenzene	20.0	19.8		ug/L		99	79 - 124
1,3-Dichlorobenzene	20.0	20.0		ug/L		100	81 - 120
1,3-Dichloropropane	20.0	22.0		ug/L		110	82 - 120
1,4-Dichlorobenzene	20.0	20.0		ug/L		100	78 - 121
2,2-Dichloropropane	20.0	19.3		ug/L		97	69 - 133
2-Butanone	20.0	20.8		ug/L		104	55 - 142
2-Chlorotoluene	20.0	19.7		ug/L		98	80 - 120
2-Hexanone	20.0	20.3		ug/L		101	54 - 138
4-Chlorotoluene	20.0	19.6		ug/L		98	80 - 121
Acetone	20.0	19.1		ug/L		95	50 - 157
Benzene	20.0	19.2		ug/L		96	80 - 120
Bromobenzene	20.0	20.2		ug/L		101	80 - 120
Bromochloromethane	20.0	22.4		ug/L		112	83 - 123
Bromodichloromethane	20.0	20.8		ug/L		104	83 - 120
Bromoform	20.0	21.9		ug/L		110	75 - 128
Bromomethane	20.0	13.0		ug/L		65	31 - 120
Carbon disulfide	20.0	17.9		ug/L		89	71 - 128
Carbon tetrachloride	20.0	17.3		ug/L		86	72 - 135
Chlorobenzene	20.0	19.3		ug/L		96	84 - 120
Chloroethane	20.0	20.7		ug/L		103	72 - 129
Chloroform	20.0	20.3		ug/L		101	79 - 120
Chloromethane	20.0	15.4		ug/L		77	36 - 148
cis-1,2-Dichloroethene	20.0	20.7		ug/L		103	81 - 120
cis-1,3-Dichloropropene	20.0	21.8		ug/L		109	76 - 125
Dibromochloromethane	20.0	22.2		ug/L		111	82 - 120
Dibromomethane	20.0	21.2		ug/L		106	85 - 120
Dichlorodifluoromethane	20.0	16.0		ug/L		80	52 - 147
Diethyl ether	20.0	22.1		ug/L		111	71 - 127
Di-isopropyl ether (DIPE)	20.0	21.4		ug/L		107	70 - 132
Ethanol	200	234		ug/L		117	48 - 163
Ethylbenzene	20.0	18.5		ug/L		92	81 - 120
Ethylene Dibromide	20.0	23.7		ug/L		119	81 - 120
Ethyl-t-butyl ether (ETBE)	20.0	21.1		ug/L		106	68 - 126
Isopropylbenzene	20.0	18.4		ug/L		92	80 - 122
m,p-Xylene	40.0	38.8		ug/L		97	79 - 122
Methylene Chloride	20.0	21.3		ug/L		106	76 - 120
Methyl-t-Butyl Ether (MTBE)	20.0	22.6		ug/L		113	70 - 124
MIBK	20.0	19.6		ug/L		98	57 - 133
Naphthalene	20.0	18.0		ug/L		90	64 - 124
n-Butylbenzene	20.0	18.1		ug/L		91	78 - 127

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 570-761520/1003

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
N-Propylbenzene	20.0	19.1		ug/L		96	80 - 121
o-Xylene	20.0	19.8		ug/L		99	81 - 120
p-Isopropyltoluene	20.0	18.7		ug/L		93	81 - 124
sec-Butylbenzene	20.0	18.3		ug/L		92	80 - 123
Styrene	20.0	20.5		ug/L		102	82 - 120
tert-Amyl alcohol	100	109		ug/L		109	30 - 157
Tert-amyl-methyl ether (TAME)	20.0	20.0		ug/L		100	71 - 121
tert-Butyl alcohol (TBA)	100	103		ug/L		103	68 - 128
tert-Butylbenzene	20.0	17.9		ug/L		89	80 - 124
Tetrachloroethene	20.0	17.3		ug/L		86	78 - 126
Toluene	20.0	17.7		ug/L		89	82 - 120
trans-1,2-Dichloroethene	20.0	19.1		ug/L		95	79 - 122
trans-1,3-Dichloropropene	20.0	24.0		ug/L		120	73 - 127
Trichloroethene	20.0	17.0		ug/L		85	83 - 120
Trichlorofluoromethane	20.0	20.7		ug/L		103	74 - 135
Vinyl acetate	20.0	21.6		ug/L		108	56 - 135
Vinyl chloride	20.0	18.1		ug/L		90	68 - 131

Surrogate	LCS %Recovery	LCS Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	110		80 - 120
4-Bromofluorobenzene (Surr)	101		80 - 120
Dibromofluoromethane (Surr)	109		80 - 120
Toluene-d8 (Surr)	97		80 - 120

Lab Sample ID: LCSD 570-761520/4

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	20.0	21.1		ug/L		105	83 - 120	1	20
1,1,1-Trichloroethane	20.0	18.1		ug/L		90	78 - 123	3	20
1,1,2,2-Tetrachloroethane	20.0	21.5		ug/L		107	74 - 125	1	20
1,1,2-Trichloro-1,2,2-trifluoroethane	20.0	14.4		ug/L		72	72 - 130	9	20
1,1,2-Trichloroethane	20.0	21.8		ug/L		109	82 - 120	0	20
1,1-Dichloroethane	20.0	19.5		ug/L		98	79 - 122	5	20
1,1-Dichloroethene	20.0	16.2		ug/L		81	74 - 127	6	20
1,1-Dichloropropene	20.0	17.1		ug/L		86	75 - 124	4	20
1,2,3-Trichlorobenzene	20.0	19.4		ug/L		97	71 - 126	2	20
1,2,3-Trichloropropane	20.0	22.8		ug/L		114	73 - 121	1	20
1,2,4-Trichlorobenzene	20.0	18.5		ug/L		92	70 - 130	0	20
1,2,4-Trimethylbenzene	20.0	19.3		ug/L		97	80 - 125	3	20
1,2-Dibromo-3-Chloropropane	20.0	21.7		ug/L		109	64 - 127	4	20
1,2-Dichlorobenzene	20.0	19.4		ug/L		97	78 - 122	2	20
1,2-Dichloroethane	20.0	20.2		ug/L		101	76 - 123	3	20
1,2-Dichloropropane	20.0	20.7		ug/L		103	82 - 120	3	20
1,3,5-Trimethylbenzene	20.0	19.6		ug/L		98	79 - 124	1	20
1,3-Dichlorobenzene	20.0	19.2		ug/L		96	81 - 120	4	20
1,3-Dichloropropane	20.0	21.9		ug/L		110	82 - 120	0	20

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 570-761520/4

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1,4-Dichlorobenzene	20.0	19.6		ug/L		98	78 - 121	2	20
2,2-Dichloropropane	20.0	18.4		ug/L		92	69 - 133	5	20
2-Butanone	20.0	19.7		ug/L		99	55 - 142	5	21
2-Chlorotoluene	20.0	19.3		ug/L		96	80 - 120	2	20
2-Hexanone	20.0	20.4		ug/L		102	54 - 138	1	21
4-Chlorotoluene	20.0	19.1		ug/L		96	80 - 121	2	20
Acetone	20.0	19.4		ug/L		97	50 - 157	2	26
Benzene	20.0	18.6		ug/L		93	80 - 120	3	20
Bromobenzene	20.0	19.5		ug/L		98	80 - 120	3	20
Bromochloromethane	20.0	21.4		ug/L		107	83 - 123	4	20
Bromodichloromethane	20.0	20.1		ug/L		101	83 - 120	3	20
Bromoform	20.0	22.3		ug/L		111	75 - 128	1	20
Bromomethane	20.0	13.0		ug/L		65	31 - 120	0	22
Carbon disulfide	20.0	16.9		ug/L		84	71 - 128	6	20
Carbon tetrachloride	20.0	16.7		ug/L		83	72 - 135	3	20
Chlorobenzene	20.0	18.8		ug/L		94	84 - 120	3	20
Chloroethane	20.0	20.4		ug/L		102	72 - 129	2	20
Chloroform	20.0	19.7		ug/L		99	79 - 120	3	20
Chloromethane	20.0	15.7		ug/L		79	36 - 148	2	20
cis-1,2-Dichloroethene	20.0	19.9		ug/L		99	81 - 120	4	20
cis-1,3-Dichloropropene	20.0	21.2		ug/L		106	76 - 125	3	20
Dibromochloromethane	20.0	22.2		ug/L		111	82 - 120	0	20
Dibromomethane	20.0	20.6		ug/L		103	85 - 120	3	20
Dichlorodifluoromethane	20.0	15.2		ug/L		76	52 - 147	5	20
Diethyl ether	20.0	22.0		ug/L		110	71 - 127	0	20
Di-isopropyl ether (DIPE)	20.0	21.1		ug/L		106	70 - 132	1	20
Ethanol	200	225		ug/L		113	48 - 163	4	30
Ethylbenzene	20.0	18.0		ug/L		90	81 - 120	3	20
Ethylene Dibromide	20.0	23.5		ug/L		117	81 - 120	1	20
Ethyl-t-butyl ether (ETBE)	20.0	20.8		ug/L		104	68 - 126	1	20
Isopropylbenzene	20.0	17.8		ug/L		89	80 - 122	3	20
m,p-Xylene	40.0	37.6		ug/L		94	79 - 122	3	20
Methylene Chloride	20.0	20.3		ug/L		102	76 - 120	5	20
Methyl-t-Butyl Ether (MTBE)	20.0	22.1		ug/L		111	70 - 124	2	20
MIBK	20.0	20.0		ug/L		100	57 - 133	2	20
Naphthalene	20.0	18.5		ug/L		93	64 - 124	3	20
n-Butylbenzene	20.0	17.8		ug/L		89	78 - 127	2	20
N-Propylbenzene	20.0	18.6		ug/L		93	80 - 121	3	20
o-Xylene	20.0	19.3		ug/L		97	81 - 120	2	20
p-Isopropyltoluene	20.0	18.4		ug/L		92	81 - 124	2	20
sec-Butylbenzene	20.0	17.7		ug/L		88	80 - 123	4	20
Styrene	20.0	19.9		ug/L		99	82 - 120	3	20
tert-Amyl alcohol	100	111		ug/L		111	30 - 157	2	30
Tert-amyl-methyl ether (TAME)	20.0	20.1		ug/L		100	71 - 121	0	20
tert-Butyl alcohol (TBA)	100	100		ug/L		100	68 - 128	3	20
tert-Butylbenzene	20.0	17.6		ug/L		88	80 - 124	2	20
Tetrachloroethene	20.0	16.7		ug/L		84	78 - 126	3	20
Toluene	20.0	17.4		ug/L		87	82 - 120	2	20
trans-1,2-Dichloroethene	20.0	18.1		ug/L		90	79 - 122	5	20

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 570-761520/4

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
trans-1,3-Dichloropropene	20.0	23.7		ug/L		118	73 - 127	1	20
Trichloroethene	20.0	17.2		ug/L		86	83 - 120	1	20
Trichlorofluoromethane	20.0	19.8		ug/L		99	74 - 135	4	20
Vinyl acetate	20.0	20.9		ug/L		104	56 - 135	3	24
Vinyl chloride	20.0	17.3		ug/L		87	68 - 131	4	20

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	109		80 - 120
4-Bromofluorobenzene (Surr)	100		80 - 120
Dibromofluoromethane (Surr)	109		80 - 120
Toluene-d8 (Surr)	98		80 - 120

Lab Sample ID: 570-284379-A-1 MS

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	<4.0		40.0	46.7		ug/L		117	56 - 156
1,1,1-Trichloroethane	<2.0		40.0	45.6		ug/L		114	56 - 155
1,1,2,2-Tetrachloroethane	<2.0		40.0	48.6		ug/L		121	52 - 151
1,1,2-Trichloro-1,2,2-trifluoroethane	<20		40.0	41.4		ug/L		104	45 - 156
1,1,2-Trichloroethane	<2.0		40.0	47.5		ug/L		119	64 - 142
1,1-Dichloroethane	<2.0		40.0	46.6		ug/L		116	58 - 151
1,1-Dichloroethene	<2.0		40.0	43.4		ug/L		109	51 - 160
1,1-Dichloropropene	<2.0		40.0	45.0		ug/L		113	59 - 151
1,2,3-Trichlorobenzene	<2.0		40.0	43.0		ug/L		107	56 - 148
1,2,3-Trichloropropane	<10		40.0	49.1		ug/L		123	54 - 145
1,2,4-Trichlorobenzene	<2.0		40.0	40.1		ug/L		100	51 - 149
1,2,4-Trimethylbenzene	<2.0		40.0	46.4		ug/L		116	54 - 149
1,2-Dibromo-3-Chloropropane	<20		40.0	50.4		ug/L		126	43 - 149
1,2-Dichlorobenzene	<2.0		40.0	44.2		ug/L		111	64 - 144
1,2-Dichloroethane	<1.0		40.0	45.9		ug/L		115	63 - 142
1,2-Dichloropropane	<2.0		40.0	46.6		ug/L		116	64 - 144
1,3,5-Trimethylbenzene	<2.0		40.0	45.3		ug/L		113	62 - 147
1,3-Dichlorobenzene	<2.0		40.0	44.3		ug/L		111	63 - 143
1,3-Dichloropropane	<2.0		40.0	48.2		ug/L		120	66 - 140
1,4-Dichlorobenzene	<2.0		40.0	44.1		ug/L		110	62 - 141
2,2-Dichloropropane	<2.0		40.0	42.9		ug/L		107	35 - 151
2-Butanone	<20		40.0	45.8		ug/L		114	44 - 162
2-Chlorotoluene	<2.0		40.0	43.9		ug/L		110	64 - 142
2-Hexanone	<20		40.0	44.3		ug/L		111	40 - 151
4-Chlorotoluene	<2.0		40.0	44.7		ug/L		112	61 - 144
Acetone	<20		40.0	41.6		ug/L		104	34 - 174
Benzene	<1.0		40.0	44.2		ug/L		111	64 - 143
Bromobenzene	<2.0		40.0	43.4		ug/L		108	67 - 144
Bromochloromethane	<4.0		40.0	47.5		ug/L		119	70 - 149
Bromodichloromethane	<2.0		40.0	45.5		ug/L		114	64 - 145
Bromoform	<10		40.0	49.4		ug/L		123	43 - 165

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 570-284379-A-1 MS

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Bromomethane	<20		40.0	39.5		ug/L		99	25 - 180
Carbon disulfide	<20		40.0	46.3		ug/L		116	50 - 156
Carbon tetrachloride	<1.0		40.0	44.3		ug/L		111	51 - 167
Chlorobenzene	<2.0		40.0	42.9		ug/L		107	67 - 141
Chloroethane	<10		40.0	51.9		ug/L		130	46 - 167
Chloroform	<2.0		40.0	45.4		ug/L		114	62 - 143
Chloromethane	<20		40.0	42.2		ug/L		106	33 - 163
cis-1,2-Dichloroethene	<2.0		40.0	46.4		ug/L		116	57 - 152
cis-1,3-Dichloropropene	<1.0		40.0	46.3		ug/L		116	55 - 141
Dibromochloromethane	<4.0		40.0	47.9		ug/L		120	54 - 155
Dibromomethane	<2.0		40.0	45.8		ug/L		114	68 - 143
Dichlorodifluoromethane	<10		40.0	37.2		ug/L		93	36 - 159
Diethyl ether	<20		40.0	47.5		ug/L		119	53 - 151
Di-isopropyl ether (DIPE)	<4.0		40.0	47.4		ug/L		119	50 - 157
Ethanol	<200		400	531		ug/L		133	29 - 180
Ethylbenzene	<2.0		40.0	42.9		ug/L		107	62 - 145
Ethylene Dibromide	<2.0		40.0	51.1		ug/L		128	65 - 141
Ethyl-t-butyl ether (ETBE)	<4.0		40.0	45.0		ug/L		113	49 - 144
Isopropylbenzene	<2.0		40.0	43.8		ug/L		110	64 - 146
m,p-Xylene	<4.0		80.0	88.4		ug/L		110	61 - 146
Methylene Chloride	<20		40.0	46.2		ug/L		115	59 - 143
Methyl-t-Butyl Ether (MTBE)	<2.0		40.0	47.4		ug/L		118	52 - 145
MIBK	<20		40.0	44.3		ug/L		111	46 - 144
Naphthalene	<20		40.0	39.9		ug/L		100	41 - 148
n-Butylbenzene	<2.0		40.0	44.1		ug/L		110	54 - 150
N-Propylbenzene	<2.0		40.0	45.3		ug/L		113	63 - 146
o-Xylene	<2.0		40.0	44.2		ug/L		110	64 - 144
p-Isopropyltoluene	<2.0		40.0	45.3		ug/L		113	59 - 147
sec-Butylbenzene	<2.0		40.0	45.0		ug/L		113	60 - 147
Styrene	<2.0		40.0	42.2		ug/L		105	44 - 154
tert-Amyl alcohol	<100		200	227		ug/L		114	25 - 164
Tert-amyl-methyl ether (TAME)	<4.0		40.0	43.0		ug/L		107	55 - 137
tert-Butyl alcohol (TBA)	<20		200	240		ug/L		120	56 - 154
tert-Butylbenzene	<2.0		40.0	43.7		ug/L		109	61 - 149
Tetrachloroethene	<2.0		40.0	42.4		ug/L		106	60 - 151
Toluene	<2.0		40.0	41.7		ug/L		104	64 - 144
trans-1,2-Dichloroethene	<2.0		40.0	44.8		ug/L		112	56 - 156
trans-1,3-Dichloropropene	<1.0		40.0	50.4		ug/L		126	52 - 143
Trichloroethene	<2.0		40.0	41.3		ug/L		103	41 - 169
Trichlorofluoromethane	<20		40.0	49.9		ug/L		125	54 - 161
Vinyl acetate	<20		40.0	47.9		ug/L		120	30 - 155
Vinyl chloride	<1.0		40.0	48.7		ug/L		122	49 - 164

Surrogate	MS %Recovery	MS Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	111		80 - 120
4-Bromofluorobenzene (Surr)	96		80 - 120
Dibromofluoromethane (Surr)	110		80 - 120
Toluene-d8 (Surr)	99		80 - 120

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 570-284379-A-1 MSD

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	0.000		40.0	43.0		ug/L		108	56 - 156	8	20
1,1,1-Trichloroethane	0.000		40.0	45.7		ug/L		114	56 - 155	0	20
1,1,2,2-Tetrachloroethane	0.000		40.0	42.6		ug/L		106	52 - 151	13	20
1,1,2-Trichloro-1,2,2-trifluoroethane	0.000		40.0	40.8		ug/L		102	45 - 156	2	20
1,1,2-Trichloroethane	0.000		40.0	43.7		ug/L		109	64 - 142	8	20
1,1-Dichloroethane	0.000		40.0	45.0		ug/L		113	58 - 151	3	20
1,1-Dichloroethene	0.000		40.0	42.6		ug/L		107	51 - 160	2	20
1,1-Dichloropropene	0.000		40.0	44.4		ug/L		111	59 - 151	1	20
1,2,3-Trichlorobenzene	0.000		40.0	38.7		ug/L		97	56 - 148	10	20
1,2,3-Trichloropropane	0.000		40.0	44.8		ug/L		112	54 - 145	9	20
1,2,4-Trichlorobenzene	0.000		40.0	36.4		ug/L		91	51 - 149	10	20
1,2,4-Trimethylbenzene	0.000		40.0	41.5		ug/L		104	54 - 149	11	20
1,2-Dibromo-3-Chloropropane	0.000		40.0	42.9		ug/L		107	43 - 149	16	20
1,2-Dichlorobenzene	0.000		40.0	39.0		ug/L		97	64 - 144	13	20
1,2-Dichloroethane	0.000		40.0	43.9		ug/L		110	63 - 142	5	20
1,2-Dichloropropane	0.000		40.0	45.2		ug/L		113	64 - 144	3	20
1,3,5-Trimethylbenzene	0.000		40.0	42.2		ug/L		106	62 - 147	7	20
1,3-Dichlorobenzene	0.000		40.0	39.3		ug/L		98	63 - 143	12	20
1,3-Dichloropropane	0.000		40.0	44.3		ug/L		111	66 - 140	8	20
1,4-Dichlorobenzene	0.000		40.0	39.4		ug/L		98	62 - 141	11	20
2,2-Dichloropropane	0.000		40.0	42.5		ug/L		106	35 - 151	1	20
2-Butanone	0.000		40.0	42.8		ug/L		107	44 - 162	7	20
2-Chlorotoluene	0.000		40.0	41.2		ug/L		103	64 - 142	6	20
2-Hexanone	0.000		40.0	39.9		ug/L		100	40 - 151	10	20
4-Chlorotoluene	0.000		40.0	40.2		ug/L		101	61 - 144	11	20
Acetone	0.000		40.0	41.2		ug/L		103	34 - 174	1	20
Benzene	0.000		40.0	42.6		ug/L		107	64 - 143	4	20
Bromobenzene	0.000		40.0	40.7		ug/L		102	67 - 144	7	20
Bromochloromethane	0.000		40.0	45.9		ug/L		115	70 - 149	3	20
Bromodichloromethane	0.000		40.0	44.6		ug/L		112	64 - 145	2	20
Bromoform	0.000		40.0	43.2		ug/L		108	43 - 165	13	20
Bromomethane	0.000		40.0	34.3		ug/L		86	25 - 180	14	23
Carbon disulfide	0.483		40.0	45.3		ug/L		113	50 - 156	2	20
Carbon tetrachloride	0.000		40.0	43.7		ug/L		109	51 - 167	1	20
Chlorobenzene	0.000		40.0	39.7		ug/L		99	67 - 141	8	20
Chloroethane	0.000		40.0	44.6		ug/L		111	46 - 167	15	20
Chloroform	0.000		40.0	44.1		ug/L		110	62 - 143	3	20
Chloromethane	0.000		40.0	39.7		ug/L		99	33 - 163	6	20
cis-1,2-Dichloroethene	0.000		40.0	44.7		ug/L		112	57 - 152	4	20
cis-1,3-Dichloropropene	0.000		40.0	44.7		ug/L		112	55 - 141	4	20
Dibromochloromethane	0.000		40.0	44.2		ug/L		111	54 - 155	8	20
Dibromomethane	0.000		40.0	43.8		ug/L		110	68 - 143	4	20
Dichlorodifluoromethane	0.000		40.0	28.9	F2	ug/L		72	36 - 159	25	20
Diethyl ether	0.000		40.0	45.8		ug/L		115	53 - 151	4	20
Di-isopropyl ether (DIPE)	0.000		40.0	46.3		ug/L		116	50 - 157	2	20
Ethanol	0.000		400	493		ug/L		123	29 - 180	7	40
Ethylbenzene	0.000		40.0	40.9		ug/L		102	62 - 145	5	20
Ethylene Dibromide	0.000		40.0	46.7		ug/L		117	65 - 141	9	20

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8260B - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 570-284379-A-1 MSD

Matrix: Water

Analysis Batch: 761520

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Ethyl-t-butyl ether (ETBE)	0.000		40.0	43.8		ug/L		110	49 - 144	3	20
Isopropylbenzene	0.000		40.0	41.1		ug/L		103	64 - 146	6	20
m,p-Xylene	0.000		80.0	83.5		ug/L		104	61 - 146	6	20
Methylene Chloride	0.000		40.0	44.6		ug/L		111	59 - 143	4	20
Methyl-t-Butyl Ether (MTBE)	0.000		40.0	45.9		ug/L		115	52 - 145	3	20
MIBK	0.000		40.0	42.8		ug/L		107	46 - 144	3	20
Naphthalene	0.000		40.0	36.2		ug/L		91	41 - 148	10	20
n-Butylbenzene	0.000		40.0	40.1		ug/L		100	54 - 150	9	20
N-Propylbenzene	0.000		40.0	42.6		ug/L		106	63 - 146	6	20
o-Xylene	0.000		40.0	41.1		ug/L		103	64 - 144	7	20
p-Isopropyltoluene	0.000		40.0	40.8		ug/L		102	59 - 147	10	20
sec-Butylbenzene	0.000		40.0	40.8		ug/L		102	60 - 147	10	20
Styrene	0.000		40.0	40.7		ug/L		102	44 - 154	4	20
tert-Amyl alcohol	0.000		200	213		ug/L		106	25 - 164	7	20
Tert-amyl-methyl ether (TAME)	0.000		40.0	41.4		ug/L		103	55 - 137	4	20
tert-Butyl alcohol (TBA)	0.000		200	235		ug/L		118	56 - 154	2	20
tert-Butylbenzene	0.000		40.0	39.2		ug/L		98	61 - 149	11	20
Tetrachloroethene	0.000		40.0	39.6		ug/L		99	60 - 151	7	20
Toluene	0.000		40.0	39.9		ug/L		100	64 - 144	4	20
trans-1,2-Dichloroethene	0.000		40.0	44.3		ug/L		111	56 - 156	1	20
trans-1,3-Dichloropropene	0.000		40.0	46.1		ug/L		115	52 - 143	9	20
Trichloroethene	0.000		40.0	40.4		ug/L		101	41 - 169	2	20
Trichlorofluoromethane	0.000		40.0	40.8		ug/L		102	54 - 161	20	20
Vinyl acetate	0.000		40.0	46.3		ug/L		116	30 - 155	3	20
Vinyl chloride	0.000		40.0	41.1		ug/L		103	49 - 164	17	20

Surrogate	MSD %Recovery	MSD Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	111		80 - 120
4-Bromofluorobenzene (Surr)	100		80 - 120
Dibromofluoromethane (Surr)	110		80 - 120
Toluene-d8 (Surr)	99		80 - 120

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: MB 570-757352/1-A

Matrix: Water

Analysis Batch: 759081

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 757352

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
2-Methylnaphthalene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Acenaphthene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Acenaphthylene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Anthracene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Benzo[a]anthracene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Benzo[a]pyrene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Benzo[b]fluoranthene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Benzo[g,h,i]perylene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Benzo[k]fluoranthene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: MB 570-757352/1-A

Matrix: Water

Analysis Batch: 759081

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 757352

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Chrysene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Dibenz(a,h)anthracene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Fluoranthene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Fluorene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Naphthalene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Phenanthrene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1
Pyrene	<0.20		0.20	ug/L		06/20/26 10:43	06/24/26 07:45	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	92		28 - 127	06/20/26 10:43	06/24/26 07:45	1
2-Fluorobiphenyl (Surr)	93		31 - 120	06/20/26 10:43	06/24/26 07:45	1
2-Fluorophenol (Surr)	70		17 - 120	06/20/26 10:43	06/24/26 07:45	1
Nitrobenzene-d5 (Surr)	90		27 - 120	06/20/26 10:43	06/24/26 07:45	1
Phenol-d6 (Surr)	43		10 - 120	06/20/26 10:43	06/24/26 07:45	1
p-Terphenyl-d14 (Surr)	90		45 - 120	06/20/26 10:43	06/24/26 07:45	1

Lab Sample ID: LCS 570-757352/2-A

Matrix: Water

Analysis Batch: 759081

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 757352

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	20.0	16.8		ug/L		84	47 - 120
2-Methylnaphthalene	20.0	15.8		ug/L		79	43 - 120
Acenaphthene	20.0	16.6		ug/L		83	60 - 132
Acenaphthylene	20.0	16.5		ug/L		83	54 - 126
Anthracene	20.0	16.2		ug/L		81	43 - 120
Benzo[a]anthracene	20.0	17.3		ug/L		86	42 - 133
Benzo[a]pyrene	20.0	18.2		ug/L		91	32 - 148
Benzo[b]fluoranthene	20.0	17.6		ug/L		88	42 - 140
Benzo[g,h,i]perylene	20.0	17.5		ug/L		87	1 - 195
Benzo[k]fluoranthene	20.0	16.8		ug/L		84	25 - 146
Chrysene	20.0	17.4		ug/L		87	44 - 140
Dibenz(a,h)anthracene	20.0	18.0		ug/L		90	1 - 200
Fluoranthene	20.0	17.1		ug/L		85	43 - 121
Fluorene	20.0	17.5		ug/L		87	70 - 120
Indeno[1,2,3-cd]pyrene	20.0	17.7		ug/L		88	1 - 151
Naphthalene	20.0	16.6		ug/L		83	36 - 120
Phenanthrene	20.0	17.1		ug/L		86	65 - 120
Pyrene	20.0	17.3		ug/L		87	70 - 120

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2,4,6-Tribromophenol (Surr)	82		28 - 127
2-Fluorobiphenyl (Surr)	82		31 - 120
2-Fluorophenol (Surr)	73		17 - 120
Nitrobenzene-d5 (Surr)	77		27 - 120
Phenol-d6 (Surr)	47		10 - 120
p-Terphenyl-d14 (Surr)	88		45 - 120

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: LCSD 570-757352/3-A

Matrix: Water

Analysis Batch: 759081

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 757352

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec	RPD	RPD
							Limits		
1-Methylnaphthalene	20.0	16.5		ug/L		83	47 - 120	2	20
2-Methylnaphthalene	20.0	15.1		ug/L		76	43 - 120	4	20
Acenaphthene	20.0	16.3		ug/L		82	60 - 132	2	29
Acenaphthylene	20.0	15.8		ug/L		79	54 - 126	5	45
Anthracene	20.0	16.7		ug/L		83	43 - 120	3	40
Benzo[a]anthracene	20.0	17.6		ug/L		88	42 - 133	2	32
Benzo[a]pyrene	20.0	18.5		ug/L		92	32 - 148	2	43
Benzo[b]fluoranthene	20.0	17.8		ug/L		89	42 - 140	1	43
Benzo[g,h,i]perylene	20.0	17.7		ug/L		88	1 - 195	1	61
Benzo[k]fluoranthene	20.0	17.8		ug/L		89	25 - 146	6	38
Chrysene	20.0	17.6		ug/L		88	44 - 140	1	53
Dibenz(a,h)anthracene	20.0	18.1		ug/L		91	1 - 200	1	75
Fluoranthene	20.0	17.6		ug/L		88	43 - 121	3	40
Fluorene	20.0	17.1		ug/L		85	70 - 120	2	23
Indeno[1,2,3-cd]pyrene	20.0	17.8		ug/L		89	1 - 151	1	60
Naphthalene	20.0	16.1		ug/L		81	36 - 120	3	39
Phenanthrene	20.0	17.5		ug/L		88	65 - 120	2	24
Pyrene	20.0	17.7		ug/L		89	70 - 120	2	30

Surrogate	LCSD		Limits
	%Recovery	Qualifier	
2,4,6-Tribromophenol (Surr)	83		28 - 127
2-Fluorobiphenyl (Surr)	78		31 - 120
2-Fluorophenol (Surr)	71		17 - 120
Nitrobenzene-d5 (Surr)	74		27 - 120
Phenol-d6 (Surr)	45		10 - 120
p-Terphenyl-d14 (Surr)	88		45 - 120

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: MB 570-761708/6

Matrix: Water

Analysis Batch: 761708

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
GRO (C6-C10)	<10		10	ug/L			06/29/26 12:27	1

Surrogate	MB		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
4-Bromofluorobenzene (Surr)	103		38 - 134		06/29/26 12:27	1

Lab Sample ID: LCS 570-761708/3

Matrix: Water

Analysis Batch: 761708

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	
Gasoline Range Organics (C4-C13)	400	398		ug/L		99	78 - 120	

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Lab Sample ID: LCS 570-761708/3

Matrix: Water

Analysis Batch: 761708

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

	LCS	LCS	
Surrogate	%Recovery	Qualifier	Limits
4-Bromofluorobenzene (Surr)	106		38 - 134

Lab Sample ID: LCSD 570-761708/4

Matrix: Water

Analysis Batch: 761708

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

	Spike	LCSD	LCSD				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD
Gasoline Range Organics (C4-C13)	400	389		ug/L		97	78 - 120	2

	LCSD	LCSD	
Surrogate	%Recovery	Qualifier	Limits
4-Bromofluorobenzene (Surr)	105		38 - 134

Lab Sample ID: MRL 570-761708/5

Matrix: Water

Analysis Batch: 761708

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

	Spike	MRL	MRL				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
Gasoline Range Organics (C4-C13)	10.0	14.1		ug/L		141	50 - 150	

	MRL	MRL	
Surrogate	%Recovery	Qualifier	Limits
4-Bromofluorobenzene (Surr)	103		38 - 134

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Lab Sample ID: MB 570-758469/1-A

Matrix: Water

Analysis Batch: 762707

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 758469

	MB	MB						
Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25	ug/L		06/23/26 09:43	07/01/26 10:18	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		06/23/26 09:43	07/01/26 10:18	1
C8-C18	<25		25	ug/L		06/23/26 09:43	07/01/26 10:18	1

	MB	MB						
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac		
n-Octacosane (Surr)	90		60 - 130	06/23/26 09:43	07/01/26 10:18	1		

Lab Sample ID: LCS 570-758469/2-A

Matrix: Water

Analysis Batch: 762707

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 758469

	Spike	LCS	LCS				%Rec	
Analyte	Added	Result	Qualifier	Unit	D	%Rec	Limits	
C10-C28	2000	1950		ug/L		98	56 - 127	

	LCS	LCS	
Surrogate	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	104		60 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

Lab Sample ID: LCSD 570-758469/3-A

Matrix: Water

Analysis Batch: 762707

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 758469

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
C10-C28			2000	1710		ug/L		86	56 - 127	13	23
Surrogate		LCSD %Recovery	LCSD Qualifier	Limits							
n-Octacosane (Surr)		93		60 - 130							

Lab Sample ID: MRL 570-758469/4-A

Matrix: Water

Analysis Batch: 762707

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 758469

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
C10-C28			0.0200	0.0332	^3+	mg/L		166	50 - 150		
Surrogate		MRL %Recovery	MRL Qualifier	Limits							
n-Octacosane (Surr)		101		60 - 130							

Lab Sample ID: 380-220504-1 MS

Matrix: Water

Analysis Batch: 762707

Client Sample ID: BWS2153-S1-AQ

Prep Type: Total/NA

Prep Batch: 758469

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
C10-C28	<25	^3+	2010	1990		ug/L		98	70 - 130		
Surrogate		MS %Recovery	MS Qualifier	Limits							
n-Octacosane (Surr)		102		60 - 130							

Lab Sample ID: 380-220504-1 MSD

Matrix: Water

Analysis Batch: 762707

Client Sample ID: BWS2153-S1-AQ

Prep Type: Total/NA

Prep Batch: 758469

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
C10-C28	<25	^3+	2000	2010		ug/L		99	70 - 130	1	20
Surrogate		MSD %Recovery	MSD Qualifier	Limits							
n-Octacosane (Surr)		102		60 - 130							

QC Association Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

GC/MS VOA

Analysis Batch: 761520

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220504-1	BWS2153-S1-AQ	Total/NA	Water	8260B	
380-220504-2	BWS2153-S1-TB	Total/NA	Water	8260B	
MB 570-761520/7	Method Blank	Total/NA	Water	8260B	
LCS 570-761520/1003	Lab Control Sample	Total/NA	Water	8260B	
LCSD 570-761520/4	Lab Control Sample Dup	Total/NA	Water	8260B	
570-284379-A-1 MS	Matrix Spike	Total/NA	Water	8260B	
570-284379-A-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8260B	

GC/MS Semi VOA

Prep Batch: 757352

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220504-1	BWS2153-S1-AQ	Total/NA	Water	625.1	
MB 570-757352/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-757352/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-757352/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	

Analysis Batch: 759081

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220504-1	BWS2153-S1-AQ	Total/NA	Water	625.1 SIM	757352
MB 570-757352/1-A	Method Blank	Total/NA	Water	625.1 SIM	757352
LCS 570-757352/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	757352
LCSD 570-757352/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	757352

Analysis Batch: 761897

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220504-1	BWS2153-S1-AQ	Total/NA	Water	625.1	757352

GC VOA

Analysis Batch: 761708

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220504-1	BWS2153-S1-AQ	Total/NA	Water	8015B GRO LL	
380-220504-2	BWS2153-S1-TB	Total/NA	Water	8015B GRO LL	
MB 570-761708/6	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-761708/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-761708/4	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-761708/5	Lab Control Sample	Total/NA	Water	8015B GRO LL	

GC Semi VOA

Prep Batch: 758469

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220504-1	BWS2153-S1-AQ	Total/NA	Water	3510C	
MB 570-758469/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-758469/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-758469/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-758469/4-A	Lab Control Sample	Total/NA	Water	3510C	
380-220504-1 MS	BWS2153-S1-AQ	Total/NA	Water	3510C	
380-220504-1 MSD	BWS2153-S1-AQ	Total/NA	Water	3510C	

QC Association Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

GC Semi VOA

Analysis Batch: 762707

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-220504-1	BWS2153-S1-AQ	Total/NA	Water	8015B	758469
MB 570-758469/1-A	Method Blank	Total/NA	Water	8015B	758469
LCS 570-758469/2-A	Lab Control Sample	Total/NA	Water	8015B	758469
LCSD 570-758469/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	758469
MRL 570-758469/4-A	Lab Control Sample	Total/NA	Water	8015B	758469
380-220504-1 MS	BWS2153-S1-AQ	Total/NA	Water	8015B	758469
380-220504-1 MSD	BWS2153-S1-AQ	Total/NA	Water	8015B	758469

Lab Chronicle

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Client Sample ID: BWS2153-S1-AQ

Lab Sample ID: 380-220504-1

Date Collected: 06/17/26 09:00

Matrix: Water

Date Received: 06/18/26 09:43

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260B		1	761520	PT	EET CAL 4	06/29/26 12:50
Total/NA	Prep	625.1			757352	TIZL	EET CAL 4	06/21/26 08:48
Total/NA	Analysis	625.1		1	761897	S4EA	EET CAL 4	06/29/26 19:37
Total/NA	Prep	625.1			757352	TIZL	EET CAL 4	06/21/26 08:48
Total/NA	Analysis	625.1 SIM		1	759081	PQS1	EET CAL 4	06/24/26 11:58
Total/NA	Analysis	8015B GRO LL		1	761708	YD9V	EET CAL 4	06/29/26 13:48
Total/NA	Prep	3510C			758469	TVD6	EET CAL 4	06/23/26 09:43
Total/NA	Analysis	8015B		1	762707	H6FE	EET CAL 4	07/01/26 12:06

Client Sample ID: BWS2153-S1-TB

Lab Sample ID: 380-220504-2

Date Collected: 06/17/26 09:00

Matrix: Water

Date Received: 06/18/26 09:43

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260B		1	761520	PT	EET CAL 4	06/29/26 11:46
Total/NA	Analysis	8015B GRO LL		1	761708	YD9V	EET CAL 4	06/29/26 18:13

Laboratory References:

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	7296.01	11-30-26
A2LA	ISO/IEC 17025	7296.01	11-30-26
Alaska (UST)	State	25-005	03-02-27
Arizona	State	AZ0830	11-17-26
California	Los Angeles County Sanitation Districts	9257304	07-31-26
California	SCAQMD LAP	17LA0919	11-30-26
California	State	3082	07-31-26
Kansas	NELAP	E-10420	07-31-26
Nevada	State	CA00111	07-31-26
Oregon	NELAP	4175	02-02-27
USDA	US Federal Programs	525-23-159-97150	09-30-26
Utah	NELAP	CA00111	02-28-27
Washington	State	C916	10-12-26

Method Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Method	Method Description	Protocol	Laboratory
8260B	Volatile Organic Compounds (GC/MS)	SW846	EET CAL 4
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: City & County of Honolulu
Project/Site: INTERA - Red-Hill-Incident

Job ID: 380-220504-1
SDG: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-220504-1	BWS2153-S1-AQ	Water	06/17/26 09:00	06/18/26 09:43	Hawaii
380-220504-2	BWS2153-S1-TB	Water	06/17/26 09:00	06/18/26 09:43	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

[illegible]

[illegible]

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-220504-1

SDG Number: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Login Number: 220504

List Source: Eurofins Pomona

List Number: 1

Creator: Ngo, Theodore

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-220504-1

SDG Number: Site S1 625.1, 8015B_DRO/_GRO, 8260B

Login Number: 220504

List Source: Eurofins Calscience

List Number: 2

List Creation: 06/19/26 11:48 AM

Creator: Ferreira, Bruno

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	Seal present with no number.
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	2.6
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	vu9z
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	