

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 6/10/2026 3:11:52 PM

JOB DESCRIPTION

RED-HILL
Weekly: Moanalua Wells

JOB NUMBER

380-216582-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
6/10/2026 3:11:52 PM



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
QC Sample Results	15
QC Association Summary	30
Lab Chronicle	32
Certification Summary	33
Method Summary	35
Sample Summary	36
Chain of Custody	37
Receipt Checklists	43

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Qualifiers

GC/MS Semi VOA

Qualifier	Qualifier Description
^3+	Reporting Limit Check Standard is outside acceptance limits, high biased
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC Semi VOA

Qualifier	Qualifier Description
^3+	Reporting Limit Check Standard is outside acceptance limits, high biased

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-216582-1

Job ID: 380-216582-1

Eurofins Pomona

Job Narrative 380-216582-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 5/28/2026 10:10 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 2 coolers at receipt time were 4.6°C and 5.8°C.

Receipt Exceptions

GC/MS Semi VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Gasoline Range Organics

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Diesel Range Organics

Method 8015B: The method reporting limit check (MRL) for preparation batch 570-747016 and analytical batch 570-750788 recovered outside control limits for the following analytes: C10-C28. These analytes were biased high in the MRL and were not detected in the associated samples; therefore, the data have been reported.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)
PWSID Number: HI0000331

Lab Sample ID: 380-216582-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Dieldrin	0.032		0.0098	ug/L	1		525.2	Total/NA

Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-216582-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-216582-1

Date Collected: 05/26/26 09:53

Matrix: Drinking Water

Date Received: 05/28/26 10:10

PWSID Number: HI0000331

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
2,4'-DDD	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
2,4'-DDE	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
2,4'-DDT	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
2,4-Dinitrotoluene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
2,6-Dinitrotoluene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
2-Methylnaphthalene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
4,4'-DDD	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
4,4'-DDE	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
4,4'-DDT	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Acenaphthene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Acenaphthylene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Acetochlor	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Alachlor	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
alpha-BHC	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
alpha-Chlordane	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Anthracene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 18:34	1
Atrazine	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Benz(a)anthracene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Benzo[a]pyrene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 18:34	1
Benzo[b]fluoranthene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 18:34	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Benzo[k]fluoranthene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 18:34	1
beta-BHC	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59	ug/L		06/02/26 15:52	06/03/26 18:34	1
Bromacil	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Butachlor	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Butylbenzylphthalate	<0.49		0.49	ug/L		06/02/26 15:52	06/03/26 18:34	1
Chlorobenzilate	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Chloroneb	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Chlorothalonil (Draconil, Bravo)	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Chlorpyrifos	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Chrysene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 18:34	1
delta-BHC	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Di(2-ethylhexyl)adipate	<0.59		0.59	ug/L		06/02/26 15:52	06/03/26 18:34	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Dieldrin	0.032		0.0098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Diethylphthalate	<0.49		0.49	ug/L		06/02/26 15:52	06/03/26 18:34	1
Dimethylphthalate	<0.49		0.49	ug/L		06/02/26 15:52	06/03/26 18:34	1
Di-n-butyl phthalate	<0.98		0.98	ug/L		06/02/26 15:52	06/03/26 18:34	1
Di-n-octyl phthalate	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Endosulfan I (Alpha)	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Endosulfan II (Beta)	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Endosulfan sulfate	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Endrin	<0.0098		0.0098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Endrin aldehyde	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
EPTC	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Fluoranthene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-216582-1

Date Collected: 05/26/26 09:53

Matrix: Drinking Water

Date Received: 05/28/26 10:10

PWSID Number: HI0000331

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
gamma-Chlordane	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Heptachlor	<0.0098		0.0098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Heptachlor epoxide (isomer B)	<0.0098	^3+	0.0098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Hexachlorobenzene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Isophorone	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Lindane	<0.0098		0.0098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Malathion	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Methoxychlor	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Metolachlor	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Molinate	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Naphthalene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Parathion	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Pendimethalin (Penoxaline)	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Phenanthrene	<0.039		0.039	ug/L		06/02/26 15:52	06/03/26 18:34	1
Propachlor	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Pyrene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Simazine	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Terbacil	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Terbutylazine	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Thiobencarb	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L		06/02/26 15:52	06/03/26 18:34	1
trans-Nonachlor	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 18:34	1
Trifluralin	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 18:34	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	06/02/26 15:52	06/03/26 18:34	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	98		70 - 130	06/02/26 15:52	06/03/26 18:34	1
Perylene-d12	90		70 - 130	06/02/26 15:52	06/03/26 18:34	1
Triphenylphosphate	107		70 - 130	06/02/26 15:52	06/03/26 18:34	1

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
2-Methylnaphthalene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Acenaphthene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Acenaphthylene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Anthracene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Benzo[a]anthracene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Benzo[a]pyrene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Benzo[b]fluoranthene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Benzo[g,h,i]perylene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Benzo[k]fluoranthene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Chrysene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Dibenz(a,h)anthracene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Fluoranthene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-216582-1

Date Collected: 05/26/26 09:53

Matrix: Drinking Water

Date Received: 05/28/26 10:10

PWSID Number: HI0000331

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Indeno[1,2,3-cd]pyrene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Naphthalene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Phenanthrene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1
Pyrene	<0.19		0.19	ug/L		05/31/26 08:21	06/03/26 12:16	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	85		28 - 127	05/31/26 08:21	06/03/26 12:16	1
2-Fluorobiphenyl (Surr)	83		31 - 120	05/31/26 08:21	06/03/26 12:16	1
2-Fluorophenol (Surr)	45		17 - 120	05/31/26 08:21	06/03/26 12:16	1
Nitrobenzene-d5 (Surr)	77		27 - 120	05/31/26 08:21	06/03/26 12:16	1
Phenol-d6 (Surr)	26		10 - 120	05/31/26 08:21	06/03/26 12:16	1
p-Terphenyl-d14 (Surr)	69		45 - 120	05/31/26 08:21	06/03/26 12:16	1

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	05/31/26 08:21	06/04/26 12:03	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	101		33 - 139	05/31/26 08:21	06/04/26 12:03	1
2-Fluorobiphenyl (Surr)	89		33 - 126	05/31/26 08:21	06/04/26 12:03	1
2-Fluorophenol (Surr)	53		12 - 120	05/31/26 08:21	06/04/26 12:03	1
Nitrobenzene-d5 (Surr)	109		36 - 120	05/31/26 08:21	06/04/26 12:03	1
Phenol-d6 (Surr)	31		10 - 120	05/31/26 08:21	06/04/26 12:03	1
p-Terphenyl-d14 (Surr)	91		47 - 131	05/31/26 08:21	06/04/26 12:03	1

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			06/01/26 16:35	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	99		38 - 134		06/01/26 16:35	1

Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26	ug/L		06/01/26 09:04	06/08/26 13:33	1
Motor Oil Range Organics [C24-C36]	<26		26	ug/L		06/01/26 09:04	06/08/26 13:33	1
C8-C18	<26		26	ug/L		06/01/26 09:04	06/08/26 13:33	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	104		60 - 130	06/01/26 09:04	06/08/26 13:33	1

Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-216582-2

Date Collected: 05/26/26 09:53

Matrix: Water

Date Received: 05/28/26 10:10

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			06/01/26 20:37	1

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-216582-2

Date Collected: 05/26/26 09:53

Matrix: Water

Date Received: 05/28/26 10:10

<u>Surrogate</u>	<u>%Recovery</u>	<u>Qualifier</u>	<u>Limits</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Dil Fac</u>
4-Bromofluorobenzene (Surr)	98		38 - 134		06/01/26 20:37	1

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)
PWSID Number: HI0000331

Lab Sample ID: 380-216582-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Alachlor	<0.049		ug/L	2	0.049	525.2	Total/NA
Atrazine	<0.049		ug/L	3	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.020		ug/L	0.2	0.020	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.59		ug/L	6	0.59	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.59		ug/L	400	0.59	525.2	Total/NA
Endrin	<0.0098		ug/L	2	0.0098	525.2	Total/NA
Heptachlor	<0.0098		ug/L	0.4	0.0098	525.2	Total/NA
Heptachlor epoxide (isomer B)	<0.0098	^3+	ug/L	0.2	0.0098	525.2	Total/NA
Hexachlorobenzene	<0.049		ug/L	1	0.049	525.2	Total/NA
Hexachlorocyclopentadiene	<0.049		ug/L	50	0.049	525.2	Total/NA
Lindane	<0.0098		ug/L	0.2	0.0098	525.2	Total/NA
Methoxychlor	<0.049	^3+	ug/L	40	0.049	525.2	Total/NA
Simazine	<0.049	^3+	ug/L	4	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.19		ug/L	0.2	0.19	625.1 SIM	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-216582-1	MOANALUA WELLS (331-223-T	98	90	107

Surrogate Legend
 2NMX = 2-Nitro-m-xylene
 PRY = Perylene-d12
 TPP = Triphenylphosphate

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-216945-B-4-A MS	Matrix Spike	100	103	111
380-216945-B-4-B MSD	Matrix Spike Duplicate	98	101	115
LCS 380-231139/23-A	Lab Control Sample	94	98	102
MB 380-231139/21-A	Method Blank	95	94	110
MRL 380-231139/22-A	Lab Control Sample	97	97	109

Surrogate Legend
 2NMX = 2-Nitro-m-xylene
 PRY = Perylene-d12
 TPP = Triphenylphosphate

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
380-216582-1	MOANALUA WELLS (331-223-T	101	89	53	109	31	91

Surrogate Legend
 TBP = 2,4,6-Tribromophenol (Surr)
 FBP = 2-Fluorobiphenyl (Surr)
 2FP = 2-Fluorophenol (Surr)
 NBZ = Nitrobenzene-d5 (Surr)
 PHL6 = Phenol-d6 (Surr)
 TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
MB 570-746664/1-A	Method Blank	106	89	60	108	37	92

Surrogate Legend
 TBP = 2,4,6-Tribromophenol (Surr)
 FBP = 2-Fluorobiphenyl (Surr)
 2FP = 2-Fluorophenol (Surr)
 NBZ = Nitrobenzene-d5 (Surr)

Surrogate Summary

Client: City & County of Honolulu

Job ID: 380-216582-1

Project/Site: RED-HILL

SDG: Weekly: Moanalua Wells

PHL6 = Phenol-d6 (Surr)

TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-216582-1	MOANALUA WELLS (331-223-T	85	83	45	77	26	69

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)

FBP = 2-Fluorobiphenyl (Surr)

2FP = 2-Fluorophenol (Surr)

NBZ = Nitrobenzene-d5 (Surr)

PHL6 = Phenol-d6 (Surr)

TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-216586-A-1-A MS	Matrix Spike	80	79	54	69	37	78
380-216586-A-1-B MSD	Matrix Spike Duplicate	77	83	57	69	39	81
LCS 570-746664/2-A	Lab Control Sample	73	75	50	64	34	70
LCSD 570-746664/3-A	Lab Control Sample Dup	69	72	47	61	33	74
MB 570-746664/1-A	Method Blank	85	83	49	80	31	78

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)

FBP = 2-Fluorobiphenyl (Surr)

2FP = 2-Fluorophenol (Surr)

NBZ = Nitrobenzene-d5 (Surr)

PHL6 = Phenol-d6 (Surr)

TPHd14 = p-Terphenyl-d14 (Surr)

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)
		BFB1 (38-134)
380-216582-1	MOANALUA WELLS (331-223-T	99

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)
		BFB1 (38-134)
380-215428-B-1 MS	Matrix Spike	99
380-215428-B-1 MSD	Matrix Spike Duplicate	101
380-216582-2	TB: MOANALUA WELLS (331-223-TP202)	98

Eurofins Pomona

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB1 (38-134)
LCS 570-746997/3	Lab Control Sample	99
LCSD 570-746997/4	Lab Control Sample Dup	101
MB 570-746997/6	Method Blank	104
MRL 570-746997/5	Lab Control Sample	104

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-216582-1	MOANALUA WELLS (331-223-T	104

Surrogate Legend

OTCSN = n-Octacosane (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-216586-C-1-A MS	Matrix Spike	110
380-216586-C-1-B MSD	Matrix Spike Duplicate	102
LCS 570-747016/2-A	Lab Control Sample	108
LCSD 570-747016/3-A	Lab Control Sample Dup	109
MB 570-747016/1-A	Method Blank	103
MRL 570-747016/4-A	Lab Control Sample	98

Surrogate Legend

OTCSN = n-Octacosane (Surr)

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-216582-1
 SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-231139/21-A
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 231139

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
2,4'-DDD	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
2,4'-DDE	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
2,4'-DDT	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
2,4-Dinitrotoluene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
2,6-Dinitrotoluene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
2-Methylnaphthalene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
4,4'-DDD	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
4,4'-DDE	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
4,4'-DDT	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Acenaphthene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Acenaphthylene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Acetochlor	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Alachlor	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
alpha-BHC	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
alpha-Chlordane	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Anthracene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 14:34	1
Atrazine	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Benz(a)anthracene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Benzo[a]pyrene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 14:34	1
Benzo[b]fluoranthene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 14:34	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Benzo[k]fluoranthene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 14:34	1
beta-BHC	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59	ug/L		06/02/26 15:52	06/03/26 14:34	1
Bromacil	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Butachlor	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Butylbenzylphthalate	<0.49		0.49	ug/L		06/02/26 15:52	06/03/26 14:34	1
Chlorobenzilate	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Chloroneb	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Chlorothalonil (Draconil, Bravo)	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Chlorpyrifos	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Chrysene	<0.020		0.020	ug/L		06/02/26 15:52	06/03/26 14:34	1
delta-BHC	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Di(2-ethylhexyl)adipate	<0.59		0.59	ug/L		06/02/26 15:52	06/03/26 14:34	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Dieldrin	<0.0098		0.0098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Diethylphthalate	<0.49		0.49	ug/L		06/02/26 15:52	06/03/26 14:34	1
Dimethylphthalate	<0.49		0.49	ug/L		06/02/26 15:52	06/03/26 14:34	1
Di-n-butyl phthalate	<0.98		0.98	ug/L		06/02/26 15:52	06/03/26 14:34	1
Di-n-octyl phthalate	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Endosulfan I (Alpha)	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Endosulfan II (Beta)	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Endosulfan sulfate	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Endrin	<0.0098		0.0098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Endrin aldehyde	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
EPTC	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-231139/21-A
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 231139

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Fluorene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
gamma-Chlordane	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Heptachlor	<0.0098		0.0098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Heptachlor epoxide (isomer B)	<0.0098	^3+	0.0098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Hexachlorobenzene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Isophorone	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Lindane	<0.0098		0.0098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Malathion	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Methoxychlor	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Metolachlor	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Molinate	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Naphthalene	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Parathion	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Pendimethalin (Penoxaline)	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Phenanthrene	<0.039		0.039	ug/L		06/02/26 15:52	06/03/26 14:34	1
Propachlor	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Pyrene	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Simazine	<0.049	^3+	0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Terbacil	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Terbutylazine	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Thiobencarb	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L		06/02/26 15:52	06/03/26 14:34	1
trans-Nonachlor	<0.049		0.049	ug/L		06/02/26 15:52	06/03/26 14:34	1
Trifluralin	<0.098		0.098	ug/L		06/02/26 15:52	06/03/26 14:34	1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	06/02/26 15:52	06/03/26 14:34	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	95		70 - 130	06/02/26 15:52	06/03/26 14:34	1
Perylene-d12	94		70 - 130	06/02/26 15:52	06/03/26 14:34	1
Triphenylphosphate	110		70 - 130	06/02/26 15:52	06/03/26 14:34	1

Lab Sample ID: LCS 380-231139/23-A
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 231139

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
1-Methylnaphthalene	1.95	1.86		ug/L		95	70 - 130
2,4'-DDD	1.95	1.85		ug/L		95	70 - 130
2,4'-DDE	1.95	1.92		ug/L		98	70 - 130
2,4'-DDT	1.95	1.74		ug/L		89	70 - 130
2,4-Dinitrotoluene	1.95	1.96		ug/L		100	70 - 130
2,6-Dinitrotoluene	1.95	2.03		ug/L		104	70 - 130
2-Methylnaphthalene	1.95	1.82		ug/L		93	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-231139/23-A
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 231139

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
4,4'-DDD	1.95	1.80		ug/L		92	70 - 130
4,4'-DDE	1.95	1.88		ug/L		96	70 - 130
4,4'-DDT	1.95	1.80		ug/L		92	70 - 130
Acenaphthene	1.95	1.97		ug/L		101	70 - 130
Acenaphthylene	1.95	1.75		ug/L		90	70 - 130
Acetochlor	1.95	2.07		ug/L		106	70 - 130
Alachlor	1.95	2.09		ug/L		107	70 - 130
alpha-BHC	1.95	2.02		ug/L		103	70 - 130
alpha-Chlordane	1.95	1.74		ug/L		89	70 - 130
Anthracene	1.95	1.80		ug/L		92	70 - 130
Atrazine	1.95	1.98		ug/L		101	70 - 130
Benz(a)anthracene	1.95	1.93		ug/L		99	70 - 130
Benzo[a]pyrene	1.95	1.96		ug/L		100	70 - 130
Benzo[b]fluoranthene	1.95	2.00		ug/L		102	70 - 130
Benzo[g,h,i]perylene	1.95	2.09		ug/L		107	70 - 130
Benzo[k]fluoranthene	1.95	2.00		ug/L		102	70 - 130
beta-BHC	1.95	2.03		ug/L		104	70 - 130
Bis(2-ethylhexyl) phthalate	1.95	2.14		ug/L		109	70 - 130
Bromacil	1.95	2.01		ug/L		103	70 - 130
Butachlor	1.95	2.22		ug/L		113	70 - 130
Butylbenzylphthalate	1.95	2.30		ug/L		118	70 - 130
Chlorobenzilate	1.95	2.02		ug/L		103	70 - 130
Chloroneb	1.95	1.99		ug/L		102	70 - 130
Chlorothalonil (Draconil, Bravo)	1.95	1.94		ug/L		99	70 - 130
Chlorpyrifos	1.95	1.80		ug/L		92	70 - 130
Chrysene	1.95	1.84		ug/L		94	70 - 130
delta-BHC	1.95	2.00		ug/L		103	70 - 130
Di(2-ethylhexyl)adipate	1.95	2.33		ug/L		119	70 - 130
Dibenz(a,h)anthracene	1.95	2.07		ug/L		106	70 - 130
Diclorvos (DDVP)	1.95	2.10		ug/L		107	70 - 130
Dieldrin	1.95	2.07		ug/L		106	70 - 130
Diethylphthalate	1.95	2.08		ug/L		106	70 - 130
Dimethylphthalate	1.95	2.02		ug/L		103	70 - 130
Di-n-butyl phthalate	3.91	4.48		ug/L		115	70 - 130
Di-n-octyl phthalate	1.95	2.09		ug/L		107	70 - 130
Endosulfan I (Alpha)	1.95	1.87		ug/L		96	70 - 130
Endosulfan II (Beta)	1.95	1.89		ug/L		97	70 - 130
Endosulfan sulfate	1.95	2.04		ug/L		104	70 - 130
Endrin	1.95	2.19		ug/L		112	70 - 130
Endrin aldehyde	1.95	1.95		ug/L		100	60 - 130
EPTC	1.95	1.90		ug/L		97	70 - 130
Fluoranthene	1.95	1.81		ug/L		93	70 - 130
Fluorene	1.95	1.91		ug/L		98	70 - 130
gamma-Chlordane	1.95	1.80		ug/L		92	70 - 130
Heptachlor	1.95	2.10		ug/L		108	70 - 130
Heptachlor epoxide (isomer B)	1.95	2.02		ug/L		103	70 - 130
Hexachlorobenzene	1.95	1.80		ug/L		92	70 - 130
Hexachlorocyclopentadiene	1.95	1.76		ug/L		90	70 - 130
Indeno[1,2,3-cd]pyrene	1.95	2.20		ug/L		113	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-231139/23-A
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 231139

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Isophorone	1.95	1.83		ug/L		94	70 - 130
Lindane	1.95	2.13		ug/L		109	70 - 130
Malathion	1.95	1.96		ug/L		101	70 - 130
Methoxychlor	1.95	1.97		ug/L		101	70 - 130
Metolachlor	1.95	2.08		ug/L		106	70 - 130
Molinate	1.95	1.95		ug/L		100	70 - 130
Naphthalene	1.95	1.82		ug/L		93	70 - 130
Parathion	1.95	2.15		ug/L		110	70 - 130
Pendimethalin (Penoxaline)	1.95	1.84		ug/L		94	70 - 130
Phenanthrene	1.95	1.85		ug/L		94	70 - 130
Propachlor	1.95	2.09		ug/L		107	70 - 130
Pyrene	1.95	1.86		ug/L		95	70 - 130
Simazine	1.95	1.94		ug/L		99	70 - 130
Terbacil	1.95	2.24		ug/L		115	70 - 130
Terbutylazine	1.95	2.07		ug/L		106	70 - 130
Thiobencarb	1.95	1.94		ug/L		99	70 - 130
trans-Nonachlor	1.95	1.75		ug/L		90	70 - 130
Trifluralin	1.95	2.13		ug/L		109	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2-Nitro-m-xylene	94		70 - 130
Perylene-d12	98		70 - 130
Triphenylphosphate	102		70 - 130

Lab Sample ID: MRL 380-231139/22-A
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 231139

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	0.0978	0.0984		ug/L		101	50 - 150
2,4'-DDD	0.0978	0.0947	J	ug/L		97	50 - 150
2,4'-DDE	0.0978	0.102		ug/L		104	50 - 150
2,4'-DDT	0.0978	0.121		ug/L		124	50 - 150
2,4-Dinitrotoluene	0.0978	0.107		ug/L		110	50 - 150
2,6-Dinitrotoluene	0.0978	0.0966	J	ug/L		99	50 - 150
2-Methylnaphthalene	0.0978	0.103		ug/L		105	50 - 150
4,4'-DDD	0.0978	0.115		ug/L		118	50 - 150
4,4'-DDE	0.0978	0.120		ug/L		123	50 - 150
4,4'-DDT	0.0978	0.121		ug/L		124	50 - 150
Acenaphthene	0.0978	0.0991		ug/L		101	50 - 150
Acenaphthylene	0.0978	0.0740	J	ug/L		76	50 - 150
Acetochlor	0.0978	0.125		ug/L		128	50 - 150
Alachlor	0.0489	0.0728		ug/L		149	50 - 150
alpha-BHC	0.0978	0.122		ug/L		124	50 - 150
alpha-Chlordane	0.0244	0.0314	J	ug/L		128	50 - 150
Anthracene	0.0196	0.0245		ug/L		125	50 - 150
Atrazine	0.0489	0.0594		ug/L		121	50 - 150
Benz(a)anthracene	0.0489	0.0558		ug/L		114	50 - 150

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-231139/22-A
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 231139

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Benzo[a]pyrene	0.0196	0.0239		ug/L		122	50 - 150
Benzo[b]fluoranthene	0.0196	0.0243		ug/L		124	50 - 150
Benzo[g,h,i]perylene	0.0489	0.0659		ug/L		135	50 - 150
Benzo[k]fluoranthene	0.0196	0.0227		ug/L		116	50 - 150
beta-BHC	0.0978	0.129		ug/L		132	50 - 150
Bis(2-ethylhexyl) phthalate	0.587	0.689		ug/L		117	50 - 150
Bromacil	0.0978	0.139		ug/L		142	50 - 150
Butachlor	0.0489	0.0765	^3+	ug/L		156	50 - 150
Butylbenzylphthalate	0.489	0.611		ug/L		125	50 - 150
Chlorobenzilate	0.0978	0.132		ug/L		135	50 - 150
Chloroneb	0.0978	0.108		ug/L		110	50 - 150
Chlorothalonil (Draconil, Bravo)	0.0978	0.110		ug/L		112	50 - 150
Chlorpyrifos	0.0489	0.0782	^3+	ug/L		160	50 - 150
Chrysene	0.0196	0.0223		ug/L		114	50 - 150
delta-BHC	0.0978	0.116		ug/L		118	50 - 150
Di(2-ethylhexyl)adipate	0.587	0.778		ug/L		133	50 - 150
Dibenz(a,h)anthracene	0.0489	0.0556		ug/L		114	50 - 150
Diclorvos (DDVP)	0.0489	0.0681		ug/L		139	50 - 150
Dieldrin	0.00978	0.0122		ug/L		125	50 - 150
Diethylphthalate	0.489	0.561		ug/L		115	50 - 150
Dimethylphthalate	0.489	0.542		ug/L		111	50 - 150
Di-n-butyl phthalate	0.489	0.657	J	ug/L		134	49 - 243
Di-n-octyl phthalate	0.0978	0.124		ug/L		127	50 - 150
Endosulfan I (Alpha)	0.0978	0.110		ug/L		113	50 - 150
Endosulfan II (Beta)	0.0978	0.143		ug/L		147	50 - 150
Endosulfan sulfate	0.0978	0.117		ug/L		120	50 - 150
Endrin	0.00978	0.0110		ug/L		112	50 - 150
Endrin aldehyde	0.0978	0.130		ug/L		133	50 - 150
EPTC	0.0978	0.106		ug/L		109	50 - 150
Fluoranthene	0.0978	0.117		ug/L		119	50 - 150
Fluorene	0.0489	0.0548		ug/L		112	50 - 150
gamma-Chlordane	0.0244	0.0361	J	ug/L		148	50 - 150
Heptachlor	0.00978	0.0135		ug/L		138	50 - 150
Heptachlor epoxide (isomer B)	0.00978	0.0154	^3+	ug/L		158	50 - 150
Hexachlorobenzene	0.0489	0.0682		ug/L		139	50 - 150
Hexachlorocyclopentadiene	0.0489	0.0471	J	ug/L		96	50 - 150
Indeno[1,2,3-cd]pyrene	0.0489	0.0619		ug/L		127	50 - 150
Isophorone	0.0978	0.106		ug/L		108	50 - 150
Lindane	0.00978	0.0138		ug/L		142	50 - 150
Malathion	0.0978	0.119		ug/L		122	50 - 150
Methoxychlor	0.0489	0.0766	^3+	ug/L		157	50 - 150
Metolachlor	0.0489	0.0631		ug/L		129	50 - 150
Molinate	0.0978	0.120		ug/L		123	50 - 150
Naphthalene	0.0978	0.102		ug/L		104	50 - 150
Parathion	0.0978	0.112		ug/L		115	50 - 150
Pendimethalin (Penoxaline)	0.0978	0.107		ug/L		110	50 - 150
Phenanthrene	0.0391	0.0453		ug/L		116	50 - 150
Propachlor	0.0489	0.0795	^3+	ug/L		163	50 - 150
Pyrene	0.0489	0.0600		ug/L		123	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-231139/22-A
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 231139

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Simazine	0.0489	0.0768	^3+	ug/L		157	50 - 150
Terbacil	0.0978	0.136		ug/L		139	50 - 150
Terbuthylazine	0.0978	0.116		ug/L		119	50 - 150
Thiobencarb	0.0978	0.117		ug/L		120	50 - 150
trans-Nonachlor	0.0244	0.0316	J	ug/L		129	50 - 150
Trifluralin	0.0978	0.121		ug/L		124	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
2-Nitro-m-xylene	97		70 - 130
Perylene-d12	97		70 - 130
Triphenylphosphate	109		70 - 130

Lab Sample ID: 380-216945-B-4-A MS
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 231139

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	<0.097		1.95	1.92		ug/L		98	70 - 130
2,4'-DDD	<0.097		1.95	1.98		ug/L		102	70 - 130
2,4'-DDE	<0.097	F1	1.95	0.873	F1	ug/L		45	70 - 130
2,4'-DDT	<0.097		1.95	1.97		ug/L		101	70 - 130
2,4-Dinitrotoluene	<0.097		1.95	2.28		ug/L		117	70 - 130
2,6-Dinitrotoluene	<0.097		1.95	2.33		ug/L		119	70 - 130
2-Methylnaphthalene	<0.097		1.95	1.90		ug/L		97	70 - 130
4,4'-DDD	<0.097		1.95	1.95		ug/L		100	70 - 130
4,4'-DDE	<0.097		1.95	1.67		ug/L		86	70 - 130
4,4'-DDT	<0.097		1.95	1.96		ug/L		100	70 - 130
Acenaphthene	<0.097		1.95	1.94		ug/L		100	70 - 130
Acenaphthylene	<0.097		1.95	1.95		ug/L		100	70 - 130
Acetochlor	<0.097		1.95	2.18		ug/L		112	70 - 130
Alachlor	<0.049		1.95	2.17		ug/L		112	70 - 130
alpha-BHC	<0.097		1.95	1.95		ug/L		100	70 - 130
alpha-Chlordane	<0.049		1.95	1.91		ug/L		98	70 - 130
Anthracene	<0.019		1.95	1.87		ug/L		96	70 - 130
Atrazine	<0.049		1.95	2.02		ug/L		103	70 - 130
Benz(a)anthracene	<0.049		1.95	2.20		ug/L		113	70 - 130
Benzo[a]pyrene	<0.019		1.95	2.48		ug/L		127	70 - 130
Benzo[b]fluoranthene	<0.019		1.95	2.36		ug/L		121	70 - 130
Benzo[g,h,i]perylene	<0.049		1.95	2.45		ug/L		126	70 - 130
Benzo[k]fluoranthene	<0.019		1.95	2.34		ug/L		120	70 - 130
beta-BHC	<0.097		1.95	2.02		ug/L		104	70 - 130
Bis(2-ethylhexyl) phthalate	<0.58		1.95	2.21		ug/L		113	70 - 130
Bromacil	<0.097		1.95	2.42		ug/L		124	70 - 130
Butachlor	<0.049	^3+	1.95	1.48		ug/L		76	70 - 130
Butylbenzylphthalate	<0.49		1.95	2.21		ug/L		114	70 - 130
Chlorobenzilate	<0.097		1.95	2.42		ug/L		124	70 - 130
Chloroneb	<0.097		1.95	2.08		ug/L		107	70 - 130
Chlorothalonil (Draconil, Bravo)	<0.097		1.95	2.20		ug/L		113	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-216945-B-4-A MS
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 231139

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
Chlorpyrifos	<0.049	^3+	1.95	1.95		ug/L		100	70 - 130
Chrysene	<0.019		1.95	2.05		ug/L		105	70 - 130
delta-BHC	<0.097		1.95	1.99		ug/L		102	70 - 130
Di(2-ethylhexyl)adipate	<0.58		1.95	2.05		ug/L		105	70 - 130
Dibenz(a,h)anthracene	<0.049		1.95	2.45		ug/L		126	70 - 130
Diclorvos (DDVP)	<0.049		1.95	2.24		ug/L		115	70 - 130
Dieldrin	<0.0097		1.95	2.18		ug/L		112	70 - 130
Diethylphthalate	<0.49		1.95	2.23		ug/L		110	70 - 130
Dimethylphthalate	<0.49		1.95	2.09		ug/L		107	70 - 130
Di-n-butyl phthalate	<0.97		3.89	3.93		ug/L		101	70 - 130
Di-n-octyl phthalate	<0.097		1.95	2.11		ug/L		109	70 - 130
Endosulfan I (Alpha)	<0.097		1.95	1.96		ug/L		101	70 - 130
Endosulfan II (Beta)	<0.097		1.95	1.88		ug/L		97	70 - 130
Endosulfan sulfate	<0.097		1.95	2.18		ug/L		112	70 - 130
Endrin	<0.0097		1.95	2.22		ug/L		114	70 - 130
Endrin aldehyde	<0.097		1.95	1.34		ug/L		69	60 - 130
EPTC	<0.097		1.95	2.06		ug/L		106	70 - 130
Fluoranthene	<0.097		1.95	1.93		ug/L		99	70 - 130
Fluorene	<0.049		1.95	1.92		ug/L		99	70 - 130
gamma-Chlordane	<0.049	F1	1.95	1.38		ug/L		71	70 - 130
Heptachlor	<0.0097		1.95	1.50		ug/L		77	70 - 130
Heptachlor epoxide (isomer B)	<0.0097	^3+	1.95	2.07		ug/L		107	70 - 130
Hexachlorobenzene	<0.049		1.95	1.71		ug/L		88	70 - 130
Hexachlorocyclopentadiene	<0.049		1.95	1.87		ug/L		96	70 - 130
Indeno[1,2,3-cd]pyrene	<0.049	F1	1.95	2.68	F1	ug/L		138	70 - 130
Isophorone	<0.097		1.95	1.95		ug/L		98	70 - 130
Lindane	<0.0097		1.95	2.25		ug/L		116	70 - 130
Malathion	<0.097		1.95	2.07		ug/L		106	70 - 130
Methoxychlor	<0.049	^3+	1.95	2.38		ug/L		122	70 - 130
Metolachlor	<0.049		1.95	2.08		ug/L		107	70 - 130
Molinate	<0.097		1.95	2.12		ug/L		109	70 - 130
Naphthalene	<0.097		1.95	1.88		ug/L		97	70 - 130
Parathion	<0.097	F1	1.95	2.50		ug/L		129	70 - 130
Pendimethalin (Penoxaline)	<0.097		1.95	2.46		ug/L		126	70 - 130
Phenanthrene	<0.039		1.95	1.89		ug/L		97	70 - 130
Propachlor	<0.049	^3+	1.95	2.30		ug/L		118	70 - 130
Pyrene	<0.049		1.95	1.90		ug/L		97	70 - 130
Simazine	<0.049	^3+	1.95	1.85		ug/L		95	70 - 130
Terbacil	<0.097	F1	1.95	2.42		ug/L		124	70 - 130
Terbutylazine	<0.097		1.95	2.02		ug/L		104	70 - 130
Thiobencarb	<0.097		1.95	1.98		ug/L		102	70 - 130
trans-Nonachlor	<0.049		1.95	2.04		ug/L		105	70 - 130
Trifluralin	<0.097	F1	1.95	2.54	F1	ug/L		131	70 - 130

Surrogate	MS MS		Limits
	%Recovery	Qualifier	
2-Nitro-m-xylene	100		70 - 130
Perylene-d12	103		70 - 130
Triphenylphosphate	111		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-216945-B-4-B MSD
Matrix: Water
Analysis Batch: 231376

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 231139

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec	RPD	RPD
	Result	Qualifier	Added	Result	Qualifier				Limits		Limit
1-Methylnaphthalene	<0.097		1.97	1.95		ug/L		98	70 - 130	2	20
2,4'-DDD	<0.097		1.97	2.06		ug/L		105	70 - 130	4	20
2,4'-DDE	<0.097	F1	1.97	0.851	F1	ug/L		43	70 - 130	3	20
2,4'-DDT	<0.097		1.97	2.07		ug/L		105	70 - 130	5	20
2,4-Dinitrotoluene	<0.097		1.97	2.46		ug/L		125	70 - 130	7	20
2,6-Dinitrotoluene	<0.097		1.97	2.43		ug/L		123	70 - 130	4	20
2-Methylnaphthalene	<0.097		1.97	1.93		ug/L		97	70 - 130	2	20
4,4'-DDD	<0.097		1.97	2.02		ug/L		102	70 - 130	4	20
4,4'-DDE	<0.097		1.97	1.75		ug/L		89	70 - 130	4	20
4,4'-DDT	<0.097		1.97	2.09		ug/L		106	70 - 130	7	20
Acenaphthene	<0.097		1.97	2.00		ug/L		102	70 - 130	3	20
Acenaphthylene	<0.097		1.97	2.01		ug/L		102	70 - 130	3	20
Acetochlor	<0.097		1.97	2.20		ug/L		112	70 - 130	1	20
Alachlor	<0.049		1.97	2.21		ug/L		112	70 - 130	2	20
alpha-BHC	<0.097		1.97	2.01		ug/L		102	70 - 130	3	20
alpha-Chlordane	<0.049		1.97	1.92		ug/L		98	70 - 130	1	20
Anthracene	<0.019		1.97	1.98		ug/L		100	70 - 130	6	20
Atrazine	<0.049		1.97	2.17		ug/L		110	70 - 130	7	20
Benz(a)anthracene	<0.049		1.97	2.28		ug/L		116	70 - 130	4	20
Benzo[a]pyrene	<0.019		1.97	2.54		ug/L		129	70 - 130	3	20
Benzo[b]fluoranthene	<0.019		1.97	2.48		ug/L		126	70 - 130	5	20
Benzo[g,h,i]perylene	<0.049		1.97	2.45		ug/L		125	70 - 130	0	20
Benzo[k]fluoranthene	<0.019		1.97	2.27		ug/L		115	70 - 130	3	20
beta-BHC	<0.097		1.97	2.17		ug/L		110	70 - 130	7	20
Bis(2-ethylhexyl) phthalate	<0.58		1.97	2.29		ug/L		116	70 - 130	4	20
Bromacil	<0.097		1.97	2.48		ug/L		126	70 - 130	3	20
Butachlor	<0.049	^3+	1.97	1.46		ug/L		74	70 - 130	1	20
Butylbenzylphthalate	<0.49		1.97	2.30		ug/L		117	70 - 130	4	20
Chlorobenzilate	<0.097		1.97	2.46		ug/L		125	70 - 130	2	20
Chloroneb	<0.097		1.97	2.08		ug/L		106	70 - 130	0	20
Chlorothalonil (Draconil, Bravo)	<0.097		1.97	2.25		ug/L		114	70 - 130	2	20
Chlorpyrifos	<0.049	^3+	1.97	2.01		ug/L		102	70 - 130	3	20
Chrysene	<0.019		1.97	2.13		ug/L		108	70 - 130	4	20
delta-BHC	<0.097		1.97	2.02		ug/L		103	70 - 130	2	20
Di(2-ethylhexyl)adipate	<0.58		1.97	2.18		ug/L		111	70 - 130	6	20
Dibenz(a,h)anthracene	<0.049		1.97	2.44		ug/L		124	70 - 130	1	20
Diclorvos (DDVP)	<0.049		1.97	2.38		ug/L		121	70 - 130	6	20
Dieldrin	<0.0097		1.97	2.13		ug/L		108	70 - 130	2	20
Diethylphthalate	<0.49		1.97	2.29		ug/L		112	70 - 130	3	20
Dimethylphthalate	<0.49		1.97	2.13		ug/L		108	70 - 130	2	20
Di-n-butyl phthalate	<0.97		3.94	3.75		ug/L		95	70 - 130	5	20
Di-n-octyl phthalate	<0.097		1.97	2.19		ug/L		111	70 - 130	4	20
Endosulfan I (Alpha)	<0.097		1.97	1.87		ug/L		95	70 - 130	5	20
Endosulfan II (Beta)	<0.097		1.97	1.96		ug/L		100	70 - 130	4	20
Endosulfan sulfate	<0.097		1.97	2.25		ug/L		114	70 - 130	3	20
Endrin	<0.0097		1.97	2.24		ug/L		114	70 - 130	1	20
Endrin aldehyde	<0.097		1.97	1.37		ug/L		70	60 - 130	2	20
EPTC	<0.097		1.97	2.12		ug/L		108	70 - 130	3	20

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-216945-B-4-B MSD

Client Sample ID: Matrix Spike Duplicate

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 231376

Prep Batch: 231139

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec	RPD	RPD
	Result	Qualifier	Added	Result	Qualifier				Limits		
Fluoranthene	<0.097		1.97	1.96		ug/L		100	70 - 130	1	20
Fluorene	<0.049		1.97	2.00		ug/L		101	70 - 130	4	20
gamma-Chlordane	<0.049	F1	1.97	1.28	F1	ug/L		65	70 - 130	8	20
Heptachlor	<0.0097		1.97	1.49		ug/L		76	70 - 130	1	20
Heptachlor epoxide (isomer B)	<0.0097	^3+	1.97	2.16		ug/L		110	70 - 130	4	20
Hexachlorobenzene	<0.049		1.97	1.80		ug/L		92	70 - 130	5	20
Hexachlorocyclopentadiene	<0.049		1.97	2.09		ug/L		106	70 - 130	11	20
Indeno[1,2,3-cd]pyrene	<0.049	F1	1.97	2.80	F1	ug/L		142	70 - 130	4	20
Isophorone	<0.097		1.97	2.10		ug/L		104	70 - 130	7	20
Lindane	<0.0097		1.97	2.32		ug/L		118	70 - 130	3	20
Malathion	<0.097		1.97	2.16		ug/L		110	70 - 130	4	20
Methoxychlor	<0.049	^3+	1.97	2.52		ug/L		128	70 - 130	6	20
Metolachlor	<0.049		1.97	2.13		ug/L		108	70 - 130	2	20
Molinate	<0.097		1.97	2.22		ug/L		113	70 - 130	5	20
Naphthalene	<0.097		1.97	1.91		ug/L		97	70 - 130	2	20
Parathion	<0.097	F1	1.97	2.60	F1	ug/L		132	70 - 130	4	20
Pendimethalin (Penoxaline)	<0.097		1.97	2.56		ug/L		130	70 - 130	4	20
Phenanthrene	<0.039		1.97	1.97		ug/L		100	70 - 130	4	20
Propachlor	<0.049	^3+	1.97	2.48		ug/L		126	70 - 130	8	20
Pyrene	<0.049		1.97	1.93		ug/L		98	70 - 130	2	20
Simazine	<0.049	^3+	1.97	2.08		ug/L		106	70 - 130	12	20
Terbacil	<0.097	F1	1.97	2.61	F1	ug/L		133	70 - 130	8	20
Terbutylazine	<0.097		1.97	2.20		ug/L		112	70 - 130	8	20
Thiobencarb	<0.097		1.97	2.07		ug/L		105	70 - 130	4	20
trans-Nonachlor	<0.049		1.97	2.10		ug/L		106	70 - 130	3	20
Trifluralin	<0.097	F1	1.97	2.66	F1	ug/L		135	70 - 130	5	20

Surrogate	MSD	MSD	Limits
	%Recovery	Qualifier	
2-Nitro-m-xylene	98		70 - 130
Perylene-d12	101		70 - 130
Triphenylphosphate	115		70 - 130

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 570-746664/1-A

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 749030

Prep Batch: 746664

Tentatively Identified Compound	MB	MB	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
	Est. Result	Qualifier							
Tentatively Identified Compound	None		ug/L			N/A	05/31/26 08:21	06/04/26 11:39	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
2,4,6-Tribromophenol (Surr)	106		33 - 139	05/31/26 08:21	06/04/26 11:39	1
2-Fluorobiphenyl (Surr)	89		33 - 126	05/31/26 08:21	06/04/26 11:39	1
2-Fluorophenol (Surr)	60		12 - 120	05/31/26 08:21	06/04/26 11:39	1
Nitrobenzene-d5 (Surr)	108		36 - 120	05/31/26 08:21	06/04/26 11:39	1
Phenol-d6 (Surr)	37		10 - 120	05/31/26 08:21	06/04/26 11:39	1
p-Terphenyl-d14 (Surr)	92		47 - 131	05/31/26 08:21	06/04/26 11:39	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: MB 570-746664/1-A
Matrix: Water
Analysis Batch: 748206

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 746664

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
2-Methylnaphthalene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Acenaphthene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Acenaphthylene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Anthracene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Benzo[a]anthracene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Benzo[a]pyrene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Benzo[b]fluoranthene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Benzo[g,h,i]perylene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Benzo[k]fluoranthene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Chrysene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Dibenz(a,h)anthracene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Fluoranthene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Fluorene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Naphthalene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Phenanthrene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1
Pyrene	<0.20		0.20	ug/L		05/31/26 08:21	06/03/26 07:55	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	85		28 - 127	05/31/26 08:21	06/03/26 07:55	1
2-Fluorobiphenyl (Surr)	83		31 - 120	05/31/26 08:21	06/03/26 07:55	1
2-Fluorophenol (Surr)	49		17 - 120	05/31/26 08:21	06/03/26 07:55	1
Nitrobenzene-d5 (Surr)	80		27 - 120	05/31/26 08:21	06/03/26 07:55	1
Phenol-d6 (Surr)	31		10 - 120	05/31/26 08:21	06/03/26 07:55	1
p-Terphenyl-d14 (Surr)	78		45 - 120	05/31/26 08:21	06/03/26 07:55	1

Lab Sample ID: LCS 570-746664/2-A
Matrix: Water
Analysis Batch: 748206

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 746664

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	20.0	13.7		ug/L		69	47 - 120
2-Methylnaphthalene	20.0	12.3		ug/L		61	43 - 120
Acenaphthene	20.0	15.6		ug/L		78	60 - 132
Acenaphthylene	20.0	15.5		ug/L		77	54 - 126
Anthracene	20.0	15.2		ug/L		76	43 - 120
Benzo[a]anthracene	20.0	14.3		ug/L		71	42 - 133
Benzo[a]pyrene	20.0	15.1		ug/L		75	32 - 148
Benzo[b]fluoranthene	20.0	14.1		ug/L		71	42 - 140
Benzo[g,h,i]perylene	20.0	13.9		ug/L		69	1 - 195
Benzo[k]fluoranthene	20.0	14.2		ug/L		71	25 - 146
Chrysene	20.0	13.5		ug/L		68	44 - 140
Dibenz(a,h)anthracene	20.0	15.2		ug/L		76	1 - 200
Fluoranthene	20.0	15.7		ug/L		78	43 - 121
Fluorene	20.0	15.7		ug/L		78	70 - 120
Indeno[1,2,3-cd]pyrene	20.0	14.6		ug/L		73	1 - 151
Naphthalene	20.0	12.9		ug/L		65	36 - 120

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCS 570-746664/2-A
Matrix: Water
Analysis Batch: 748206

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 746664

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Phenanthrene	20.0	15.2		ug/L		76	65 - 120
Pyrene	20.0	14.4		ug/L		72	70 - 120

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2,4,6-Tribromophenol (Surr)	73		28 - 127
2-Fluorobiphenyl (Surr)	75		31 - 120
2-Fluorophenol (Surr)	50		17 - 120
Nitrobenzene-d5 (Surr)	64		27 - 120
Phenol-d6 (Surr)	34		10 - 120
p-Terphenyl-d14 (Surr)	70		45 - 120

Lab Sample ID: LCSD 570-746664/3-A
Matrix: Water
Analysis Batch: 748206

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 746664

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene	20.0	13.0		ug/L		65	47 - 120	6	20
2-Methylnaphthalene	20.0	11.1		ug/L		56	43 - 120	10	20
Acenaphthene	20.0	15.2		ug/L		76	60 - 132	3	29
Acenaphthylene	20.0	14.9		ug/L		75	54 - 126	4	45
Anthracene	20.0	14.4		ug/L		72	43 - 120	5	40
Benzo[a]anthracene	20.0	15.4		ug/L		77	42 - 133	8	32
Benzo[a]pyrene	20.0	16.3		ug/L		82	32 - 148	8	43
Benzo[b]fluoranthene	20.0	15.6		ug/L		78	42 - 140	10	43
Benzo[g,h,i]perylene	20.0	15.7		ug/L		79	1 - 195	12	61
Benzo[k]fluoranthene	20.0	15.7		ug/L		79	25 - 146	10	38
Chrysene	20.0	15.1		ug/L		76	44 - 140	11	53
Dibenz(a,h)anthracene	20.0	17.0		ug/L		85	1 - 200	11	75
Fluoranthene	20.0	15.0		ug/L		75	43 - 121	4	40
Fluorene	20.0	15.2		ug/L		76	70 - 120	3	23
Indeno[1,2,3-cd]pyrene	20.0	16.0		ug/L		80	1 - 151	9	60
Naphthalene	20.0	11.9		ug/L		60	36 - 120	8	39
Phenanthrene	20.0	15.2		ug/L		76	65 - 120	0	24
Pyrene	20.0	15.6		ug/L		78	70 - 120	8	30

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
2,4,6-Tribromophenol (Surr)	69		28 - 127
2-Fluorobiphenyl (Surr)	72		31 - 120
2-Fluorophenol (Surr)	47		17 - 120
Nitrobenzene-d5 (Surr)	61		27 - 120
Phenol-d6 (Surr)	33		10 - 120
p-Terphenyl-d14 (Surr)	74		45 - 120

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: 380-216586-A-1-A MS
Matrix: Water
Analysis Batch: 748206

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 746664

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
1-Methylnaphthalene	<0.19		19.6	14.6		ug/L		74	36 - 120
2-Methylnaphthalene	<0.19		19.6	13.0		ug/L		66	32 - 124
Acenaphthene	<0.19		19.6	16.6		ug/L		85	47 - 145
Acenaphthylene	<0.19		19.6	16.5		ug/L		84	33 - 145
Anthracene	<0.19		19.6	15.4		ug/L		78	27 - 133
Benzo[a]anthracene	<0.19		19.6	16.3		ug/L		83	33 - 143
Benzo[a]pyrene	<0.19		19.6	17.7		ug/L		90	17 - 163
Benzo[b]fluoranthene	<0.19		19.6	16.6		ug/L		84	24 - 159
Benzo[g,h,i]perylene	<0.19		19.6	16.6		ug/L		85	1 - 219
Benzo[k]fluoranthene	<0.19		19.6	16.4		ug/L		84	11 - 162
Chrysene	<0.19		19.6	16.5		ug/L		84	17 - 168
Dibenz(a,h)anthracene	<0.19		19.6	17.8		ug/L		90	1 - 227
Fluoranthene	<0.19		19.6	16.2		ug/L		83	26 - 137
Fluorene	<0.19		19.6	16.9		ug/L		86	59 - 121
Indeno[1,2,3-cd]pyrene	<0.19		19.6	17.2		ug/L		88	1 - 171
Naphthalene	<0.19		19.6	13.6		ug/L		69	21 - 133
Phenanthrene	<0.19		19.6	16.5		ug/L		84	54 - 120
Pyrene	<0.19		19.6	17.1		ug/L		87	52 - 120

Surrogate	MS	MS	Limits
	%Recovery	Qualifier	
2,4,6-Tribromophenol (Surr)	80		28 - 127
2-Fluorobiphenyl (Surr)	79		31 - 120
2-Fluorophenol (Surr)	54		17 - 120
Nitrobenzene-d5 (Surr)	69		27 - 120
Phenol-d6 (Surr)	37		10 - 120
p-Terphenyl-d14 (Surr)	78		45 - 120

Lab Sample ID: 380-216586-A-1-B MSD
Matrix: Water
Analysis Batch: 748206

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 746664

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
	Result	Qualifier	Added	Result	Qualifier						
1-Methylnaphthalene	<0.19		19.6	14.8		ug/L		75	36 - 120	1	30
2-Methylnaphthalene	<0.19		19.6	13.1		ug/L		67	32 - 124	1	30
Acenaphthene	<0.19		19.6	16.6		ug/L		85	47 - 145	0	48
Acenaphthylene	<0.19		19.6	16.7		ug/L		85	33 - 145	1	74
Anthracene	<0.19		19.6	15.8		ug/L		81	27 - 133	3	66
Benzo[a]anthracene	<0.19		19.6	17.6		ug/L		90	33 - 143	8	53
Benzo[a]pyrene	<0.19		19.6	18.6		ug/L		95	17 - 163	5	72
Benzo[b]fluoranthene	<0.19		19.6	17.7		ug/L		90	24 - 159	7	71
Benzo[g,h,i]perylene	<0.19		19.6	17.3		ug/L		88	1 - 219	4	97
Benzo[k]fluoranthene	<0.19		19.6	17.5		ug/L		89	11 - 162	6	63
Chrysene	<0.19		19.6	16.8		ug/L		86	17 - 168	2	87
Dibenz(a,h)anthracene	<0.19		19.6	18.6		ug/L		95	1 - 227	4	126
Fluoranthene	<0.19		19.6	16.3		ug/L		83	26 - 137	0	66
Fluorene	<0.19		19.6	16.7		ug/L		85	59 - 121	1	38
Indeno[1,2,3-cd]pyrene	<0.19		19.6	17.7		ug/L		90	1 - 171	2	99
Naphthalene	<0.19		19.6	13.7		ug/L		70	21 - 133	0	65

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: 380-216586-A-1-B MSD
Matrix: Water
Analysis Batch: 748206

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 746664

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Phenanthrene	<0.19		19.6	17.1		ug/L		87	54 - 120	4	39
Pyrene	<0.19		19.6	18.1		ug/L		92	52 - 120	6	49
MSD MSD											
Surrogate	%Recovery	Qualifier	Limits								
2,4,6-Tribromophenol (Surr)	77		28 - 127								
2-Fluorobiphenyl (Surr)	83		31 - 120								
2-Fluorophenol (Surr)	57		17 - 120								
Nitrobenzene-d5 (Surr)	69		27 - 120								
Phenol-d6 (Surr)	39		10 - 120								
p-Terphenyl-d14 (Surr)	81		45 - 120								

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: MB 570-746997/6
Matrix: Water
Analysis Batch: 746997

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			06/01/26 12:16	1
MB MB								
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	104		38 - 134				06/01/26 12:16	1

Lab Sample ID: LCS 570-746997/3
Matrix: Water
Analysis Batch: 746997

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	400	400		ug/L		100	78 - 120
LCS LCS							
Surrogate	%Recovery	Qualifier	Limits				
4-Bromofluorobenzene (Surr)	99		38 - 134				

Lab Sample ID: LCSD 570-746997/4
Matrix: Water
Analysis Batch: 746997

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	400	385		ug/L		96	78 - 120	4	10
LCSD LCSD									
Surrogate	%Recovery	Qualifier	Limits						
4-Bromofluorobenzene (Surr)	101		38 - 134						

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Lab Sample ID: MRL 570-746997/5
Matrix: Water
Analysis Batch: 746997

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	10.0	11.7		ug/L		117	50 - 150
Surrogate		MRL %Recovery	MRL Qualifier				Limits
4-Bromofluorobenzene (Surr)		104					38 - 134

Lab Sample ID: 380-215428-B-1 MS
Matrix: Water
Analysis Batch: 746997

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	<10		400	360		ug/L		90	68 - 122
Surrogate		MS %Recovery		MS Qualifier					Limits
4-Bromofluorobenzene (Surr)		99							38 - 134

Lab Sample ID: 380-215428-B-1 MSD
Matrix: Water
Analysis Batch: 746997

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	325		ug/L		81	68 - 122	10	18
Surrogate		MSD %Recovery		MSD Qualifier					Limits		
4-Bromofluorobenzene (Surr)		101							38 - 134		

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Lab Sample ID: MB 570-747016/1-A
Matrix: Water
Analysis Batch: 750788

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 747016

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25	ug/L		06/01/26 09:03	06/08/26 11:46	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		06/01/26 09:03	06/08/26 11:46	1
C8-C18	<25		25	ug/L		06/01/26 09:03	06/08/26 11:46	1
Surrogate		MB %Recovery	MB Qualifier			Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)		103				06/01/26 09:03	06/08/26 11:46	1

Lab Sample ID: LCS 570-747016/2-A
Matrix: Water
Analysis Batch: 750788

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 747016

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
C10-C28	1600	1720		ug/L		108	56 - 127

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

Lab Sample ID: LCS 570-747016/2-A
Matrix: Water
Analysis Batch: 750788

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 747016

	LCS %Recovery	LCS Qualifier	Limits
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>	108		60 - 130

Lab Sample ID: LCSD 570-747016/3-A
Matrix: Water
Analysis Batch: 750788

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 747016

	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	Limit
Analyte C10-C28	1600	1680		ug/L		105	56 - 127	2	23
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>									
	LCSD %Recovery	LCSD Qualifier							
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>	109								

Lab Sample ID: MRL 570-747016/4-A
Matrix: Water
Analysis Batch: 750788

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 747016

	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
Analyte C10-C28	0.0200	0.0311	^3+	mg/L		156	50 - 150		
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>									
	MRL %Recovery	MRL Qualifier							
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>	98								

Lab Sample ID: 380-216586-C-1-A MS
Matrix: Water
Analysis Batch: 750788

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 747016

	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Analyte C10-C28	<25	^3+	1650	1800		ug/L		109	70 - 130		
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>											
	MS %Recovery	MS Qualifier									
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>	110										

Lab Sample ID: 380-216586-C-1-B MSD
Matrix: Water
Analysis Batch: 750788

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 747016

	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	Limit
Analyte C10-C28	<25	^3+	1660	1720		ug/L		104	70 - 130	5	20
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>											
	MSD %Recovery	MSD Qualifier									
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>	102										

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

GC/MS Semi VOA

Prep Batch: 231139

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-216582-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	525.2	
MB 380-231139/21-A	Method Blank	Total/NA	Water	525.2	
LCS 380-231139/23-A	Lab Control Sample	Total/NA	Water	525.2	
MRL 380-231139/22-A	Lab Control Sample	Total/NA	Water	525.2	
380-216945-B-4-A MS	Matrix Spike	Total/NA	Water	525.2	
380-216945-B-4-B MSD	Matrix Spike Duplicate	Total/NA	Water	525.2	

Analysis Batch: 231376

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-216582-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	525.2	231139
MB 380-231139/21-A	Method Blank	Total/NA	Water	525.2	231139
LCS 380-231139/23-A	Lab Control Sample	Total/NA	Water	525.2	231139
MRL 380-231139/22-A	Lab Control Sample	Total/NA	Water	525.2	231139
380-216945-B-4-A MS	Matrix Spike	Total/NA	Water	525.2	231139
380-216945-B-4-B MSD	Matrix Spike Duplicate	Total/NA	Water	525.2	231139

Prep Batch: 746664

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-216582-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	625.1	
MB 570-746664/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-746664/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-746664/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	
380-216586-A-1-A MS	Matrix Spike	Total/NA	Water	625.1	
380-216586-A-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	625.1	

Analysis Batch: 748206

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-216582-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	625.1 SIM	746664
MB 570-746664/1-A	Method Blank	Total/NA	Water	625.1 SIM	746664
LCS 570-746664/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	746664
LCSD 570-746664/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	746664
380-216586-A-1-A MS	Matrix Spike	Total/NA	Water	625.1 SIM	746664
380-216586-A-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	625.1 SIM	746664

Analysis Batch: 749030

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-216582-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	625.1	746664
MB 570-746664/1-A	Method Blank	Total/NA	Water	625.1	746664

GC VOA

Analysis Batch: 746997

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-216582-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	8015B GRO LL	
380-216582-2	TB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	8015B GRO LL	
MB 570-746997/6	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-746997/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-746997/4	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-746997/5	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-215428-B-1 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-215428-B-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

Eurofins Pomona

QC Association Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-216582-1
 SDG: Weekly: Moanalua Wells

GC Semi VOA

Prep Batch: 747016

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-216582-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	3510C	
MB 570-747016/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-747016/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-747016/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-747016/4-A	Lab Control Sample	Total/NA	Water	3510C	
380-216586-C-1-A MS	Matrix Spike	Total/NA	Water	3510C	
380-216586-C-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	3510C	

Analysis Batch: 750788

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-216582-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	8015B	747016
MB 570-747016/1-A	Method Blank	Total/NA	Water	8015B	747016
LCS 570-747016/2-A	Lab Control Sample	Total/NA	Water	8015B	747016
LCSD 570-747016/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	747016
MRL 570-747016/4-A	Lab Control Sample	Total/NA	Water	8015B	747016
380-216586-C-1-A MS	Matrix Spike	Total/NA	Water	8015B	747016
380-216586-C-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	8015B	747016



Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-216582-1

Date Collected: 05/26/26 09:53

Matrix: Drinking Water

Date Received: 05/28/26 10:10

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			231139	IQ42	EA POM	06/02/26 15:52
Total/NA	Analysis	525.2		1	231376	UPAC	EA POM	06/03/26 18:34
Total/NA	Prep	625.1			746664	KLZQ	EET CAL 4	05/31/26 08:21
Total/NA	Analysis	625.1		1	749030	PQS1	EET CAL 4	06/04/26 12:03
Total/NA	Prep	625.1			746664	KLZQ	EET CAL 4	05/31/26 08:21
Total/NA	Analysis	625.1 SIM		1	748206	PQS1	EET CAL 4	06/03/26 12:16
Total/NA	Analysis	8015B GRO LL		1	746997	A9VE	EET CAL 4	06/01/26 16:35
Total/NA	Prep	3510C			747016	TVD6	EET CAL 4	06/01/26 09:04
Total/NA	Analysis	8015B		1	750788	NR	EET CAL 4	06/08/26 13:33

Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-216582-2

Date Collected: 05/26/26 09:53

Matrix: Water

Date Received: 05/28/26 10:10

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	746997	A9VE	EET CAL 4	06/01/26 20:37

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Laboratory: Eurofins Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *
The following analytes are included in this report, but the laboratory is not certified by Hawaii State CA00006. This list may include analytes for which the agency does not offer certification:			
Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Drinking Water	1-Methylnaphthalene
525.2	525.2	Drinking Water	2,4'-DDD
525.2	525.2	Drinking Water	2,4'-DDE
525.2	525.2	Drinking Water	2,4'-DDT
525.2	525.2	Drinking Water	2,4-Dinitrotoluene
525.2	525.2	Drinking Water	2,6-Dinitrotoluene
525.2	525.2	Drinking Water	2-Methylnaphthalene
525.2	525.2	Drinking Water	4,4'-DDD
525.2	525.2	Drinking Water	4,4'-DDE
525.2	525.2	Drinking Water	4,4'-DDT
525.2	525.2	Drinking Water	Acetochlor
525.2	525.2	Drinking Water	alpha-BHC
525.2	525.2	Drinking Water	alpha-Chlordane
525.2	525.2	Drinking Water	beta-BHC
525.2	525.2	Drinking Water	Chlorobenzilate
525.2	525.2	Drinking Water	Chloroneb
525.2	525.2	Drinking Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Drinking Water	Chlorpyrifos
525.2	525.2	Drinking Water	delta-BHC
525.2	525.2	Drinking Water	Diclorvos (DDVP)
525.2	525.2	Drinking Water	Endosulfan I (Alpha)
525.2	525.2	Drinking Water	Endosulfan II (Beta)
525.2	525.2	Drinking Water	Endosulfan sulfate
525.2	525.2	Drinking Water	Endrin aldehyde
525.2	525.2	Drinking Water	EPTC
525.2	525.2	Drinking Water	gamma-Chlordane
525.2	525.2	Drinking Water	Isophorone
525.2	525.2	Drinking Water	Malathion
525.2	525.2	Drinking Water	Parathion
525.2	525.2	Drinking Water	Pendimethalin (Penoxaline)
525.2	525.2	Drinking Water	Terbacil
525.2	525.2	Drinking Water	Terbutylazine
525.2	525.2	Drinking Water	Total Permethrin (mixed isomers)
525.2	525.2	Drinking Water	trans-Nonachlor

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	7296.01	11-30-26
A2LA	ISO/IEC 17025	7296.01	11-30-26
Alaska (UST)	State	25-005	03-02-27
Arizona	State	AZ0830	11-17-26
California	Los Angeles County Sanitation Districts	9257304	07-31-26
California	SCAQMD LAP	17LA0919	11-30-26

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Eurofins Pomona

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Laboratory: Eurofins Calscience (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
California	State	3082	07-31-26
Kansas	NELAP	E-10420	07-31-26
Nevada	State	CA00111	07-31-26
Oregon	NELAP	4175	02-02-27
USDA	US Federal Programs	525-23-159-97150	09-30-26
Utah	NELAP	CA00111	02-28-27
Washington	State	C916	10-12-26

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Method	Method Description	Protocol	Laboratory
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA POM
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
525.2	Extraction of Semivolatile Compounds	EPA	EA POM
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-216582-1
SDG: Weekly: Moanalua Wells

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-216582-1	MOANALUA WELLS (331-223-TP202)	Drinking Water	05/26/26 09:53	05/28/26 10:10	HI0000331
380-216582-2	TB: MOANALUA WELLS (331-223-TP202)	Water	05/26/26 09:53	05/28/26 10:10	

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

ORIGIN ID HIKA (808) 748-5840
BWS CHEMLAB
HONOLULU BOARD OF WATER SUPPLY
630 S. BERETANIA ST
CHEMICAL LABORATORY
HONOLULU HI 96843
UNITED STATES US

SHIP DATE: 27MAY26
ACTWGT 62.00 LB
CAD 258050552INET4535

BILL RECIPIENT

TO **EUROFINS RECEIVING DEPARTMENT**
EUROFINS DRINKING WATER TESTING
941 CORPORATE CENTER DR

POMONA CA 91768

(626) 386-1100 REF
INV. PO. DEPT.



THU - 28 MAY 10:30A
PRIORITY OVERNIGHT

4 of 6

MPS# 8723 0837 5588


0263 Mstr# 8723 0837 5555

WM ONTA

91768

CA-US

ONT



(631A) 9-840-0 5-8 gel frozen
Mantle Vaccination 5/28/26 1010

After printing this label
1 Fold the printed page along the horizontal line
2 Place label in shipping pouch and affix it to your shipment

68KJ3VA906/494B

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Client Information		Sampler: bailey	Lab P/N: Lopez, Maria	Carrier Tracking No(s):	COC No:
Client Contact: Kirk Iwamoto		Phone: +1 808 748 5840	E-Mail: Maria.Lopez@et-eurofins.com	State of Origin:	Page: 1 of 1
Company: City & County of Honolulu		PWSID:		Job #:	
Address: 630 South Beretania Street Chemistry Lab		Due Date Requested:		Analysis Requested	
City: Honolulu		TAT Requested (days):		533 - All Analytes	
State, Zip: HI, 96843		Compliance Project: <input type="checkbox"/> Yes <input type="checkbox"/> No		537.1_DW_PREC - 537.1 Full List	
Phone: 808-748-5840 (Tel)		PO #: C20525101 exp 05312023		525.2_PREC - (MOD) 525plus Plus TICA	
Email: kiwamoto@hbws.org		WO #:		5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
Project Name: RED-HILL/HBWS Sites Event Desc: RUSH Weekly Red Hill		Project #: 38001111		5015B_GRO_LL - (MOD) GRO	
Site: Hawaii		SSOW#:		525.1_525.1_8IM	
		Sample Date		R	
		Sample Time		2 3 2 1	
		Sample Type (C=Comp, G=grab)		QA Y I	
		Matrix (Water, Solid, Other)		533 - All Analytes	
Sample Identification		Sample Date		537.1_DW_PREC - 537.1 Full List	
Moanalua Wells (331-223-TP202)		26-May-2026		525.2_PREC - (MOD) 525plus Plus TICA	
Moanalua Wells (331-223-TP202) (Matrix Spike)		0953		5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
Moanalua Wells (331-223-TP202) (Matrix Spike Duplicate)		0953		5015B_GRO_LL - (MOD) GRO	
TB: Moanalua Wells (331-223-TP202)		0953		525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525.2_PREC - (MOD) 525plus Plus TICA	
				5015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/C8-C18	
				5015B_GRO_LL - (MOD) GRO	
				525.1_525.1_8IM	
				Perform MMSD (Yes or No)	
				Field Filtered Sample (Yes or No)	
				RA Q	
				2 3 2 1	
				QA Y I	
				533 - All Analytes	
				537.1_DW_PREC - 537.1 Full List	
				525	

ORIGIN ID:HIKA (808) 748-5840
BWS CHEMLAB
HONOLULU BOARD OF WATER SUPPLY
630 S. BERETANIA ST
CHEMICAL LABORATORY
HONOLULU, HI 96843
UNITED STATES US

SHIP DATE: 27MAY26
ACTWGT: 62.00 LB
CAD: 25805052/INET4555



BILL RECIPIENT

TO EUROFINS RECEIVING DEPARTMENT
EUROFINS DRINKING WATER TESTING
941 CORPORATE CENTER DR

POMONA CA 91768 REF
(626) 386-1700

58K13/A906/A94B

PC: DEPT: 02001




2261028012001INV

5 of 6
MPS# 8723 0837 5599
Mstr# 8723 0837 5555

THU - 28 MAY 10:30A
PRIORITY OVERNIGHT

WM ONTA CA-US 91768 ONT




(631A) 505050 761-100207
JOURNAL Markkuration 5/21/26 1003

After printing this label
CONSIGNEE COPY - PLEASE PLACE IN FRONT OF POUCH
1 Fold the printed page along the horizontal line
2 Place label in shipping pouch and affix it to your shipment

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Chain of Custody Record



Client Information (Sub Contract Lab)		Sampler: N/A	Lab PM: Lopez, Maria	Carrier Tracking No(s): N/A	COC No: 380-339922.1										
Client Contact: Shipping/Receiving		Phone: N/A	E-Mail: Maria.Lopez@et.eurofinsus.com	State of Origin: Hawaii	Page: Page 1 of 1										
Company: Eurofins Environment Testing Southwest L			Accreditations Required (See note): State - Hawaii		Job #: 380-216582-1										
Address: 2841 Dow Avenue, Suite 100, City: Tustin State, Zip: CA, 92780 Phone: 714-895-5494(Tel) Email: N/A Project Name: RED-HILL Site: Honolulu BWS Sites		Due Date Requested: 6/10/2026 TAT Requested (days): N/A PO #: N/A WO #: N/A Project #: 38001111 SSOW#: N/A	Analysis Requested			Preservation Codes: Other: N/A									
Sample Identification - Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=organic, L=oil, T=tissue, A=air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	625_1_SLM625_Prep(MOD) Extended PAH List	625_1625_Precip(MOD) Tentatively Identified Compounds (Hold)	8016B_DIRO_LL_CS3510C_LLHML_Ranges: C10-C24/C24-C36/C8-C18	8016B_GRO_LL1603C(MOD) GRO	Total Number of Containers	Special Instructions/Note:		
MOANALUA WELLS (331-223-TP202) (380-216582-1)		5/26/26	09:53 Hawaiian	G	Water			X	X	X	X	0	MRLs are needed. Confirm any hits >RL.		
TB: MOANALUA WELLS (331-223-TP202) (380-216582-2)		5/26/26	09:53 Hawaiian	G	Water						X	2	MRLs are needed. Confirm any hits >RL.		
 380-216582 Chain of Custody															
<p>Note: Since laboratory accreditations are subject to change, Eurofins Drinking Water and Wastewater West, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Drinking Water and Wastewater West, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Drinking Water and Wastewater West, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Drinking Water and Wastewater West, LLC.</p>															
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)									
Unconfirmed						<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months									
Deliverable Requested: I, II, III, IV, Other (specify)						Primary Deliverable Rank: 2		Special Instructions/QC Requirements:							
Empty Kit Relinquished by:				Date:		Time:		Method of Shipment:							
Relinquished by: <i>Maria Lopez</i>				Date/Time: <i>5/29/26 15:30</i>		Company: <i>EEAD</i>		Received by: <i>John C. Pocala</i>				Date/Time: <i>5/29/26 15:30</i>		Company: <i>WP</i>	
Relinquished by: <i>John C. Pocala</i>				Date/Time: <i>5/29/26 17:30</i>		Company: <i>WP</i>		Received by: <i>[Signature]</i>				Date/Time: <i>5/29/26 17:30</i>		Company: <i>WP</i>	
Relinquished by:				Date/Time:		Company:		Received by:				Date/Time:		Company:	
Custody Seals Intact: Δ Yes Δ No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: <i>1.8 / 1.9 IR-4</i>											



Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-216582-1
SDG Number: Weekly: Moanalua Wells

Login Number: 216582

List Number: 1

Creator: Tran, Kristine

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	



Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-216582-1
SDG Number: Weekly: Moanalua Wells

Login Number: 216582

List Number: 2

Creator: Khana, Piyush

List Source: Eurofins Calscience

List Creation: 05/29/26 03:36 PM

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	1.4
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <math><6\text{mm}</math> (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-216582-1
SDG Number: Weekly: Moanalua Wells

Login Number: 216582

List Number: 3

Creator: Khana, Piyush

List Source: Eurofins Calscience

List Creation: 05/29/26 07:14 PM

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	1.9
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <math><6\text{mm}</math> (1/4").	True	fgf5
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	