

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 5/22/2026 6:23:10 PM

JOB DESCRIPTION

RED-HILL
PFAS: Aiea Gulch Wells Pump 2

JOB NUMBER

380-213694-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
5/22/2026 6:23:10 PM



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	15
QC Association Summary	26
Lab Chronicle	27
Certification Summary	28
Method Summary	29
Sample Summary	30
Chain of Custody	31
Receipt Checklists	32

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Qualifiers

LCMS

Qualifier	Qualifier Description
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-213694-1

Job ID: 380-213694-1

Eurofins Pomona

Job Narrative 380-213694-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 5/13/2026 9:28 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 2.6°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)
PWSID Number: HI0000331

Lab Sample ID: 380-213694-1

No Detections.

Client Sample ID: FB: AIEA GULCH WELLS PUMP 2
(331-202-TP072)
PWSID Number: HI0000331

Lab Sample ID: 380-213694-2

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

This Detection Summary does not include radiochemical test results.

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-213694-1

Date Collected: 05/11/26 10:56

Matrix: Drinking Water

Date Received: 05/13/26 09:28

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:30	1
Isotope Dilution	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	90		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C6 PFDA	97		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C5 PFHxA	99		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C4 PFHpA	101		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C8 PFOA	103		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C9 PFNA	104		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C7 PFUnA	97		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C2 PFDoA	95		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C4 PFBA	114		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C5 PFPeA	113		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C3 PFBS	111		50 - 200			05/21/26 06:02	05/21/26 17:30	1
13C3 PFHxS	109		50 - 200			05/21/26 06:02	05/21/26 17:30	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-213694-1

Date Collected: 05/11/26 10:56

Matrix: Drinking Water

Date Received: 05/13/26 09:28

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	111		50 - 200	05/21/26 06:02	05/21/26 17:30	1
13C2-4:2-FTS	121		50 - 200	05/21/26 06:02	05/21/26 17:30	1
13C2-6:2-FTS	111		50 - 200	05/21/26 06:02	05/21/26 17:30	1
13C2-8:2-FTS	110		50 - 200	05/21/26 06:02	05/21/26 17:30	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:41	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	121		70 - 130	05/16/26 11:15	05/18/26 07:41	1
13C2 PFHxA	112		70 - 130	05/16/26 11:15	05/18/26 07:41	1
13C2 PFDA	116		70 - 130	05/16/26 11:15	05/18/26 07:41	1
13C3-GenX	114		70 - 130	05/16/26 11:15	05/18/26 07:41	1

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-213694-2

Date Collected: 05/11/26 10:56

Matrix: Water

Date Received: 05/13/26 09:28

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-213694-2

Date Collected: 05/11/26 10:56

Matrix: Water

Date Received: 05/13/26 09:28

PWSID Number: HI0000331

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		05/21/26 06:02	05/21/26 17:39	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	93		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C6 PFDA	98		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C5 PFHxA	103		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C4 PFHpA	104		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C8 PFOA	105		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C9 PFNA	104		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C7 PFUnA	98		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C2 PFDoA	101		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C4 PFBA	118		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C5 PFPeA	123		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C3 PFBS	119		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C3 PFHxS	115		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C8 PFOS	115		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C2-4:2-FTS	128		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C2-6:2-FTS	116		50 - 200	05/21/26 06:02	05/21/26 17:39	1
13C2-8:2-FTS	114		50 - 200	05/21/26 06:02	05/21/26 17:39	1

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-213694-2

Date Collected: 05/11/26 10:56

Matrix: Water

Date Received: 05/13/26 09:28

PWSID Number: HI0000331

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
N-methylperfluorooctanesulfonamide cetic acid (NMeFOSAA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
N-ethylperfluorooctanesulfonamide cetic acid (NEtFOSAA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		05/16/26 11:15	05/18/26 07:50	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	106		70 - 130			05/16/26 11:15	05/18/26 07:50	1
13C2 PFHxA	105		70 - 130			05/16/26 11:15	05/18/26 07:50	1
13C2 PFDA	112		70 - 130			05/16/26 11:15	05/18/26 07:50	1
13C3-GenX	92		70 - 130			05/16/26 11:15	05/18/26 07:50	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)
PWSID Number: HI0000331

Lab Sample ID: 380-213694-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB: AIEA GULCH WELLS PUMP 2
(331-202-TP072)
PWSID Number: HI0000331

Lab Sample ID: 380-213694-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-213694-1	AIEA GULCH WELLS PUMP 2 (331	121	112	116	114
Surrogate Legend					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-213692-E-1-A MS	Matrix Spike	110	115	126	129
380-213692-F-1-A MSD	Matrix Spike Duplicate	107	98	113	122
380-213694-2	FB: AIEA GULCH WELLS PUMP 2 (331-202-TP072)	106	105	112	92
LCS 380-227532/23-A	Lab Control Sample	111	121	120	123
MBL 380-227532/21-A	Method Blank	110	116	122	110
MRL 380-227532/22-A	Lab Control Sample	118	117	118	118
Surrogate Legend					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)							
		HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-213694-1	AIEA GULCH WELLS PUMP 2 (331	90	97	99	101	103	104	97	95

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)							
		PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-213694-1	AIEA GULCH WELLS PUMP 2 (331	114	113	111	109	111	121	111	110

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDaA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)							
		HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-213694-2	FB: AIEA GULCH WELLS PUMP 2 (93	98	103	104	105	104	98	101
380-213796-B-7-A MS	Matrix Spike	72	73	78	76	77	76	75	78
380-213796-B-7-B MSD	Matrix Spike Duplicate	78	73	82	81	79	75	70	76
LCS 380-228574/22-A	Lab Control Sample	99	112	106	106	108	108	107	109
MBL 380-228574/20-A	Method Blank	89	100	98	103	102	104	96	97
MRL 380-228574/21-A	Lab Control Sample	84	100	97	102	102	107	102	100

Lab Sample ID	Client Sample ID	Percent Isotope Dilution Recovery (Acceptance Limits)							
		PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-213694-2	FB: AIEA GULCH WELLS PUMP 2 (118	123	119	115	115	128	116	114
380-213796-B-7-A MS	Matrix Spike	87	84	112	107	109	118	112	114
380-213796-B-7-B MSD	Matrix Spike Duplicate	93	89	111	110	111	122	115	114
LCS 380-228574/22-A	Lab Control Sample	121	117	116	114	115	126	127	122
MBL 380-228574/20-A	Method Blank	111	114	111	105	111	125	111	112
MRL 380-228574/21-A	Lab Control Sample	107	111	114	111	116	123	116	113

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA

Isotope Dilution Summary

Client: City & County of Honolulu

Project/Site: RED-HILL

C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDoA = 13C2 PFDoA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-228574/20-A
Matrix: Water
Analysis Batch: 228751

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 228574

Analyte	MBL	MBL	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.48		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.25		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		05/21/26 06:02	05/21/26 15:54	1

Isotope Dilution	MBL	MBL	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C3 HFPO-DA	89		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C6 PFDA	100		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C5 PFHxA	98		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C4 PFHpA	103		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C8 PFOA	102		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C9 PFNA	104		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C7 PFUnA	96		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C2 PFDoA	97		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C4 PFBA	111		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C5 PFPeA	114		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C3 PFBS	111		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C3 PFHxS	105		50 - 200	05/21/26 06:02	05/21/26 15:54	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-228574/20-A
Matrix: Water
Analysis Batch: 228751

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 228574

<i>Isotope Dilution</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	<i>%Recovery</i>	<i>Qualifier</i>				
13C8 PFOS	111		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C2-4:2-FTS	125		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C2-6:2-FTS	111		50 - 200	05/21/26 06:02	05/21/26 15:54	1
13C2-8:2-FTS	112		50 - 200	05/21/26 06:02	05/21/26 15:54	1

Lab Sample ID: LCS 380-228574/22-A
Matrix: Water
Analysis Batch: 228751

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 228574

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>			<i>Limits</i>	
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	120	103		ng/L		85	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	120	105		ng/L		87	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	120	102		ng/L		84	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	120	104		ng/L		86	70 - 130
Perfluorobutanesulfonic acid (PFBS)	120	112		ng/L		93	70 - 130
Perfluorodecanoic acid (PFDA)	120	100		ng/L		83	70 - 130
Perfluorododecanoic acid (PFDoA)	120	107		ng/L		88	70 - 130
Perfluoroheptanoic acid (PFHpA)	120	105		ng/L		87	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	120	106		ng/L		88	70 - 130
Perfluorohexanoic acid (PFHxA)	120	103		ng/L		85	70 - 130
Perfluorononanoic acid (PFNA)	120	111		ng/L		92	70 - 130
Perfluorooctanesulfonic acid (PFOS)	120	106		ng/L		88	70 - 130
Perfluorooctanoic acid (PFOA)	120	102		ng/L		85	70 - 130
Perfluoroundecanoic acid (PFUnA)	120	102		ng/L		84	70 - 130
Perfluorobutanoic acid (PFBA)	120	101		ng/L		84	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	120	102		ng/L		85	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	120	104		ng/L		86	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	120	94.8		ng/L		79	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	120	99.1		ng/L		82	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	120	112		ng/L		93	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	120	97.3		ng/L		81	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	120	97.8		ng/L		81	70 - 130
Perfluoropentanoic acid (PFPeA)	120	104		ng/L		87	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	120	111		ng/L		92	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-228574/22-A
Matrix: Water
Analysis Batch: 228751

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 228574

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	
Perfluoropentanesulfonic acid (PFPeS)	120	106		ng/L		88	70 - 130	
LCS LCS								
Isotope Dilution	%Recovery	Qualifier						Limits
13C3 HFPO-DA	99							50 - 200
13C6 PFDA	112							50 - 200
13C5 PFHxA	106							50 - 200
13C4 PFHpA	106							50 - 200
13C8 PFOA	108							50 - 200
13C9 PFNA	108							50 - 200
13C7 PFUnA	107							50 - 200
13C2 PFDoA	109							50 - 200
13C4 PFBA	121							50 - 200
13C5 PFPeA	117							50 - 200
13C3 PFBS	116							50 - 200
13C3 PFHxS	114							50 - 200
13C8 PFOS	115							50 - 200
13C2-4:2-FTS	126							50 - 200
13C2-6:2-FTS	127							50 - 200
13C2-8:2-FTS	122							50 - 200

Lab Sample ID: MRL 380-228574/21-A
Matrix: Water
Analysis Batch: 228751

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 228574

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.65	J	ng/L		82	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	1.63	J	ng/L		81	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.69	J	ng/L		84	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	1.90	J	ng/L		95	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	1.88	J	ng/L		94	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	1.80	J	ng/L		90	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	2.09	J	ng/L		104	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	1.87	J	ng/L		93	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	1.86	J	ng/L		93	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	1.76	J	ng/L		88	50 - 150
Perfluorononanoic acid (PFNA)	2.01	1.81	J	ng/L		90	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	1.83	J	ng/L		91	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	1.83	J	ng/L		91	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	1.92	J	ng/L		95	50 - 150
Perfluorobutanoic acid (PFBA)	2.01	1.88	J	ng/L		94	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-228574/21-A

Matrix: Water

Analysis Batch: 228751

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 228574

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.01	2.02	J	ng/L		100	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.01	2.04	J	ng/L		102	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.01	1.99	J	ng/L		99	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.01	1.51	J	ng/L		75	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.01	1.76	J	ng/L		88	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.01	1.84	J	ng/L		91	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.01	1.68	J	ng/L		84	50 - 150
Perfluoropentanoic acid (PFPeA)	2.01	1.81	J	ng/L		90	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.01	1.82	J	ng/L		91	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.01	1.81	J	ng/L		90	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	84		50 - 200
13C6 PFDA	100		50 - 200
13C5 PFHxA	97		50 - 200
13C4 PFHpA	102		50 - 200
13C8 PFOA	102		50 - 200
13C9 PFNA	107		50 - 200
13C7 PFUnA	102		50 - 200
13C2 PFDoA	100		50 - 200
13C4 PFBA	107		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	114		50 - 200
13C3 PFHxS	111		50 - 200
13C8 PFOS	116		50 - 200
13C2-4:2-FTS	123		50 - 200
13C2-6:2-FTS	116		50 - 200
13C2-8:2-FTS	113		50 - 200

Lab Sample ID: 380-213796-B-7-A MS

Matrix: Water

Analysis Batch: 228751

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 228574

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		121	103		ng/L		85	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		121	104		ng/L		86	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		121	107		ng/L		88	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-213796-B-7-A MS

Client Sample ID: Matrix Spike

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 228751

Prep Batch: 228574

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
Hexafluoropropylene Oxide	<2.0		121	110		ng/L		91	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		121	108		ng/L		89	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		121	108		ng/L		90	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0	*5-	121	108		ng/L		89	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		121	111		ng/L		92	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		121	108		ng/L		89	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		121	108		ng/L		89	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		121	118		ng/L		98	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		121	108		ng/L		89	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		121	106		ng/L		88	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0	*5-	121	110		ng/L		91	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		121	109		ng/L		89	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		121	108		ng/L		89	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		121	110		ng/L		91	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		121	104		ng/L		86	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		121	102		ng/L		84	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		121	108		ng/L		90	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		121	103		ng/L		85	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		121	109		ng/L		90	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		121	109		ng/L		91	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		121	111		ng/L		92	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		121	107		ng/L		89	70 - 130

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	72		50 - 200
13C6 PFDA	73		50 - 200
13C5 PFHxA	78		50 - 200
13C4 PFHpA	76		50 - 200
13C8 PFOA	77		50 - 200
13C9 PFNA	76		50 - 200
13C7 PFUnA	75		50 - 200
13C2 PFDoA	78		50 - 200
13C4 PFBA	87		50 - 200
13C5 PFPeA	84		50 - 200
13C3 PFBS	112		50 - 200
13C3 PFHxS	107		50 - 200
13C8 PFOS	109		50 - 200

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-213796-B-7-A MS
Matrix: Water
Analysis Batch: 228751

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 228574

<i>Isotope Dilution</i>	<i>MS MS</i>	<i>Limits</i>
	%Recovery	Qualifier
13C2-4:2-FTS	118	50 - 200
13C2-6:2-FTS	112	50 - 200
13C2-8:2-FTS	114	50 - 200

Lab Sample ID: 380-213796-B-7-B MSD
Matrix: Water
Analysis Batch: 228751

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 228574

Analyte	Sample	Sample	Spike	MSD		Unit	D	%Rec	%Rec	Limits	RPD	RPD	Limit
	Result	Qualifier		Added	Result								
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	102		ng/L		85	70 - 130	0		30	
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	104		ng/L		86	70 - 130	1		30	
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	105		ng/L		88	70 - 130	1		30	
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		120	106		ng/L		88	70 - 130	3		30	
Perfluorobutanesulfonic acid (PFBS)	<2.0		120	111		ng/L		92	70 - 130	3		30	
Perfluorodecanoic acid (PFDA)	<2.0		120	106		ng/L		88	70 - 130	2		30	
Perfluorododecanoic acid (PFDoA)	<2.0	*5-	120	113		ng/L		94	70 - 130	4		30	
Perfluoroheptanoic acid (PFHpA)	<2.0		120	107		ng/L		89	70 - 130	4		30	
Perfluorohexanesulfonic acid (PFHxS)	<2.0		120	109		ng/L		90	70 - 130	1		30	
Perfluorohexanoic acid (PFHxA)	<2.0		120	106		ng/L		88	70 - 130	2		30	
Perfluorononanoic acid (PFNA)	<2.0		120	119		ng/L		99	70 - 130	1		30	
Perfluorooctanesulfonic acid (PFOS)	<2.0		120	110		ng/L		91	70 - 130	2		30	
Perfluorooctanoic acid (PFOA)	<2.0		120	107		ng/L		89	70 - 130	1		30	
Perfluoroundecanoic acid (PFUnA)	<2.0	*5-	120	108		ng/L		89	70 - 130	2		30	
Perfluorobutanoic acid (PFBA)	<2.0		120	107		ng/L		89	70 - 130	1		30	
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	108		ng/L		90	70 - 130	1		30	
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	107		ng/L		89	70 - 130	2		30	
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	107		ng/L		89	70 - 130	3		30	
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	109		ng/L		91	70 - 130	7		30	
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		120	113		ng/L		93	70 - 130	4		30	
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	104		ng/L		86	70 - 130	1		30	
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	107		ng/L		89	70 - 130	2		30	
Perfluoropentanoic acid (PFPeA)	<2.0		120	112		ng/L		93	70 - 130	2		30	
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	113		ng/L		94	70 - 130	2		30	
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	111		ng/L		92	70 - 130	4		30	

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	78		50 - 200
13C6 PFDA	73		50 - 200
13C5 PFHxA	82		50 - 200
13C4 PFHpA	81		50 - 200
13C8 PFOA	79		50 - 200
13C9 PFNA	75		50 - 200
13C7 PFUnA	70		50 - 200
13C2 PFDoA	76		50 - 200
13C4 PFBA	93		50 - 200
13C5 PFPeA	89		50 - 200
13C3 PFBS	111		50 - 200
13C3 PFHxS	110		50 - 200
13C8 PFOS	111		50 - 200
13C2-4:2-FTS	122		50 - 200
13C2-6:2-FTS	115		50 - 200
13C2-8:2-FTS	114		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-227532/21-A
Matrix: Water
Analysis Batch: 227732

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 227532

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Perfluorotridecanoic acid (PFTTrDA)	<0.36		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		05/16/26 11:15	05/18/26 06:34	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	110		70 - 130			05/16/26 11:15	05/18/26 06:34	1
13C2 PFHxA	116		70 - 130			05/16/26 11:15	05/18/26 06:34	1
13C2 PFDA	122		70 - 130			05/16/26 11:15	05/18/26 06:34	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-227532/21-A
Matrix: Water
Analysis Batch: 227732

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 227532

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	110		70 - 130	05/16/26 11:15	05/18/26 06:34	1

Lab Sample ID: LCS 380-227532/23-A
Matrix: Water
Analysis Batch: 227732

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 227532

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	50.2	53.5		ng/L		107	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	50.2	52.8		ng/L		105	70 - 130
Perfluoroundecanoic acid (PFUnA)	50.2	55.8		ng/L		111	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	50.2	51.4		ng/L		102	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	50.2	52.8		ng/L		105	70 - 130
Perfluorohexanoic acid (PFHxA)	50.2	54.4		ng/L		108	70 - 130
Perfluorododecanoic acid (PFDoA)	50.2	54.6		ng/L		109	70 - 130
Perfluorooctanoic acid (PFOA)	50.2	55.0		ng/L		110	70 - 130
Perfluorodecanoic acid (PFDA)	50.2	53.0		ng/L		106	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	50.2	51.0		ng/L		102	70 - 130
Perfluorobutanesulfonic acid (PFBS)	50.2	50.5		ng/L		101	70 - 130
Perfluoroheptanoic acid (PFHpA)	50.2	53.6		ng/L		107	70 - 130
Perfluorononanoic acid (PFNA)	50.2	53.4		ng/L		106	70 - 130
Perfluorotetradecanoic acid (PFTA)	50.2	55.1		ng/L		110	70 - 130
Perfluorotridecanoic acid (PFTrDA)	50.2	62.7		ng/L		125	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	50.2	52.2		ng/L		104	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	50.2	52.5		ng/L		105	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	50.2	51.5		ng/L		103	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	111		70 - 130
13C2 PFHxA	121		70 - 130
13C2 PFDA	120		70 - 130
13C3-GenX	123		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-227532/22-A
Matrix: Water
Analysis Batch: 227732

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 227532

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	2.00	2.40	J	ng/L		120	50 - 150
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	2.00	2.12	J	ng/L		106	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.42	J	ng/L		121	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.00	2.14	J	ng/L		107	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.00	2.33	J	ng/L		116	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.25	J	ng/L		112	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.28	J	ng/L		114	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.25	J	ng/L		112	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.22	J	ng/L		111	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	2.01	J	ng/L		100	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	2.02	J	ng/L		101	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	2.27	J	ng/L		113	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.24	J	ng/L		112	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.00	2.34	J	ng/L		117	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.00	2.59	J	ng/L		129	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	2.18	J	ng/L		109	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	1.95	J	ng/L		97	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	2.20	J	ng/L		110	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	118		70 - 130
13C2 PFHxA	117		70 - 130
13C2 PFDA	118		70 - 130
13C3-GenX	118		70 - 130

Lab Sample ID: 380-213692-E-1-A MS
Matrix: Water
Analysis Batch: 227732

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 227532

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		50.2	59.7		ng/L		119	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorooctanesulfonic acid (PFOS)	2.6		50.2	57.1		ng/L		108	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		50.2	57.3		ng/L		114	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		50.2	53.8		ng/L		107	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-213692-E-1-A MS

Matrix: Water

Analysis Batch: 227732

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 227532

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		50.2	54.1		ng/L		108	70 - 130
Perfluorohexanoic acid (PFHxA)	3.5		50.2	58.9		ng/L		110	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		50.2	58.1		ng/L		116	70 - 130
Perfluorooctanoic acid (PFOA)	2.1		50.2	60.2		ng/L		116	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		50.2	56.7		ng/L		113	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	2.8		50.2	57.3		ng/L		108	70 - 130
Perfluorobutanesulfonic acid (PFBS)	<2.0		50.2	55.6		ng/L		108	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		50.2	56.9		ng/L		111	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		50.2	56.2		ng/L		112	70 - 130
Perfluorotetradecanoic acid (PFTA)	<2.0		50.2	60.2		ng/L		120	70 - 130
Perfluorotridecanoic acid (PFTrDA)	<2.0	F1	50.2	66.5	F1	ng/L		132	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		50.2	55.9		ng/L		111	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		50.2	54.8		ng/L		109	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		50.2	58.4		ng/L		116	70 - 130
MS MS									
Surrogate	%Recovery	Qualifier	Limits						
d5-NEtFOSAA	110		70 - 130						
13C2 PFHxA	115		70 - 130						
13C2 PFDA	126		70 - 130						
13C3-GenX	129		70 - 130						

Lab Sample ID: 380-213692-F-1-A MSD

Matrix: Water

Analysis Batch: 227732

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 227532

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec Limits	RPD	
	Result	Qualifier	Added	Result	Qualifier					RPD	Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		50.1	54.3		ng/L		108	70 - 130	9	30
Perfluorooctanesulfonic acid (PFOS)	2.6		50.1	54.0		ng/L		103	70 - 130	5	30
Perfluoroundecanoic acid (PFUnA)	<2.0		50.1	53.1		ng/L		106	70 - 130	8	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		50.1	48.6		ng/L		97	70 - 130	10	30
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		50.1	50.6		ng/L		101	70 - 130	7	30
Perfluorohexanoic acid (PFHxA)	3.5		50.1	55.5		ng/L		104	70 - 130	6	30
Perfluorododecanoic acid (PFDoA)	<2.0		50.1	52.7		ng/L		105	70 - 130	10	30
Perfluorooctanoic acid (PFOA)	2.1		50.1	57.4		ng/L		110	70 - 130	5	30
Perfluorodecanoic acid (PFDA)	<2.0		50.1	51.5		ng/L		103	70 - 130	10	30

Eurofins Pomona

QC Association Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-213694-1
 SDG: PFAS: Aiea Gulch Wells Pump 2

LCMS

Prep Batch: 227532

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-213694-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	537.1 DW	
380-213694-2	FB: AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	537.1 DW	
MBL 380-227532/21-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-227532/23-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-227532/22-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-213692-E-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-213692-F-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

Analysis Batch: 227732

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-213694-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	EPA 537.1 V2	227532
380-213694-2	FB: AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	EPA 537.1 V2	227532
MBL 380-227532/21-A	Method Blank	Total/NA	Water	EPA 537.1 V2	227532
LCS 380-227532/23-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	227532
MRL 380-227532/22-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	227532
380-213692-E-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	227532
380-213692-F-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	227532

Prep Batch: 228574

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-213694-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	533	
380-213694-2	FB: AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	533	
MBL 380-228574/20-A	Method Blank	Total/NA	Water	533	
LCS 380-228574/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-228574/21-A	Lab Control Sample	Total/NA	Water	533	
380-213796-B-7-A MS	Matrix Spike	Total/NA	Water	533	
380-213796-B-7-B MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 228751

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-213694-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	533	228574
380-213694-2	FB: AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	533	228574
MBL 380-228574/20-A	Method Blank	Total/NA	Water	533	228574
LCS 380-228574/22-A	Lab Control Sample	Total/NA	Water	533	228574
MRL 380-228574/21-A	Lab Control Sample	Total/NA	Water	533	228574
380-213796-B-7-A MS	Matrix Spike	Total/NA	Water	533	228574
380-213796-B-7-B MSD	Matrix Spike Duplicate	Total/NA	Water	533	228574

Lab Chronicle

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-213694-1
 SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
 (331-202-TP072)**

Lab Sample ID: 380-213694-1

Date Collected: 05/11/26 10:56

Matrix: Drinking Water

Date Received: 05/13/26 09:28

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			228574	XTD8	EA POM	05/21/26 06:02
Total/NA	Analysis	533		1	228751	Y5FM	EA POM	05/21/26 17:30
Total/NA	Prep	537.1 DW			227532	E9PK	EA POM	05/16/26 11:15
Total/NA	Analysis	EPA 537.1 V2		1	227732	SZ9R	EA POM	05/18/26 07:41

**Client Sample ID: FB: AIEA GULCH WELLS PUMP 2
 (331-202-TP072)**

Lab Sample ID: 380-213694-2

Date Collected: 05/11/26 10:56

Matrix: Water

Date Received: 05/13/26 09:28

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			228574	XTD8	EA POM	05/21/26 06:02
Total/NA	Analysis	533		1	228751	Y5FM	EA POM	05/21/26 17:39
Total/NA	Prep	537.1 DW			227532	E9PK	EA POM	05/16/26 11:15
Total/NA	Analysis	EPA 537.1 V2		1	227732	SZ9R	EA POM	05/18/26 07:50

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-213694-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-213694-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Drinking Water	05/11/26 10:56	05/13/26 09:28	HI0000331
380-213694-2	FB: AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Water	05/11/26 10:56	05/13/26 09:28	HI0000331

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-213694-1
SDG Number: PFAS: Aiea Gulch Wells Pump 2

Login Number: 213694

List Number: 1

Creator: Del Rosario, Michael

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
ClO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

