

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 6/1/2026 4:19:50 PM

JOB DESCRIPTION

RED-HILL
PFAS: Halawa Wells P1

JOB NUMBER

380-215240-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
6/1/2026 4:19:50 PM



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	14
QC Association Summary	25
Lab Chronicle	26
Certification Summary	27
Method Summary	28
Sample Summary	29
Chain of Custody	30
Receipt Checklists	31

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Qualifiers

LCMS

Qualifier	Qualifier Description
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-215240-1

Job ID: 380-215240-1

Eurofins Pomona

Job Narrative 380-215240-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 5/20/2026 9:27 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 2.2°C.

PFAS.

EPA 537.1 and EPA 533 are two distinct methods for the analysis of PFAS in drinking water. The analyses are conducted on differing instrumentation, with calibrations, extraction solvents and sample preservatives being dissimilar among the two methods. Therefore it is probable and not unexpected to see the methods having slight variations in analytical results:HALAWA WELLS P1 (331-023-WL065) (380-215240-1).(XWB4)

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanesulfonic acid (PFHxS)	2.7		2.0	ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	3.6		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	2.6		2.0	ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	4.4		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	2.6		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanoic acid (PFHxA)	3.6		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	2.0		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.0		2.0	ng/L	1		EPA 537.1 V2	Total/NA

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-1

Date Collected: 05/18/26 10:45

Matrix: Water

Date Received: 05/20/26 09:27

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluorohexanesulfonic acid (PFHxS)	2.7		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluorohexanoic acid (PFHxA)	3.6		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluorooctanesulfonic acid (PFOS)	2.6		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluoropentanoic acid (PFPeA)	4.4		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:14	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	77		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C6 PFDA	84		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C5 PFHxA	90		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C4 PFHpA	90		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C8 PFOA	97		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C9 PFNA	93		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C7 PFUnA	83		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C2 PFDoA	77		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C4 PFBA	106		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C5 PFPeA	95		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C3 PFBS	101		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C3 PFHxS	99		50 - 200	05/29/26 07:57	05/30/26 01:14	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-1

Date Collected: 05/18/26 10:45

Matrix: Water

Date Received: 05/20/26 09:27

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	102		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C2-4:2-FTS	122		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C2-6:2-FTS	100		50 - 200	05/29/26 07:57	05/30/26 01:14	1
13C2-8:2-FTS	96		50 - 200	05/29/26 07:57	05/30/26 01:14	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorooctanesulfonic acid (PFOS)	2.6		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorohexanoic acid (PFHxA)	3.6		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorooctanoic acid (PFOA)	2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorohexanesulfonic acid (PFHxS)	3.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:04	1
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac		
d5-NEtFOSAA	96		70 - 130	05/22/26 16:13	05/23/26 16:04	1		
13C2 PFHxA	107		70 - 130	05/22/26 16:13	05/23/26 16:04	1		
13C2 PFDA	99		70 - 130	05/22/26 16:13	05/23/26 16:04	1		
13C3-GenX	105		70 - 130	05/22/26 16:13	05/23/26 16:04	1		

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-2

Date Collected: 05/18/26 10:45

Matrix: Water

Date Received: 05/20/26 09:27

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-2

Date Collected: 05/18/26 10:45

Matrix: Water

Date Received: 05/20/26 09:27

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		05/29/26 07:57	05/30/26 01:23	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	89		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C6 PFDA	95		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C5 PFHxA	106		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C4 PFHpA	100		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C8 PFOA	103		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C9 PFNA	103		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C7 PFUnA	99		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C2 PFDoA	97		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C4 PFBA	116		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C5 PFPeA	111		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C3 PFBS	108		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C3 PFHxS	108		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C8 PFOS	116		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C2-4:2-FTS	131		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C2-6:2-FTS	109		50 - 200	05/29/26 07:57	05/30/26 01:23	1
13C2-8:2-FTS	115		50 - 200	05/29/26 07:57	05/30/26 01:23	1

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-2

Date Collected: 05/18/26 10:45

Matrix: Water

Date Received: 05/20/26 09:27

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		05/22/26 16:13	05/23/26 16:13	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	103		70 - 130			05/22/26 16:13	05/23/26 16:13	1
13C2 PFHxA	99		70 - 130			05/22/26 16:13	05/23/26 16:13	1
13C2 PFDA	97		70 - 130			05/22/26 16:13	05/23/26 16:13	1
13C3-GenX	99		70 - 130			05/22/26 16:13	05/23/26 16:13	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	2.7		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	2.6		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	2.6		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-215240-1
 SDG: PFAS: Halawa Wells P1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-215204-B-1-A MS	Matrix Spike	98	108	103	105
380-215204-C-1-A MSD	Matrix Spike Duplicate	93	107	106	106
380-215240-1	HALAWA WELLS P1 (331-023-WL065)	96	107	99	105
380-215240-2	FB: HALAWA WELLS P1 (331-023-WL065)	103	99	97	99
LCS 380-229099/21-A	Lab Control Sample	99	101	103	105
MBL 380-229099/19-A	Method Blank	100	103	104	99
MRL 380-229099/20-A	Lab Control Sample	98	103	100	101

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
 PFHxA = 13C2 PFHxA
 PFDA = 13C2 PFDA
 GenX = 13C3-GenX



Isotope Dilution Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-215240-1
 SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-214934-B-3-A MS	Matrix Spike	92	93	99	106	100	103	99	98
380-214934-C-3-B MSD	Matrix Spike Duplicate	88	88	96	92	94	98	91	92
380-215240-1	HALAWA WELLS P1 (331-023-WL065)	77	84	90	90	97	93	83	77
380-215240-2	FB: HALAWA WELLS P1 (331-023-WL065)	89	95	106	100	103	103	99	97
LCS 380-230294/22-A	Lab Control Sample	79	93	96	93	96	101	95	96
MBL 380-230294/20-A	Method Blank	60	69	74	79	77	78	73	74
MRL 380-230294/21-A	Lab Control Sample	68	80	82	80	84	86	83	85

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-214934-B-3-A MS	Matrix Spike	118	114	116	110	111	127	113	109
380-214934-C-3-B MSD	Matrix Spike Duplicate	112	104	111	107	108	120	107	103
380-215240-1	HALAWA WELLS P1 (331-023-WL065)	106	95	101	99	102	122	100	96
380-215240-2	FB: HALAWA WELLS P1 (331-023-WL065)	116	111	108	108	116	131	109	115
LCS 380-230294/22-A	Lab Control Sample	103	95	113	109	110	121	110	110
MBL 380-230294/20-A	Method Blank	93	87	104	110	115	125	117	112
MRL 380-230294/21-A	Lab Control Sample	93	87	111	111	109	130	111	115

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDoA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-230294/20-A
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 230294

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosfluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.48		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<0.25		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		05/29/26 07:57	05/29/26 22:12	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	60		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C6 PFDA	69		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C5 PFHxA	74		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C4 PFHpA	79		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C8 PFOA	77		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C9 PFNA	78		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C7 PFUnA	73		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C2 PFDoA	74		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C4 PFBA	93		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C5 PFPeA	87		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C3 PFBS	104		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C3 PFHxS	110		50 - 200	05/29/26 07:57	05/29/26 22:12	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-230294/20-A
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 230294

<i>Isotope Dilution</i>	<i>MBL %Recovery</i>	<i>MBL Qualifier</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C8 PFOS	115		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C2-4:2-FTS	125		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C2-6:2-FTS	117		50 - 200	05/29/26 07:57	05/29/26 22:12	1
13C2-8:2-FTS	112		50 - 200	05/29/26 07:57	05/29/26 22:12	1

Lab Sample ID: LCS 380-230294/22-A
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 230294

<i>Analyte</i>	<i>Spike Added</i>	<i>LCS Result</i>	<i>LCS Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec Limits</i>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	60.4	57.1		ng/L		95	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	60.4	57.0		ng/L		94	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	60.4	60.0		ng/L		99	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	60.4	57.1		ng/L		95	70 - 130
Perfluorobutanesulfonic acid (PFBS)	60.4	57.1		ng/L		95	70 - 130
Perfluorodecanoic acid (PFDA)	60.4	64.7		ng/L		107	70 - 130
Perfluorododecanoic acid (PFDoA)	60.4	63.0		ng/L		104	70 - 130
Perfluoroheptanoic acid (PFHpA)	60.4	62.4		ng/L		103	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	60.4	61.3		ng/L		101	70 - 130
Perfluorohexanoic acid (PFHxA)	60.4	56.9		ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	60.4	59.5		ng/L		99	70 - 130
Perfluorooctanesulfonic acid (PFOS)	60.4	61.7		ng/L		102	70 - 130
Perfluorooctanoic acid (PFOA)	60.4	60.1		ng/L		100	70 - 130
Perfluoroundecanoic acid (PFUnA)	60.4	61.4		ng/L		102	70 - 130
Perfluorobutanoic acid (PFBA)	60.4	58.4		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	60.4	61.8		ng/L		102	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	60.4	52.8		ng/L		87	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	60.4	61.0		ng/L		101	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	60.4	48.8		ng/L		81	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	60.4	58.9		ng/L		98	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	60.4	62.0		ng/L		103	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	60.4	58.0		ng/L		96	70 - 130
Perfluoropentanoic acid (PFPeA)	60.4	63.1		ng/L		105	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	60.4	63.8		ng/L		106	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-230294/22-A
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 230294

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	60.4	59.1		ng/L		98	70 - 130
LCS LCS							
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	79		50 - 200				
13C6 PFDA	93		50 - 200				
13C5 PFHxA	96		50 - 200				
13C4 PFHpA	93		50 - 200				
13C8 PFOA	96		50 - 200				
13C9 PFNA	101		50 - 200				
13C7 PFUnA	95		50 - 200				
13C2 PFDoA	96		50 - 200				
13C4 PFBA	103		50 - 200				
13C5 PFPeA	95		50 - 200				
13C3 PFBS	113		50 - 200				
13C3 PFHxS	109		50 - 200				
13C8 PFOS	110		50 - 200				
13C2-4:2-FTS	121		50 - 200				
13C2-6:2-FTS	110		50 - 200				
13C2-8:2-FTS	110		50 - 200				

Lab Sample ID: MRL 380-230294/21-A
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 230294

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	2.28	J	ng/L		113	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	2.17	J	ng/L		108	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.87	J	ng/L		93	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	1.82	J	ng/L		91	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	1.92	J	ng/L		96	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.54	J	ng/L		127	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	2.51	J	ng/L		125	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	2.09	J	ng/L		104	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	2.10	J	ng/L		105	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	2.00	J	ng/L		99	50 - 150
Perfluorononanoic acid (PFNA)	2.01	2.22	J	ng/L		111	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	2.43	J	ng/L		121	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	2.00	J	ng/L		99	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.42	J	ng/L		121	50 - 150
Perfluorobutanoic acid (PFBA)	2.01	2.13	J	ng/L		106	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-230294/21-A
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 230294

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.01	2.47	J	ng/L		123	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.01	1.84	J	ng/L		92	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.01	2.29	J	ng/L		114	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.01	1.78	J	ng/L		89	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.01	2.02	J	ng/L		100	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.01	2.03	J	ng/L		101	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.01	1.93	J	ng/L		96	50 - 150
Perfluoropentanoic acid (PFPeA)	2.01	2.20	J	ng/L		109	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.01	2.30	J	ng/L		114	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.01	1.79	J	ng/L		89	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	68		50 - 200
13C6 PFDA	80		50 - 200
13C5 PFHxA	82		50 - 200
13C4 PFHpA	80		50 - 200
13C8 PFOA	84		50 - 200
13C9 PFNA	86		50 - 200
13C7 PFUnA	83		50 - 200
13C2 PFDoA	85		50 - 200
13C4 PFBA	93		50 - 200
13C5 PFPeA	87		50 - 200
13C3 PFBS	111		50 - 200
13C3 PFHxS	111		50 - 200
13C8 PFOS	109		50 - 200
13C2-4:2-FTS	130		50 - 200
13C2-6:2-FTS	111		50 - 200
13C2-8:2-FTS	115		50 - 200

Lab Sample ID: 380-214934-B-3-A MS
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 230294

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.2	57.1		ng/L		95	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.2	55.3		ng/L		92	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.2	53.9		ng/L		90	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-214934-B-3-A MS
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 230294

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		60.2	55.4		ng/L		92	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	4.4		60.2	60.2		ng/L		93	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		60.2	67.5		ng/L		111	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		60.2	58.8		ng/L		98	70 - 130
Perfluoroheptanoic acid (PFHpA)	3.5		60.2	57.8		ng/L		90	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	3.6		60.2	64.1		ng/L		101	70 - 130
Perfluorohexanoic acid (PFHxA)	13		60.2	71.9		ng/L		98	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		60.2	59.7		ng/L		98	70 - 130
Perfluorooctanesulfonic acid (PFOS)	7.8		60.2	68.6		ng/L		101	70 - 130
Perfluorooctanoic acid (PFOA)	7.8		60.2	63.9		ng/L		93	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		60.2	57.3		ng/L		95	70 - 130
Perfluorobutanoic acid (PFBA)	5.5		60.2	59.0		ng/L		89	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.2	62.1		ng/L		103	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.2	51.9		ng/L		86	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.2	64.8		ng/L		108	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0	F1	60.2	41.7	F1	ng/L		69	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.2	54.2		ng/L		90	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.2	59.4		ng/L		99	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.2	58.2		ng/L		97	70 - 130
Perfluoropentanoic acid (PFPeA)	10		60.2	66.8		ng/L		94	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.2	58.9		ng/L		98	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.2	58.4		ng/L		96	70 - 130

<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>
13C3 HFPO-DA	92		50 - 200
13C6 PFDA	93		50 - 200
13C5 PFHxA	99		50 - 200
13C4 PFHpA	106		50 - 200
13C8 PFOA	100		50 - 200
13C9 PFNA	103		50 - 200
13C7 PFUnA	99		50 - 200
13C2 PFDoA	98		50 - 200
13C4 PFBA	118		50 - 200
13C5 PFPeA	114		50 - 200
13C3 PFBS	116		50 - 200
13C3 PFHxS	110		50 - 200
13C8 PFOS	111		50 - 200

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-214934-B-3-A MS
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 230294

<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>MS MS Qualifier</i>	<i>Limits</i>
13C2-4:2-FTS	127		50 - 200
13C2-6:2-FTS	113		50 - 200
13C2-8:2-FTS	109		50 - 200

Lab Sample ID: 380-214934-C-3-B MSD
Matrix: Water
Analysis Batch: 230525

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 230294

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.1	55.9		ng/L		93	70 - 130	2	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.1	55.6		ng/L		92	70 - 130	1	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.1	62.5		ng/L		104	70 - 130	15	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		60.1	56.1		ng/L		93	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	4.4		60.1	60.7		ng/L		94	70 - 130	1	30
Perfluorodecanoic acid (PFDA)	<2.0		60.1	66.4		ng/L		109	70 - 130	2	30
Perfluorododecanoic acid (PFDoA)	<2.0		60.1	59.3		ng/L		99	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	3.5		60.1	65.6		ng/L		103	70 - 130	13	30
Perfluorohexanesulfonic acid (PFHxS)	3.6		60.1	63.0		ng/L		99	70 - 130	2	30
Perfluorohexanoic acid (PFHxA)	13		60.1	72.7		ng/L		100	70 - 130	1	30
Perfluorononanoic acid (PFNA)	<2.0		60.1	60.3		ng/L		99	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	7.8		60.1	69.5		ng/L		103	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	7.8		60.1	67.3		ng/L		99	70 - 130	5	30
Perfluoroundecanoic acid (PFUnA)	<2.0		60.1	60.1		ng/L		100	70 - 130	5	30
Perfluorobutanoic acid (PFBA)	5.5		60.1	60.4		ng/L		91	70 - 130	2	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.1	65.2		ng/L		108	70 - 130	5	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.1	56.3		ng/L		94	70 - 130	8	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.1	57.9		ng/L		96	70 - 130	11	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0	F1	60.1	53.7		ng/L		89	70 - 130	25	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.1	59.3		ng/L		99	70 - 130	9	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.1	62.5		ng/L		104	70 - 130	5	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.1	62.0		ng/L		103	70 - 130	6	30
Perfluoropentanoic acid (PFPeA)	10		60.1	70.4		ng/L		100	70 - 130	5	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.1	62.3		ng/L		104	70 - 130	5	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.1	57.2		ng/L		94	70 - 130	2	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

<i>Isotope Dilution</i>	<i>MSD</i>	<i>MSD</i>	<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
13C3 HFPO-DA	88		50 - 200
13C6 PFDA	88		50 - 200
13C5 PFHxA	96		50 - 200
13C4 PFHpA	92		50 - 200
13C8 PFOA	94		50 - 200
13C9 PFNA	98		50 - 200
13C7 PFUnA	91		50 - 200
13C2 PFDoA	92		50 - 200
13C4 PFBA	112		50 - 200
13C5 PFPeA	104		50 - 200
13C3 PFBS	111		50 - 200
13C3 PFHxS	107		50 - 200
13C8 PFOS	108		50 - 200
13C2-4:2-FTS	120		50 - 200
13C2-6:2-FTS	107		50 - 200
13C2-8:2-FTS	103		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-229099/19-A
Matrix: Water
Analysis Batch: 229167

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 229099

<i>Analyte</i>	<i>MBL</i>	<i>MBL</i>	<i>RL</i>	<i>Unit</i>	<i>D</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	<i>Result</i>	<i>Qualifier</i>						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
Perfluorotridecanoic acid (PFTrDA)	<0.36		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		05/22/26 16:13	05/23/26 13:01	1
<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>			<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	<i>%Recovery</i>	<i>Qualifier</i>						
d5-NEtFOSAA	100		70 - 130			05/22/26 16:13	05/23/26 13:01	1
13C2 PFHxA	103		70 - 130			05/22/26 16:13	05/23/26 13:01	1
13C2 PFDA	104		70 - 130			05/22/26 16:13	05/23/26 13:01	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-229099/19-A
Matrix: Water
Analysis Batch: 229167

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 229099

<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3-GenX	99	Qualifier	70 - 130	05/22/26 16:13	05/23/26 13:01	1

Lab Sample ID: LCS 380-229099/21-A
Matrix: Water
Analysis Batch: 229167

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 229099

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>	<i>Limits</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>					
Hexafluoropropylene Oxide	25.0	25.6		ng/L		102		70 - 130
Dimer Acid (HFPO-DA/GenX)								
Perfluorooctanesulfonic acid (PFOS)	25.0	25.4		ng/L		102		70 - 130
Perfluoroundecanoic acid (PFUnA)	25.0	25.1		ng/L		100		70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	25.0	24.4		ng/L		98		70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	25.0	24.7		ng/L		99		70 - 130
Perfluorohexanoic acid (PFHxA)	25.0	26.8		ng/L		107		70 - 130
Perfluorododecanoic acid (PFDoA)	25.0	26.1		ng/L		104		70 - 130
Perfluorooctanoic acid (PFOA)	25.0	26.4		ng/L		106		70 - 130
Perfluorodecanoic acid (PFDA)	25.0	25.5		ng/L		102		70 - 130
Perfluorohexanesulfonic acid (PFHxS)	25.0	27.6		ng/L		110		70 - 130
Perfluorobutanesulfonic acid (PFBS)	25.0	25.2		ng/L		101		70 - 130
Perfluoroheptanoic acid (PFHpA)	25.0	26.4		ng/L		106		70 - 130
Perfluorononanoic acid (PFNA)	25.0	26.5		ng/L		106		70 - 130
Perfluorotetradecanoic acid (PFTA)	25.0	20.9		ng/L		83		70 - 130
Perfluorotridecanoic acid (PFTrDA)	25.0	27.4		ng/L		110		70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	25.0	25.8		ng/L		103		70 - 130
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	25.0	24.7		ng/L		99		70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	25.0	25.9		ng/L		103		70 - 130

<i>Surrogate</i>	<i>LCS</i>	<i>LCS</i>	<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
d5-NEtFOSAA	99		70 - 130
13C2 PFHxA	101		70 - 130
13C2 PFDA	103		70 - 130
13C3-GenX	105		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-229099/20-A
Matrix: Water
Analysis Batch: 229167

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 229099

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	2.03	J	ng/L		102	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	2.06	J	ng/L		103	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.09	J	ng/L		105	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.00	1.91	J	ng/L		96	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.00	2.11	J	ng/L		105	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.06	J	ng/L		103	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	1.98	J	ng/L		99	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.00	J	ng/L		100	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.08	J	ng/L		104	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	2.06	J	ng/L		103	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	1.95	J	ng/L		97	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	2.12	J	ng/L		106	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.19	J	ng/L		110	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.00	1.68	J	ng/L		84	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.00	2.10	J	ng/L		105	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	1.98	J	ng/L		99	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	1.91	J	ng/L		96	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	2.08	J	ng/L		104	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	98		70 - 130
13C2 PFHxA	103		70 - 130
13C2 PFDA	100		70 - 130
13C3-GenX	101		70 - 130

Lab Sample ID: 380-215204-B-1-A MS
Matrix: Water
Analysis Batch: 229167

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 229099

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		25.1	25.8		ng/L		103	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		25.1	24.9		ng/L		99	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		25.1	26.9		ng/L		108	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.1	24.3		ng/L		97	70 - 130

Eurofins Pomona

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

LCMS

Prep Batch: 229099

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-215240-1	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	537.1 DW	
380-215240-2	FB: HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	537.1 DW	
MBL 380-229099/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-229099/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-229099/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-215204-B-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-215204-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

Analysis Batch: 229167

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-215240-1	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	EPA 537.1 V2	229099
380-215240-2	FB: HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	EPA 537.1 V2	229099
MBL 380-229099/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	229099
LCS 380-229099/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	229099
MRL 380-229099/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	229099
380-215204-B-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	229099
380-215204-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	229099

Prep Batch: 230294

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-215240-1	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	533	
380-215240-2	FB: HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	533	
MBL 380-230294/20-A	Method Blank	Total/NA	Water	533	
LCS 380-230294/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-230294/21-A	Lab Control Sample	Total/NA	Water	533	
380-214934-B-3-A MS	Matrix Spike	Total/NA	Water	533	
380-214934-C-3-B MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 230525

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-215240-1	HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	533	230294
380-215240-2	FB: HALAWA WELLS P1 (331-023-WL065)	Total/NA	Water	533	230294
MBL 380-230294/20-A	Method Blank	Total/NA	Water	533	230294
LCS 380-230294/22-A	Lab Control Sample	Total/NA	Water	533	230294
MRL 380-230294/21-A	Lab Control Sample	Total/NA	Water	533	230294
380-214934-B-3-A MS	Matrix Spike	Total/NA	Water	533	230294
380-214934-C-3-B MSD	Matrix Spike Duplicate	Total/NA	Water	533	230294

Lab Chronicle

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-215240-1
 SDG: PFAS: Halawa Wells P1

Client Sample ID: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-1

Date Collected: 05/18/26 10:45

Matrix: Water

Date Received: 05/20/26 09:27

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			230294	XTD8	EA POM	05/29/26 07:57
Total/NA	Analysis	533		1	230525	Y5FM	EA POM	05/30/26 01:14
Total/NA	Prep	537.1 DW			229099	E2HD	EA POM	05/22/26 16:13
Total/NA	Analysis	EPA 537.1 V2		1	229167	SZ9R	EA POM	05/23/26 16:04

Client Sample ID: FB: HALAWA WELLS P1 (331-023-WL065)

Lab Sample ID: 380-215240-2

Date Collected: 05/18/26 10:45

Matrix: Water

Date Received: 05/20/26 09:27

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			230294	XTD8	EA POM	05/29/26 07:57
Total/NA	Analysis	533		1	230525	Y5FM	EA POM	05/30/26 01:23
Total/NA	Prep	537.1 DW			229099	E2HD	EA POM	05/22/26 16:13
Total/NA	Analysis	EPA 537.1 V2		1	229167	SZ9R	EA POM	05/23/26 16:13

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-215240-1
SDG: PFAS: Halawa Wells P1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-215240-1	HALAWA WELLS P1 (331-023-WL065)	Water	05/18/26 10:45	05/20/26 09:27	Hawaii
380-215240-2	FB: HALAWA WELLS P1 (331-023-WL065)	Water	05/18/26 10:45	05/20/26 09:27	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Monrovia, CA (Suite 100)

750 Royal Oaks Drive Suite 100
 Monrovia, CA 91016
 Phone (626) 386-1100

Chain of Custody Record



Environment
America



Client Information		Sampler bailey	Lab PM. Lopez, Maria	Carrier Tracking No(s)	COC No										
Client Contact: Kirk Iwamoto		Phone +1 808 748 5840	E-Mail Maria.Lopez@et.eurofins.com	State of Origin:	Page: Page 1 of 1										
Company City & County of Honolulu		PWSID	Analysis Requested												
Address 630 South Beretania Street, Chemistry Lab		Due Date Requested:	Field Filtered Sample (Yes or No) _____ Perform in PWSID (Yes or No) _____ SUBTRACT - 625 PAH Physis LL (EAL) + TICs _____ 8015B_GRO_LL - (MOD) GRO _____ 8015B_GRO_LL_CS - HNL Ranges: C10-C24C24-C36/C8-C18 _____ 525.2_PREC - (MOD) 525plus PLUS TICs _____ 537.1_DW_PREC - 537.1 Full List _____ 533 - All Analyses _____												
City: Honolulu		TAT Requested (days):													
State, Zip: HI, 96843		Compliance Project: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No													
Phone 808-748-5840 (tel)		PO #: C20525101 exp 05312023													
Email: kiwamoto@hbws.org		WO #:													
Project Name: RED-HILL/HBWS sites Event Desc: RUSH Weekly Red Hill		Project #: 38001111	Preservation Codes: A - HCL M - Hexane B - NaOH N - None C - Zn Acetate O - AsNaO2 D - Nitric Acid P - Na2O4S E - NaHSO4 Q - Na2SO3 F - MeOH R - Na2S2O3 G - Amchlor S - H2SO4 H - Ascorbic Acid T - TSP Dodecahydrate I - Ice U - Acetone J - DI Water V - MCAA K - EDTA W - pH 4-5 L - EDA Y - Trizma Z - other (specify)												
Site:		SSOW#:													
Sample Identification		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=water/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform in PWSID (Yes or No)	Subtract	8015B_GRO_LL - (MOD) GRO	8015B_GRO_LL_CS - HNL Ranges: C10-C24C24-C36/C8-C18	525.2_PREC - (MOD) 525plus PLUS TICs	537.1_DW_PREC - 537.1 Full List	533 - All Analyses	Total Number of Containers	Special Instructions/Note:
Halawa Wells P1 (331-023-WL065)		18-May-2026	1045	G	Water										
FB: Halawa Wells P1 (331-023-WL065)		18-May-2026	1045												
Possible Hazard Identification		<input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological			Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)										
Deliverable Requested I, II, III, IV, Other (specify)					<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months										
Empty Kit Relinquished by		Date	Time	Method of Shipment: FedEx 8720 0324 5847											
Relinquished by		Date/Time	Company	Received by		Date/Time	Company								
Relinquished by		Date/Time	Company	Received by		Date/Time	Company								
Custody Seals Intact:		Custody Seal No.		Cooler Temperature(s) °C and Other Remarks											
<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				(6314) 2-2 + 0.0 = 2.2 g/L - frozen											



Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-215240-1
SDG Number: PFAS: Halawa Wells P1

Login Number: 215240

List Number: 1

Creator: Avila, Ivan

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

