eurofins | Environment Testing

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 10/30/2026 9:34:01 AM

JOB DESCRIPTION

RED-HILL
Weekly: Halawa Shaft Viewing Pool

JOB NUMBER

380-242295-1

Eurofins Pomona
941 Corporate Center Drive
Pomona CA 91768-2642

See page two for job notes and contact information.

my EOL

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW,Water matrices)

Authorization



Generated
10/30/2026 9:34:01 AM

Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Table of Contents

Cover Page 1
Table of Contents 3
Definitions/Glossary 4
Case Narrative 5
Detection Summary 6
Client Sample Results 7
Action Limit Summary 11
Surrogate Summary 12
QC Sample Results 14
QC Association Summary 28
Lab Chronicle 30
Certification Summary 31
Method Summary 33
Sample Summary 34
Chain of Custody 35
Receipt Checklists 37

Qualifiers

GC/MS Semi VOA

Qualifier	Qualifier Description
*+	LCS and/or LCSD is outside acceptance limits, high biased.
^+	Continuing Calibration Verification (CCV) is outside acceptance limits, high biased.
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Job Narrative
380-242295-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt
The samples were received on 10/15/2026 9:52 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.7°C.

GC/MS Semi VOA
No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Gasoline Range Organics
No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Diesel Range Organics
Method 8015B: Insufficient sample volume was available to perform a matrix spike/matrix spike duplicate (MS/MSD) associated with preparation batch 570-817609. The laboratory control sample (LCS) was performed in duplicate (LCSD) to provide precision data for this batch.

Method: 8015B_DRO_LL_CS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Client Sample ID: HALAWA SHAFT VIEWING POOL — Lab Sample ID: 380-242295-1

No Detections.

Client Sample ID: TB: HALAWA SHAFT VIEWING POOL — Lab Sample ID: 380-242295-2

No Detections.

This Detection Summary does not include radiochemical test results.

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Client Sample ID: HALAWA SHAFT VIEWING POOL
Date Collected: 10/13/26 09:30
Date Received: 10/15/26 09:52

Lab Sample ID: 380-242295-1
Matrix: Water

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
2,4'-DDD	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
2,4'-DDE	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
2,4'-DDT	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
2,4-Dinitrotoluene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
2,6-Dinitrotoluene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
2-Methylnaphthalene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
4,4'-DDD	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
4,4'-DDE	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
4,4'-DDT	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Acenaphthene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Acenaphthylene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Acetochlor	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Alachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
alpha-BHC	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
alpha-Chlordane	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Anthracene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 16:56	1
Atrazine	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Benz(a)anthracene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Benzo[a]pyrene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 16:56	1
Benzo[b]fluoranthene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 16:56	1
Benzo[g,h,i]perylene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Benzo[k]fluoranthene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 16:56	1
beta-BHC	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59		ug/L		10/16/26 15:26	10/19/26 16:56	1
Bromacil	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Butachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Butylbenzylphthalate	<0.49		0.49		ug/L		10/16/26 15:26	10/19/26 16:56	1
Chlorobenzilate	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Chloroneb	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Chlorothalonil (Draconil, Bravo)	<0.098	*+ ^+	0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Chlorpyrifos	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Chrysene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 16:56	1
delta-BHC	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Di(2-ethylhexyl)adipate	<0.59		0.59		ug/L		10/16/26 15:26	10/19/26 16:56	1
Dibenz(a,h)anthracene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Diclorvos (DDVP)	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Dieldrin	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Diethylphthalate	<0.49		0.49		ug/L		10/16/26 15:26	10/19/26 16:56	1
Dimethylphthalate	<0.49		0.49		ug/L		10/16/26 15:26	10/19/26 16:56	1
Di-n-butyl phthalate	<0.98		0.98		ug/L		10/16/26 15:26	10/19/26 16:56	1
Di-n-octyl phthalate	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Endosulfan I (Alpha)	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Endosulfan II (Beta)	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Endosulfan sulfate	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Endrin	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Endrin aldehyde	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
EPTC	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Fluoranthene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1

Client Sample ID: HALAWA SHAFT VIEWING POOL
Date Collected: 10/13/26 09:30
Date Received: 10/15/26 09:52

Lab Sample ID: 380-242295-1
Matrix: Water

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
gamma-Chlordane	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Heptachlor	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Heptachlor epoxide (isomer B)	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Hexachlorobenzene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Hexachlorocyclopentadiene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Isophorone	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Lindane	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Malathion	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Methoxychlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Metolachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Molinate	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Naphthalene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Parathion	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Pendimethalin (Penoxaline)	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Phenanthrene	<0.039		0.039		ug/L		10/16/26 15:26	10/19/26 16:56	1
Propachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Pyrene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Simazine	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Terbacil	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Terbuthylazine	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Thiobencarb	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1
Total Permethrin (mixed isomers)	<0.20		0.20		ug/L		10/16/26 15:26	10/19/26 16:56	1
trans-Nonachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 16:56	1
Trifluralin	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 16:56	1

Tentatively Identified Compound	*Est. Result*	*Qualifier*	*Unit*	*D*	*RT*	*CAS No.*	*Prepared*	*Analyzed*	*Dil Fac*
Tentatively Identified Compound	*None*		*ug/L*			*N/A*	*10/16/26 15:26*	*10/19/26 16:56*	*1*

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2-Nitro-m-xylene	*97*		*70 - 130*	*10/16/26 15:26*	*10/19/26 16:56*	*1*
Perylene-d12	*91*		*70 - 130*	*10/16/26 15:26*	*10/19/26 16:56*	*1*
Triphenylphosphate	*105*		*70 - 130*	*10/16/26 15:26*	*10/19/26 16:56*	*1*

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
2-Methylnaphthalene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Acenaphthene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Acenaphthylene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Anthracene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Benzo[a]anthracene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Benzo[a]pyrene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Benzo[b]fluoranthene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Benzo[g,h,i]perylene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Benzo[k]fluoranthene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Chrysene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Dibenz(a,h)anthracene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Fluoranthene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1

Client Sample ID: HALAWA SHAFT VIEWING POOL

Lab Sample ID: 380-242295-1

Date Collected: 10/13/26 09:30
Matrix: Water
Date Received: 10/15/26 09:52

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Indeno[1,2,3-cd]pyrene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Naphthalene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Phenanthrene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1
Pyrene	<0.19		0.19		ug/L		10/19/26 08:23	10/30/26 01:24	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2,4,6-Tribromophenol (Surr)	*70*		*28 - 127*	*10/19/26 08:23*	*10/30/26 01:24*	*1*
2-Fluorobiphenyl (Surr)	*59*		*31 - 120*	*10/19/26 08:23*	*10/30/26 01:24*	*1*
2-Fluorophenol (Surr)	*41*		*17 - 120*	*10/19/26 08:23*	*10/30/26 01:24*	*1*
Nitrobenzene-d5 (Surr)	*66*		*27 - 120*	*10/19/26 08:23*	*10/30/26 01:24*	*1*
Phenol-d6 (Surr)	*22*		*10 - 120*	*10/19/26 08:23*	*10/30/26 01:24*	*1*
p-Terphenyl-d14 (Surr)	*75*		*45 - 120*	*10/19/26 08:23*	*10/30/26 01:24*	*1*

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)

Tentatively Identified Compound	*Est. Result*	*Qualifier*	*Unit*	*D*	*RT*	*CAS No.*	*Prepared*	*Analyzed*	*Dil Fac*
Tentatively Identified Compound	*None*		*ug/L*			*N/A*	*10/19/26 08:23*	*10/30/26 02:37*	*1*

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2,4,6-Tribromophenol (Surr)	*63*		*33 - 139*	*10/19/26 08:23*	*10/30/26 02:37*	*1*
2-Fluorobiphenyl (Surr)	*61*		*33 - 126*	*10/19/26 08:23*	*10/30/26 02:37*	*1*
2-Fluorophenol (Surr)	*35*		*12 - 120*	*10/19/26 08:23*	*10/30/26 02:37*	*1*
Nitrobenzene-d5 (Surr)	*53*		*36 - 120*	*10/19/26 08:23*	*10/30/26 02:37*	*1*
Phenol-d6 (Surr)	*21*		*10 - 120*	*10/19/26 08:23*	*10/30/26 02:37*	*1*
p-Terphenyl-d14 (Surr)	*87*		*47 - 131*	*10/19/26 08:23*	*10/30/26 02:37*	*1*

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10		ug/L			10/24/26 15:09	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
4-Bromofluorobenzene (Surr)	*74*		*38 - 134*		*10/24/26 15:09*	*1*

Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26		ug/L		10/19/26 10:08	10/27/26 15:33	1
Motor Oil Range Organics [C24-C36]	<26		26		ug/L		10/19/26 10:08	10/27/26 15:33	1
C8-C18	<26		26		ug/L		10/19/26 10:08	10/27/26 15:33	1

Surrogate	*%Recovery*	*Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
n-Octacosane (Surr)	*98*		*60 - 130*	*10/19/26 10:08*	*10/27/26 15:33*	*1*

Client Sample ID: TB: HALAWA SHAFT VIEWING POOL

Lab Sample ID: 380-242295-2

Date Collected: 10/13/26 09:30
Matrix: Water
Date Received: 10/15/26 09:52

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10		ug/L			10/24/26 20:10	1

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Client Sample ID: TB: HALAWA SHAFT VIEWING POOL
Date Collected: 10/13/26 09:30
Date Received: 10/15/26 09:52

Lab Sample ID: 380-242295-2
Matrix: Water

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	*100*		*38 - 134*		*10/24/26 20:10*	*1*

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Client Sample ID: HALAWA SHAFT VIEWING POOL

Lab Sample ID: 380-242295-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Alachlor	<0.049		ug/L	2	0.049	525.2	Total/NA
Atrazine	<0.049		ug/L	3	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.020		ug/L	0.2	0.020	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.59		ug/L	6	0.59	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.59		ug/L	400	0.59	525.2	Total/NA
Endrin	<0.0098		ug/L	2	0.0098	525.2	Total/NA
Heptachlor	<0.0098		ug/L	0.4	0.0098	525.2	Total/NA
Heptachlor epoxide (isomer B)	<0.0098		ug/L	0.2	0.0098	525.2	Total/NA
Hexachlorobenzene	<0.049		ug/L	1	0.049	525.2	Total/NA
Hexachlorocyclopentadiene	<0.049		ug/L	50	0.049	525.2	Total/NA
Lindane	<0.0098		ug/L	0.2	0.0098	525.2	Total/NA
Methoxychlor	<0.049		ug/L	40	0.049	525.2	Total/NA
Simazine	<0.049		ug/L	4	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.19		ug/L	0.2	0.19	625.1 SIM	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water — **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)									
		2NMX	PRY	TPP							
Lab Sample ID	Client Sample ID	(70-130)	(70-130)	(70-130)							
380-242295-1	HALAWA SHAFT VIEWING POOL	97	91	105							
380-242306-R-1-A MS	Matrix Spike	98	97	103							
380-242306-S-1-A MSD	Matrix Spike Duplicate	98	99	107							
LCS 380-259287/23-A	Lab Control Sample	97	100	104							
MB 380-259287/21-A	Method Blank	96	88	101							
MRL 380-259287/22-A	Lab Control Sample	96	93	104							

Surrogate Legend

2NMX = 2-Nitro-m-xylene
PRY = Perylene-d12
TPP = Triphenylphosphate

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water — **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)							
		TBP	FBP	2FP	NBZ	PHL6	TPHd14		
Lab Sample ID	Client Sample ID	(33-139)	(33-126)	(12-120)	(36-120)	(10-120)	(47-131)		
380-242295-1	HALAWA SHAFT VIEWING POOL	63	61	35	53	21	87		
MB 570-817509/1-A	Method Blank	72	80	52	73	29	83		

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water — **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)							
		TBP	FBP	2FP	NBZ	PHL6	TPHd14		
Lab Sample ID	Client Sample ID	(28-127)	(31-120)	(17-120)	(27-120)	(10-120)	(45-120)		
380-242295-1	HALAWA SHAFT VIEWING POOL	70	59	41	66	22	75		
LCS 570-817509/2-A	Lab Control Sample	88	87	70	79	39	94		
LCSD 570-817509/3-A	Lab Control Sample Dup	81	76	58	64	33	89		
MB 570-817509/1-A	Method Blank	84	81	60	89	33	80		

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
FBP = 2-Fluorobiphenyl (Surr)
2FP = 2-Fluorophenol (Surr)
NBZ = Nitrobenzene-d5 (Surr)
PHL6 = Phenol-d6 (Surr)
TPHd14 = p-Terphenyl-d14 (Surr)

Surrogate Summary

Client: City & County of Honolulu
Job ID: 380-242295-1
Project/Site: RED-HILL
SDG: Weekly: Halawa Shaft Viewing Pool

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)
		BFB1
Lab Sample ID	Client Sample ID	(38-134)
380-241911-B-1 MS	Matrix Spike	99
380-241911-B-1 MSD	Matrix Spike Duplicate	100
380-242295-1	HALAWA SHAFT VIEWING POOL	74
380-242295-2	TB: HALAWA SHAFT VIEWING POOL	100
LCS 570-820765/3	Lab Control Sample	95
LCSD 570-820765/4	Lab Control Sample Dup	97
MB 570-820765/5	Method Blank	96
MRL 570-820765/6	Lab Control Sample	95

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water **Prep Type: Total/NA**

		Percent Surrogate Recovery (Acceptance Limits)
		OTCSN1
Lab Sample ID	Client Sample ID	(60-130)
380-242295-1	HALAWA SHAFT VIEWING POOL	98
LCS 570-817609/2-A	Lab Control Sample	117
LCSD 570-817609/3-A	Lab Control Sample Dup	114
MB 570-817609/1-A	Method Blank	105
MRL 570-817609/4-A	Lab Control Sample	101

Surrogate Legend

OTCSN = n-Octacosane (Surr)

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-259287/21-A
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 259287

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
2,4'-DDD	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
2,4'-DDE	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
2,4'-DDT	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
2,4-Dinitrotoluene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
2,6-Dinitrotoluene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
2-Methylnaphthalene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
4,4'-DDD	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
4,4'-DDE	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
4,4'-DDT	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Acenaphthene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Acenaphthylene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Acetochlor	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Alachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
alpha-BHC	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
alpha-Chlordane	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Anthracene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 13:54	1
Atrazine	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Benz(a)anthracene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Benzo[a]pyrene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 13:54	1
Benzo[b]fluoranthene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 13:54	1
Benzo[g,h,i]perylene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Benzo[k]fluoranthene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 13:54	1
beta-BHC	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59		ug/L		10/16/26 15:26	10/19/26 13:54	1
Bromacil	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Butachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Butylbenzylphthalate	<0.49		0.49		ug/L		10/16/26 15:26	10/19/26 13:54	1
Chlorobenzilate	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Chloroneb	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Chlorothalonil (Draconil, Bravo)	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Chlorpyrifos	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Chrysene	<0.020		0.020		ug/L		10/16/26 15:26	10/19/26 13:54	1
delta-BHC	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Di(2-ethylhexyl)adipate	<0.59		0.59		ug/L		10/16/26 15:26	10/19/26 13:54	1
Dibenz(a,h)anthracene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Diclorvos (DDVP)	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Dieldrin	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Diethylphthalate	<0.49		0.49		ug/L		10/16/26 15:26	10/19/26 13:54	1
Dimethylphthalate	<0.49		0.49		ug/L		10/16/26 15:26	10/19/26 13:54	1
Di-n-butyl phthalate	<0.98		0.98		ug/L		10/16/26 15:26	10/19/26 13:54	1
Di-n-octyl phthalate	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Endosulfan I (Alpha)	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Endosulfan II (Beta)	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Endosulfan sulfate	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Endrin	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Endrin aldehyde	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
EPTC	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-259287/21-A
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 259287

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Fluorene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
gamma-Chlordane	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Heptachlor	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Heptachlor epoxide (isomer B)	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Hexachlorobenzene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Hexachlorocyclopentadiene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Isophorone	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Lindane	<0.0098		0.0098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Malathion	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Methoxychlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Metolachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Molinate	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Naphthalene	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Parathion	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Pendimethalin (Penoxaline)	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Phenanthrene	<0.039		0.039		ug/L		10/16/26 15:26	10/19/26 13:54	1
Propachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Pyrene	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Simazine	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Terbacil	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Terbuthylazine	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Thiobencarb	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1
Total Permethrin (mixed isomers)	<0.20		0.20		ug/L		10/16/26 15:26	10/19/26 13:54	1
trans-Nonachlor	<0.049		0.049		ug/L		10/16/26 15:26	10/19/26 13:54	1
Trifluralin	<0.098		0.098		ug/L		10/16/26 15:26	10/19/26 13:54	1

Tentatively Identified Compound	*MB Est. Result*	*MB Qualifier*	*Unit*	*D*	*RT*	*CAS No.*	*Prepared*	*Analyzed*	*Dil Fac*
Unknown	*0.721*	*T J*	*ug/L*		*2.60*	*N/A*	*10/16/26 15:26*	*10/19/26 13:54*	*1*
Undecane	*5.03*	*T J N*	*ug/L*		*3.20*	*1120-21-4*	*10/16/26 15:26*	*10/19/26 13:54*	*1*

Surrogate	*MB %Recovery*	*MB Qualifier*	*Limits*	*Prepared*	*Analyzed*	*Dil Fac*
2-Nitro-m-xylene	*96*		*70 - 130*	*10/16/26 15:26*	*10/19/26 13:54*	*1*
Perylene-d12	*88*		*70 - 130*	*10/16/26 15:26*	*10/19/26 13:54*	*1*
Triphenylphosphate	*101*		*70 - 130*	*10/16/26 15:26*	*10/19/26 13:54*	*1*

Lab Sample ID: LCS 380-259287/23-A
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 259287

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	1.97	2.07		ug/L		105	70 - 130
2,4'-DDD	1.97	2.10		ug/L		107	70 - 130
2,4'-DDE	1.97	2.15		ug/L		109	70 - 130
2,4'-DDT	1.97	2.17		ug/L		111	70 - 130
2,4-Dinitrotoluene	1.97	1.87		ug/L		95	70 - 130
2,6-Dinitrotoluene	1.97	1.85		ug/L		94	70 - 130

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-259287/23-A
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 259287

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
2-Methylnaphthalene	1.97	2.06		ug/L		105	70 - 130
4,4'-DDD	1.97	2.26		ug/L		115	70 - 130
4,4'-DDE	1.97	2.01		ug/L		102	70 - 130
4,4'-DDT	1.97	2.21		ug/L		112	70 - 130
Acenaphthene	1.97	1.93		ug/L		98	70 - 130
Acenaphthylene	1.97	1.91		ug/L		97	70 - 130
Acetochlor	1.97	2.07		ug/L		105	70 - 130
Alachlor	1.97	2.09		ug/L		106	70 - 130
alpha-BHC	1.97	1.99		ug/L		101	70 - 130
alpha-Chlordane	1.97	2.05		ug/L		104	70 - 130
Anthracene	1.97	1.94		ug/L		99	70 - 130
Atrazine	1.97	2.23		ug/L		114	70 - 130
Benz(a)anthracene	1.97	2.07		ug/L		106	70 - 130
Benzo[a]pyrene	1.97	2.01		ug/L		102	70 - 130
Benzo[b]fluoranthene	1.97	2.11		ug/L		107	70 - 130
Benzo[g,h,i]perylene	1.97	2.11		ug/L		107	70 - 130
Benzo[k]fluoranthene	1.97	2.04		ug/L		104	70 - 130
beta-BHC	1.97	2.04		ug/L		104	70 - 130
Bis(2-ethylhexyl) phthalate	1.97	1.74		ug/L		88	70 - 130
Bromacil	1.97	1.54		ug/L		78	70 - 130
Butachlor	1.97	2.05		ug/L		105	70 - 130
Butylbenzylphthalate	1.97	2.21		ug/L		112	70 - 130
Chlorobenzilate	1.97	1.94		ug/L		99	70 - 130
Chloroneb	1.97	2.13		ug/L		108	70 - 130
Chlorothalonil (Draconil, Bravo)	1.97	2.57	*+	ug/L		131	70 - 130
Chlorpyrifos	1.97	2.07		ug/L		105	70 - 130
Chrysene	1.97	1.99		ug/L		101	70 - 130
delta-BHC	1.97	2.13		ug/L		108	70 - 130
Di(2-ethylhexyl)adipate	1.97	2.13		ug/L		109	70 - 130
Dibenz(a,h)anthracene	1.97	2.14		ug/L		109	70 - 130
Diclorvos (DDVP)	1.97	1.82		ug/L		92	70 - 130
Dieldrin	1.97	2.24		ug/L		114	70 - 130
Diethylphthalate	1.97	2.13		ug/L		109	70 - 130
Dimethylphthalate	1.97	2.01		ug/L		102	70 - 130
Di-n-butyl phthalate	3.93	4.02		ug/L		102	70 - 130
Di-n-octyl phthalate	1.97	1.70		ug/L		87	70 - 130
Endosulfan I (Alpha)	1.97	1.99		ug/L		101	70 - 130
Endosulfan II (Beta)	1.97	1.83		ug/L		93	70 - 130
Endosulfan sulfate	1.97	2.39		ug/L		122	70 - 130
Endrin	1.97	2.35		ug/L		120	70 - 130
Endrin aldehyde	1.97	2.01		ug/L		102	60 - 130
EPTC	1.97	2.07		ug/L		105	70 - 130
Fluoranthene	1.97	1.95		ug/L		99	70 - 130
Fluorene	1.97	2.03		ug/L		103	70 - 130
gamma-Chlordane	1.97	2.13		ug/L		108	70 - 130
Heptachlor	1.97	2.19		ug/L		111	70 - 130
Heptachlor epoxide (isomer B)	1.97	2.00		ug/L		102	70 - 130
Hexachlorobenzene	1.97	2.09		ug/L		106	70 - 130
Hexachlorocyclopentadiene	1.97	2.30		ug/L		117	70 - 130

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-259287/23-A
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 259287

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Indeno[1,2,3-cd]pyrene	1.97	2.12		ug/L		108	70 - 130
Isophorone	1.97	1.85		ug/L		94	70 - 130
Lindane	1.97	2.21		ug/L		113	70 - 130
Malathion	1.97	2.02		ug/L		103	70 - 130
Methoxychlor	1.97	1.82		ug/L		93	70 - 130
Metolachlor	1.97	1.97		ug/L		100	70 - 130
Molinate	1.97	2.08		ug/L		106	70 - 130
Naphthalene	1.97	1.95		ug/L		99	70 - 130
Parathion	1.97	2.02		ug/L		103	70 - 130
Pendimethalin (Penoxaline)	1.97	2.23		ug/L		113	70 - 130
Phenanthrene	1.97	1.88		ug/L		96	70 - 130
Propachlor	1.97	2.13		ug/L		109	70 - 130
Pyrene	1.97	2.06		ug/L		105	70 - 130
Simazine	1.97	1.95		ug/L		99	70 - 130
Terbacil	1.97	1.73		ug/L		88	70 - 130
Terbuthylazine	1.97	2.21		ug/L		112	70 - 130
Thiobencarb	1.97	2.05		ug/L		104	70 - 130
trans-Nonachlor	1.97	2.03		ug/L		103	70 - 130
Trifluralin	1.97	2.21		ug/L		112	70 - 130

Surrogate	*LCS %Recovery*	*LCS Qualifier*	*Limits*
2-Nitro-m-xylene	*97*		*70 - 130*
Perylene-d12	*100*		*70 - 130*
Triphenylphosphate	*104*		*70 - 130*

Lab Sample ID: MRL 380-259287/22-A
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 259287

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	0.0985	0.0979	J	ug/L		99	50 - 150
2,4'-DDD	0.0985	0.0800	J	ug/L		81	50 - 150
2,4'-DDE	0.0985	0.0962	J	ug/L		98	50 - 150
2,4'-DDT	0.0985	0.0979	J	ug/L		99	50 - 150
2,4-Dinitrotoluene	0.0985	0.110		ug/L		112	50 - 150
2,6-Dinitrotoluene	0.0985	0.100		ug/L		102	50 - 150
2-Methylnaphthalene	0.0985	0.0985		ug/L		100	50 - 150
4,4'-DDD	0.0985	0.101		ug/L		102	50 - 150
4,4'-DDE	0.0985	0.116		ug/L		118	50 - 150
4,4'-DDT	0.0985	0.110		ug/L		112	50 - 150
Acenaphthene	0.0985	0.0981		ug/L		100	50 - 150
Acenaphthylene	0.0985	0.0975	J	ug/L		99	50 - 150
Acetochlor	0.0985	0.0995		ug/L		101	50 - 150
Alachlor	0.0492	0.0534		ug/L		108	50 - 150
alpha-BHC	0.0985	0.108		ug/L		110	50 - 150
alpha-Chlordane	0.0246	<0.029		ug/L		96	50 - 150
Anthracene	0.0197	<0.019		ug/L		93	50 - 150
Atrazine	0.0492	0.0533		ug/L		108	50 - 150

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-259287/22-A
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 259287

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Benz(a)anthracene	0.0492	0.0464	J	ug/L		94	50 - 150
Benzo[a]pyrene	0.0197	0.0155	J	ug/L		79	50 - 150
Benzo[b]fluoranthene	0.0197	0.0157	J	ug/L		79	50 - 150
Benzo[g,h,i]perylene	0.0492	0.0528		ug/L		107	50 - 150
Benzo[k]fluoranthene	0.0197	0.0188	J	ug/L		96	50 - 150
beta-BHC	0.0985	0.114		ug/L		116	50 - 150
Bis(2-ethylhexyl) phthalate	0.591	0.556	J	ug/L		94	50 - 150
Bromacil	0.0985	0.0947	J	ug/L		96	50 - 150
Butachlor	0.0492	0.0591		ug/L		120	50 - 150
Butylbenzylphthalate	0.492	0.615		ug/L		125	50 - 150
Chlorobenzilate	0.0985	0.0979	J	ug/L		99	50 - 150
Chloroneb	0.0985	0.0968	J	ug/L		98	50 - 150
Chlorothalonil (Draconil, Bravo)	0.0985	0.140		ug/L		142	50 - 150
Chlorpyrifos	0.0492	0.0558		ug/L		113	50 - 150
Chrysene	0.0197	0.0164	J	ug/L		83	50 - 150
delta-BHC	0.0985	0.120		ug/L		121	50 - 150
Di(2-ethylhexyl)adipate	0.591	0.710		ug/L		120	50 - 150
Dibenz(a,h)anthracene	0.0492	0.0513		ug/L		104	50 - 150
Diclorvos (DDVP)	0.0492	0.0526		ug/L		107	50 - 150
Dieldrin	0.00985	0.0103		ug/L		105	50 - 150
Diethylphthalate	0.492	0.613		ug/L		124	50 - 150
Dimethylphthalate	0.492	0.549		ug/L		111	50 - 150
Di-n-butyl phthalate	0.492	0.537	J	ug/L		109	49 - 243
Di-n-octyl phthalate	0.0985	0.0766	J	ug/L		78	50 - 150
Endosulfan I (Alpha)	0.0985	0.0931	J	ug/L		95	50 - 150
Endosulfan II (Beta)	0.0985	0.113		ug/L		115	50 - 150
Endosulfan sulfate	0.0985	0.135		ug/L		137	50 - 150
Endrin	0.00985	0.0107		ug/L		109	50 - 150
Endrin aldehyde	0.0985	0.104		ug/L		105	50 - 150
EPTC	0.0985	0.0975	J	ug/L		99	50 - 150
Fluoranthene	0.0985	0.0929	J	ug/L		94	50 - 150
Fluorene	0.0492	0.0523		ug/L		106	50 - 150
gamma-Chlordane	0.0246	0.0249	J	ug/L		101	50 - 150
Heptachlor	0.00985	0.0122		ug/L		124	50 - 150
Heptachlor epoxide (isomer B)	0.00985	0.0129		ug/L		131	50 - 150
Hexachlorobenzene	0.0492	0.0538		ug/L		109	50 - 150
Hexachlorocyclopentadiene	0.0492	0.0590		ug/L		120	50 - 150
Indeno[1,2,3-cd]pyrene	0.0492	0.0554		ug/L		112	50 - 150
Isophorone	0.0985	0.0909	J	ug/L		92	50 - 150
Lindane	0.00985	0.00967	J	ug/L		98	50 - 150
Malathion	0.0985	0.114		ug/L		116	50 - 150
Methoxychlor	0.0492	0.0453	J	ug/L		92	50 - 150
Metolachlor	0.0492	0.0545		ug/L		111	50 - 150
Molinate	0.0985	0.108		ug/L		110	50 - 150
Naphthalene	0.0985	0.0965	J	ug/L		98	50 - 150
Parathion	0.0985	0.101		ug/L		102	50 - 150
Pendimethalin (Penoxaline)	0.0985	0.102		ug/L		104	50 - 150
Phenanthrene	0.0394	0.0406		ug/L		103	50 - 150
Propachlor	0.0492	0.0515		ug/L		105	50 - 150

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-259287/22-A
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 259287

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
Pyrene			0.0492	0.0446	J	ug/L		91	50 - 150		
Simazine			0.0492	0.0518		ug/L		105	50 - 150		
Terbacil			0.0985	0.0874	J	ug/L		89	50 - 150		
Terbuthylazine			0.0985	0.0985		ug/L		100	50 - 150		
Thiobencarb			0.0985	0.106		ug/L		108	50 - 150		
trans-Nonachlor			0.0246	<0.026		ug/L		101	50 - 150		
Trifluralin			0.0985	0.116		ug/L		118	50 - 150		

Surrogate	*MRL %Recovery*	*MRL Qualifier*	*Limits*
2-Nitro-m-xylene	*96*		*70 - 130*
Perylene-d12	*93*		*70 - 130*
Triphenylphosphate	*104*		*70 - 130*

Lab Sample ID: 380-242306-R-1-A MS
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 259287

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
1-Methylnaphthalene	<0.099		1.95	2.05		ug/L		105	70 - 130		
2,4'-DDD	<0.099		1.95	2.01		ug/L		103	70 - 130		
2,4'-DDE	<0.099		1.95	2.07		ug/L		106	70 - 130		
2,4'-DDT	<0.099		1.95	2.07		ug/L		106	70 - 130		
2,4-Dinitrotoluene	<0.099		1.95	2.02		ug/L		103	70 - 130		
2,6-Dinitrotoluene	<0.099		1.95	2.02		ug/L		103	70 - 130		
2-Methylnaphthalene	<0.099		1.95	2.02		ug/L		104	70 - 130		
4,4'-DDD	<0.099		1.95	2.18		ug/L		111	70 - 130		
4,4'-DDE	<0.099		1.95	1.91		ug/L		98	70 - 130		
4,4'-DDT	<0.099		1.95	2.06		ug/L		105	70 - 130		
Acenaphthene	<0.099		1.95	1.91		ug/L		98	70 - 130		
Acenaphthylene	<0.099		1.95	1.90		ug/L		97	70 - 130		
Acetochlor	<0.099		1.95	2.02		ug/L		104	70 - 130		
Alachlor	<0.049		1.95	2.05		ug/L		105	70 - 130		
alpha-BHC	<0.099		1.95	1.99		ug/L		102	70 - 130		
alpha-Chlordane	<0.049		1.95	2.00		ug/L		101	70 - 130		
Anthracene	<0.020	F1	1.95	0.813	F1	ug/L		42	70 - 130		
Atrazine	<0.049		1.95	2.25		ug/L		115	70 - 130		
Benz(a)anthracene	<0.049		1.95	1.71		ug/L		87	70 - 130		
Benzo[a]pyrene	<0.020	F1	1.95	1.35	F1	ug/L		69	70 - 130		
Benzo[b]fluoranthene	<0.020		1.95	1.98		ug/L		101	70 - 130		
Benzo[g,h,i]perylene	<0.049		1.95	2.01		ug/L		103	70 - 130		
Benzo[k]fluoranthene	<0.020		1.95	1.93		ug/L		99	70 - 130		
beta-BHC	<0.099		1.95	2.01		ug/L		103	70 - 130		
Bis(2-ethylhexyl) phthalate	<0.59		1.95	1.46		ug/L		74	70 - 130		
Bromacil	<0.099		1.95	1.80		ug/L		92	70 - 130		
Butachlor	<0.049		1.95	2.01		ug/L		103	70 - 130		
Butylbenzylphthalate	<0.49		1.95	2.14		ug/L		110	70 - 130		
Chlorobenzilate	<0.099		1.95	1.88		ug/L		96	70 - 130		
Chloroneb	<0.099		1.95	2.15		ug/L		110	70 - 130		

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-242306-R-1-A MS
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 259287

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Chlorothalonil (Draconil, Bravo)	<0.099	F1 *+ ^+	1.95	2.51		ug/L		128	70 - 130
Chlorpyrifos	<0.049		1.95	2.03		ug/L		104	70 - 130
Chrysene	<0.020		1.95	1.82		ug/L		93	70 - 130
delta-BHC	<0.099		1.95	2.09		ug/L		107	70 - 130
Di(2-ethylhexyl)adipate	<0.59		1.95	1.84		ug/L		94	70 - 130
Dibenz(a,h)anthracene	<0.049		1.95	2.00		ug/L		102	70 - 130
Diclorvos (DDVP)	<0.049		1.95	1.92		ug/L		98	70 - 130
Dieldrin	0.073		1.95	2.21		ug/L		109	70 - 130
Diethylphthalate	<0.49		1.95	2.12		ug/L		105	70 - 130
Dimethylphthalate	<0.49		1.95	2.03		ug/L		104	70 - 130
Di-n-butyl phthalate	<0.99		3.91	3.86		ug/L		99	70 - 130
Di-n-octyl phthalate	<0.099		1.95	1.38		ug/L		71	70 - 130
Endosulfan I (Alpha)	<0.099		1.95	1.93		ug/L		99	70 - 130
Endosulfan II (Beta)	<0.099		1.95	1.76		ug/L		90	70 - 130
Endosulfan sulfate	<0.099		1.95	2.30		ug/L		118	70 - 130
Endrin	<0.0099		1.95	2.31		ug/L		118	70 - 130
Endrin aldehyde	<0.099		1.95	1.78		ug/L		91	60 - 130
EPTC	<0.099		1.95	2.06		ug/L		105	70 - 130
Fluoranthene	<0.099		1.95	1.88		ug/L		96	70 - 130
Fluorene	<0.049		1.95	2.02		ug/L		103	70 - 130
gamma-Chlordane	<0.049		1.95	2.07		ug/L		105	70 - 130
Heptachlor	<0.0099		1.95	2.14		ug/L		110	70 - 130
Heptachlor epoxide (isomer B)	0.010		1.95	1.95		ug/L		99	70 - 130
Hexachlorobenzene	<0.049		1.95	2.08		ug/L		107	70 - 130
Hexachlorocyclopentadiene	<0.049		1.95	2.30		ug/L		118	70 - 130
Indeno[1,2,3-cd]pyrene	<0.049		1.95	2.03		ug/L		104	70 - 130
Isophorone	<0.099		1.95	1.89		ug/L		97	70 - 130
Lindane	<0.0099		1.95	2.17		ug/L		111	70 - 130
Malathion	<0.099		1.95	1.99		ug/L		102	70 - 130
Methoxychlor	<0.049		1.95	1.77		ug/L		91	70 - 130
Metolachlor	<0.049		1.95	1.93		ug/L		99	70 - 130
Molinate	<0.099		1.95	2.05		ug/L		105	70 - 130
Naphthalene	<0.099		1.95	1.93		ug/L		99	70 - 130
Parathion	<0.099		1.95	2.03		ug/L		104	70 - 130
Pendimethalin (Penoxaline)	<0.099		1.95	2.24		ug/L		115	70 - 130
Phenanthrene	<0.039		1.95	1.87		ug/L		96	70 - 130
Propachlor	<0.049		1.95	2.15		ug/L		110	70 - 130
Pyrene	<0.049		1.95	1.95		ug/L		100	70 - 130
Simazine	<0.049		1.95	2.03		ug/L		104	70 - 130
Terbacil	<0.099		1.95	2.03		ug/L		104	70 - 130
Terbuthylazine	<0.099		1.95	2.16		ug/L		111	70 - 130
Thiobencarb	<0.099		1.95	2.00		ug/L		102	70 - 130
trans-Nonachlor	<0.049		1.95	1.93		ug/L		99	70 - 130
Trifluralin	<0.099		1.95	2.20		ug/L		113	70 - 130

Surrogate	*MS %Recovery*	*MS Qualifier*	*Limits*
2-Nitro-m-xylene	*98*		*70 - 130*
Perylene-d12	*97*		*70 - 130*

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-242306-R-1-A MS
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 259287

Surrogate	MS %Recovery	MS Qualifier	Limits
Triphenylphosphate	*103*		*70 - 130*

Lab Sample ID: 380-242306-S-1-A MSD
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 259287

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene	<0.099		1.95	2.03		ug/L		104	70 - 130	1	20
2,4'-DDD	<0.099		1.95	2.08		ug/L		106	70 - 130	3	20
2,4'-DDE	<0.099		1.95	2.12		ug/L		108	70 - 130	2	20
2,4'-DDT	<0.099		1.95	2.17		ug/L		111	70 - 130	5	20
2,4-Dinitrotoluene	<0.099		1.95	2.03		ug/L		104	70 - 130	1	20
2,6-Dinitrotoluene	<0.099		1.95	2.03		ug/L		104	70 - 130	1	20
2-Methylnaphthalene	<0.099		1.95	2.02		ug/L		103	70 - 130	0	20
4,4'-DDD	<0.099		1.95	2.26		ug/L		116	70 - 130	4	20
4,4'-DDE	<0.099		1.95	1.98		ug/L		101	70 - 130	4	20
4,4'-DDT	<0.099		1.95	2.18		ug/L		112	70 - 130	6	20
Acenaphthene	<0.099		1.95	1.89		ug/L		97	70 - 130	1	20
Acenaphthylene	<0.099		1.95	1.93		ug/L		99	70 - 130	1	20
Acetochlor	<0.099		1.95	2.03		ug/L		104	70 - 130	0	20
Alachlor	<0.049		1.95	2.09		ug/L		107	70 - 130	2	20
alpha-BHC	<0.099		1.95	2.01		ug/L		103	70 - 130	1	20
alpha-Chlordane	<0.049		1.95	2.06		ug/L		104	70 - 130	3	20
Anthracene	<0.020	F1	1.95	0.942	F1	ug/L		48	70 - 130	15	20
Atrazine	<0.049		1.95	2.33		ug/L		119	70 - 130	3	20
Benz(a)anthracene	<0.049		1.95	1.82		ug/L		93	70 - 130	6	20
Benzo[a]pyrene	<0.020	F1	1.95	1.45		ug/L		74	70 - 130	7	20
Benzo[b]fluoranthene	<0.020		1.95	1.99		ug/L		102	70 - 130	1	20
Benzo[g,h,i]perylene	<0.049		1.95	1.96		ug/L		100	70 - 130	2	20
Benzo[k]fluoranthene	<0.020		1.95	1.96		ug/L		100	70 - 130	2	20
beta-BHC	<0.099		1.95	2.07		ug/L		106	70 - 130	3	20
Bis(2-ethylhexyl) phthalate	<0.59		1.95	1.55		ug/L		79	70 - 130	6	20
Bromacil	<0.099		1.95	1.82		ug/L		93	70 - 130	1	20
Butachlor	<0.049		1.95	2.05		ug/L		105	70 - 130	2	20
Butylbenzylphthalate	<0.49		1.95	2.23		ug/L		114	70 - 130	4	20
Chlorobenzilate	<0.099		1.95	1.96		ug/L		100	70 - 130	4	20
Chloroneb	<0.099		1.95	2.13		ug/L		109	70 - 130	1	20
Chlorothalonil (Draconil, Bravo)	<0.099	F1 *+ ^+	1.95	2.61	F1	ug/L		134	70 - 130	4	20
Chlorpyrifos	<0.049		1.95	2.10		ug/L		107	70 - 130	3	20
Chrysene	<0.020		1.95	1.91		ug/L		98	70 - 130	5	20
delta-BHC	<0.099		1.95	2.14		ug/L		110	70 - 130	3	20
Di(2-ethylhexyl)adipate	<0.59		1.95	2.01		ug/L		103	70 - 130	9	20
Dibenz(a,h)anthracene	<0.049		1.95	2.03		ug/L		104	70 - 130	2	20
Diclorvos (DDVP)	<0.049		1.95	1.94		ug/L		99	70 - 130	1	20
Dieldrin	0.073		1.95	2.27		ug/L		112	70 - 130	2	20
Diethylphthalate	<0.49		1.95	2.11		ug/L		105	70 - 130	1	20
Dimethylphthalate	<0.49		1.95	2.04		ug/L		105	70 - 130	1	20
Di-n-butyl phthalate	<0.99		3.91	3.99		ug/L		102	70 - 130	3	20

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-242306-S-1-A MSD
Matrix: Water
Analysis Batch: 259706

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 259287

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Di-n-octyl phthalate	<0.099		1.95	1.47		ug/L		75	70 - 130	6	20
Endosulfan I (Alpha)	<0.099		1.95	1.98		ug/L		101	70 - 130	3	20
Endosulfan II (Beta)	<0.099		1.95	1.83		ug/L		94	70 - 130	4	20
Endosulfan sulfate	<0.099		1.95	2.37		ug/L		121	70 - 130	3	20
Endrin	<0.0099		1.95	2.37		ug/L		121	70 - 130	2	20
Endrin aldehyde	<0.099		1.95	1.88		ug/L		96	60 - 130	6	20
EPTC	<0.099		1.95	2.05		ug/L		105	70 - 130	0	20
Fluoranthene	<0.099		1.95	1.93		ug/L		99	70 - 130	2	20
Fluorene	<0.049		1.95	2.01		ug/L		103	70 - 130	0	20
gamma-Chlordane	<0.049		1.95	2.07		ug/L		105	70 - 130	0	20
Heptachlor	<0.0099		1.95	2.19		ug/L		112	70 - 130	2	20
Heptachlor epoxide (isomer B)	0.010		1.95	2.01		ug/L		102	70 - 130	3	20
Hexachlorobenzene	<0.049		1.95	2.10		ug/L		107	70 - 130	1	20
Hexachlorocyclopentadiene	<0.049		1.95	2.37		ug/L		121	70 - 130	3	20
Indeno[1,2,3-cd]pyrene	<0.049		1.95	2.05		ug/L		105	70 - 130	1	20
Isophorone	<0.099		1.95	1.88		ug/L		96	70 - 130	1	20
Lindane	<0.0099		1.95	2.23		ug/L		114	70 - 130	3	20
Malathion	<0.099		1.95	2.06		ug/L		105	70 - 130	3	20
Methoxychlor	<0.049		1.95	1.85		ug/L		95	70 - 130	4	20
Metolachlor	<0.049		1.95	1.95		ug/L		100	70 - 130	1	20
Molinate	<0.099		1.95	2.08		ug/L		107	70 - 130	2	20
Naphthalene	<0.099		1.95	1.91		ug/L		98	70 - 130	1	20
Parathion	<0.099		1.95	2.10		ug/L		107	70 - 130	3	20
Pendimethalin (Penoxaline)	<0.099		1.95	2.34		ug/L		120	70 - 130	4	20
Phenanthrene	<0.039		1.95	1.89		ug/L		97	70 - 130	1	20
Propachlor	<0.049		1.95	2.18		ug/L		112	70 - 130	1	20
Pyrene	<0.049		1.95	2.01		ug/L		103	70 - 130	3	20
Simazine	<0.049		1.95	2.07		ug/L		106	70 - 130	2	20
Terbacil	<0.099		1.95	2.05		ug/L		105	70 - 130	1	20
Terbuthylazine	<0.099		1.95	2.23		ug/L		114	70 - 130	3	20
Thiobencarb	<0.099		1.95	2.06		ug/L		105	70 - 130	3	20
trans-Nonachlor	<0.049		1.95	2.00		ug/L		102	70 - 130	3	20
Trifluralin	<0.099		1.95	2.24		ug/L		115	70 - 130	2	20

Surrogate	*MSD %Recovery*	*MSD Qualifier*	*Limits*
2-Nitro-m-xylene	*98*		*70 - 130*
Perylene-d12	*99*		*70 - 130*
Triphenylphosphate	*107*		*70 - 130*

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 570-817509/1-A
Matrix: Water
Analysis Batch: 823736

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 817509

Tentatively Identified Compound	*MB Est. Result*	*MB Qualifier*	*Unit*	*D*	*RT*	*CAS No.*	*Prepared*	*Analyzed*	*Dil Fac*
Tentatively Identified Compound	*None*		*ug/L*			*N/A*	*10/19/26 08:23*	*10/29/26 20:19*	*1*

Method: 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 570-817509/1-A
Matrix: Water
Analysis Batch: 823736

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 817509

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	*72*		*33 - 139*	*10/19/26 08:23*	*10/29/26 20:19*	*1*
2-Fluorobiphenyl (Surr)	*80*		*33 - 126*	*10/19/26 08:23*	*10/29/26 20:19*	*1*
2-Fluorophenol (Surr)	*52*		*12 - 120*	*10/19/26 08:23*	*10/29/26 20:19*	*1*
Nitrobenzene-d5 (Surr)	*73*		*36 - 120*	*10/19/26 08:23*	*10/29/26 20:19*	*1*
Phenol-d6 (Surr)	*29*		*10 - 120*	*10/19/26 08 23*	*10/29/26 20 19*	*1*
p-Terphenyl-d14 (Surr)	*83*		*47 - 131*	*10/19/26 08:23*	*10/29/26 20:19*	*1*

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: MB 570-817509/1-A
Matrix: Water
Analysis Batch: 823800

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 817509

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
2-Methylnaphthalene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Acenaphthene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Acenaphthylene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Anthracene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Benzo[a]anthracene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Benzo[a]pyrene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Benzo[b]fluoranthene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Benzo[g,h,i]perylene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Benzo[k]fluoranthene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Chrysene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Dibenz(a,h)anthracene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Fluoranthene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Fluorene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Naphthalene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Phenanthrene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1
Pyrene	<0.20		0.20		ug/L		10/19/26 08:23	10/29/26 23:54	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	*84*		*28 - 127*	*10/19/26 08:23*	*10/29/26 23:54*	*1*
2-Fluorobiphenyl (Surr)	*81*		*31 - 120*	*10/19/26 08:23*	*10/29/26 23:54*	*1*
2-Fluorophenol (Surr)	*60*		*17 - 120*	*10/19/26 08:23*	*10/29/26 23:54*	*1*
Nitrobenzene-d5 (Surr)	*89*		*27 - 120*	*10/19/26 08:23*	*10/29/26 23:54*	*1*
Phenol-d6 (Surr)	*33*		*10 - 120*	*10/19/26 08:23*	*10/29/26 23:54*	*1*
p-Terphenyl-d14 (Surr)	*80*		*45 - 120*	*10/19/26 08:23*	*10/29/26 23:54*	*1*

Lab Sample ID: LCS 570-817509/2-A
Matrix: Water
Analysis Batch: 823800

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 817509

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
1-Methylnaphthalene			20.0	12.3		ug/L		61	47 - 120		
2-Methylnaphthalene			20.0	12.6		ug/L		63	43 - 120		

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCS 570-817509/2-A
Matrix: Water
Analysis Batch: 823800

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 817509

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Acenaphthene			20.0	15.2		ug/L		76	60 - 132		
Acenaphthylene			20.0	15.4		ug/L		77	54 - 126		
Anthracene			20.0	16.1		ug/L		81	43 - 120		
Benzo[a]anthracene			20.0	17.1		ug/L		85	42 - 133		
Benzo[a]pyrene			20.0	18.4		ug/L		92	32 - 148		
Benzo[b]fluoranthene			20.0	18.3		ug/L		91	42 - 140		
Benzo[g,h,i]perylene			20.0	17.0		ug/L		85	1 - 195		
Benzo[k]fluoranthene			20.0	16.9		ug/L		84	25 - 146		
Chrysene			20.0	16.6		ug/L		83	44 - 140		
Dibenz(a,h)anthracene			20.0	17.3		ug/L		87	1 - 200		
Fluoranthene			20.0	16.5		ug/L		83	43 - 121		
Fluorene			20.0	15.5		ug/L		77	70 - 120		
Indeno[1,2,3-cd]pyrene			20.0	17.4		ug/L		87	1 - 151		
Naphthalene			20.0	11.8		ug/L		59	36 - 120		
Phenanthrene			20.0	16.6		ug/L		83	65 - 120		
Pyrene			20.0	17.7		ug/L		88	70 - 120		

Surrogate	*LCS %Recovery*	*LCS Qualifier*	*Limits*
2,4,6-Tribromophenol (Surr)	*88*		*28 - 127*
2-Fluorobiphenyl (Surr)	*87*		*31 - 120*
2-Fluorophenol (Surr)	*70*		*17 - 120*
Nitrobenzene-d5 (Surr)	*79*		*27 - 120*
Phenol-d6 (Surr)	*39*		*10 - 120*
p-Terphenyl-d14 (Surr)	*94*		*45 - 120*

Lab Sample ID: LCSD 570-817509/3-A
Matrix: Water
Analysis Batch: 823800

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 817509

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene			20.0	10.3		ug/L		51	47 - 120	17	20
2-Methylnaphthalene			20.0	10.4		ug/L		52	43 - 120	19	20
Acenaphthene			20.0	13.7		ug/L		68	60 - 132	10	29
Acenaphthylene			20.0	13.9		ug/L		70	54 - 126	10	45
Anthracene			20.0	15.5		ug/L		78	43 - 120	4	40
Benzo[a]anthracene			20.0	16.4		ug/L		82	42 - 133	4	32
Benzo[a]pyrene			20.0	17.7		ug/L		89	32 - 148	3	43
Benzo[b]fluoranthene			20.0	17.8		ug/L		89	42 - 140	3	43
Benzo[g,h,i]perylene			20.0	16.3		ug/L		82	1 - 195	4	61
Benzo[k]fluoranthene			20.0	16.2		ug/L		81	25 - 146	4	38
Chrysene			20.0	15.7		ug/L		79	44 - 140	5	53
Dibenz(a,h)anthracene			20.0	16.6		ug/L		83	1 - 200	4	75
Fluoranthene			20.0	16.3		ug/L		81	43 - 121	1	40
Fluorene			20.0	14.2		ug/L		71	70 - 120	9	23
Indeno[1,2,3-cd]pyrene			20.0	16.7		ug/L		83	1 - 151	4	60
Naphthalene			20.0	9.53		ug/L		48	36 - 120	22	39
Phenanthrene			20.0	15.7		ug/L		79	65 - 120	5	24
Pyrene			20.0	16.7		ug/L		83	70 - 120	6	30

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCSD 570-817509/3-A
Matrix: Water
Analysis Batch: 823800

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 817509

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
2,4,6-Tribromophenol (Surr)	81		28 - 127
2-Fluorobiphenyl (Surr)	76		31 - 120
2-Fluorophenol (Surr)	58		17 - 120
Nitrobenzene-d5 (Surr)	64		27 - 120
Phenol d6 (Surr)	33		10 - 120
p-Terphenyl-d14 (Surr)	89		45 - 120

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: MB 570-820765/5
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10		ug/L			10/24/26 11:27	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	96		38 - 134		10/24/26 11:27	1

Lab Sample ID: LCS 570-820765/3
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)			400	331		ug/L		83	78 - 120		

Surrogate	LCS %Recovery	LCS Qualifier	Limits
4-Bromofluorobenzene (Surr)	95		38 - 134

Lab Sample ID: LCSD 570-820765/4
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)			400	325		ug/L		81	78 - 120	2	10

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
4-Bromofluorobenzene (Surr)	97		38 - 134

Lab Sample ID: MRL 570-820765/6
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)			10.0	10.9		ug/L		109	50 - 150		

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Lab Sample ID: MRL 570-820765/6
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Surrogate	MRL %Recovery	MRL Qualifier	Limits
4-Bromofluorobenzene (Surr)	*95*		*38 - 134*

Lab Sample ID: 380-241911-B-1 MS
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)	<10		400	340		ug/L		85	68 - 122		

Surrogate	MS %Recovery	MS Qualifier	Limits
4-Bromofluorobenzene (Surr)	*99*		*38 - 134*

Lab Sample ID: 380-241911-B-1 MSD
Matrix: Water
Analysis Batch: 820765

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	328		ug/L		82	68 - 122	4	18

Surrogate	MSD %Recovery	MSD Qualifier	Limits
4-Bromofluorobenzene (Surr)	*100*		*38 - 134*

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Lab Sample ID: MB 570-817609/1-A
Matrix: Water
Analysis Batch: 822141

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 817609

Analyte	MB Result	MB Qualifier	RL		Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25		ug/L		10/19/26 10:08	10/27/26 14:50	1
Motor Oil Range Organics [C24-C36]	<25		25		ug/L		10/19/26 10:08	10/27/26 14:50	1
C8-C18	<25		25		ug/L		10/19/26 10:08	10/27/26 14:50	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	*105*		*60 - 130*	*10/19/26 10:08*	*10/27/26 14:50*	*1*

Lab Sample ID: LCS 570-817609/2-A
Matrix: Water
Analysis Batch: 821788

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 817609

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
C10-C28			1600	1650		ug/L		103	56 - 127		

Surrogate	LCS %Recovery	LCS Qualifier	Limits
n-Octacosane (Surr)	*117*		*60 - 130*

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

Lab Sample ID: LCSD 570-817609/3-A
Matrix: Water
Analysis Batch: 821788

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 817609

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
C10-C28			1600	1540		ug/L		96	56 - 127	7	23

Surrogate	*LCSD %Recovery*	*LCSD Qualifier*	*Limits*
n-Octacosane (Surr)	*114*		*60 - 130*

Lab Sample ID: MRL 570-817609/4-A
Matrix: Water
Analysis Batch: 822141

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 817609

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
C10-C28			0.0200	0.0254		mg/L		127	50 - 150		

Surrogate	*MRL %Recovery*	*MRL Qualifier*	*Limits*
n-Octacosane (Surr)	*101*		*60 - 130*

GC/MS Semi VOA

Prep Batch: 259287

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-242295-1	HALAWA SHAFT VIEWING POOL	Total/NA	Water	525.2	
MB 380-259287/21-A	Method Blank	Total/NA	Water	525.2	
LCS 380-259287/23-A	Lab Control Sample	Total/NA	Water	525.2	
MRL 380-259287/22-A	Lab Control Sample	Total/NA	Water	525.2	
380-242306-R-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-242306-S-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	525.2	

Analysis Batch: 259706

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-242295-1	HALAWA SHAFT VIEWING POOL	Total/NA	Water	525.2	259287
MB 380-259287/21-A	Method Blank	Total/NA	Water	525.2	259287
LCS 380-259287/23-A	Lab Control Sample	Total/NA	Water	525.2	259287
MRL 380-259287/22-A	Lab Control Sample	Total/NA	Water	525.2	259287
380-242306-R-1-A MS	Matrix Spike	Total/NA	Water	525.2	259287
380-242306-S-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	525.2	259287

Prep Batch: 817509

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-242295-1	HALAWA SHAFT VIEWING POOL	Total/NA	Water	625.1	
MB 570-817509/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-817509/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-817509/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	

Analysis Batch: 823736

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-242295-1	HALAWA SHAFT VIEWING POOL	Total/NA	Water	625.1	817509
MB 570-817509/1-A	Method Blank	Total/NA	Water	625.1	817509

Analysis Batch: 823800

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-242295-1	HALAWA SHAFT VIEWING POOL	Total/NA	Water	625.1 SIM	817509
MB 570-817509/1-A	Method Blank	Total/NA	Water	625.1 SIM	817509
LCS 570-817509/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	817509
LCSD 570-817509/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	817509

GC VOA

Analysis Batch: 820765

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-242295-1	HALAWA SHAFT VIEWING POOL	Total/NA	Water	8015B GRO LL	
380-242295-2	TB: HALAWA SHAFT VIEWING POOL	Total/NA	Water	8015B GRO LL	
MB 570-820765/5	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-820765/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-820765/4	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-820765/6	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-241911-B-1 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-241911-B-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

GC Semi VOA

Prep Batch: 817609

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-242295-1	HALAWA SHAFT VIEWING POOL	Total/NA	Water	3510C	
MB 570-817609/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-817609/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-817609/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-817609/4-A	Lab Control Sample	Total/NA	Water	3510C	

Analysis Batch: 821788

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LCS 570-817609/2-A	Lab Control Sample	Total/NA	Water	8015B	817609
LCSD 570-817609/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	817609

Analysis Batch: 822141

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-242295-1	HALAWA SHAFT VIEWING POOL	Total/NA	Water	8015B	817609
MB 570-817609/1-A	Method Blank	Total/NA	Water	8015B	817609
MRL 570-817609/4-A	Lab Control Sample	Total/NA	Water	8015B	817609

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Client Sample ID: HALAWA SHAFT VIEWING POOL

Lab Sample ID: 380-242295-1

Date Collected: 10/13/26 09:30
Matrix: Water
Date Received: 10/15/26 09:52

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			259287	IQ42	EA POM	10/16/26 15:26
Total/NA	Analysis	525.2		1	259706	UPAC	EA POM	10/19/26 16:56
Total/NA	Prep	625.1			817509	KLZQ	EET CAL 4	10/19/26 08:23
Total/NA	Analysis	625.1		1	823736	5BV3	EET CAL 4	10/30/26 02:37
Total/NA	Prep	625.1			817509	KLZQ	EET CAL 4	10/19/26 08:23
Total/NA	Analysis	625.1 SIM		1	823800	S4EA	EET CAL 4	10/30/26 01:24
Total/NA	Analysis	8015B GRO LL		1	820765	W4LC	EET CAL 4	10/24/26 15:09
Total/NA	Prep	3510C			817609	TVD6	EET CAL 4	10/19/26 10:08
Total/NA	Analysis	8015B		1	822141	H6FE	EET CAL 4	10/27/26 15:33

Client Sample ID: TB: HALAWA SHAFT VIEWING POOL

Lab Sample ID: 380-242295-2

Date Collected: 10/13/26 09:30
Matrix: Water
Date Received: 10/15/26 09:52

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	820765	W4LC	EET CAL 4	10/24/26 20:10

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Laboratory: Eurofins Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-27

The following analytes are included in this report, but the laboratory is not certified by Hawaii State CA00006. This list may include analytes for which the agency does not offer certification:

Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Water	1-Methylnaphthalene
525.2	525.2	Water	2,4'-DDD
525.2	525.2	Water	2,4'-DDE
525.2	525.2	Water	2,4'-DDT
525.2	525.2	Water	2,4-Dinitrotoluene
525.2	525.2	Water	2,6-Dinitrotoluene
525.2	525.2	Water	2-Methylnaphthalene
525.2	525.2	Water	4,4'-DDD
525.2	525.2	Water	4,4'-DDE
525.2	525.2	Water	4,4'-DDT
525.2	525.2	Water	Acetochlor
525.2	525.2	Water	alpha-BHC
525.2	525.2	Water	alpha-Chlordane
525.2	525.2	Water	beta-BHC
525.2	525.2	Water	Chlorobenzilate
525.2	525.2	Water	Chloroneb
525.2	525.2	Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Water	Chlorpyrifos
525.2	525.2	Water	delta-BHC
525.2	525.2	Water	Diclorvos (DDVP)
525.2	525.2	Water	Endosulfan I (Alpha)
525.2	525.2	Water	Endosulfan II (Beta)
525.2	525.2	Water	Endosulfan sulfate
525.2	525.2	Water	Endrin aldehyde
525.2	525.2	Water	EPTC
525.2	525.2	Water	gamma-Chlordane
525.2	525.2	Water	Isophorone
525.2	525.2	Water	Malathion
525.2	525.2	Water	Parathion
525.2	525.2	Water	Pendimethalin (Penoxaline)
525.2	525.2	Water	Terbacil
525.2	525.2	Water	Terbuthylazine
525.2	525.2	Water	Total Permethrin (mixed isomers)
525.2	525.2	Water	trans-Nonachlor

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	7296.01	11-30-26
A2LA	ISO/IEC 17025	7296.01	11-30-26
Alaska (UST)	State	25-005	03-02-27
Arizona	State	AZ0830	11-16-26
California	Los Angeles County Sanitation Districts	9257304	07-31-28
California	SCAQMD LAP	17LA0919	11-30-26

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Laboratory: Eurofins Calscience (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
California	State	3082	07-31-28
Kansas	NELAP	E-10420	07-31-27
Nevada	State	CA00111	07-31-27
Oregon	NELAP	4175	02-02-27
Texas	NELAP	T104704499	07-31-27
USDA	US Federal Programs	525-23-159-97150	01-01-27
Utah	NELAP	CA00111	02-28-27
Washington	State	C916	10-11-27

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Method	Method Description	Protocol	Laboratory
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA POM
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
525.2	Extraction of Semivolatile Compounds	EPA	EA POM
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater ", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.
EPA = US Environmental Protection Agency
SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100
EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-242295-1
SDG: Weekly: Halawa Shaft Viewing Pool

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-242295-1	HALAWA SHAFT VIEWING POOL	Water	10/13/26 09:30	10/15/26 09:52	Hawaii
380-242295-2	TB: HALAWA SHAFT VIEWING POOL	Water	10/13/26 09:30	10/15/26 09:52	Hawaii

Eurofins Eaton Analytical Pomona
941 Corporate Center Drive
Pomona, CA 91768-2642
Phone (626) 386-1100

Chain of Custody Record

eurofins

380-242295 COC

Client Information	Sampler: Kai Edison	Lab PM: Lopez, Maria	Carrier Tracking No(s):	COC No:
Client Contact: Kirk Iwamoto	Phone: +1 808 748 5840	E-Mail: Maria.Lopez@et.eurofinsus.com	State of Origin:	Page: Page 1 of 1
Company: City & County of Honolulu	PWSID:			Job #:
Address: 630 South Beretania Street Chemistry Lab	Due Date Requested:			
City: Honolulu	TAT Requested (days):			
State, Zip: HI, 96843	Compliance Project: Δ Yes Δ No			
Phone: 808-748-5840 (Tel)	PO #: C20525101 exp 05312023			
Email: kiwamoto@hbws.org	WO #:			
Project Name: RED-HILL/HBWS Sites Event Desc: RUSH Weekly Red Hill	Project #: 38001111			
Site: Hawaii	SSOW#:			

Analysis Requested

Preservation Codes:
R - NaThioSO4
RA - NaThio/HCl
Q - Na2SO3
QA - Na2SO3/HCl
Y - Trizma
I - NH4 Acetate
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	525.1, 625.1_SIM	8015B_GRO_LL - (MOD) GRO	8015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C36/C8-C18	525.2_PREC - (MOD) 525plus Plus TICs	Total Number of containers	Special Instructions/Note:
			Preservation Code:				R	RA	Q	QA		
HALAWA SHAFT VIEWING POOL	13-Oct-2026	9:30	G	Water			2	3	2	2		
TB: HALAWA SHAFT VIEWING POOL	13-Oct-2026	9:30	G	Water				2				

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment: FX			
Relinquished by: [redacted]	Date/Time: 10/14/26 12:00	Company: HBWS	Received by:	Date/Time: 10/15/26 952	Company: EEPP
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks: 7.6 IR 9.9 9.7 Gel-Frozen

Ver: 04/02/2024

Eurofins Pomona
941 Corporate Center Drive
Pomona, CA 91768-2642
Phone: 626-386-1100

Chain of Custody Record

eurofins | Environ

Loc: 380
242295

Client Information (Sub Contract Lab)	Sampler: N/A	Lab PM: Lopez, Maria	Carrier Tracking No(s): N/A	COC No: 380-393584.1
Client Contact: Shipping/Receiving	Phone: N/A	E-Mail: Maria.Lopez@et.eurofinsus.com	State of Origin: Hawaii	Page: Page 1 of 1
Company: Eurofins Environment Testing Southwest L		Accreditations Required (See note): State - Hawaii		Job #: 380-242295-1
Address: 2841 Dow Avenue, Suite 100,	Due Date Requested: 10/26/2026	Analysis Requested		Preservation Codes: -
City: Tustin	TAT Requested (days): N/A			
State, Zip: CA, 92780				
Phone: 714-895-5494(Tel)	PO #: N/A			
Email: N/A	WO #: N/A			
Project Name: RED-HILL	Project #: 38001111			
Site: Honolulu BWS Sites	SSOW#: N/A			Other: N/A

Sample Identification - Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=wasteoil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	8015B_DRO_LL_CS/3510C_LL/HNL Ranges: C10-C24/C24-C36/C8-C18	8015B_GRO_LL/5030C(MOD) GRO	625.1_SIM/625_Prep(MOD) Extended PAH List	625.1/625_Prep(MOD) Tentatively Identified Compounds (Hold)	Total Number of containers	Special Instructions/Note:
			Preservation Code:									
HALAWA SHAFT VIEWING POOL (380-242295-1)	10/13/26	09:30 Hawaiian	G	Water			X	X	X	X	7	MRLs are needed. Confirm any hits >RL.
TB: HALAWA SHAFT VIEWING POOL (380-242295-2)	10/13/26	09:30 Hawaiian	G	Water				X			2	MRLs are needed. Confirm any hits >RL.

380-242295 Chain of Custody

Note: Since laboratory accreditations are subject to change, Eurofins Drinking Water and Wastewater West, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Drinking Water and Wastewater West, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Drinking Water and Wastewater West, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Drinking Water and Wastewater West, LLC.

Possible Hazard Identification	Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
Unconfirmed	☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months
Deliverable Requested: I, II, III, IV, Other (specify) Primary Deliverable Rank: 2	Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
	10/16/26 1036	Pom	EDDIE LUNA	10-16-26 10:37	DCS
Relinquished by: EDDIE LUNA	Date/Time: 10-16-26 1142	Company	Received by:	Date/Time: 10/16/26 1142	Company EC
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: ☐ Yes ☐ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks: 5.5/5.3 0.6/0.4 #R-9

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-242295-1
SDG Number: Weekly: Halawa Shaft Viewing Pool

Login Number: 242295
List Number: 1
Creator: Tran, Kristine

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
ClO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-242295-1
SDG Number: Weekly: Halawa Shaft Viewing Pool

Login Number: 242295
List Number: 2
Creator: Mills, Mary

List Source: Eurofins Calscience
List Creation: 10/16/26 02:25 PM

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	5.3, 0.4
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	