

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 9/21/2026 11:28:51 AM

JOB DESCRIPTION

RED-HILL
Weekly: Ka'amilo Wells P1

JOB NUMBER

380-235642-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1145

Generated
9/21/2026 11:28:51 AM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
QC Sample Results	14
QC Association Summary	28
Lab Chronicle	30
Certification Summary	31
Method Summary	33
Sample Summary	34
Chain of Custody	35
Receipt Checklists	37



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Qualifiers

GC/MS Semi VOA

Qualifier	Qualifier Description
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

GC Semi VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-235642-1

Job ID: 380-235642-1

Eurofins Pomona

Job Narrative 380-235642-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 9/10/2026 10:05 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 1.7°C.

GC/MS Semi VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Gasoline Range Organics

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Diesel Range Organics

Method 8015B: An incorrect volume of spiking solution was inadvertently added to the laboratory control sample (LCS), laboratory control sample duplicate (LCSD), matrix spike (MS), and matrix spike duplicate (MSD) associated with preparation batch 570-799575 and analytical batch 570-802267. Percent recoveries are based on the amount spiked.

Method: 8015B_DRO_LL_CS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-235642-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Dieldrin	0.069		0.0097	ug/L	1		525.2	Total/NA
Heptachlor epoxide (isomer B)	0.011		0.0097	ug/L	1		525.2	Total/NA

Client Sample ID: TB: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-235642-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-235642-1

Date Collected: 09/08/26 13:07

Matrix: Water

Date Received: 09/10/26 10:05

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
2,4'-DDD	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
2,4'-DDE	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
2,4'-DDT	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
2,4-Dinitrotoluene	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
2,6-Dinitrotoluene	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
2-Methylnaphthalene	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
4,4'-DDD	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
4,4'-DDE	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
4,4'-DDT	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Acenaphthene	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Acenaphthylene	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Acetochlor	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Alachlor	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
alpha-BHC	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
alpha-Chlordane	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Anthracene	<0.019		0.019	ug/L		09/14/26 08:24	09/14/26 21:12	1
Atrazine	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Benz(a)anthracene	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Benzo[a]pyrene	<0.019		0.019	ug/L		09/14/26 08:24	09/14/26 21:12	1
Benzo[b]fluoranthene	<0.019		0.019	ug/L		09/14/26 08:24	09/14/26 21:12	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Benzo[k]fluoranthene	<0.019		0.019	ug/L		09/14/26 08:24	09/14/26 21:12	1
beta-BHC	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Bis(2-ethylhexyl) phthalate	<0.58		0.58	ug/L		09/14/26 08:24	09/14/26 21:12	1
Bromacil	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Butachlor	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Butylbenzylphthalate	<0.49		0.49	ug/L		09/14/26 08:24	09/14/26 21:12	1
Chlorobenzilate	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Chloroneb	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Chlorothalonil (Draconil, Bravo)	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Chlorpyrifos	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Chrysene	<0.019		0.019	ug/L		09/14/26 08:24	09/14/26 21:12	1
delta-BHC	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Di(2-ethylhexyl)adipate	<0.58		0.58	ug/L		09/14/26 08:24	09/14/26 21:12	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Dieldrin	0.069		0.0097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Diethylphthalate	<0.49		0.49	ug/L		09/14/26 08:24	09/14/26 21:12	1
Dimethylphthalate	<0.49		0.49	ug/L		09/14/26 08:24	09/14/26 21:12	1
Di-n-butyl phthalate	<0.97		0.97	ug/L		09/14/26 08:24	09/14/26 21:12	1
Di-n-octyl phthalate	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Endosulfan I (Alpha)	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Endosulfan II (Beta)	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Endosulfan sulfate	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Endrin	<0.0097		0.0097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Endrin aldehyde	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
EPTC	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Fluoranthene	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-235642-1

Date Collected: 09/08/26 13:07

Matrix: Water

Date Received: 09/10/26 10:05

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
gamma-Chlordane	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Heptachlor	<0.0097		0.0097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Heptachlor epoxide (isomer B)	0.011		0.0097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Hexachlorobenzene	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Isophorone	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Lindane	<0.0097		0.0097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Malathion	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Methoxychlor	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Metolachlor	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Molinate	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Naphthalene	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Parathion	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Pendimethalin (Penoxaline)	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Phenanthrene	<0.039		0.039	ug/L		09/14/26 08:24	09/14/26 21:12	1
Propachlor	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Pyrene	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Simazine	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Terbacil	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Terbutylazine	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Thiobencarb	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1
Total Permethrin (mixed isomers)	<0.19		0.19	ug/L		09/14/26 08:24	09/14/26 21:12	1
trans-Nonachlor	<0.049		0.049	ug/L		09/14/26 08:24	09/14/26 21:12	1
Trifluralin	<0.097		0.097	ug/L		09/14/26 08:24	09/14/26 21:12	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	09/14/26 08:24	09/14/26 21:12	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	92		70 - 130	09/14/26 08:24	09/14/26 21:12	1
Perylene-d12	96		70 - 130	09/14/26 08:24	09/14/26 21:12	1
Triphenylphosphate	109		70 - 130	09/14/26 08:24	09/14/26 21:12	1

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
2-Methylnaphthalene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Acenaphthene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Acenaphthylene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Anthracene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Benzo[a]anthracene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Benzo[a]pyrene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Benzo[b]fluoranthene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Benzo[g,h,i]perylene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Benzo[k]fluoranthene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Chrysene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Dibenz(a,h)anthracene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Fluoranthene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-235642-1

Date Collected: 09/08/26 13:07

Matrix: Water

Date Received: 09/10/26 10:05

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Indeno[1,2,3-cd]pyrene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Naphthalene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Phenanthrene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1
Pyrene	<0.19		0.19	ug/L		09/11/26 19:46	09/15/26 01:58	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	83		28 - 127	09/11/26 19:46	09/15/26 01:58	1
2-Fluorobiphenyl (Surr)	82		31 - 120	09/11/26 19:46	09/15/26 01:58	1
2-Fluorophenol (Surr)	45		17 - 120	09/11/26 19:46	09/15/26 01:58	1
Nitrobenzene-d5 (Surr)	85		27 - 120	09/11/26 19:46	09/15/26 01:58	1
Phenol-d6 (Surr)	29		10 - 120	09/11/26 19:46	09/15/26 01:58	1
p-Terphenyl-d14 (Surr)	82		45 - 120	09/11/26 19:46	09/15/26 01:58	1

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	09/11/26 19:46	09/17/26 17:50	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	61		33 - 139	09/11/26 19:46	09/17/26 17:50	1
2-Fluorobiphenyl (Surr)	86		33 - 126	09/11/26 19:46	09/17/26 17:50	1
2-Fluorophenol (Surr)	38		12 - 120	09/11/26 19:46	09/17/26 17:50	1
Nitrobenzene-d5 (Surr)	78		36 - 120	09/11/26 19:46	09/17/26 17:50	1
Phenol-d6 (Surr)	18		10 - 120	09/11/26 19:46	09/17/26 17:50	1
p-Terphenyl-d14 (Surr)	86		47 - 131	09/11/26 19:46	09/17/26 17:50	1

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			09/16/26 20:59	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	97		38 - 134		09/16/26 20:59	1

Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26	ug/L		09/14/26 09:20	09/18/26 23:34	1
Motor Oil Range Organics [C24-C36]	<26		26	ug/L		09/14/26 09:20	09/18/26 23:34	1
C8-C18	<26		26	ug/L		09/14/26 09:20	09/18/26 23:34	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	88		60 - 130	09/14/26 09:20	09/18/26 23:34	1

Client Sample ID: TB: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-235642-2

Date Collected: 09/08/26 13:07

Matrix: Water

Date Received: 09/10/26 10:05

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			09/16/26 14:12	1

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: TB: Ka'amilo Wells P1 (331-031-WL008)
Date Collected: 09/08/26 13:07
Date Received: 09/10/26 10:05

Lab Sample ID: 380-235642-2
Matrix: Water

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	85		38 - 134		09/16/26 14:12	1

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-235642-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Alachlor	<0.049		ug/L	2	0.049	525.2	Total/NA
Atrazine	<0.049		ug/L	3	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.019		ug/L	0.2	0.019	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.58		ug/L	6	0.58	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.58		ug/L	400	0.58	525.2	Total/NA
Endrin	<0.0097		ug/L	2	0.0097	525.2	Total/NA
Heptachlor	<0.0097		ug/L	0.4	0.0097	525.2	Total/NA
Heptachlor epoxide (isomer B)	0.011		ug/L	0.2	0.0097	525.2	Total/NA
Hexachlorobenzene	<0.049		ug/L	1	0.049	525.2	Total/NA
Hexachlorocyclopentadiene	<0.049		ug/L	50	0.049	525.2	Total/NA
Lindane	<0.0097		ug/L	0.2	0.0097	525.2	Total/NA
Methoxychlor	<0.049		ug/L	40	0.049	525.2	Total/NA
Simazine	<0.049		ug/L	4	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.19		ug/L	0.2	0.19	625.1 SIM	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	92	96	109
380-235909-AG-1-A MS	Matrix Spike	91	96	112
380-236033-B-1-A DU	Duplicate	91	100	114
MB 380-252437/21-A	Method Blank	91	86	104
MRL 380-252437/22-A	Lab Control Sample	91	92	106
Surrogate Legend				
2NMX = 2-Nitro-m-xylene				
PRY = Perylene-d12				
TPP = Triphenylphosphate				

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	61	86	38	78	18	86
MB 570-798497/1-A	Method Blank	67	87	44	82	30	84
Surrogate Legend							
TBP = 2,4,6-Tribromophenol (Surr)							
FBP = 2-Fluorobiphenyl (Surr)							
2FP = 2-Fluorophenol (Surr)							
NBZ = Nitrobenzene-d5 (Surr)							
PHL6 = Phenol-d6 (Surr)							
TPHd14 = p-Terphenyl-d14 (Surr)							

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-235627-A-1-A MS	Matrix Spike	97	88	78	72	61	105
380-235627-A-1-B MSD	Matrix Spike Duplicate	90	84	58	65	37	95
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	83	82	45	85	29	82
LCS 570-798497/2-A	Lab Control Sample	88	84	58	68	38	90
LCSD 570-798497/3-A	Lab Control Sample Dup	84	79	57	65	40	91
MB 570-798497/1-A	Method Blank	85	80	53	86	34	80
Surrogate Legend							
TBP = 2,4,6-Tribromophenol (Surr)							
FBP = 2-Fluorobiphenyl (Surr)							
2FP = 2-Fluorophenol (Surr)							
NBZ = Nitrobenzene-d5 (Surr)							
PHL6 = Phenol-d6 (Surr)							
TPHd14 = p-Terphenyl-d14 (Surr)							

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB1 (38-134)
380-235627-C-1 MS	Matrix Spike	95
380-235627-C-1 MSD	Matrix Spike Duplicate	101
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	97
380-235642-2	TB: Ka'amilo Wells P1 (331-031-WL008)	85
LCS 570-800773/3	Lab Control Sample	94
LCSD 570-800773/4	Lab Control Sample Dup	93
MB 570-800773/6	Method Blank	95
MRL 570-800773/5	Lab Control Sample	94

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	88
380-235901-J-1-A MS	Matrix Spike	89
380-235901-K-1-A MSD	Matrix Spike Duplicate	79
LCS 570-799575/2-A	Lab Control Sample	119
LCSD 570-799575/3-A	Lab Control Sample Dup	114
MB 570-799575/1-A	Method Blank	120
MRL 570-799575/4-A	Lab Control Sample	105

Surrogate Legend

OTCSN = n-Octacosane (Surr)

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-252437/21-A
Matrix: Water
Analysis Batch: 252459

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 252437

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
2,4'-DDD	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
2,4'-DDE	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
2,4'-DDT	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
2,4-Dinitrotoluene	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
2,6-Dinitrotoluene	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
2-Methylnaphthalene	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
4,4'-DDD	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
4,4'-DDE	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
4,4'-DDT	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Acenaphthene	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Acenaphthylene	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Acetochlor	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Alachlor	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
alpha-BHC	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
alpha-Chlordane	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Anthracene	<0.020		0.020	ug/L		09/14/26 08:24	09/14/26 14:00	1
Atrazine	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Benz(a)anthracene	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Benzo[a]pyrene	<0.020		0.020	ug/L		09/14/26 08:24	09/14/26 14:00	1
Benzo[b]fluoranthene	<0.020		0.020	ug/L		09/14/26 08:24	09/14/26 14:00	1
Benzo[g,h,i]perylene	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Benzo[k]fluoranthene	<0.020		0.020	ug/L		09/14/26 08:24	09/14/26 14:00	1
beta-BHC	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Bis(2-ethylhexyl) phthalate	<0.60		0.60	ug/L		09/14/26 08:24	09/14/26 14:00	1
Bromacil	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Butachlor	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Butylbenzylphthalate	<0.50		0.50	ug/L		09/14/26 08:24	09/14/26 14:00	1
Chlorobenzilate	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Chloroneb	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Chlorothalonil (Draconil, Bravo)	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Chlorpyrifos	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Chrysene	<0.020		0.020	ug/L		09/14/26 08:24	09/14/26 14:00	1
delta-BHC	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Di(2-ethylhexyl)adipate	<0.60		0.60	ug/L		09/14/26 08:24	09/14/26 14:00	1
Dibenz(a,h)anthracene	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Diclorvos (DDVP)	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Dieldrin	<0.0099		0.0099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Diethylphthalate	<0.50		0.50	ug/L		09/14/26 08:24	09/14/26 14:00	1
Dimethylphthalate	<0.50		0.50	ug/L		09/14/26 08:24	09/14/26 14:00	1
Di-n-butyl phthalate	<0.99		0.99	ug/L		09/14/26 08:24	09/14/26 14:00	1
Di-n-octyl phthalate	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Endosulfan I (Alpha)	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Endosulfan II (Beta)	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Endosulfan sulfate	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Endrin	<0.0099		0.0099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Endrin aldehyde	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
EPTC	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-252437/21-A

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 252437

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Fluorene	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
gamma-Chlordane	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Heptachlor	<0.0099		0.0099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Heptachlor epoxide (isomer B)	<0.0099		0.0099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Hexachlorobenzene	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Hexachlorocyclopentadiene	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Indeno[1,2,3-cd]pyrene	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Isophorone	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Lindane	<0.0099		0.0099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Malathion	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Methoxychlor	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Metolachlor	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Molinate	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Naphthalene	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Parathion	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Pendimethalin (Penoxaline)	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Phenanthrene	<0.040		0.040	ug/L		09/14/26 08:24	09/14/26 14:00	1
Propachlor	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Pyrene	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Simazine	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Terbacil	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Terbutylazine	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Thiobencarb	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L		09/14/26 08:24	09/14/26 14:00	1
trans-Nonachlor	<0.050		0.050	ug/L		09/14/26 08:24	09/14/26 14:00	1
Trifluralin	<0.099		0.099	ug/L		09/14/26 08:24	09/14/26 14:00	1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Pentadecane, 7-methyl-	1.03	T J N	ug/L		3.04	6165-40-8	09/14/26 08:24	09/14/26 14:00	1
Undecane	5.52	T J N	ug/L		3.16	1120-21-4	09/14/26 08:24	09/14/26 14:00	1
9-Octadecenamide, (Z)-	1.69	T J N	ug/L		7.95	301-02-0	09/14/26 08:24	09/14/26 14:00	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	91		70 - 130	09/14/26 08:24	09/14/26 14:00	1
Perylene-d12	86		70 - 130	09/14/26 08:24	09/14/26 14:00	1
Triphenylphosphate	104		70 - 130	09/14/26 08:24	09/14/26 14:00	1

Lab Sample ID: MRL 380-252437/22-A

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 252437

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	0.0995	0.0950	J	ug/L		96	50 - 150
2,4'-DDD	0.0995	0.0902	J	ug/L		91	50 - 150
2,4'-DDE	0.0995	0.105		ug/L		106	50 - 150
2,4'-DDT	0.0995	0.106		ug/L		106	50 - 150
2,4-Dinitrotoluene	0.0995	0.0964	J	ug/L		97	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-252437/22-A

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 252437

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
2,6-Dinitrotoluene	0.0995	0.104		ug/L		105	50 - 150
2-Methylnaphthalene	0.0995	0.0969	J	ug/L		97	50 - 150
4,4'-DDD	0.0995	0.108		ug/L		109	50 - 150
4,4'-DDE	0.0995	0.106		ug/L		107	50 - 150
4,4'-DDT	0.0995	0.111		ug/L		111	50 - 150
Acenaphthene	0.0995	0.101		ug/L		101	50 - 150
Acenaphthylene	0.0995	0.0853	J	ug/L		86	50 - 150
Acetochlor	0.0995	0.100		ug/L		101	50 - 150
Alachlor	0.0497	0.0501		ug/L		101	50 - 150
alpha-BHC	0.0995	0.105		ug/L		106	50 - 150
alpha-Chlordane	0.0249	0.0296	J	ug/L		119	50 - 150
Anthracene	0.0199	0.0202		ug/L		102	50 - 150
Atrazine	0.0497	0.0528		ug/L		106	50 - 150
Benz(a)anthracene	0.0497	0.0511		ug/L		103	50 - 150
Benzo[a]pyrene	0.0199	0.0155	J	ug/L		78	50 - 150
Benzo[b]fluoranthene	0.0199	0.0197	J	ug/L		99	50 - 150
Benzo[g,h,i]perylene	0.0497	0.0459	J	ug/L		92	50 - 150
Benzo[k]fluoranthene	0.0199	0.0210		ug/L		106	50 - 150
beta-BHC	0.0995	0.111		ug/L		112	50 - 150
Bis(2-ethylhexyl) phthalate	0.597	0.633		ug/L		106	50 - 150
Bromacil	0.0995	0.0933	J	ug/L		94	50 - 150
Butachlor	0.0497	0.0486	J	ug/L		98	50 - 150
Butylbenzylphthalate	0.497	0.584		ug/L		117	50 - 150
Chlorobenzilate	0.0995	0.0855	J	ug/L		86	50 - 150
Chloroneb	0.0995	0.114		ug/L		115	50 - 150
Chlorothalonil (Draconil, Bravo)	0.0995	0.109		ug/L		109	50 - 150
Chlorpyrifos	0.0497	0.0487	J	ug/L		98	50 - 150
Chrysene	0.0199	0.0238		ug/L		119	50 - 150
delta-BHC	0.0995	0.101		ug/L		101	50 - 150
Di(2-ethylhexyl)adipate	0.597	0.653		ug/L		109	50 - 150
Dibenz(a,h)anthracene	0.0497	0.0505		ug/L		102	50 - 150
Diclorvos (DDVP)	0.0497	0.0450	J	ug/L		90	50 - 150
Dieldrin	0.00995	0.0142		ug/L		143	50 - 150
Diethylphthalate	0.497	0.577		ug/L		116	50 - 150
Dimethylphthalate	0.497	0.563		ug/L		113	50 - 150
Di-n-butyl phthalate	0.497	0.550	J	ug/L		111	49 - 243
Di-n-octyl phthalate	0.0995	0.0813	J	ug/L		82	50 - 150
Endosulfan I (Alpha)	0.0995	0.0898	J	ug/L		90	50 - 150
Endosulfan II (Beta)	0.0995	0.0956	J	ug/L		96	50 - 150
Endosulfan sulfate	0.0995	0.116		ug/L		117	50 - 150
Endrin	0.00995	0.00976	J	ug/L		98	50 - 150
Endrin aldehyde	0.0995	0.107		ug/L		107	50 - 150
EPTC	0.0995	0.0888	J	ug/L		89	50 - 150
Fluoranthene	0.0995	0.105		ug/L		105	50 - 150
Fluorene	0.0497	0.0537		ug/L		108	50 - 150
gamma-Chlordane	0.0249	0.0289	J	ug/L		116	50 - 150
Heptachlor	0.00995	0.0112		ug/L		113	50 - 150
Heptachlor epoxide (isomer B)	0.00995	0.0147		ug/L		148	50 - 150
Hexachlorobenzene	0.0497	0.0540		ug/L		109	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-252437/22-A

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 252437

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexachlorocyclopentadiene	0.0497	0.0467	J	ug/L		94	50 - 150
Indeno[1,2,3-cd]pyrene	0.0497	0.0459	J	ug/L		92	50 - 150
Isophorone	0.0995	0.0848	J	ug/L		85	50 - 150
Lindane	0.00995	0.0120		ug/L		121	50 - 150
Malathion	0.0995	0.0867	J	ug/L		87	50 - 150
Methoxychlor	0.0497	0.0489	J	ug/L		98	50 - 150
Metolachlor	0.0497	0.0476	J	ug/L		96	50 - 150
Molinate	0.0995	0.110		ug/L		110	50 - 150
Naphthalene	0.0995	0.0929	J	ug/L		93	50 - 150
Parathion	0.0995	0.0821	J	ug/L		83	50 - 150
Pendimethalin (Penoxaline)	0.0995	0.0887	J	ug/L		89	50 - 150
Phenanthrene	0.0398	0.0404		ug/L		101	50 - 150
Propachlor	0.0497	0.0469	J	ug/L		94	50 - 150
Pyrene	0.0497	0.0512		ug/L		103	50 - 150
Simazine	0.0497	0.0492	J	ug/L		99	50 - 150
Terbacil	0.0995	0.0841	J	ug/L		85	50 - 150
Terbutylazine	0.0995	0.111		ug/L		112	50 - 150
Thiobencarb	0.0995	0.0970	J	ug/L		98	50 - 150
trans-Nonachlor	0.0249	0.0295	J	ug/L		119	50 - 150
Trifluralin	0.0995	0.0975	J	ug/L		98	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
2-Nitro-m-xylene	91		70 - 130
Perylene-d12	92		70 - 130
Triphenylphosphate	106		70 - 130

Lab Sample ID: 380-235909-AG-1-A MS

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 252437

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	<0.098		1.96	1.97		ug/L		101	70 - 130
2,4'-DDD	<0.098		1.96	1.88		ug/L		96	70 - 130
2,4'-DDE	<0.098		1.96	1.82		ug/L		93	70 - 130
2,4'-DDT	<0.098		1.96	1.77		ug/L		90	70 - 130
2,4-Dinitrotoluene	<0.098		1.96	1.96		ug/L		100	70 - 130
2,6-Dinitrotoluene	<0.098		1.96	1.93		ug/L		99	70 - 130
2-Methylnaphthalene	<0.098		1.96	1.96		ug/L		100	70 - 130
4,4'-DDD	<0.098		1.96	1.97		ug/L		101	70 - 130
4,4'-DDE	<0.098		1.96	1.82		ug/L		93	70 - 130
4,4'-DDT	<0.098		1.96	1.73		ug/L		88	70 - 130
Acenaphthene	<0.098		1.96	1.95		ug/L		100	70 - 130
Acenaphthylene	<0.098		1.96	1.82		ug/L		93	70 - 130
Acetochlor	<0.098		1.96	1.86		ug/L		95	70 - 130
Alachlor	<0.049		1.96	1.88		ug/L		96	70 - 130
alpha-BHC	<0.098		1.96	1.98		ug/L		101	70 - 130
alpha-Chlordane	<0.049		1.96	2.08		ug/L		106	70 - 130
Anthracene	<0.020	F1	1.96	0.940	F1	ug/L		48	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-235909-AG-1-A MS

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 252437

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Atrazine	<0.049		1.96	2.12		ug/L		109	70 - 130
Benz(a)anthracene	<0.049		1.96	1.74		ug/L		89	70 - 130
Benzo[a]pyrene	<0.020		1.96	1.76		ug/L		90	70 - 130
Benzo[b]fluoranthene	<0.020		1.96	2.24		ug/L		114	70 - 130
Benzo[g,h,i]perylene	<0.049		1.96	1.93		ug/L		99	70 - 130
Benzo[k]fluoranthene	<0.020		1.96	2.20		ug/L		113	70 - 130
beta-BHC	<0.098		1.96	1.97		ug/L		101	70 - 130
Bis(2-ethylhexyl) phthalate	<0.59		1.96	1.74		ug/L		89	70 - 130
Bromacil	<0.098		1.96	1.90		ug/L		97	70 - 130
Butachlor	<0.049		1.96	1.94		ug/L		99	70 - 130
Butylbenzylphthalate	<0.49		1.96	2.08		ug/L		106	70 - 130
Chlorobenzilate	<0.098		1.96	1.85		ug/L		95	70 - 130
Chloroneb	<0.098		1.96	2.05		ug/L		105	70 - 130
Chlorothalonil (Draconil, Bravo)	<0.098		1.96	2.12		ug/L		109	70 - 130
Chlorpyrifos	<0.049		1.96	1.89		ug/L		97	70 - 130
Chrysene	<0.020		1.96	2.17		ug/L		111	70 - 130
delta-BHC	<0.098		1.96	1.95		ug/L		100	70 - 130
Di(2-ethylhexyl)adipate	<0.59		1.96	1.45		ug/L		74	70 - 130
Dibenz(a,h)anthracene	<0.049		1.96	1.86		ug/L		95	70 - 130
Diclorvos (DDVP)	<0.049		1.96	1.77		ug/L		90	70 - 130
Dieldrin	<0.0098		1.96	2.00		ug/L		102	70 - 130
Diethylphthalate	<0.49		1.96	2.03		ug/L		104	70 - 130
Dimethylphthalate	<0.49		1.96	2.03		ug/L		104	70 - 130
Di-n-butyl phthalate	<0.98		3.91	4.10		ug/L		105	70 - 130
Di-n-octyl phthalate	<0.098		1.96	1.62		ug/L		83	70 - 130
Endosulfan I (Alpha)	<0.098		1.96	1.90		ug/L		97	70 - 130
Endosulfan II (Beta)	<0.098		1.96	1.89		ug/L		97	70 - 130
Endosulfan sulfate	<0.098		1.96	2.06		ug/L		106	70 - 130
Endrin	<0.0098		1.96	2.00		ug/L		103	70 - 130
Endrin aldehyde	<0.098		1.96	1.74		ug/L		89	60 - 130
EPTC	<0.098		1.96	1.87		ug/L		96	70 - 130
Fluoranthene	<0.098		1.96	2.08		ug/L		106	70 - 130
Fluorene	<0.049		1.96	2.08		ug/L		106	70 - 130
gamma-Chlordane	<0.049		1.96	2.00		ug/L		102	70 - 130
Heptachlor	<0.0098		1.96	1.95		ug/L		100	70 - 130
Heptachlor epoxide (isomer B)	<0.0098		1.96	2.12		ug/L		109	70 - 130
Hexachlorobenzene	<0.049		1.96	2.04		ug/L		104	70 - 130
Hexachlorocyclopentadiene	<0.049		1.96	2.04		ug/L		104	70 - 130
Indeno[1,2,3-cd]pyrene	<0.049		1.96	1.93		ug/L		99	70 - 130
Isophorone	<0.098		1.96	1.71		ug/L		87	70 - 130
Lindane	<0.0098		1.96	2.07		ug/L		106	70 - 130
Malathion	<0.098		1.96	1.94		ug/L		99	70 - 130
Methoxychlor	<0.049	F1	1.96	2.67	F1	ug/L		136	70 - 130
Metolachlor	<0.049		1.96	1.99		ug/L		102	70 - 130
Molinate	<0.098		1.96	1.92		ug/L		98	70 - 130
Naphthalene	<0.098		1.96	1.84		ug/L		94	70 - 130
Parathion	<0.098		1.96	1.85		ug/L		94	70 - 130
Pendimethalin (Penoxaline)	<0.098		1.96	2.06		ug/L		105	70 - 130
Phenanthrene	<0.039		1.96	1.98		ug/L		101	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-235909-AG-1-A MS

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 252437

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Propachlor	<0.049		1.96	1.91		ug/L		98	70 - 130
Pyrene	<0.049		1.96	2.03		ug/L		104	70 - 130
Simazine	<0.049		1.96	2.01		ug/L		103	70 - 130
Terbacil	<0.098		1.96	1.81		ug/L		93	70 - 130
Terbutylazine	<0.098		1.96	2.12		ug/L		108	70 - 130
Thiobencarb	<0.098		1.96	1.85		ug/L		95	70 - 130
trans-Nonachlor	<0.049		1.96	2.02		ug/L		103	70 - 130
Trifluralin	<0.098		1.96	2.02		ug/L		103	70 - 130

Surrogate	MS %Recovery	MS Qualifier	MS Limits
2-Nitro-m-xylene	91		70 - 130
Perylene-d12	96		70 - 130
Triphenylphosphate	112		70 - 130

Lab Sample ID: 380-236033-B-1-A DU

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Duplicate

Prep Type: Total/NA

Prep Batch: 252437

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
1-Methylnaphthalene	<0.098		<0.098		ug/L		NC	20
2,4'-DDD	<0.098		<0.098		ug/L		NC	20
2,4'-DDE	<0.098		<0.098		ug/L		NC	20
2,4'-DDT	<0.098		<0.098		ug/L		NC	20
2,4-Dinitrotoluene	<0.098		<0.098		ug/L		NC	20
2,6-Dinitrotoluene	<0.098		<0.098		ug/L		NC	20
2-Methylnaphthalene	<0.098		<0.098		ug/L		NC	20
4,4'-DDD	<0.098		<0.098		ug/L		NC	20
4,4'-DDE	<0.098		<0.098		ug/L		NC	20
4,4'-DDT	<0.098		<0.098		ug/L		NC	20
Acenaphthene	<0.098		<0.098		ug/L		NC	20
Acenaphthylene	<0.098		<0.098		ug/L		NC	20
Acetochlor	<0.098		<0.098		ug/L		NC	20
Alachlor	<0.049		<0.049		ug/L		NC	20
alpha-BHC	<0.098		<0.098		ug/L		NC	20
alpha-Chlordane	<0.049		<0.049		ug/L		NC	20
Anthracene	<0.020		<0.020		ug/L		NC	20
Atrazine	<0.049		<0.049		ug/L		NC	20
Benz(a)anthracene	<0.049		<0.049		ug/L		NC	20
Benzo[a]pyrene	<0.020		<0.020		ug/L		NC	20
Benzo[b]fluoranthene	<0.020		<0.020		ug/L		NC	20
Benzo[g,h,i]perylene	<0.049		<0.049		ug/L		NC	20
Benzo[k]fluoranthene	<0.020		<0.020		ug/L		NC	20
beta-BHC	<0.098		<0.098		ug/L		NC	20
Bis(2-ethylhexyl) phthalate	<0.59		<0.59		ug/L		NC	20
Bromacil	<0.098		<0.098		ug/L		NC	20
Butachlor	<0.049		<0.049		ug/L		NC	20
Butylbenzylphthalate	<0.49		<0.49		ug/L		NC	20
Chlorobenzilate	<0.098		<0.098		ug/L		NC	20

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-236033-B-1-A DU

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Duplicate

Prep Type: Total/NA

Prep Batch: 252437

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
Chloroneb	<0.098		<0.098		ug/L		NC	20
Chlorothalonil (Draconil, Bravo)	<0.098		<0.098		ug/L		NC	20
Chlorpyrifos	<0.049		<0.049		ug/L		NC	20
Chrysene	<0.020		<0.020		ug/L		NC	20
delta-BHC	<0.098		<0.098		ug/L		NC	20
Di(2-ethylhexyl)adipate	<0.59		<0.59		ug/L		NC	20
Dibenz(a,h)anthracene	<0.049		<0.049		ug/L		NC	20
Diclorvos (DDVP)	<0.049		<0.049		ug/L		NC	20
Dieldrin	<0.0098		<0.0098		ug/L		NC	20
Diethylphthalate	<0.49		<0.49		ug/L		NC	20
Dimethylphthalate	<0.49		<0.49		ug/L		NC	20
Di-n-butyl phthalate	<0.98		<0.98		ug/L		NC	20
Di-n-octyl phthalate	<0.098		<0.098		ug/L		NC	20
Endosulfan I (Alpha)	<0.098		<0.098		ug/L		NC	20
Endosulfan II (Beta)	<0.098		<0.098		ug/L		NC	20
Endosulfan sulfate	<0.098		<0.098		ug/L		NC	20
Endrin	<0.0098		<0.0098		ug/L		NC	20
Endrin aldehyde	<0.098		<0.098		ug/L		NC	20
EPTC	<0.098		<0.098		ug/L		NC	20
Fluoranthene	<0.098		<0.098		ug/L		NC	20
Fluorene	<0.049		<0.049		ug/L		NC	20
gamma-Chlordane	<0.049		<0.049		ug/L		NC	20
Heptachlor	<0.0098		<0.0098		ug/L		NC	20
Heptachlor epoxide (isomer B)	<0.0098		<0.0098		ug/L		NC	20
Hexachlorobenzene	<0.049		<0.049		ug/L		NC	20
Hexachlorocyclopentadiene	<0.049		<0.049		ug/L		NC	20
Indeno[1,2,3-cd]pyrene	<0.049		<0.049		ug/L		NC	20
Isophorone	<0.098		<0.098		ug/L		NC	20
Lindane	<0.0098		<0.0098		ug/L		NC	20
Malathion	<0.098		<0.098		ug/L		NC	20
Methoxychlor	<0.049		<0.049		ug/L		NC	20
Metolachlor	<0.049		<0.049		ug/L		NC	20
Molinate	<0.098		<0.098		ug/L		NC	20
Naphthalene	<0.098		<0.098		ug/L		NC	20
Parathion	<0.098		<0.098		ug/L		NC	20
Pendimethalin (Penoxaline)	<0.098		<0.098		ug/L		NC	20
Phenanthrene	<0.039		<0.039		ug/L		NC	20
Propachlor	<0.049		<0.049		ug/L		NC	20
Pyrene	<0.049		<0.049		ug/L		NC	20
Simazine	<0.049		<0.049		ug/L		NC	20
Terbacil	<0.098		<0.098		ug/L		NC	20
Terbutylazine	<0.098		<0.098		ug/L		NC	20
Thiobencarb	<0.098		<0.098		ug/L		NC	20
Total Permethrin (mixed isomers)	<0.20		<0.20		ug/L		NC	20
trans-Nonachlor	<0.049		<0.049		ug/L		NC	20
Trifluralin	<0.098		<0.098		ug/L		NC	20

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-236033-B-1-A DU

Matrix: Water

Analysis Batch: 252459

Client Sample ID: Duplicate

Prep Type: Total/NA

Prep Batch: 252437

	DU	DU	
Surrogate	%Recovery	Qualifier	Limits
2-Nitro-m-xylene	91		70 - 130
Perylene-d12	100		70 - 130
Triphenylphosphate	114		70 - 130

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 570-798497/1-A

Matrix: Water

Analysis Batch: 801479

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 798497

	MB	MB							
Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	09/11/26 08:36	09/17/26 12:36	1

Surrogate	MB	MB					Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier	Limits						
2,4,6-Tribromophenol (Surr)	67		33 - 139				09/11/26 08:36	09/17/26 12:36	1
2-Fluorobiphenyl (Surr)	87		33 - 126				09/11/26 08:36	09/17/26 12:36	1
2-Fluorophenol (Surr)	44		12 - 120				09/11/26 08:36	09/17/26 12:36	1
Nitrobenzene-d5 (Surr)	82		36 - 120				09/11/26 08:36	09/17/26 12:36	1
Phenol-d6 (Surr)	30		10 - 120				09/11/26 08:36	09/17/26 12:36	1
p-Terphenyl-d14 (Surr)	84		47 - 131				09/11/26 08:36	09/17/26 12:36	1

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: MB 570-798497/1-A

Matrix: Water

Analysis Batch: 799913

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 798497

Analyte	MB	MB					Prepared	Analyzed	Dil Fac
	Result	Qualifier	RL		Unit	D			
1-Methylnaphthalene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
2-Methylnaphthalene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Acenaphthene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Acenaphthylene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Anthracene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Benzo[a]anthracene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Benzo[a]pyrene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Benzo[b]fluoranthene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Benzo[g,h,i]perylene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Benzo[k]fluoranthene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Chrysene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Dibenz(a,h)anthracene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Fluoranthene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Fluorene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Naphthalene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Phenanthrene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1
Pyrene	<0.20		0.20		ug/L		09/11/26 08:36	09/14/26 22:14	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: MB 570-798497/1-A

Matrix: Water

Analysis Batch: 799913

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 798497

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	85		28 - 127	09/11/26 08:36	09/14/26 22:14	1
2-Fluorobiphenyl (Surr)	80		31 - 120	09/11/26 08:36	09/14/26 22:14	1
2-Fluorophenol (Surr)	53		17 - 120	09/11/26 08:36	09/14/26 22:14	1
Nitrobenzene-d5 (Surr)	86		27 - 120	09/11/26 08:36	09/14/26 22:14	1
Phenol-d6 (Surr)	34		10 - 120	09/11/26 08:36	09/14/26 22:14	1
p-Terphenyl-d14 (Surr)	80		45 - 120	09/11/26 08:36	09/14/26 22:14	1

Lab Sample ID: LCS 570-798497/2-A

Matrix: Water

Analysis Batch: 799913

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 798497

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	20.0	11.3		ug/L		57	47 - 120
2-Methylnaphthalene	20.0	11.5		ug/L		58	43 - 120
Acenaphthene	20.0	16.0		ug/L		80	60 - 132
Acenaphthylene	20.0	16.5		ug/L		82	54 - 126
Anthracene	20.0	16.8		ug/L		84	43 - 120
Benzo[a]anthracene	20.0	18.4		ug/L		92	42 - 133
Benzo[a]pyrene	20.0	17.8		ug/L		89	32 - 148
Benzo[b]fluoranthene	20.0	17.2		ug/L		86	42 - 140
Benzo[g,h,i]perylene	20.0	17.1		ug/L		85	1 - 195
Benzo[k]fluoranthene	20.0	18.0		ug/L		90	25 - 146
Chrysene	20.0	17.2		ug/L		86	44 - 140
Dibenz[a,h]anthracene	20.0	17.5		ug/L		88	1 - 200
Fluoranthene	20.0	17.8		ug/L		89	43 - 121
Fluorene	20.0	16.4		ug/L		82	70 - 120
Indeno[1,2,3-cd]pyrene	20.0	17.4		ug/L		87	1 - 151
Naphthalene	20.0	11.7		ug/L		58	36 - 120
Phenanthrene	20.0	16.0		ug/L		80	65 - 120
Pyrene	20.0	17.7		ug/L		88	70 - 120

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2,4,6-Tribromophenol (Surr)	88		28 - 127
2-Fluorobiphenyl (Surr)	84		31 - 120
2-Fluorophenol (Surr)	58		17 - 120
Nitrobenzene-d5 (Surr)	68		27 - 120
Phenol-d6 (Surr)	38		10 - 120
p-Terphenyl-d14 (Surr)	90		45 - 120

Lab Sample ID: LCSD 570-798497/3-A

Matrix: Water

Analysis Batch: 799913

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 798497

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene	20.0	11.8		ug/L		59	47 - 120	4	20
2-Methylnaphthalene	20.0	12.3		ug/L		62	43 - 120	7	20
Acenaphthene	20.0	16.0		ug/L		80	60 - 132	0	29
Acenaphthylene	20.0	16.3		ug/L		82	54 - 126	1	45

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCSD 570-798497/3-A

Matrix: Water

Analysis Batch: 799913

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 798497

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Anthracene	20.0	16.6		ug/L		83	43 - 120	1	40
Benzo[a]anthracene	20.0	18.3		ug/L		91	42 - 133	1	32
Benzo[a]pyrene	20.0	17.9		ug/L		89	32 - 148	0	43
Benzo[b]fluoranthene	20.0	17.4		ug/L		87	42 - 140	1	43
Benzo[g,h,i]perylene	20.0	17.3		ug/L		86	1 - 195	1	61
Benzo[k]fluoranthene	20.0	18.0		ug/L		90	25 - 146	0	38
Chrysene	20.0	16.8		ug/L		84	44 - 140	2	53
Dibenz(a,h)anthracene	20.0	17.5		ug/L		87	1 - 200	0	75
Fluoranthene	20.0	16.9		ug/L		84	43 - 121	5	40
Fluorene	20.0	16.5		ug/L		83	70 - 120	1	23
Indeno[1,2,3-cd]pyrene	20.0	17.5		ug/L		88	1 - 151	1	60
Naphthalene	20.0	11.7		ug/L		58	36 - 120	0	39
Phenanthrene	20.0	16.0		ug/L		80	65 - 120	0	24
Pyrene	20.0	18.8		ug/L		94	70 - 120	6	30

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
2,4,6-Tribromophenol (Surr)	84		28 - 127
2-Fluorobiphenyl (Surr)	79		31 - 120
2-Fluorophenol (Surr)	57		17 - 120
Nitrobenzene-d5 (Surr)	65		27 - 120
Phenol-d6 (Surr)	40		10 - 120
p-Terphenyl-d14 (Surr)	91		45 - 120

Lab Sample ID: 380-235627-A-1-A MS

Matrix: Water

Analysis Batch: 799913

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 798497

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	<0.20		19.3	12.8		ug/L		66	36 - 120
2-Methylnaphthalene	<0.20		19.3	13.0		ug/L		67	32 - 124
Acenaphthene	<0.20		19.3	16.5		ug/L		85	47 - 145
Acenaphthylene	<0.20		19.3	16.9		ug/L		88	33 - 145
Anthracene	<0.20		19.3	17.3		ug/L		90	27 - 133
Benzo[a]anthracene	<0.20		19.3	19.1		ug/L		99	33 - 143
Benzo[a]pyrene	<0.20		19.3	18.3		ug/L		94	17 - 163
Benzo[b]fluoranthene	<0.20		19.3	17.7		ug/L		92	24 - 159
Benzo[g,h,i]perylene	<0.20		19.3	17.2		ug/L		89	1 - 219
Benzo[k]fluoranthene	<0.20		19.3	18.5		ug/L		96	11 - 162
Chrysene	<0.20		19.3	17.6		ug/L		91	17 - 168
Dibenz(a,h)anthracene	<0.20		19.3	17.6		ug/L		91	1 - 227
Fluoranthene	<0.20		19.3	17.6		ug/L		91	26 - 137
Fluorene	<0.20		19.3	16.6		ug/L		86	59 - 121
Indeno[1,2,3-cd]pyrene	<0.20		19.3	17.5		ug/L		91	1 - 171
Naphthalene	<0.20		19.3	11.8		ug/L		61	21 - 133
Phenanthrene	<0.20		19.3	16.6		ug/L		86	54 - 120
Pyrene	<0.20		19.3	20.2		ug/L		105	52 - 120

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 625.1 SIM - Semivolatle Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: 380-235627-A-1-A MS

Matrix: Water

Analysis Batch: 799913

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 798497

	MS	MS	
Surrogate	%Recovery	Qualifier	Limits
2,4,6-Tribromophenol (Surr)	97		28 - 127
2-Fluorobiphenyl (Surr)	88		31 - 120
2-Fluorophenol (Surr)	78		17 - 120
Nitrobenzene-d5 (Surr)	72		27 - 120
Phenol d6 (Surr)	61		10 - 120
p-Terphenyl-d14 (Surr)	105		45 - 120

Lab Sample ID: 380-235627-A-1-B MSD

Matrix: Water

Analysis Batch: 799913

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 798497

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene	<0.20		19.6	12.5		ug/L		64	36 - 120	2	30
2-Methylnaphthalene	<0.20		19.6	12.6		ug/L		65	32 - 124	2	30
Acenaphthene	<0.20		19.6	16.0		ug/L		82	47 - 145	3	48
Acenaphthylene	<0.20		19.6	16.4		ug/L		84	33 - 145	3	74
Anthracene	<0.20		19.6	16.7		ug/L		85	27 - 133	4	66
Benzo[a]anthracene	<0.20		19.6	18.7		ug/L		96	33 - 143	2	53
Benzo[a]pyrene	<0.20		19.6	16.9		ug/L		86	17 - 163	8	72
Benzo[b]fluoranthene	<0.20		19.6	16.6		ug/L		85	24 - 159	6	71
Benzo[g,h,i]perylene	<0.20		19.6	16.6		ug/L		85	1 - 219	4	97
Benzo[k]fluoranthene	<0.20		19.6	17.3		ug/L		89	11 - 162	7	63
Chrysene	<0.20		19.6	17.3		ug/L		89	17 - 168	2	87
Dibenz(a,h)anthracene	<0.20		19.6	17.0		ug/L		87	1 - 227	4	126
Fluoranthene	<0.20		19.6	17.5		ug/L		89	26 - 137	1	66
Fluorene	<0.20		19.6	16.4		ug/L		84	59 - 121	1	38
Indeno[1,2,3-cd]pyrene	<0.20		19.6	16.8		ug/L		86	1 - 171	4	99
Naphthalene	<0.20		19.6	11.4		ug/L		58	21 - 133	3	65
Phenanthrene	<0.20		19.6	16.0		ug/L		82	54 - 120	4	39
Pyrene	<0.20		19.6	19.4		ug/L		99	52 - 120	4	49

	MSD	MSD	
Surrogate	%Recovery	Qualifier	Limits
2,4,6-Tribromophenol (Surr)	90		28 - 127
2-Fluorobiphenyl (Surr)	84		31 - 120
2-Fluorophenol (Surr)	58		17 - 120
Nitrobenzene-d5 (Surr)	65		27 - 120
Phenol-d6 (Surr)	37		10 - 120
p-Terphenyl-d14 (Surr)	95		45 - 120

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: MB 570-800773/6

Matrix: Water

Analysis Batch: 800773

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			09/16/26 12:05	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Lab Sample ID: MB 570-800773/6

Matrix: Water

Analysis Batch: 800773

Client Sample ID: Method Blank

Prep Type: Total/NA

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	95		38 - 134		09/16/26 12:05	1

Lab Sample ID: LCS 570-800773/3

Matrix: Water

Analysis Batch: 800773

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

			Spike	LCS	LCS				%Rec		
Analyte			Added	Result	Qualifier	Unit	D	%Rec	Limits		
Gasoline Range Organics (C4-C13)			400	367		ug/L		92	78 - 120		

Lab Sample ID: LCSD 570-800773/4

Matrix: Water

Analysis Batch: 800773

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

			Spike	LCSD	LCSD				%Rec	RPD	
Analyte			Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Gasoline Range Organics (C4-C13)			400	371		ug/L	-	93	78 - 120	1	10
Surrogate	LCSD %Recovery	LCSD Qualifier	Limits								
4-Bromofluorobenzene (Surr)	93		38 - 134								

Lab Sample ID: MRL 570-800773/5

Matrix: Water

Analysis Batch: 800773

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

			Spike	MRL	MRL				%Rec		
Analyte			Added	Result	Qualifier	Unit	D	%Rec	%Rec	Limits	
Gasoline Range Organics (C4-C13)			10.0	12.6		ug/L		126		50 - 150	
Surrogate	MRL	MRL									
	%Recovery	Qualifier	Limits								
4-Bromofluorobenzene (Surr)	94		38 - 134								

Lab Sample ID: 380-235627-C-1 MS

Matrix: Water

Analysis Batch: 800773

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)	<10		400	370		ug/L		92	68 - 122		
Surrogate	MS %Recovery	MS Qualifier	Limits								
4-Bromofluorobenzene (Surr)	95		38 - 134								

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Lab Sample ID: 380-235627-C-1 MSD

Matrix: Water

Analysis Batch: 800773

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	358		ug/L		90	68 - 122	3	18
Surrogate	%Recovery	MSD Qualifier	MSD Limits								
4-Bromofluorobenzene (Surr)	101		38 - 134								

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Lab Sample ID: MB 570-799575/1-A

Matrix: Water

Analysis Batch: 802267

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 799575

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25	ug/L		09/14/26 09:20	09/18/26 19:15	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		09/14/26 09:20	09/18/26 19:15	1
C8-C18	<25		25	ug/L		09/14/26 09:20	09/18/26 19:15	1
Surrogate	%Recovery	MB Qualifier	MB Limits					Dil Fac
n-Octacosane (Surr)	120		60 - 130					1

Lab Sample ID: LCS 570-799575/2-A

Matrix: Water

Analysis Batch: 802267

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 799575

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	RPD
C10-C28	2000	2070		ug/L		104	56 - 127	
Surrogate	%Recovery	LCS Qualifier	LCS Limits					
n-Octacosane (Surr)	119		60 - 130					

Lab Sample ID: LCSD 570-799575/3-A

Matrix: Water

Analysis Batch: 802267

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 799575

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD
C10-C28	2000	1880		ug/L		94	56 - 127	10
Surrogate	%Recovery	LCSD Qualifier	LCSD Limits					
n-Octacosane (Surr)	114		60 - 130					

Lab Sample ID: MRL 570-799575/4-A

Matrix: Water

Analysis Batch: 802267

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 799575

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits	RPD
C10-C28	0.0200	0.0249	J	mg/L		124	50 - 150	

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

Lab Sample ID: MRL 570-799575/4-A

Matrix: Water

Analysis Batch: 802267

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 799575

	MRL	MRL	
Surrogate	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	105		60 - 130

Lab Sample ID: 380-235901-J-1-A MS

Matrix: Water

Analysis Batch: 802267

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 799575

	Sample	Sample	Spike	MS	MS				%Rec	
Analyte	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec	Limits	
C10-C28	<25		2010	1520		ug/L		76	70 - 130	
	MS	MS								
Surrogate	%Recovery	Qualifier	Limits							
n-Octacosane (Surr)	89		60 - 130							

Lab Sample ID: 380-235901-K-1-A MSD

Matrix: Water

Analysis Batch: 802267

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 799575

	Sample	Sample	Spike	MSD	MSD				%Rec		RPD	
Analyte	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec	Limits	RPD	Limit	
C10-C28	<25		2000	1450		ug/L		73	70 - 130	5	20	
	MSD	MSD										
Surrogate	%Recovery	Qualifier	Limits									
n-Octacosane (Surr)	79		60 - 130									

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

GC/MS Semi VOA

Prep Batch: 252437

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	525.2	
MB 380-252437/21-A	Method Blank	Total/NA	Water	525.2	
MRL 380-252437/22-A	Lab Control Sample	Total/NA	Water	525.2	
380-235909-AG-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-236033-B-1-A DU	Duplicate	Total/NA	Water	525.2	

Analysis Batch: 252459

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	525.2	252437
MB 380-252437/21-A	Method Blank	Total/NA	Water	525.2	252437
MRL 380-252437/22-A	Lab Control Sample	Total/NA	Water	525.2	252437
380-235909-AG-1-A MS	Matrix Spike	Total/NA	Water	525.2	252437
380-236033-B-1-A DU	Duplicate	Total/NA	Water	525.2	252437

Prep Batch: 798497

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	625.1	
MB 570-798497/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-798497/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-798497/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	
380-235627-A-1-A MS	Matrix Spike	Total/NA	Water	625.1	
380-235627-A-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	625.1	

Analysis Batch: 799913

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	625.1 SIM	798497
MB 570-798497/1-A	Method Blank	Total/NA	Water	625.1 SIM	798497
LCS 570-798497/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	798497
LCSD 570-798497/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	798497
380-235627-A-1-A MS	Matrix Spike	Total/NA	Water	625.1 SIM	798497
380-235627-A-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	625.1 SIM	798497

Analysis Batch: 801479

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	625.1	798497
MB 570-798497/1-A	Method Blank	Total/NA	Water	625.1	798497

GC VOA

Analysis Batch: 800773

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	8015B GRO LL	
380-235642-2	TB: Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	8015B GRO LL	
MB 570-800773/6	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-800773/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-800773/4	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-800773/5	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-235627-C-1 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-235627-C-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

GC Semi VOA

Prep Batch: 799575

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	3510C	
MB 570-799575/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-799575/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-799575/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-799575/4-A	Lab Control Sample	Total/NA	Water	3510C	
380-235901-J-1-A MS	Matrix Spike	Total/NA	Water	3510C	
380-235901-K-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	3510C	

Analysis Batch: 802267

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	Total/NA	Water	8015B	799575
MB 570-799575/1-A	Method Blank	Total/NA	Water	8015B	799575
LCS 570-799575/2-A	Lab Control Sample	Total/NA	Water	8015B	799575
LCSD 570-799575/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	799575
MRL 570-799575/4-A	Lab Control Sample	Total/NA	Water	8015B	799575
380-235901-J-1-A MS	Matrix Spike	Total/NA	Water	8015B	799575
380-235901-K-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	8015B	799575

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-235642-1

Date Collected: 09/08/26 13:07

Matrix: Water

Date Received: 09/10/26 10:05

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			252437	OTM3	EA POM	09/14/26 08:24
Total/NA	Analysis	525.2		1	252459	Q8LA	EA POM	09/14/26 21:12
Total/NA	Prep	625.1			798497	OAJ3	EET CAL 4	09/11/26 19:46
Total/NA	Analysis	625.1		1	801479	J7WE	EET CAL 4	09/17/26 17:50
Total/NA	Prep	625.1			798497	OAJ3	EET CAL 4	09/11/26 19:46
Total/NA	Analysis	625.1 SIM		1	799913	S4EA	EET CAL 4	09/15/26 01:58
Total/NA	Analysis	8015B GRO LL		1	800773	7CF2	EET CAL 4	09/16/26 20:59
Total/NA	Prep	3510C			799575	TVD6	EET CAL 4	09/14/26 09:20
Total/NA	Analysis	8015B		1	802267	H6FE	EET CAL 4	09/18/26 23:34

Client Sample ID: TB: Ka'amilo Wells P1 (331-031-WL008)

Lab Sample ID: 380-235642-2

Date Collected: 09/08/26 13:07

Matrix: Water

Date Received: 09/10/26 10:05

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	800773	7CF2	EET CAL 4	09/16/26 14:12

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Laboratory: Eurofins Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-27
The following analytes are included in this report, but the laboratory is not certified by Hawaii State CA00006. This list may include analytes for which the agency does not offer certification :			
Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Water	1-Methylnaphthalene
525.2	525.2	Water	2,4'-DDD
525.2	525.2	Water	2,4'-DDE
525.2	525.2	Water	2,4'-DDT
525.2	525.2	Water	2,4-Dinitrotoluene
525.2	525.2	Water	2,6-Dinitrotoluene
525.2	525.2	Water	2-Methylnaphthalene
525.2	525.2	Water	4,4'-DDD
525.2	525.2	Water	4,4'-DDE
525.2	525.2	Water	4,4'-DDT
525.2	525.2	Water	Acetochlor
525.2	525.2	Water	alpha-BHC
525.2	525.2	Water	alpha-Chlordane
525.2	525.2	Water	beta-BHC
525.2	525.2	Water	Chlorobenzilate
525.2	525.2	Water	Chloroneb
525.2	525.2	Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Water	Chlorpyrifos
525.2	525.2	Water	delta-BHC
525.2	525.2	Water	Diclorvos (DDVP)
525.2	525.2	Water	Endosulfan I (Alpha)
525.2	525.2	Water	Endosulfan II (Beta)
525.2	525.2	Water	Endosulfan sulfate
525.2	525.2	Water	Endrin aldehyde
525.2	525.2	Water	EPTC
525.2	525.2	Water	gamma-Chlordane
525.2	525.2	Water	Isophorone
525.2	525.2	Water	Malathion
525.2	525.2	Water	Parathion
525.2	525.2	Water	Pendimethalin (Penoxaline)
525.2	525.2	Water	Terbacil
525.2	525.2	Water	Terbutylazine
525.2	525.2	Water	Total Permethrin (mixed isomers)
525.2	525.2	Water	trans-Nonachlor

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	7296.01	11-30-26
A2LA	ISO/IEC 17025	7296.01	11-30-26
Alaska (UST)	State	25-005	03-02-27
Arizona	State	AZ0830	11-16-26
California	Los Angeles County Sanitation Districts	9257304	07-31-28
California	SCAQMD LAP	17LA0919	11-30-26

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Laboratory: Eurofins Calscience (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
California	State	3082	07-31-28
Kansas	NELAP	E-10420	07-31-27
Nevada	State	CA00111	07-31-27
Oregon	NELAP	4175	02-02-27
Texas	NELAP	T104704499	07-31-27
USDA	US Federal Programs	525-23-159-97150	09-29-26
Utah	NELAP	CA00111	02-28-27
Washington	State	C916	10-12-26

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Method	Method Description	Protocol	Laboratory
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA POM
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
525.2	Extraction of Semivolatile Compounds	EPA	EA POM
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-235642-1
SDG: Weekly: Ka'amilo Wells P1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-235642-1	Ka'amilo Wells P1 (331-031-WL008)	Water	09/08/26 13:07	09/10/26 10:05	Hawaii
380-235642-2	TB: Ka'amilo Wells P1 (331-031-WL008)	Water	09/08/26 13:07	09/10/26 10:05	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Ver. 04/02/2024
9/21/2026

[illegible]

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-235642-1
SDG Number: Weekly: Ka'amilo Wells P1

Login Number: 235642

List Number: 1

Creator: Segura, Ryan

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-235642-1
SDG Number: Weekly: Ka'amilo Wells P1

Login Number: 235642

List Number: 2

Creator: Khana, Piyush

List Source: Eurofins Calscience

List Creation: 09/11/26 02:41 PM

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	2.5 /2.6 1.8 /1.9 IR-4
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	